

# Town of Darlington 2011 Drinking Water Quality Report

PWSID: 012 0009



## Important Information Concerning Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2011. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service, an Agency of the State of Maryland, began operating the water treatment facility in January 2002 and prepared this report on behalf of the Town of Darlington.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate and identifies several hundred drinking water contaminants, establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely complete Sanitary Surveys as part of there ongoing inspection and monitoring program. MES provides safe dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney at 410-729-8350, e-mail [jjann@menv.com](mailto:jjann@menv.com)**

### Public Meeting Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact Jay Janney at 410-729-8350 and/or refer to MES website at <http://www.menv.com> for schedule and meeting location information.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline (1-800-426-4791)*.

### Inside This Issue:

Definitions	2
Special Points of Interest	2
Water Quality Report	3
Sources of Drinking Water	4
Water Security	4
Lead Prevention	4

# Town of Darlington Treated Water Quality Report 2011

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

*In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.*



## Lead Prevention

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Darlington is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

**T**he drinking water for the Town of Darlington consists of water from two wells in the Quartz Gabbro and Diorite Gneiss rock formations. Water is pumped out of the wells and a corrosion inhibitor is added for corrosion control. In addition, a disinfectant is added to protect against microbial contaminants. The Maryland Department of the Environment has completed an assessment of the source water. If you are interested in receiving a copy of the source water assessment report please call Jay Janney at 410-729-8350 or email your request to [jjann@menv.com](mailto:jjann@menv.com).

## Water Security is Everyone's Responsibility

Water system security continues to be an enormously important issue. If you notice suspicious activities in or around local water utilities, such as persons cutting or climbing facility fencing, loitering, tampering with equipment or other similar activities, please contact your local law enforcement agency immediately by dialing 911.



*If you have any questions about this report or your drinking water, please call Jay Janney at 410-729-8350 or email your request to [jjann@menv.com](mailto:jjann@menv.com).*

# Town of Darlington Treated Water Quality Report 2011

Contaminant	Highest Level Allowed (EPA's MCL)	Highest Level Detected	Ideal Goal (EPA's MCLG)
<b>Regulated at the Treatment Plant</b>			
Total Trihalomethanes (TTHM)	80 ppb	0.57 ppb	n/a
Haloacetic Acid (HAA5)	60 ppb	0.79 ppb	n/a
(2010 Testing) Typical Source of Contamination: By-product of drinking water disinfection			
<b>Wells 1A (1) and 1B (2)</b>			
Nitrate	10 ppm	3.63 ppm	10 ppm
Typical Source of Contamination: Runoff from fertilizer use; erosion			
Gross Alpha (2008 Testing)	15 pCi/l	1 pCi/l	0 pCi/l
Typical Source of Contamination: Erosion of natural deposits			
<b>Regulated at the Consumer's Tap</b>			
Copper (2011 Testing)	1.3 ppm (action level)	90th percentile = 0.246 ppm	1.3 ppm
Lead (2011 Testing)	15 ppb (action level)	90th percentile = 7 ppb	0 ppb
Typical Source of Contamination: Corrosion of household plumbing fixtures and systems			

The table above lists all the drinking water contaminants that were detected during the 2011 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk.


Unless otherwise noted, the data presented in the table is from conducted between January 1 – December 31, 2011.

The State requires monitor of certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

# Town of Darlington Treated Water Quality Report 2011

## *Definitions:*

- ◆ *Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ *Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ *Action Level* - The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow
- ◆ *Treatment Technique (TT)* - A required process intended to reduce the level of a contaminant in drinking water
- ◆ *Turbidity* - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of “cloudiness” of the water.
- ◆ *NTU - Nephelometric Turbidity Units*. Units of measurement used to report the level of turbidity or “cloudiness” in the water.
- ◆ *pCi/l* - Picocuries per liter. A measure of radiation.
- ◆ *ppb* - parts per billion or micrograms per liter
- ◆ *ppm* - parts per million or milligrams per liter



## Special points of interest:

- \* The Town of Darlington's water is tested for over 120 different compounds.
- \* The Town of Darlington's Drinking Water met all of the State and Federal requirements

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the *Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791)*