



Chapel Hill Nursing Center

2015 Annual Drinking Water Quality Report



PWSID#: 003-0202

Is my water safe?

Chapel Hill Nursing Center is pleased to provide this annual water quality report for calendar year 2014. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. Chapel Hill Nursing Center routinely monitors for contaminants in your drinking water. We vigilantly safeguard our water supplies and are committed to ensuring the quality of your water. Last year, our system was in violation of the Total Coliform Rule (TCR) for not reporting results in a timely manner; we have since been returned to compliance status.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from and what are the potential sources of contamination?

The sources of water supply wells in northern Baltimore County are unconfined fractured rock aquifers. The Chapel Hill water system, located in northwestern Baltimore County, is currently using two wells and has one backup well that draws water from the Ultramafic Complex. No point sources of contamination were identified within the assessment area from field inspections, contaminant inventory databases, and previous studies. The susceptibility analysis is based on a review of the existing water quality data for the water system, the presence of potential sources of contamination in the individual assessment areas, well integrity, and the inherent vulnerability of the aquifer. For more information on the source of your water and the significant potential sources of contamination, contact the Maryland Source Water Assessment Program at the Maryland Department of the Environment at (410) 537-3714 or visit on the web at: www.mde.state.md.us.

Why may there be contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

1. Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 2. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
 3. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
 4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
 5. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Lead

If present, elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Chapel Hill Nursing Center is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Copper

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.

Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected in your water. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, may be up to five years old.

Contaminants (units)	MCLG	MCL	Your Water	Range Low	Range High	Sample Date	Violation	Typical Source	Plant ID
Disinfectants & Disinfection By-Products									
Haloacetic Acids HAA5 (ppb)	NA	60	1.1	NA	NA	07/16/14	No	By-product of chlorination	Dist.
Total Trihalomethanes (ppb)	NA	80	0.8	NA	NA	07/16/14	No	By-product of chlorination	Dist.
Inorganic Contaminants									
Copper (ppm)	1.3	1.3AL	0.6	NA	NA	12/31/14	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Dist.
Nitrate (ppm)	10	10	4.6	3.8	5.3	1/4ly 2014	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	01
Barium (ppm)	2	2	0.2	NA	NA	02/12/14	No	Discharge of drilling wastes/metal refineries; erosion of natural products	01
Chromium (ppb)	100	100	4.0	NA	NA	01/13/14	No	Discharge from steel and pulp mills; erosion of natural deposits	01
Radioactive Contaminants									
Alpha emitters (pCi/L)	0	15	3.5	NA	NA	02/12/14	No	Erosion of natural deposits	01
Beta photon emitters (pCi/L)	0	50*	12.3	NA	NA	10/29/13	No	Decay of natural and man-made deposits	01
Combined Radium (pCi/L)	0	5	0.5	NA	NA	02/12/14	No	Erosion of natural deposits	01
Unregulated Contaminants									
Chloroform (ppb)	not regulated		0.6	NA	NA	10/24/13	No	EPA regulations require us to monitor this contaminant while EPA considers setting a limit on it.	01

Dist.: Water from the system's distribution.

*EPA considers 50pCi/l to be the level of concern for beta particles

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risks for safety. MCLG allows for margin of safety.

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units of Measurement & Conversions:

NA: Not applicable

pCi/L: picocuries per liter (a measure of radioactivity)

ppm: parts per million, or milligrams per liter (mg/L)

ppb: parts per billion, or micrograms per liter ($\mu\text{g}/\text{L}$)

Chapel Hill Nursing Center

For additional information or questions contact:

Clay Kirkland, Maintenance Director

(410) 922-2443

Prepared by: Water Testing Labs of Maryland, Inc.

For more information on contaminants in drinking water and its effects go to www.wtlmd.com