2015 Annual Drinking Water Quality Report
Boh-Nak Mobile Home Park
PWSID # 0220218

In compliance with Safe Drinking Water Act amendments by Congress of 1996 and subsequent Federal and State regulations, Boh-Nak Mobile Home Park is pleased to provide this annual water quality report for calendar year 2014. Boh-Nak Mobile Home Park routinely monitors for contaminants in your drinking water. For more information on the source of your water and the significant potential sources of contamination, contact the Maryland Water Supply Program at the Maryland Department of the Environment at (410) 537-3714 or visit on the web: http://www.mde.state.md.us/programs/Water/Water_Supply/Source_Water_Assessment_Program/Pages/programs/waterprograms/water_supply/sourcewaterassessment/by_county.aspx

Is my water safe?

We are very pleased to provide you with this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. Last year, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

How do we monitor for contaminants?

Boh-Nak Mobile Home Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2014. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Educational Statement on Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Boh-Nak MHP is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at: http://www.epa.gov/safewater/lead

Educational Statement on Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Inorganic Contaminants Plant ID 01

Contaminant, units	MCLG	MCL	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Health Effects	Plant ID
Nitrate, ppm (2012)	10	10	9.2	-	-	4/6/2012	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.	01

Inorganic Contaminants Plant ID 02

Contaminant, units	MCLG	MCL	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Health Effects	Plant ID
Barium, ppm (2013)	2	2	0.19	-	-	10/31/2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.	02
Sodium, ppm (2013)	NA	NA	18.7	-	-	10/31/2013	NA	Erosion of natural deposits; Leaching	-	02
Nitrate, ppm	10	10	- 8.4 8.6 9.2 7.9	7.9	9.2	- 7/7/2014 4/14/2014 10/13/2014 1/10/2014	- No No No No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.	02 02 02 02 02

Radioactive Contaminants Plant ID 02

Contaminant, units	MCLG	MCL	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Health Effects	Plant ID
Gross Alpha, pCi/L (2009)	0	15	1.4	-	-	11/2/2009	No	Erosion of natural deposits	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.	01
Gross Beta, pCi/L (2009)	0	50**	5.5	-	-	11/2/2009	No	Decay of natural and man-made deposits	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.	01
Radium-226, pCi/L (2009)	0***	5***	0.3	-	-	11/2/2009	No	Erosion of natural deposits	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.	01

**= The MCL for beta particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.
***= based on the MCLG and MCL of Combined Radium (226&228).

Organic Contaminants Plant ID 02

Contaminant, units	MCLG	MCL	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Health Effects	Plant ID
Methyl-Tert-Butyl Ether, ppb	NA	NA	- 0.6 0.7 0.8 0.7	0.6	0.8	- 10/21/2014 6/19/2014 8/14/2014 3/6/2014	NA	-	-	02

Tetrachloroethylene, ppb	0	5	0.8	-	-	3/6/2014	No	Discharge from factories and dry cleaners	Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.	02
m-Dichlorobenzene, ppb	NA	NA	0.6	-	-	3/6/2014	NA	-	-	02
p-Dichlorobenzene, ppb	75	75	0.6	-	-	3/6/2014	No	Discharge from industrial chemical factories	Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.	02

Secondary Standards Plant ID 02
(Related to the aesthetic quality of drinking water)

Substance, units	Suggested Limit	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Plant ID
pH, SU (2013)	6.5-8.5	6.1	-	-	10/31/2013	NA	-	01

Inorganic Contaminants, Plant ID: 00 Distribution Sampling

Contaminant, units	MCLG	MCL	Result	Range Low	Range High	Sample Date	Violation	Typical Source	Health Effects	Plant ID
Copper, ppm (2012)	1.3	AL 1.3	0.11*	0 Exceeded AL		12/21/2012	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.	00

*= result is the 90th Percentile reading

Units Description:

NA: Not applicable
ND: Not detected
MNR: Monitoring not required, but recommended.
ppb: parts per billion, or micrograms per liter (μg/L)
pCi/L: picocuries per liter (a measure of radioactivity)
mrem/yr: millirems per year (a measure of radiation absorbed by the body)

Important Drinking Water Definitions:

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water.
AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

For more information contact:
Boh-Nak Mobile Home Park
Attn: Karen Mildon
P.O. Box 59
Fruitland, MD 21826
Phone: 410-749-0514