

Savage Mountain Boys Camp

2016 Drinking Water

Quality Report

PWSID: 011-0227



Important Information Concerning Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2016. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service (MES), an Agency of the State of Maryland, operates the water treatment facility and prepared this report on behalf of Savage Mountain Boys Camp.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate and identifies several hundred drinking water contaminants, establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely complete Sanitary Surveys as part of their ongoing inspection and monitoring program. MES provides safe dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or

For More Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact **Steve Baer with the Maryland Department of Juvenile Services at 301-777-2486.**

The Savage Mountain Boys Camp water comes from five (5) drilled wells in the Conemaugh formation. The waterworks consists of two (2) 2,000-gallon below grade clarifiers, a 6000 gallon reservoir, a 8,000-gallon hydro-pneumatic tank, and the distribution network. The treatment facility consists of two (2) greensand filters and a chemical feed system. Sodium Hypochlorite, Potassium Permanganate, and Soda Ash are fed. Soda ash is added for pH control and potassium permanganate is used to regenerate the green sand filters. Sodium hypochlorite is used to disinfect the water prior to distribution. The Maryland Department of the Environment has performed an assessment of the source water. A copy of the results is available. Call Maryland Environmental Service at 410-729-8350.

Inside This Issue:


| | |
|----------------------------|---|
| Definitions | 2 |
| Special Points of Interest | 2 |
| Water Quality Report | 3 |
| Lead Prevention | 3 |
| About your Treatment Plant | 4 |
| Water Security | 4 |
| Sources of Drinking Water | 4 |

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the **Safe Drinking Water Hotline (1-800-426-4791).**

Savage Mountain Boys Camp Treated Water Quality Report 2016

Definitions:

- ◆ **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ **Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- ◆ **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water
- ◆ **Turbidity** - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of “cloudiness” of the water.
- ◆ **NTU - Nephelometric Turbidity Units.** Units of measurement used to report the level of turbidity or “cloudiness” in the water.
- ◆ **pCi/l** - Picocuries per liter. A measure of radiation.
- ◆ **ppb** - parts per billion or micrograms per liter
- ◆ **ppm** - parts per million or milligrams per liter



Special points of interest:

The water at Savage Mountain Boys Camp is tested for over 120 different compounds.

The Savage Mountain Boys Camp Drinking Water met all of the State and Federal requirements.

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-**

Savage Mountain Boys Camp Treated Water Quality Report 2015

| Contaminant | Highest Level Allowed (EPA's MCL) | Highest Level Detected | Ideal Goal (EPA's MCLG) |
|--|--------------------------------------|--------------------------|----------------------------|
| Regulated at the Treatment Plant | | | |
| Nitrate | 10 ppm | 0.10 ppm | 10 ppm |
| Typical Source of Contamination: Runoff from fertilizer use and erosion of natural deposits | | | |
| Fluoride (2016 Testing) | 4000 ppb | 167 ppb | 4000 ppb |
| Typical Source of Contamination: Water additive which promotes strong teeth and/or erosion of natural deposits | | | |
| Barium (2016 Testing) | 2000 ppb | 52 ppb | 2000 ppb |
| Typical Source of Contamination: Discharge from petroleum factories | | | |
| Regulated in the Distribution System | | | |
| Chlorine | 4 ppm | 1.18 ppm * | 4 ppm |
| Water additive used to control microbes | | (Range: 1.00 - 1.49 ppm) | |
| * Annual average of results | | | |
| Total Trihalomethanes (TTHM) (2014 Testing) | 80 ppb | 5.34 ppb | N/A |
| Typical Source of Contamination: By-product of drinking water chlorination | | | |
| Haloacetic Acids (HAA5) (2014 Testing) | 60 ppb | 6.85 ppb | N/A |
| Typical Source of Contamination: By-product of drinking water chlorination | | | |
| Regulated in the Distribution System | Action Level | 90th percentile | Ideal Goal |
| Copper (2014 Testing) | 1300 ppb | 37 ppb | 1300 ppb |
| Typical Source of Contamination: Corrosion of household plumbing fixtures and systems | | | |
| Lead (2014 Testing) | 15 ppb | 0 ppb | 0 ppb |
| Typical Source of Contamination: Corrosion of household plumbing fixtures and systems | | | |

The table above lists all the drinking water contaminants that were detected during the 2016 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk.

Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2016. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these

Lead Prevention

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Savage Mountain Boys Camp is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the **EPA Safe Drinking Water Hotline at 1-800-426-4791** or at <http://www.epa.gov/safewater/lead>.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must

Water Security is Everyone's Responsibility

Water system security continues to be an enormously important issue. If you notice suspicious activities in or around local water utilities, such as persons cutting or climbing facility fencing, loitering, tampering with equipment or other similar activities, please contact your local law enforcement agency immediately by dialing 911.

Your Water Treatment Facility

The Savage Mountain Youth Center water works consists of five drilled wells in the Conemaugh Formation Aquifer, a treatment facility, a 8,000 gallon hydropneumatic tank, 6,000 gallon storage reservoir, and a distribution network. The treatment facility consists of two (2) greensand filters and a chemical feed system. Sodium Hypochlorite, Potassium Permanganate, and Soda Ash are fed. Soda ash is added for pH control and potassium permanganate is used to regenerate the green sand filters. Sodium hypochlorite is used to disinfect the water prior to distribution.



If you have any questions about this report or your drinking water, please call Jay Janney at 410-729-8350 or email your request to jjann@menv.com.





Maryland

Department of
the Environment

Larry Hogan
Governor

Boyd Rutherford
Lieutenant Governor

Ben Grumbles
Secretary

Consumer Confidence Report Certification

Water Supply System Name: SAVAGE MT YOUTH CENTER

PWSID: 0110227 County: GARRETT

Consumer Confidence Report due to customers and to MDE no later than July 1st;
Certification of Delivery due to MDE no later than October 1st each year.
CCR and Certification are best delivered together by email attachment if possible.

I confirm that the Consumer Confidence Report for the year **2016** has been distributed to customers (and appropriate notices of availability have been given) in accordance with COMAR 26.04.01 by July 1, 2017. I further certify that the report is correct and consistent with compliance monitoring data previously submitted to MDE.

Certified by: Name STEVE BARR
 Signature [Signature]
 Title MAINT SUPER
 Phone # 301-722-1618 Date 6-12-17

Specific details on CCR distribution: (Date all that apply)

 Date CCR was delivered to MDE.

☒ Date CCR was distributed by mail.

 Date CCR was distributed by other methods. List methods of delivery: _____

☐ Approved electronic delivery plan is on file with MDE. (Check if applicable)

 Date a notice of CCR availability was published.

 Date good faith efforts were used to reach non-bill paying consumers. Those efforts included the following recommended methods:

- Date of posting the CCR on the Internet at: _____
- Date of mailing the CCR to postal patrons (bulk mail) within the service area (attach zip codes).
- Date of advertising availability of the CCR in news media (attach copy of announcement).
- Date of publication of CCR in local newspaper (attach copy).
- Date of delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers.
- Date of delivery to community organizations (attach a list).

Check violation types addressed:

- ☐ A tier 3 public notice is distributed with the CCR.
- ☐ Monitoring violations are addressed in the CCR.
- ☐ MCL violations are addressed in the CCR.
- ☐ CCR Delivery or Adequacy Violations are addressed in the CCR.

Mandatory for systems serving 100,000 or more persons:

 Date posted CCR on a publicly accessible Internet site. List Internet address: _____

 Date CCR delivered to other agencies or additional methods used. (Optional, attach list or description).

MDE/WMA/COM.025 (Revised 3/2016)