

Maryland Monthly AST System Visual Inspection Form

MDE Oil Operations Permit #:		OR	□ General Permit by Rule
Facility Name:			
Facility Address:			
City:	State: MD	Zip:	
Date of Inspection (mm/dd/yyyy): /	/		
Person Performing Visual Inspection:			
Title:	Signature: _		
I certify that I have personally performed the monthly v below for this facility and I further certify that the	-		
Person notified of deficiencies found during visu	al inspection:		
Title:			

Instructions: Inspect each AST system and where no problem is observed \checkmark P (pass). If a defeciency is found, \checkmark F (fail). Describe the deficiency found and provide a record of how and when the deficiency was corrected in the Describe Deficiencies / Corrective Actions section. If certain equipment is not required and/or not present, \checkmark N/A (not applicable). If evidence of a spill, release, discharge, or other unusual operating conditions are observed, notify the Oil Control Program immediately, but not later than 2 hours after detection, at 410-537-3442 during normal business hours, or to the Emergency Response Division hotline at 1-866-633-4686. Maintain this monthly record for 5 years, available for MDE's inspection upon request.

	Tank #:										
Size in gallons:											
Product stored:											
Signs of oil Spills, Releases, or Discharges											
Tank shell, heads, roof, and bottom free of visible leaks?	□ _{N/A}	□Р	□F	□Р	□ F	□Р	□ F	□Р	🗆 F	□Р	🗆 F
Tank connections, fittings, valves, pumps, and piping free of visible leaks?	□ _{N/A}	□Р	□F	□Р	□F	□Р	□ F	□ P	□F	□Р	□F
Interstice of double-walled or double bottomed tank free of oil?	□ _{N/A}	□Р	□F	□Р	□F	□Р	□ F	□Р	□F	□Р	□F
Area around the tank free of visible leaks, stressed vegetation, and oil contaminated soil?	□ N/A	□ P	□ F	□Р	🗆 F	□Р	□ F	□Р	🗆 F	□Р	🗆 F
Secondary containment dike free of oil sheen, visible leaks, and releases?	□ _{N/A}	□Р	□F	□Р	□F	□Р	□ F	□Р	□F	□ P	□F

Maryland Monthly AST System Visual Inspection From

Date of Inspection: ____ / ____ / ____

	Tank #:								
Signs of Water Accumulation									
Primary tank free of water?	□ N/A	\Box P \Box F							
Interstice free of water?	□ N/A								
Secondary containment dike free of water?	□ N/A								
Water Removal									
If present, water removed from the secondary containment dike?	□ _{N/A}	$\Box P \Box F$							
If present, water removed from AST?	□ _{N/A}								
If present, water removed from AST interstice?	□ _{N/A}								
Secondary Containment Dike									
Dike free of vegetation, debris, erosion, and combustible materials?	□ _{N/A}					\Box P \Box F			
Bed, walls, and hairlines of concrete or asphalt dike free of cracks and spalling?	□ N/A					$\Box P \Box F$			
Drain valve closed, locked, and in good working order?	□ N/A								
Shell and Foundation									
Tank shell free from distortion, buckling, denting, and bulging?	□ _{N/A}								
Concrete foundation free from broken concrete, spalling, and cracks?	□ _{N/A}								
Foundation free from cavities and vegetation?	□ N/A								
No sign of settlement around perimeter of tank?	□ _{N/A}								
Exterior Coating and Signs of Corr	osion								
Steel tank supports free from visible corrosion and damage?	□ _{N/A}		□ P □ F			$\Box P \Box F$			
Tank shell, heads, and roof free from pitting, corrosion, and signs of coating failure?	□ _{N/A}		□ P □ F						
Roof free from standing water?	□ N/A								
Ladders, platforms, and walkways secure with no signs of corrosion and damage?	□ _{N/A}								
Seams, Rivets, Nozzle Connections, Valves, Pumps, and Piping									
Seams and rivets free from leaks, corrosion, and wear?	□ N/A								
Nozzle connections and welds free from leaks, corrosion, and wear?	□ _{N/A}								
Valves, pumps, and piping free of corrosion and damage?	□ _{N/A}								
						1			

Maryland Monthly AST System Visual Inspection From

Date of Inspection: ____ / ____ / ____

	Tank #:									
Tank Gauge / Monitoring Device										
Directly visible during a transfer operation?	□ _{N/A}	\Box P \Box F		$\Box P \Box F$	$\Box P \Box F$					
In good working order?	□ _{N/A}									
Overfill Protection Equipment										
Overfill prevention equipment in good working condition?	□ _{N/A}		$\Box P \Box F$		$\Box P \Box F$					
Test button on the overfill prevention equipment activates alarm or light?	□ _{N/A}									
Test mechanism on the overfill prevention equipment operates when actuated?	□ N/A									
Release Detection System										
Visual Inspection										
Monthly visual inspection completed?	□ _{N/A}									
Electronic Release Detection System										
Power is on an in good working order?	□ N/A		$\Box P \Box F$	$\Box P \Box F$	$\Box P \Box F$					
No warnings or alarms?	□ N/A		$\Box P \Box F$	$\Box P \Box F$		\Box P \Box F				
Mechanical Release Detection System										
In good working order?	□ N/A		$\Box P \Box F$	$\Box P \Box F$	$\Box P \Box F$	\Box P \Box F				
No warnings or alarms?	□ _{N/A}			$\Box P \Box F$		$\Box P \Box F$				
Containment Sumps Associated with Underground Piping Systems										
Evidence of a spill, release, or discharge?	□ _{N/A}									
If present, removed liquids and debris?	□ N/A	$\Box P \Box F$	$\Box P \Box F$	$\Box P \Box F$	$\Box P \Box F$	\Box P \Box F				

DESCRIBE DEFICIENCIES / CORRECTIVE ACTIONS: