DMR Copy of Record

Form Approved OMB No. 2040-0004 expires on 07/31/2026

EPA may make all the information submitted through this form (including all attachments) available to the public without further notice to you. Do not use this online form to submit personal information (e.g., non-business cell phone number or non-business email address), confidential business information (CBI), or if you intend to assert a CBI claim on any of the submitted information. Pursuant to 40 CFR 2.203(a), EPA is providing you with notice that all CBI claims must be asserted at the time of submission. EPA cannot accommodate a late CBI claim to cover previously submitted information because efforts to protect the information are not administratively practicable since it may already be disclosed to the public. Although we do not foresee a need for persons to assert a claim of CBI based on the types of information requested in this form, if persons wish to assert a CBI claim we direct submitters to contact the NPDES eReporting Help Desk for further guidance. Please note that EPA may contact you after you submit this report for more information.

This collection of information is approved by OMB under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. (OMB Control No. 2040-0004). Responses to this collection of information are mandatory in accordance with this permit and EPA NPDES regulations 40 CFR 122.41(l)(4)(i). An agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The public reporting and recordkeeping burden for this collection of information are estimated to average 2 hours per outfall. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates and any suggested methods for minimizing respondent burden to the Regulatory Support Division Director, U.S. Environmental Protection Agency (2821T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

Permit

Permit #:	**MD0021555**	**Permittee:**	BACK RIVER WWTP	**Facility:**	BACK RIVER WWTP
Major:	Yes	**Permittee Address:**	8201 EASTERN AVENUE BALTIMORE COUNTY BALTIMORE, MD 21224	**Facility Location:**	8201 EASTERN AVENUE BALTIMORE COUNTY BALTIMORE COUNTY, MD 21224
Permitted Feature:	002 External Outfall	**Discharge:**	**002-A** 15-DP-0581, TOXIC REPORTING REQUIRED		

Report Dates & Status

Monitoring Period:	**From 05/01/26 to 05/31/26**	**DMR Due Date:**	**06/28/26**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name:	Matthew	**Title:**	Director of Public Works	**Telephone:**	410-396-9815
Last Name:	Garbark				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	**Oxygen, dissolved [DO]**	1 - Effluent Gross	0	--	Sample						=	7.2					19 - mg/L	0	03/01 - Three Per Day	GR - Grab
					Permit Req.						>=	5.0 INST MIN					19 - mg/L		03/01 - Three Per Day	GR - Grab
					Value NODI															
00300	**Oxygen, dissolved [DO]**	1 - Effluent Gross	1	--	Sample						=	7.7					19 - mg/L	0	03/01 - Three Per Day	GR - Grab
					Permit Req.						>=	6.0 MN WK AV					19 - mg/L		03/01 - Three Per Day	GR - Grab
					Value NODI															
00310	**BOD, 5-day, 20 deg. C**	1 - Effluent Gross	0	--	Sample	=	235.0	=	367.0	26 - lb/d			<	2.0	=	2.0	19 - mg/L	0	01/01 - Daily	24 - 24 Hour Composite
					Permit Req.	<=	8340.0 MX MO AV	<=	12520.0 MX WK AV	26 - lb/d			<=	20.0 MX MO AV	<=	30.0 MX WK AV	19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00400	**pH**	1 - Effluent Gross	0	--	Sample						=	7.2			=	7.8	12 - SU	0	03/01 - Three Per Day	GR - Grab
					Permit Req.						>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU		03/01 - Three Per Day	GR - Grab
					Value NODI															
00530	**Solids, total suspended**	1 - Effluent Gross	0	--	Sample	=	322.0	=	984.0	26 - lb/d			=	2.0	=	5.0	19 - mg/L	0	01/01 - Daily	24 - 24 Hour Composite
					Permit Req.	<=	12520.0 MX MO AV	<=	18770.0 MX WK AV	26 - lb/d			<=	30.0 MX MO AV	<=	45.0 MX WK AV	19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00530	**Solids, total suspended**	1 - Effluent Gross	1	--	Sample			=	9987.0	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Value NODI															
00530	**Solids, total suspended**	1 - Effluent Gross	2	--	Sample			=	31805.0	50 - lb/yr								0	01/30 - Monthly	CA - Calculated
					Permit Req.			<=	4589026.0 CUM TOTL	50 - lb/yr									01/30 - Monthly	CA - Calculated
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	0	--	Sample								=	1.9			19 - mg/L		01/30 - Monthly	CA - Calculated
					Permit Req.									Req Mon MO AVG			19 - mg/L		01/30 - Monthly	CA - Calculated
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	1	--	Sample			=	10243.0	50 - lb/yr								0	01/30 - Monthly	CA - Calculated
					Permit Req.			<=	230294.0 SEAS TDT	50 - lb/yr									01/30 - Monthly	CA - Calculated
					Value NODI															
					Sample			=	42285.0	50 - lb/yr									01/30 - Monthly	CA - Calculated

00600	**Nitrogen, total [as N]**	1 - Effluent Gross	2	--	Permit Req.			<=	610748.0 CUM TOTL	50 - lb/yr								0	01/30 - Monthly	CA - Calculated
					Value NODI															
00600	**Nitrogen, total [as N]**	EG - Effluent Gross	1	--	Sample			=	10243.0	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Permit Req.				Req Mon MO TOTAL	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Value NODI															
00605	**Nitrogen, organic total [as N]**	1 - Effluent Gross	0	--	Sample	=	202.6			26 - lb/d			=	1.2			19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Permit Req.		Req Mon MO LOAD			26 - lb/d				Req Mon MO AVG			19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00610	**Nitrogen, ammonia total [as N]**	1 - Effluent Gross	0	--	Sample	=	32.0	=	83.0	26 - lb/d			=	0.2	=	0.5	19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Permit Req.	<=	830.0 MX MO AV	<=	1250.0 MX WK AV	26 - lb/d			<=	2.0 MX MO AV	<=	3.0 MX WK AV	19 - mg/L	0	01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00630	**Nitrite + Nitrate total [as N]**	1 - Effluent Gross	0	--	Sample	=	95.5			26 - lb/d			=	0.5			19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Permit Req.		Req Mon MO LOAD			26 - lb/d				Req Mon MO AVG			19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	0	--	Sample	=	22.0	=	32.0	26 - lb/d			=	0.13	=	0.17	19 - mg/L		01/01 - Daily	24 - 24 Hour Composite
					Permit Req.	<=	83.0 MO AVG	<=	125.0 WKLY AVG	26 - lb/d			<=	0.2 MO AVG	<=	0.3 WKLY AVG	19 - mg/L	0	01/01 - Daily	24 - 24 Hour Composite
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	1	--	Sample			=	689.0	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Permit Req.				Req Mon TOTAL	76 - lb/mo									01/30 - Monthly	CA - Calculated
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	2	--	Sample			=	1969.0	50 - lb/yr									01/30 - Monthly	CA - Calculated
					Permit Req.			<=	30363.0 CUM TOTL	50 - lb/yr								0	01/30 - Monthly	CA - Calculated
					Value NODI															
00665	**Phosphorus, total [as P]**	EG - Effluent Gross	2	--	Sample			=	689.0	50 - lb/yr									01/30 - Monthly	CA - Calculated
					Permit Req.			<=	15353.0 SEAS TDT	50 - lb/yr								0	01/30 - Monthly	CA - Calculated
					Value NODI															
00722	**Cyanide, free [amenable to chlorination]**	1 - Effluent Gross	0	--	Sample								=	10.9			28 - ug/L		01/30 - Monthly	GR - Grab
					Permit Req.									Req Mon MO AVG			28 - ug/L		01/30 - Monthly	GR - Grab
					Value NODI															
04175	**Phosphate, ortho [as P]**	1 - Effluent Gross	0	--	Sample			=	5.0	26 - lb/d			<	0.047			19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Permit Req.				Req Mon MO LOAD	26 - lb/d				Req Mon MO AVG			19 - mg/L		01/07 - Weekly	24 - 24 Hour Composite
					Value NODI															
39350	**Chlordane [tech mix. and metabolites]**	1 - Effluent Gross	0	--	Sample										<	0.19	28 - ug/L		01/30 - Monthly	24 - 24 Hour Composite
					Permit Req.											Req Mon TOTAL	28 - ug/L		01/30 - Monthly	24 - 24 Hour Composite
					Value NODI															
39390	**Endrin**	1 - Effluent Gross	0	--	Sample										<	0.019	28 - ug/L		01/30 - Monthly	24 - 24 Hour Composite
					Permit Req.											Req Mon TOTAL	28 - ug/L		01/30 - Monthly	24 - 24 Hour Composite
					Value NODI															
50050	**Flow, in conduit or thru treatment plant**	1 - Effluent Gross	0	--	Sample	=	20.1	=	31.4	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Value NODI															
50060	**Chlorine, total residual**	1 - Effluent Gross	0	--	Sample										=	2.0	19 - mg/L		03/01 - Three Per Day	GR - Grab
					Permit Req.											Req Mon MAXIMUM	19 - mg/L		03/01 - Three Per Day	GR - Grab
					Value NODI															
51040	**E. coli**	1 - Effluent Gross	0	--	Sample										=	2.0	30 - MPN/100mL		01/01 - Daily	GR - Grab
					Permit Req.										<=	126.0 MX MO GMN	30 - MPN/100mL	0	01/01 - Daily	GR - Grab
					Value NODI															
82220	**Flow, total**	1 - Effluent Gross	0	--	Sample			=	623.1	80 - Mgal/mo									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.				Req Mon TOTAL	80 - Mgal/mo									99/99 - Continuous	RC - Recorder (auto)
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

The May 2026 cover letter, discharge monitoring report and monthly operations report are attachments with this submission.

Attachments

Name	Type	Size

MAY_26_MOR.pdf	pdf	4291313.0
MAY_26_002_DMR.pdf	pdf	1201895.0
MAY_26_Cover_letter_signed.pdf	pdf	266204.0

Report Last Saved By

BACK RIVER WWTP

User:	rayford.mceachern@baltimorecity.gov
Name:	Rayford McEachern
E-Mail:	rayford.mceachern@baltimorecity.gov
Date/Time:	2026-06-26 16:16 (Time Zone: -04:00)

Report Last Signed By

User:	rayford.mceachern@baltimorecity.gov
Name:	Rayford McEachern
E-Mail:	rayford.mceachern@baltimorecity.gov
Date/Time:	2026-06-26 16:16 (Time Zone: -04:00)