

535 Route 38 East, Suite 355
Cherry Hill, New Jersey 08002

T: 856.382.7170
F: 201.236.1607



July 9, 2013

Mr. Michael T. Axelsson & Ms. Krystin Porcella
1 Meadow Spring Drive
Bel Air, Maryland 21015

144514.005.001

Subject: Point of Entry Treatment System Sampling Results
May 14, 2013 Sampling Event
1 Meadow Spring Drive, Bel Air, Maryland

Dear Mr. Axelsson and Ms. Porcella:

Brown and Caldwell (BC), on behalf of Drake Petroleum Company Inc. (Drake) would like to thank you for allowing us to conduct sampling of your point of entry treatment (POET) system on May 14, 2013. The sampling was conducted to evaluate the effectiveness of the POET system that was installed to treat the water coming into your home.

To help better understand the results, the following information is supplied:

- **Pre-carbon filtration** – water sample of the untreated water coming directly into your home from your well; referred to as influent and denoted as “1 MEADOW-INF” on the laboratory report.
- **Mid-carbon filtration** – water sample collected between the granular activated carbon (GAC) vessels, this sample is collected between the second and third GAC vessels; referred to as mid-fluent and denoted as “1 MEADOW-MID2” on the laboratory report.
- **Post-carbon filtration** – water sample of the finished treated water; referred to as effluent and denoted as “1 MEADOW-EFF” on the laboratory report.

Water samples were collected pre-, mid- and post-carbon filtration and were analyzed for volatile organic compounds (VOCs) including petroleum constituents, using a United States (US) Environmental Protection Agency (EPA) approved method for drinking water samples (US EPA Method 524.2). The following constituents were detected from the effluent post-carbon filtration sample: Chloromethane at 0.57 micrograms per liter ($\mu\text{g}/\text{L}$) and carbon disulfide at an estimated 0.11 $\mu\text{g}/\text{L}$. Chloromethane is not a petroleum-containing compound, and was below the Maryland Department of the Environment (MDE) groundwater standard of 19 $\mu\text{g}/\text{L}$ for chloromethane. Carbon disulfide is used in a number of industrial applications and was below the MDE groundwater standard of 100 $\mu\text{g}/\text{L}$. The MDE groundwater standards can be found in MDE Cleanup Standards for Soil and Groundwater, Interim Final Guidance (June 2008). The sample results demonstrated that no petroleum-containing compounds were detected in the effluent water sample in exceedance of the regulatory limits, indicating that the POET system is functioning properly. Your analytical results of the pre-carbon, mid-carbon, and post-carbon filtration points are attached.

As you know, sampling of your water filtration system was conducted by Drake as part of a groundwater investigation being conducted in cooperation with the MDE and the Harford County Health Department. Drake would like to sample the water from your water filtration system again in the month of July as directed by the MDE. BC will contact you regarding the next round of sampling.

Again, thank you for your patience and cooperation. If you have any questions regarding the enclosed test results feel free to call me at 856-324-0485.

Very truly yours,

Brown and Caldwell



Carolyn Roth
Project Manager

cc: Eric Harvey, Drake, (*via electronic submittal*)
Susan Bull, Maryland Department of the Environment (*via email and FedEx*)
Jeanette DeBartolomeo, Maryland Department of the Environment (*via email and FedEx*)
Peter Smith, Harford County Health Department (*via email and FedEx*)

Attachments (1)

Attachment: Laboratory Data



Technical Report for

Drake Petroleum Company, Inc.

BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD
143732 PC#007805

Accutest Job Number: JB37051

Sampling Date: 05/14/13

Report to:

Brown & Caldwell

hwhite@BrwnCald.com

ATTN: Hunter White

Total number of pages in report: **20**



Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Conference and/or state specific certification programs as applicable.

Nancy Cole
Laboratory Director

Client Service contact: Kristin Beebe 732-329-0200

Certifications: NJ(12129), NY(10983), CA, CT, DE, FL, IL, IN, KS, KY, LA, MA, MD, MI, MT, NC,
OH VAP (CL0056), PA, RI, SC, TN, VA, WV

This report shall not be reproduced, except in its entirety, without the written approval of Accutest Laboratories.
Test results relate only to samples analyzed.

Table of Contents

Sections:



-1-

Section 1: Sample Summary 3

Section 2: Summary of Hits 4

Section 3: Sample Results 5

3.1: JB37051-1: 1 MEADOW-EFF 6

3.2: JB37051-2: 1 MEADOW-MID2 9

3.3: JB37051-3: 1 MEADOW-INF 12

3.4: JB37051-4: TRIP BLANK 15

Section 4: Misc. Forms 18

4.1: Chain of Custody 19



Sample Summary

Drake Petroleum Company, Inc.

Job No: JB37051

BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD

Project No: 143732 PC#007805

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JB37051-1	05/14/13	09:30 HW	05/14/13	DW	Drinking Water Eff	1 MEADOW-EFF
JB37051-2	05/14/13	09:35 HW	05/14/13	DW	Drinking Water	1 MEADOW-MID2
JB37051-3	05/14/13	09:40 HW	05/14/13	DW	Drinking Water Inf	1 MEADOW-INF
JB37051-4	05/14/13	09:40 HW	05/14/13	DW	Drinking Water TB	TRIP BLANK

Summary of Hits



Job Number: JB37051
Account: Drake Petroleum Company, Inc.
Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD
Collected: 05/14/13

Lab Sample ID	Client Sample ID	Result/ Qual	RL	MDL	Units	Method
---------------	------------------	-----------------	----	-----	-------	--------

JB37051-1 1 MEADOW-EFF

Carbon disulfide	0.11 J	0.50	0.10	ug/l	EPA 524.2 REV 4.1
Chloromethane	0.57	0.50	0.095	ug/l	EPA 524.2 REV 4.1
Total TIC, Volatile	1.6 J			ug/l	

JB37051-2 1 MEADOW-MID2

Total TIC, Volatile	0.54 J			ug/l	
---------------------	--------	--	--	------	--

JB37051-3 1 MEADOW-INF

Benzene	19.7	0.50	0.047	ug/l	EPA 524.2 REV 4.1
Di-Isopropyl ether	1.4	0.50	0.062	ug/l	EPA 524.2 REV 4.1
Ethyl tert Butyl Ether	0.36 J	0.50	0.064	ug/l	EPA 524.2 REV 4.1
Isopropylbenzene	0.33 J	0.50	0.11	ug/l	EPA 524.2 REV 4.1
Methyl Tert Butyl Ether	441	13	1.7	ug/l	EPA 524.2 REV 4.1
Naphthalene	0.67	0.50	0.060	ug/l	EPA 524.2 REV 4.1
tert-Amyl Methyl Ether	12.1	0.50	0.050	ug/l	EPA 524.2 REV 4.1
1,2,4-Trimethylbenzene	0.34 J	0.50	0.12	ug/l	EPA 524.2 REV 4.1
Tertiary Butyl Alcohol	117	5.0	2.4	ug/l	EPA 524.2 REV 4.1
m,p-Xylene	0.20 J	1.0	0.18	ug/l	EPA 524.2 REV 4.1
o-Xylene	0.31 J	0.50	0.12	ug/l	EPA 524.2 REV 4.1
Xylenes (total)	0.51	0.50	0.12	ug/l	EPA 524.2 REV 4.1
Total TIC, Volatile	4.99 J			ug/l	

JB37051-4 TRIP BLANK

No hits reported in this sample.

Sample Results

Report of Analysis

Report of Analysis

Client Sample ID:	1 MEADOW-EFF	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-1	Date Received:	05/14/13
Matrix:	DW - Drinking Water Eff	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1	Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1B79136.D	1	05/17/13	MFH	n/a	n/a	V1B3697
Run #2							

Run #	Purge Volume
Run #1	5.0 ml
Run #2	

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
67-64-1	Acetone	ND		5.0	1.6	ug/l	
78-93-3	2-Butanone	ND		5.0	1.6	ug/l	
71-43-2	Benzene	ND	5.0	0.50	0.047	ug/l	
108-86-1	Bromobenzene	ND		0.50	0.13	ug/l	
74-97-5	Bromochloromethane	ND		0.50	0.13	ug/l	
75-27-4	Bromodichloromethane	ND		0.50	0.088	ug/l	
75-25-2	Bromoform	ND		0.50	0.11	ug/l	
74-83-9	Bromomethane	ND		0.50	0.11	ug/l	
104-51-8	n-Butylbenzene	ND		0.50	0.11	ug/l	
135-98-8	sec-Butylbenzene	ND		0.50	0.12	ug/l	
98-06-6	tert-Butylbenzene	ND		0.50	0.062	ug/l	
75-15-0	Carbon disulfide	0.11		0.50	0.10	ug/l	J
108-90-7	Chlorobenzene	ND	100	0.50	0.046	ug/l	
75-00-3	Chloroethane	ND		0.50	0.16	ug/l	
67-66-3	Chloroform	ND		0.50	0.069	ug/l	
74-87-3	Chloromethane	0.57		0.50	0.095	ug/l	
95-49-8	o-Chlorotoluene	ND		0.50	0.069	ug/l	
106-43-4	p-Chlorotoluene	ND		0.50	0.048	ug/l	
56-23-5	Carbon tetrachloride	ND	5.0	0.50	0.083	ug/l	
75-34-3	1,1-Dichloroethane	ND		0.50	0.067	ug/l	
75-35-4	1,1-Dichloroethylene	ND	7.0	0.50	0.14	ug/l	
563-58-6	1,1-Dichloropropene	ND		0.50	0.095	ug/l	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.20	1.0	0.22	ug/l	
106-93-4	1,2-Dibromoethane	ND	0.050	0.50	0.082	ug/l	
107-06-2	1,2-Dichloroethane	ND	5.0	0.50	0.11	ug/l	
78-87-5	1,2-Dichloropropane	ND	5.0	0.50	0.080	ug/l	
142-28-9	1,3-Dichloropropane	ND		0.50	0.11	ug/l	
594-20-7	2,2-Dichloropropane	ND		0.50	0.17	ug/l	
124-48-1	Dibromochloromethane	ND		0.50	0.075	ug/l	
74-95-3	Dibromomethane	ND		0.50	0.11	ug/l	
75-71-8	Dichlorodifluoromethane	ND		1.0	0.10	ug/l	
541-73-1	m-Dichlorobenzene	ND		0.50	0.11	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-EFF	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-1	Date Received:	05/14/13
Matrix:	DW - Drinking Water Eff	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1		
Project:	BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD		

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
95-50-1	o-Dichlorobenzene	ND	600	0.50	0.073	ug/l	
106-46-7	p-Dichlorobenzene	ND	75	0.50	0.063	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	100	0.50	0.10	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	70	0.50	0.13	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND		0.50	0.094	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND		0.50	0.10	ug/l	
108-20-3	Di-Isopropyl ether	ND		0.50	0.062	ug/l	
100-41-4	Ethylbenzene	ND	700	0.50	0.14	ug/l	
637-92-3	Ethyl tert Butyl Ether	ND		0.50	0.064	ug/l	
87-68-3	Hexachlorobutadiene	ND		2.0	0.096	ug/l	
110-54-3	Hexane	ND		0.50	0.28	ug/l	
591-78-6	2-Hexanone	ND		2.0	0.37	ug/l	
98-82-8	Isopropylbenzene	ND		0.50	0.11	ug/l	
99-87-6	p-Isopropyltoluene	ND		0.50	0.053	ug/l	
75-09-2	Methylene chloride	ND	5.0	0.50	0.11	ug/l	
1634-04-4	Methyl Tert Butyl Ether	ND		0.50	0.068	ug/l	
108-10-1	4-Methyl-2-pentanone	ND		2.0	0.47	ug/l	
91-20-3	Naphthalene	ND		0.50	0.060	ug/l	
103-65-1	n-Propylbenzene	ND		0.50	0.12	ug/l	
100-42-5	Styrene	ND	100	0.50	0.058	ug/l	
994-05-8	tert-Amyl Methyl Ether	ND		0.50	0.050	ug/l	
630-20-6	1,1,1,2-Tetrachloroethane	ND		0.50	0.097	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	200	0.50	0.059	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND		0.50	0.041	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	5.0	0.50	0.075	ug/l	
87-61-6	1,2,3-Trichlorobenzene	ND		0.50	0.053	ug/l	
96-18-4	1,2,3-Trichloropropane	ND		0.50	0.20	ug/l	
120-82-1	1,2,4-Trichlorobenzene	ND	70	0.50	0.073	ug/l	
95-63-6	1,2,4-Trimethylbenzene	ND		0.50	0.12	ug/l	
108-67-8	1,3,5-Trimethylbenzene	ND		0.50	0.091	ug/l	
127-18-4	Tetrachloroethylene	ND	5.0	0.50	0.12	ug/l	
108-88-3	Toluene	ND	1000	0.50	0.079	ug/l	
79-01-6	Trichloroethylene	ND	5.0	0.50	0.15	ug/l	
75-69-4	Trichlorofluoromethane	ND		1.0	0.15	ug/l	
75-65-0	Tertiary Butyl Alcohol	ND		5.0	2.4	ug/l	
75-01-4	Vinyl chloride	ND	2.0	0.50	0.12	ug/l	
	m,p-Xylene	ND		1.0	0.18	ug/l	
95-47-6	o-Xylene	ND		0.50	0.12	ug/l	
1330-20-7	Xylenes (total)	ND	10000	0.50	0.12	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

3.1
3

Client Sample ID: 1 MEADOW-EFF Lab Sample ID: JB37051-1 Matrix: DW - Drinking Water Eff Method: EPA 524.2 REV 4.1 Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	Date Sampled: 05/14/13 Date Received: 05/14/13 Percent Solids: n/a
--	---

VOA List

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	93%		78-114%
460-00-4	4-Bromofluorobenzene	93%		77-115%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Silanol, trimethyl-	9.10	1.6	ug/l	J
	Total TIC, Volatile		1.6	ug/l	J

ND = Not detected MDL - Method Detection Limit
 MCL = Maximum Contamination Level (40 CFR 141)
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-MID2	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-2	Date Received:	05/14/13
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1	Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1B79137.D	1	05/17/13	MFH	n/a	n/a	V1B3697
Run #2							

Run #	Purge Volume
Run #1	5.0 ml
Run #2	

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
67-64-1	Acetone	ND		5.0	1.6	ug/l	
78-93-3	2-Butanone	ND		5.0	1.6	ug/l	
71-43-2	Benzene	ND	5.0	0.50	0.047	ug/l	
108-86-1	Bromobenzene	ND		0.50	0.13	ug/l	
74-97-5	Bromochloromethane	ND		0.50	0.13	ug/l	
75-27-4	Bromodichloromethane	ND		0.50	0.088	ug/l	
75-25-2	Bromoform	ND		0.50	0.11	ug/l	
74-83-9	Bromomethane	ND		0.50	0.11	ug/l	
104-51-8	n-Butylbenzene	ND		0.50	0.11	ug/l	
135-98-8	sec-Butylbenzene	ND		0.50	0.12	ug/l	
98-06-6	tert-Butylbenzene	ND		0.50	0.062	ug/l	
75-15-0	Carbon disulfide	ND		0.50	0.10	ug/l	
108-90-7	Chlorobenzene	ND	100	0.50	0.046	ug/l	
75-00-3	Chloroethane	ND		0.50	0.16	ug/l	
67-66-3	Chloroform	ND		0.50	0.069	ug/l	
74-87-3	Chloromethane	ND		0.50	0.095	ug/l	
95-49-8	o-Chlorotoluene	ND		0.50	0.069	ug/l	
106-43-4	p-Chlorotoluene	ND		0.50	0.048	ug/l	
56-23-5	Carbon tetrachloride	ND	5.0	0.50	0.083	ug/l	
75-34-3	1,1-Dichloroethane	ND		0.50	0.067	ug/l	
75-35-4	1,1-Dichloroethylene	ND	7.0	0.50	0.14	ug/l	
563-58-6	1,1-Dichloropropene	ND		0.50	0.095	ug/l	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.20	1.0	0.22	ug/l	
106-93-4	1,2-Dibromoethane	ND	0.050	0.50	0.082	ug/l	
107-06-2	1,2-Dichloroethane	ND	5.0	0.50	0.11	ug/l	
78-87-5	1,2-Dichloropropane	ND	5.0	0.50	0.080	ug/l	
142-28-9	1,3-Dichloropropane	ND		0.50	0.11	ug/l	
594-20-7	2,2-Dichloropropane	ND		0.50	0.17	ug/l	
124-48-1	Dibromochloromethane	ND		0.50	0.075	ug/l	
74-95-3	Dibromomethane	ND		0.50	0.11	ug/l	
75-71-8	Dichlorodifluoromethane	ND		1.0	0.10	ug/l	
541-73-1	m-Dichlorobenzene	ND		0.50	0.11	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-MID2	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-2	Date Received:	05/14/13
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1		
Project:	BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD		

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
95-50-1	o-Dichlorobenzene	ND	600	0.50	0.073	ug/l	
106-46-7	p-Dichlorobenzene	ND	75	0.50	0.063	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	100	0.50	0.10	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	70	0.50	0.13	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND		0.50	0.094	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND		0.50	0.10	ug/l	
108-20-3	Di-Isopropyl ether	ND		0.50	0.062	ug/l	
100-41-4	Ethylbenzene	ND	700	0.50	0.14	ug/l	
637-92-3	Ethyl tert Butyl Ether	ND		0.50	0.064	ug/l	
87-68-3	Hexachlorobutadiene	ND		2.0	0.096	ug/l	
110-54-3	Hexane	ND		0.50	0.28	ug/l	
591-78-6	2-Hexanone	ND		2.0	0.37	ug/l	
98-82-8	Isopropylbenzene	ND		0.50	0.11	ug/l	
99-87-6	p-Isopropyltoluene	ND		0.50	0.053	ug/l	
75-09-2	Methylene chloride	ND	5.0	0.50	0.11	ug/l	
1634-04-4	Methyl Tert Butyl Ether	ND		0.50	0.068	ug/l	
108-10-1	4-Methyl-2-pentanone	ND		2.0	0.47	ug/l	
91-20-3	Naphthalene	ND		0.50	0.060	ug/l	
103-65-1	n-Propylbenzene	ND		0.50	0.12	ug/l	
100-42-5	Styrene	ND	100	0.50	0.058	ug/l	
994-05-8	tert-Amyl Methyl Ether	ND		0.50	0.050	ug/l	
630-20-6	1,1,1,2-Tetrachloroethane	ND		0.50	0.097	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	200	0.50	0.059	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND		0.50	0.041	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	5.0	0.50	0.075	ug/l	
87-61-6	1,2,3-Trichlorobenzene	ND		0.50	0.053	ug/l	
96-18-4	1,2,3-Trichloropropane	ND		0.50	0.20	ug/l	
120-82-1	1,2,4-Trichlorobenzene	ND	70	0.50	0.073	ug/l	
95-63-6	1,2,4-Trimethylbenzene	ND		0.50	0.12	ug/l	
108-67-8	1,3,5-Trimethylbenzene	ND		0.50	0.091	ug/l	
127-18-4	Tetrachloroethylene	ND	5.0	0.50	0.12	ug/l	
108-88-3	Toluene	ND	1000	0.50	0.079	ug/l	
79-01-6	Trichloroethylene	ND	5.0	0.50	0.15	ug/l	
75-69-4	Trichlorofluoromethane	ND		1.0	0.15	ug/l	
75-65-0	Tertiary Butyl Alcohol	ND		5.0	2.4	ug/l	
75-01-4	Vinyl chloride	ND	2.0	0.50	0.12	ug/l	
	m,p-Xylene	ND		1.0	0.18	ug/l	
95-47-6	o-Xylene	ND		0.50	0.12	ug/l	
1330-20-7	Xylenes (total)	ND	10000	0.50	0.12	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-MID2	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-2	Date Received:	05/14/13
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1	Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

VOA List

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits	
2199-69-1	1,2-Dichlorobenzene-d4	93%		78-114%	
460-00-4	4-Bromofluorobenzene	96%		77-115%	

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	alcohols	16.95	.54	ug/l	J
	Total TIC, Volatile		.54	ug/l	J

ND = Not detected MDL - Method Detection Limit
 MCL = Maximum Contamination Level (40 CFR 141)
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-INF	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-3	Date Received:	05/14/13
Matrix:	DW - Drinking Water Inf	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1	Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1B79138.D	1	05/17/13	MFH	n/a	n/a	V1B3697
Run #2	1B79220.D	25	05/20/13	MFH	n/a	n/a	V1B3701

Run #	Purge Volume
Run #1	5.0 ml
Run #2	5.0 ml

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
67-64-1	Acetone	ND		5.0	1.6	ug/l	
78-93-3	2-Butanone	ND		5.0	1.6	ug/l	
71-43-2	Benzene	19.7	5.0	0.50	0.047	ug/l	
108-86-1	Bromobenzene	ND		0.50	0.13	ug/l	
74-97-5	Bromochloromethane	ND		0.50	0.13	ug/l	
75-27-4	Bromodichloromethane	ND		0.50	0.088	ug/l	
75-25-2	Bromoform	ND		0.50	0.11	ug/l	
74-83-9	Bromomethane	ND		0.50	0.11	ug/l	
104-51-8	n-Butylbenzene	ND		0.50	0.11	ug/l	
135-98-8	sec-Butylbenzene	ND		0.50	0.12	ug/l	
98-06-6	tert-Butylbenzene	ND		0.50	0.062	ug/l	
75-15-0	Carbon disulfide	ND		0.50	0.10	ug/l	
108-90-7	Chlorobenzene	ND	100	0.50	0.046	ug/l	
75-00-3	Chloroethane	ND		0.50	0.16	ug/l	
67-66-3	Chloroform	ND		0.50	0.069	ug/l	
74-87-3	Chloromethane	ND		0.50	0.095	ug/l	
95-49-8	o-Chlorotoluene	ND		0.50	0.069	ug/l	
106-43-4	p-Chlorotoluene	ND		0.50	0.048	ug/l	
56-23-5	Carbon tetrachloride	ND	5.0	0.50	0.083	ug/l	
75-34-3	1,1-Dichloroethane	ND		0.50	0.067	ug/l	
75-35-4	1,1-Dichloroethylene	ND	7.0	0.50	0.14	ug/l	
563-58-6	1,1-Dichloropropene	ND		0.50	0.095	ug/l	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.20	1.0	0.22	ug/l	
106-93-4	1,2-Dibromoethane	ND	0.050	0.50	0.082	ug/l	
107-06-2	1,2-Dichloroethane	ND	5.0	0.50	0.11	ug/l	
78-87-5	1,2-Dichloropropane	ND	5.0	0.50	0.080	ug/l	
142-28-9	1,3-Dichloropropane	ND		0.50	0.11	ug/l	
594-20-7	2,2-Dichloropropane	ND		0.50	0.17	ug/l	
124-48-1	Dibromochloromethane	ND		0.50	0.075	ug/l	
74-95-3	Dibromomethane	ND		0.50	0.11	ug/l	
75-71-8	Dichlorodifluoromethane	ND		1.0	0.10	ug/l	
541-73-1	m-Dichlorobenzene	ND		0.50	0.11	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	1 MEADOW-INF	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-3	Date Received:	05/14/13
Matrix:	DW - Drinking Water Inf	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1		
Project:	BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD		

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
95-50-1	o-Dichlorobenzene	ND	600	0.50	0.073	ug/l	
106-46-7	p-Dichlorobenzene	ND	75	0.50	0.063	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	100	0.50	0.10	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	70	0.50	0.13	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND		0.50	0.094	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND		0.50	0.10	ug/l	
108-20-3	Di-Isopropyl ether	1.4		0.50	0.062	ug/l	
100-41-4	Ethylbenzene	ND	700	0.50	0.14	ug/l	
637-92-3	Ethyl tert Butyl Ether	0.36		0.50	0.064	ug/l	J
87-68-3	Hexachlorobutadiene	ND		2.0	0.096	ug/l	
110-54-3	Hexane	ND		0.50	0.28	ug/l	
591-78-6	2-Hexanone	ND		2.0	0.37	ug/l	
98-82-8	Isopropylbenzene	0.33		0.50	0.11	ug/l	J
99-87-6	p-Isopropyltoluene	ND		0.50	0.053	ug/l	
75-09-2	Methylene chloride	ND	5.0	0.50	0.11	ug/l	
1634-04-4	Methyl Tert Butyl Ether	441 ^a		13	1.7	ug/l	
108-10-1	4-Methyl-2-pentanone	ND		2.0	0.47	ug/l	
91-20-3	Naphthalene	0.67		0.50	0.060	ug/l	
103-65-1	n-Propylbenzene	ND		0.50	0.12	ug/l	
100-42-5	Styrene	ND	100	0.50	0.058	ug/l	
994-05-8	tert-Amyl Methyl Ether	12.1		0.50	0.050	ug/l	
630-20-6	1,1,1,2-Tetrachloroethane	ND		0.50	0.097	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	200	0.50	0.059	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND		0.50	0.041	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	5.0	0.50	0.075	ug/l	
87-61-6	1,2,3-Trichlorobenzene	ND		0.50	0.053	ug/l	
96-18-4	1,2,3-Trichloropropane	ND		0.50	0.20	ug/l	
120-82-1	1,2,4-Trichlorobenzene	ND	70	0.50	0.073	ug/l	
95-63-6	1,2,4-Trimethylbenzene	0.34		0.50	0.12	ug/l	J
108-67-8	1,3,5-Trimethylbenzene	ND		0.50	0.091	ug/l	
127-18-4	Tetrachloroethylene	ND	5.0	0.50	0.12	ug/l	
108-88-3	Toluene	ND	1000	0.50	0.079	ug/l	
79-01-6	Trichloroethylene	ND	5.0	0.50	0.15	ug/l	
75-69-4	Trichlorofluoromethane	ND		1.0	0.15	ug/l	
75-65-0	Tertiary Butyl Alcohol	117		5.0	2.4	ug/l	
75-01-4	Vinyl chloride	ND	2.0	0.50	0.12	ug/l	
	m,p-Xylene	0.20		1.0	0.18	ug/l	J
95-47-6	o-Xylene	0.31		0.50	0.12	ug/l	J
1330-20-7	Xylenes (total)	0.51	10000	0.50	0.12	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis



Client Sample ID: 1 MEADOW-INF	
Lab Sample ID: JB37051-3	Date Sampled: 05/14/13
Matrix: DW - Drinking Water Inf	Date Received: 05/14/13
Method: EPA 524.2 REV 4.1	Percent Solids: n/a
Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

VOA List

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	94%	94%	78-114%
460-00-4	4-Bromofluorobenzene	94%	95%	77-115%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	alkane	4.17	.56	ug/l	J
	alkene	4.51	.51	ug/l	J
	alkane	6.80	1.1	ug/l	J
75-85-4	Amylene Hydrate	10.44	1.6	ug/l	JN
	C3 alkyl benzene	16.31	.58	ug/l	J
	C3 alkyl benzene	16.95	.64	ug/l	J
	Total TIC, Volatile		4.99	ug/l	J

(a) Result is from Run# 2

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TRIP BLANK	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-4	Date Received:	05/14/13
Matrix:	DW - Drinking Water TB	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1	Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

Run #	File ID	DF	Analyzed	By	Prep Date	Prep Batch	Analytical Batch
Run #1	1B79139.D	1	05/17/13	MFH	n/a	n/a	V1B3697
Run #2							

Run #	Purge Volume
Run #1	5.0 ml
Run #2	

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
67-64-1	Acetone	ND		5.0	1.6	ug/l	
78-93-3	2-Butanone	ND		5.0	1.6	ug/l	
71-43-2	Benzene	ND	5.0	0.50	0.047	ug/l	
108-86-1	Bromobenzene	ND		0.50	0.13	ug/l	
74-97-5	Bromochloromethane	ND		0.50	0.13	ug/l	
75-27-4	Bromodichloromethane	ND		0.50	0.088	ug/l	
75-25-2	Bromoform	ND		0.50	0.11	ug/l	
74-83-9	Bromomethane	ND		0.50	0.11	ug/l	
104-51-8	n-Butylbenzene	ND		0.50	0.11	ug/l	
135-98-8	sec-Butylbenzene	ND		0.50	0.12	ug/l	
98-06-6	tert-Butylbenzene	ND		0.50	0.062	ug/l	
75-15-0	Carbon disulfide	ND		0.50	0.10	ug/l	
108-90-7	Chlorobenzene	ND	100	0.50	0.046	ug/l	
75-00-3	Chloroethane	ND		0.50	0.16	ug/l	
67-66-3	Chloroform	ND		0.50	0.069	ug/l	
74-87-3	Chloromethane	ND		0.50	0.095	ug/l	
95-49-8	o-Chlorotoluene	ND		0.50	0.069	ug/l	
106-43-4	p-Chlorotoluene	ND		0.50	0.048	ug/l	
56-23-5	Carbon tetrachloride	ND	5.0	0.50	0.083	ug/l	
75-34-3	1,1-Dichloroethane	ND		0.50	0.067	ug/l	
75-35-4	1,1-Dichloroethylene	ND	7.0	0.50	0.14	ug/l	
563-58-6	1,1-Dichloropropene	ND		0.50	0.095	ug/l	
96-12-8	1,2-Dibromo-3-chloropropane	ND	0.20	1.0	0.22	ug/l	
106-93-4	1,2-Dibromoethane	ND	0.050	0.50	0.082	ug/l	
107-06-2	1,2-Dichloroethane	ND	5.0	0.50	0.11	ug/l	
78-87-5	1,2-Dichloropropane	ND	5.0	0.50	0.080	ug/l	
142-28-9	1,3-Dichloropropane	ND		0.50	0.11	ug/l	
594-20-7	2,2-Dichloropropane	ND		0.50	0.17	ug/l	
124-48-1	Dibromochloromethane	ND		0.50	0.075	ug/l	
74-95-3	Dibromomethane	ND		0.50	0.11	ug/l	
75-71-8	Dichlorodifluoromethane	ND		1.0	0.10	ug/l	
541-73-1	m-Dichlorobenzene	ND		0.50	0.11	ug/l	

ND = Not detected MDL - Method Detection Limit

MCL = Maximum Contamination Level (40 CFR 141)

E = Indicates value exceeds calibration range

J = Indicates an estimated value

B = Indicates analyte found in associated method blank

N = Indicates presumptive evidence of a compound

Report of Analysis

Client Sample ID:	TRIP BLANK	Date Sampled:	05/14/13
Lab Sample ID:	JB37051-4	Date Received:	05/14/13
Matrix:	DW - Drinking Water TB	Percent Solids:	n/a
Method:	EPA 524.2 REV 4.1		
Project:	BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD		

VOA List

CAS No.	Compound	Result	MCL	RL	MDL	Units	Q
95-50-1	o-Dichlorobenzene	ND	600	0.50	0.073	ug/l	
106-46-7	p-Dichlorobenzene	ND	75	0.50	0.063	ug/l	
156-60-5	trans-1,2-Dichloroethylene	ND	100	0.50	0.10	ug/l	
156-59-2	cis-1,2-Dichloroethylene	ND	70	0.50	0.13	ug/l	
10061-02-6	trans-1,3-Dichloropropene	ND		0.50	0.094	ug/l	
10061-01-5	cis-1,3-Dichloropropene	ND		0.50	0.10	ug/l	
108-20-3	Di-Isopropyl ether	ND		0.50	0.062	ug/l	
100-41-4	Ethylbenzene	ND	700	0.50	0.14	ug/l	
637-92-3	Ethyl tert Butyl Ether	ND		0.50	0.064	ug/l	
87-68-3	Hexachlorobutadiene	ND		2.0	0.096	ug/l	
110-54-3	Hexane	ND		0.50	0.28	ug/l	
591-78-6	2-Hexanone	ND		2.0	0.37	ug/l	
98-82-8	Isopropylbenzene	ND		0.50	0.11	ug/l	
99-87-6	p-Isopropyltoluene	ND		0.50	0.053	ug/l	
75-09-2	Methylene chloride	ND	5.0	0.50	0.11	ug/l	
1634-04-4	Methyl Tert Butyl Ether	ND		0.50	0.068	ug/l	
108-10-1	4-Methyl-2-pentanone	ND		2.0	0.47	ug/l	
91-20-3	Naphthalene	ND		0.50	0.060	ug/l	
103-65-1	n-Propylbenzene	ND		0.50	0.12	ug/l	
100-42-5	Styrene	ND	100	0.50	0.058	ug/l	
994-05-8	tert-Amyl Methyl Ether	ND		0.50	0.050	ug/l	
630-20-6	1,1,1,2-Tetrachloroethane	ND		0.50	0.097	ug/l	
71-55-6	1,1,1-Trichloroethane	ND	200	0.50	0.059	ug/l	
79-34-5	1,1,2,2-Tetrachloroethane	ND		0.50	0.041	ug/l	
79-00-5	1,1,2-Trichloroethane	ND	5.0	0.50	0.075	ug/l	
87-61-6	1,2,3-Trichlorobenzene	ND		0.50	0.053	ug/l	
96-18-4	1,2,3-Trichloropropane	ND		0.50	0.20	ug/l	
120-82-1	1,2,4-Trichlorobenzene	ND	70	0.50	0.073	ug/l	
95-63-6	1,2,4-Trimethylbenzene	ND		0.50	0.12	ug/l	
108-67-8	1,3,5-Trimethylbenzene	ND		0.50	0.091	ug/l	
127-18-4	Tetrachloroethylene	ND	5.0	0.50	0.12	ug/l	
108-88-3	Toluene	ND	1000	0.50	0.079	ug/l	
79-01-6	Trichloroethylene	ND	5.0	0.50	0.15	ug/l	
75-69-4	Trichlorofluoromethane	ND		1.0	0.15	ug/l	
75-65-0	Tertiary Butyl Alcohol	ND		5.0	2.4	ug/l	
75-01-4	Vinyl chloride	ND	2.0	0.50	0.12	ug/l	
	m,p-Xylene	ND		1.0	0.18	ug/l	
95-47-6	o-Xylene	ND		0.50	0.12	ug/l	
1330-20-7	Xylenes (total)	ND	10000	0.50	0.12	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Report of Analysis

3.4
3

Client Sample ID: TRIP BLANK	Date Sampled: 05/14/13
Lab Sample ID: JB37051-4	Date Received: 05/14/13
Matrix: DW - Drinking Water TB	Percent Solids: n/a
Method: EPA 524.2 REV 4.1	
Project: BCNJCH:PC# 007805 Bel Air Xtra Fuels, 2476 Churchville Road, Bel Air, MD	

VOA List

CAS No.	Surrogate Recoveries	Run# 1	Run# 2	Limits
2199-69-1	1,2-Dichlorobenzene-d4	93%		78-114%
460-00-4	4-Bromofluorobenzene	95%		77-115%

CAS No.	Tentatively Identified Compounds	R.T.	Est. Conc.	Units	Q
	Total TIC, Volatile		0	ug/l	

ND = Not detected MDL - Method Detection Limit
MCL = Maximum Contamination Level (40 CFR 141)
E = Indicates value exceeds calibration range

J = Indicates an estimated value
B = Indicates analyte found in associated method blank
N = Indicates presumptive evidence of a compound

Misc. Forms

Custody Documents and Other Forms

Includes the following where applicable:

- Chain of Custody



DW
WB

CHAIN OF CUSTODY

495 Tech Center West, Bldg. 1, Marlboro, MA 01752
508-481-6200 FAX: 508-481-7753

FED-EX Tracking #	Bottle Order Control #
Accutest Quote #	Accutest Job # JB37051

Client / Reporting Information			Project Information								Requested Analysis												Matrix Codes				
Company Name Drake Petroleum Company, Inc. Attn: Eric Harvey			Project Name: Bel Air Xtra Fuels, PC #007805								<small>Full Suite VOCs w/ Fuel Oxygenates and TICs via EPA method 524.2</small>												DW- Drinking Water OW- Ground Water WW- Water SW- Surface Water SO- Soil SL- Sludge OI- Oil LIQ- Other Liquid AIR- Air SOL- Other Solid WP- Wipes LAB USE ONLY				
Address P.O. Box 866 221 Quinebaug Road			Street 2476 Churchville Road																								
City North Grosvenordale State CT Zip 06255			City Bel Air State MD																								
Project Contact: Carolyn Roth croth@brwncaid.com			Project # 143732																								
Phone # 856-324-0485			Fax #																								
Samplers Name Hunter White			Client Purchase Order # #007805																								
Accutest Sample #	Field ID / Point of Collection	SUMMA # MEOH Vial #	Collection					Number of preserved Bottles												LAB USE ONLY							
			Date	Time	Sampled by	Matrix	# of bottles	HEP	MOB	PHOS	PCB	PCPN	PCPN	PCPN	PCPN	PCPN	PCPN	PCPN	PCPN		PCPN	PCPN	PCPN	PCPN	PCPN	PCPN	
-1	1 meadow- Eff		5/14/2013	0930	HW	DW	3	3																		X	
-2	1 meadow- Mid2		5/14/2013	0935	HW	DW	3	3																		X	
-3	1 meadow- Inf		5/14/2013	0940	HW	DW	3	3																		X	
-4	Trip Blank					TB	2	2																		X	

4.1
4

Data Deliverable Information			Comments / Remarks				
<input checked="" type="checkbox"/> Std. 10 Business Days <input type="checkbox"/> 10 Day RUSH <input type="checkbox"/> 5 Day RUSH <input type="checkbox"/> 3 Day EMERGENCY <input type="checkbox"/> 2 Day EMERGENCY <input type="checkbox"/> 1 Day EMERGENCY <input type="checkbox"/> Other		Approved By/ Date:	<input checked="" type="checkbox"/> Commercial "A" <input type="checkbox"/> Commercial "B" <input type="checkbox"/> NJ Reduced <input type="checkbox"/> NJ Full <input type="checkbox"/> Other		<input type="checkbox"/> FULL CLP <input type="checkbox"/> NYASP Category A <input type="checkbox"/> NYASP Category B <input type="checkbox"/> State Forms <input checked="" type="checkbox"/> EDD Format		EDD to Carolyn Roth when completed, croth@brwncaid.com
Emergency T/A data available VIA Lablink			Commercial "A" = Results Only				
Sample Custody must be documented below each time samples change possession, including courier delivery.							
Relinquished by Sample:	Date Time:	Received By:	Date Time:	Relinquished By:	Date Time:	Received By:	
1 Hunter White	5-14-13	Eric Roth	5-14-13	Eric Roth	5-14-13	Eric Roth	
3							
5							

On Ice Cooler Temp. **3.0°C**

Accutest Laboratories Sample Receipt Summary

Accutest Job Number: JB37051 **Client:** _____ **Project:** _____
Date / Time Received: 5/14/2013 **Delivery Method:** _____ **Airbill #'s:** _____
Cooler Temps (Initial/Adjusted): #1: (3/3); 0

<u>Cooler Security</u>	<u>Y or N</u>		<u>Y or N</u>	
1. Custody Seals Present:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3. COC Present:	<input checked="" type="checkbox"/> <input type="checkbox"/>
2. Custody Seals Intact:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. Smp'l Dates/Time OK	<input checked="" type="checkbox"/> <input type="checkbox"/>

<u>Cooler Temperature</u>	<u>Y or N</u>	
1. Temp criteria achieved:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Cooler temp verification:	Bar Therm _____	
3. Cooler media:	Ice (Bag) _____	
4. No. Coolers:	1	

<u>Quality Control Preservation</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Trip Blank present / cooler:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
2. Trip Blank listed on COC:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
3. Samples preserved properly:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. VOCs headspace free:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>

<u>Sample Integrity - Documentation</u>	<u>Y or N</u>	
1. Sample labels present on bottles:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Container labeling complete:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Sample container label / COC agree:	<input checked="" type="checkbox"/>	<input type="checkbox"/>

<u>Sample Integrity - Condition</u>	<u>Y or N</u>	
1. Sample recvd within HT:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. All containers accounted for:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Condition of sample:	Intact _____	

<u>Sample Integrity - Instructions</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Analysis requested is clear:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
2. Bottles received for unspecified tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>	
3. Sufficient volume recvd for analysis:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. Compositing instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Filtering instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments