



Maryland  
Department of  
the Environment

## Maryland Catchment Basin and Containment Sump Test Report

MDE Facility I.D. #:	
Facility Name:	UST Owner:
Facility Address:	Owner Address:
City: State: MD Zip:	City: State: Zip:
	Owner Telephone Number:
Testing Company:	
Company Telephone Number:	

Test Date:	Weather Condition:	Temperature:
------------	--------------------	--------------

Product:			
Testing:	<input checked="" type="checkbox"/> Check One Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe): _____	<input checked="" type="checkbox"/> Check One Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe): _____	<input checked="" type="checkbox"/> Check One Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe): _____
Construction:	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:			
Start Time:			
End Level:			
End Time:			
Level Change:			
Test Results:	Pass Fail	Pass Fail	Pass Fail
Test Failure:	Reported to MDE Date: _____ Time: _____		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

Product:			
Testing:	<u>√ Check One</u> Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe):	<u>√ Check One</u> Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe):	<u>√ Check One</u> Spill Bucket Stage I Bucket Dispenser Sump # _____ STP Sump Tank Top Sump Transition Sump Vent Riser Sump Other (Describe):
Construction:	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	Single-walled Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:			
Start Time:			
End Level:			
End Time:			
Level Change:			
Test Result:	Pass      Fail	Pass      Fail	Pass      Fail
Test Failure	Reported to MDE Date: _____ Time: _____		

**- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.**

**- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.**

**Tester Certification** (check one):

MDE Technician    MDIC-    -    - T  
 MDE Inspector    MDIC-    -    - I

Precision Tester: Test Method \_\_\_\_\_ Certification Expiration Date: \_\_\_\_\_

Tester's Name (print) : \_\_\_\_\_ Tester's Signature: \_\_\_\_\_

Comments:

Copy of the test report must be maintained by the owner/operator for a period of 5 years and made available to the Department upon request and during UST inspections.