

**Appendix P** EPA, Chromium in Drinking Water Web Page  
Excerpt

## Water: Chromium in Drinking Water

You are here: [Water](#) » [Drinking Water](#) » [Consumer Information](#) » Chromium in Drinking Water

# Chromium in Drinking Water



Chromium is an odorless and tasteless metallic element. Chromium is found naturally in rocks, plants, soil and volcanic dust, and animals. The most common forms of chromium that occur in natural waters in the environment are trivalent chromium (chromium-3) and hexavalent chromium (chromium-6).

Chromium-3 is an essential human dietary element and is found in many vegetables, fruits, meats, grains and yeast. Chromium-6 occurs naturally in the environment from the erosion of natural chromium deposits, and it can also be produced by industrial processes. There are demonstrated instances of chromium being released to the environment by leakage, poor storage or inadequate industrial waste disposal practices.

The Safe Drinking Water Act requires EPA to determine the level of contaminants in drinking water at which no adverse health effects are likely to occur. These non-enforceable health goals, based on possible health risks from exposure over a lifetime, are called maximum contaminant level goals (MCLG).

EPA sets enforceable standards for drinking water contaminants based on the best available science to prevent potential health problems. In most cases, the enforceable standard is known as a maximum contaminant level (MCL), the maximum permissible level of a contaminant in water which is delivered to any user of a public water system. MCLs are set as close to the health goals as possible after considering costs, benefits and the ability of public water systems to detect and remove contaminants using suitable treatment technologies.

The national primary drinking water regulation that established the MCL for total chromium was promulgated in 1991. The Safe Drinking Water Act requires EPA to periodically review the national primary drinking water regulation for each contaminant and revise the regulation, if appropriate. EPA reviewed total chromium as part of the second six-year review that was announced in March 2010. The Agency noted in March 2010 that it had initiated a reassessment of the health risks associated with chromium exposure and that the Agency did not believe it was appropriate to revise the national primary drinking water regulation while that effort was in process. In 2008, EPA began a rigorous and comprehensive review of chromium-6 health effects based on new science. When this human health assessment is finalized EPA will carefully review the conclusions and consider all relevant information to determine if the current chromium standard should be revised.

- [What are EPA's drinking water regulations for chromium ?](#)
- [Is total chromium or chromium-6 in drinking water a health concern?](#)
- [If EPA decides to revise the regulation that includes chromium-6 in drinking water, what is the process the agency will follow?](#)
- [What related activities are underway at state agencies?](#)

### **What are EPA's drinking water regulations for chromium (total)?**

EPA has a drinking water standard of 0.1 milligrams per liter (mg/L) or 100 parts per billion (ppb) for total chromium, which includes all forms of chromium including chromium-6. Water systems are required to test for total chromium. The current standard is based on potential adverse dermatological effects over many years, such as allergic dermatitis (skin reactions). EPA regularly re-evaluates drinking water standards and, based on new science on chromium-6, began a rigorous and comprehensive review of its health effects in 2008.

- [More information on the drinking water regulatory process](#)

### **Is total chromium or chromium-6 in drinking water a health concern?**

The current federal drinking water standard for total chromium is 0.1 mg/L or 100 ppb. Chromium-6 and chromium-3 are covered under the total chromium drinking water standard because these forms of chromium can convert back and forth in water and in the human body, depending on environmental conditions. Measuring just one form may not capture all of the chromium that is present. In order to ensure that the greatest potential risk is addressed, EPA's regulation assumes that a measurement of total chromium is 100 percent chromium-6, the more toxic form. If tap water from a public water system exceeds this federal standard, consumers will be notified.

The MCL for total chromium was established in 1991 and is based on the best available science at the time which indicated that continued exposure to chromium-6 could result in allergic dermatitis (skin reactions). EPA is now reviewing data from a 2008 long-term animal study by the Department of Health and Human Service's National Toxicology Program, which suggested that chromium-6 may be a human carcinogen if ingested. When the review is completed, EPA will consider this and other information to determine whether the drinking water standard for total chromium needs to be revised.

- [Status of the ongoing risk assessment for chromium-6](#)

### **If EPA decides to revise the regulation that includes chromium-6 in drinking water, what is the process the agency will follow?**

Prior to EPA making any decisions about revising the chromium drinking water regulation, EPA must issue its final human health assessment for chromium-6. More

information regarding EPA's current schedule for the chromium-6 assessment is available at: [http://cfpub.epa.gov/ncea/iristrac/index.cfm?fuseaction=viewChemical.showChemical&sw\\_id=1114](http://cfpub.epa.gov/ncea/iristrac/index.cfm?fuseaction=viewChemical.showChemical&sw_id=1114)

EPA will carefully review the final assessment and consider all other relevant information to determine if a new drinking water regulation for chromium-6 or a revision to the current total chromium standard is warranted.

More information about the EPA's drinking water regulatory process is available at the EPA website.

- [More information on the drinking water regulatory process](#)

**What related activities are underway at state agencies?**

See California's chromium-6 MCL Update <http://www.cdph.ca.gov/certlic/drinkingwater/Pages/Chromium6.aspx>

**On this website:**

- [Basic Information about Chromium in Drinking Water](#)
  - [Administrator Jackson's Statement on Chromium-6 | En Español](#)
  - [Enhanced Monitoring Guidance for Chromium-6](#)
    - [Memo to Drinking Water Systems \(PDF\)](#) (2pp, 28K)
    - [EPA Press Release](#)
  - [IRIS Toxicological Review of Chromium-6](#)
- 

Last updated on Wednesday, April 18, 2012