



TOWN OF DENTON

ANNUAL DRINKING WATER QUALITY REPORT FOR 2016

PWSID # 0050001

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is three (3) potable wells drilled at an average depth of 450 feet in the Piney Point Aquifer.

We have a source water protection plan available from our office that provides more information such as potential sources of contamination.

I'm pleased to report that our drinking water is safe and meets all federal and state requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water utility, please contact **Mark Chandler of the Department of Public Works at 410-479-5446**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Council meetings held on the first Thursday of each month at the Denton Police Department.

The Water Treatment Division of the Department of Public Works routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1 to December 31, **2016**. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS						
Microbiological Contaminants						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants						
Beta/photon emitters (2015)	N	6.5	pCi/1	0	50	Decay of natural and man-made deposits
Alpha emitters	N	6	pCi/1	0	15	Erosion of natural deposits
Combined Radium (2015)	N	0.2	pCi/1	0	5	Erosion of natural deposits
Inorganic Contaminants						
Arsenic Well 3 (2015) Well 5 (2012) Well 6	N N N	4.24 3.47 4.2	ppb	0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Copper (distribution) (2014)	N	0.094	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (distribution) (2014)	N	3	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Fluoride Well 3 (2015) Well 5 (2015) Well 6	N N N	1.17 1.21 1.18	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Chromium Well 3 (2015) Well 5 (2015)	N N	9.27 14.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Disinfectant and Disinfection By-Products						
TTHM [Total trihalomethanes] (distribution)	N	6.2	ppb	0	80	By-product of drinking water chlorination
HAA5 [Haloacetic Acids] (distribution)	N	4.8	ppb	0	60	By-product of drinking water chlorination
Chlorine	N	0.3	ppm	4	4	Water additive used to control microbes

Note: Tests were completed in year 2016 or as otherwise noted. Some testing is not required annually.

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained at the Caroline County Library or by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Denton Public Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Thank you for allowing us to continue providing your family with clean, quality water this year. To maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.