



Consumer Confidence Report Certification

Water Supply System Name: NELPINE MOBILE HOME PARK

PWSID: 0050210 County: CAROLINE

**Consumer Confidence Report due to customers and to MDE no later than July 1st;
Certification of Delivery due to MDE no later than October 1st each year.
CCR and Certification are best delivered together by email attachment if possible.**

I confirm that the Consumer Confidence Report for the year **2015** has been distributed to customers (and appropriate notices of availability have been given) in accordance with COMAR 26.04.01 by July 1, 2016. I further certify that the report is correct and consistent with compliance monitoring data previously submitted to MDE.

Certified by: Name JAMIE WHITBY
Signature Jamie Whitby
Title OWNER + OPERATOR
Phone # 410-634-1953 Date 5/15/16
CELL # 410-714-9113

Specific details on CCR distribution: (Date all that apply)

5/16/16 **Date** CCR was delivered to MDE.

 Date CCR was distributed by mail.

5/15/16 **Date** CCR was distributed by other methods. List methods of delivery: HAND DELIVERY

Approved electronic delivery plan is on file with MDE. (Check if applicable)

 Date a notice of CCR availability was published.

 Date good faith efforts were used to reach non-bill paying consumers. Those efforts included the following recommended methods:

- Date** of posting the CCR on the Internet at: _____
- Date** of mailing the CCR to postal patrons (bulk mail) within the service area (attach zip codes).
- Date** of advertising availability of the CCR in news media (attach copy of announcement).
- Date** of publication of CCR in local newspaper (attach copy).
- Date** of delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers.
- Date** of delivery to community organizations (attach a list).

Check violation types addressed:

- A tier 3 public notice is distributed with the CCR.
- Monitoring violations are addressed in the CCR.
- MCL violations are addressed in the CCR.
- CCR Delivery or Adequacy Violations are addressed in the CCR.

Mandatory for systems serving 100,000 or more persons:

 Date posted CCR on a publicly accessible Internet site. List Internet address: _____
 Date CCR delivered to other agencies or additional methods used. (Optional, attach list or description).

Annual Drinking Water Quality Report
Nelpine Park

We're very pleased to provide you with this year's Annual Quality Water Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is from two Wells at a depth of 440 to 460 feet and is the Piney Point aquifer. The water system's ID number is 50210.

I'm pleased to report that our drinking water is safe and meets federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Jamie Whitby at (410)-634-1953 address 22732 Squire Lane Queen Anne, MD. 21657. We want our valued customers to be informed about their water utility.

Nelpine Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st,2015. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonable expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provide the following definitions.

Non-Detects (ND)- laboratory analysis indicates that the contaminant is not present.

Parts per million (ppm) or Milligrams per liter (mg/l)- one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter- one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L)- picocuries per liter is a measure of the radioactivity in water.

Action Level- the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level- (mandatory language) The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -(mandatory language) The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Date Tested	Unit	MCL	MCLG	Detected Level	Violation	Likely Source Of Contamination
Inorganic Contaminants							
1. Fluoride	1/19/15	ppm	4	4	0.4	NO	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2. Arsenic	2/5/15	ppb	10	0	2	NO	Erosion of natural deposits; runoff from glass & electronics production wastes

2nd Standards

1. Chloride	4/29/08	ppm	250	250	5.3	NO	Erosion of natural deposits
2. PH	4/29/08		6.5-8.5	6.5-8.5	7.3	NO	Erosion of natural deposits
3. Total Dissolved Solids	4/29/08	ppm	500	500	161	NO	Erosion of natural deposits

Radioactive Contaminants

1. Beta Particles	8/15/15	pCi/L	50*	0	10.2**	NO	Erosion of natural and man-made deposits.
-------------------	---------	-------	-----	---	--------	----	---

*The MCL for Beta Particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for beta particles.

**Because the Beta Particle results were below 50 pCi/L, no testing for individual Beta Particle constituents was required.

Unregulated Contaminants

1. Sodium	1/16/15	ppm	N/A	N/A	31	NO	Erosion of natural deposits.
2. Calcium	4/29/08	ppm	N/A	N/A	18	NO	Erosion of natural deposits.
3. Hardness	4/29/08	ppm	N/A	N/A	60	NO	Erosion of natural deposits.
4. Alkalinity, Carbonate	4/29/08	ppm	N/A	N/A	244	NO	Erosion of natural deposits.
5. Radon-222	10/31/00	pCi/L	N/A	N/A	435	NO	Erosion of natural deposits.

We constantly monitor the water supply for various contaminants. We have detected radon in the finished water supply in one out of one samples tested. There is no federal regulation for radon levels in drinking water. Exposure to air transmitted radon over a long period of time may cause adverse health effects.

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Nelpine Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.”

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nelpine Park Rentals LLC is dedicated to providing premium water service. We are proud of our continued record of consistently meeting all water quality standards and requirements. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. If you have any questions about this report please call us at (410) 634-1953.