

2017 Annual Drinking Water Quality Report

Heritage Park

MD00090224

Annual Water Quality Report for the period of
January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report
contact:

Gordon Heck (Operator)

Phone (410) 943-3640

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que lo entienda bien.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MCLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect or MRDLG: the benefits of the use of disinfectants to control microbial contaminants.

mrem :

Millirems per year (a measure of radiation absorbed by the body)

na :

Not applicable

ppb:

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water
milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppm:

Treatment Technique or TT:

Source Water Information

Source water name	Type of water	Report Status	Location
Well One DO810198	GW	Y	Near 1.3 Mi NE of East New Market Appox, 800 Ft W Creamery Road
Well Two DO940435	GW	Y	Near E N Market Appox.. 50 Ft N of Heritage Park Rd.

2016 Regulated Contaminants Detected

Lead and Copper
Definitions:

Lead and Copper Date Sampled MCLG Action Level 90th
(AL) Percentile # Sites Over AL Units Violation Likely Source of Contamination (AL)

Copper	12/11/2014	1.3	1.3	0.06	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
---------------	------------	-----	-----	------	-----	---	---

The following tables contain scientific terms and measures, some of which may require explanation.

Definitions:

Action Level Goal (ALG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine		0.6	0.5-0.6	MRDLG = 4	MRDL = 4	ppm	n	Water additive used to control microbes.
Halooacetic Acids (THM)	08/19/2014	5.51	5.51-5.51	No goal for the total	60	ppb	n	By-product of drinking water disinfection
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Total Trihalomethanes (THM)	08/19/2014	17.5	17.5-17.5	No goal for the total	80	ppb	n	
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Inorganic Contaminants								
Contaminants	Collection	Highest Level	Range of Levels	MCLG	MCL	Units	Violation	
Arsenic-While your drinking Water meets EPA standards For arsenic, it does contain Low levels of arsenic. EPAs standard balances the current understanding of arsenics possible health effects against the costs of removing arsenic from drinking water. EPA continucs to research the health effects of low level of arsenic, which is a mineral know to Cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems		0	0-7.9	0	15	ppm	N	Erosion of natural deposits; Runoff from orchids; runoff from glass and electronic production wastes.
Fluoride	05/04/2015	1.1	1.1-1.1	4	4.0	ppm	n	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation
Beta/Photon emitters	10/15/2014	7.1	7.1-7.1	0	5.0	pCi/L	N
Gross alpha excluding	10/15/2014	3.2	3.2-3.2	0	15	pCi/L	N
							Erosion of natural deposits

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Park owner Alex Williams
Phone (202) 256-6981

Park Manager: Erin Holliday
Phone: (443) 521-3256

Operator: Gordon Heck,
Phone (410) 943-3640