

Annual Drinking Water Quality Report

PORT HERMAN BEACH CONDOMINIUM, INC. PWSID# 0070027

June 15, 2018

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. The source of our drinking water is two wells drilled into the Magothy aquifer. Our old well is about 400 feet in depth, and our new well is 70 feet. An aquifer is an underground body of water, which is tapped by drilling wells and pumping the water to the surface for distribution.

The 400 feet of earth between surface sources and this aquifer helps to purify the water before it actually reaches the aquifer, making it easier for us to treat before we pump it into your water distribution system. The following report is provided in compliance with Federal regulations and will be provided annually. This report outlines the quality of our finished drinking water and what that quality means.

If you have any questions about this report or concerning the water utility, please contact Mr. Brad Carillo at (410) 620-2598, extension 4002. We want our valued customers to be informed about the water utility.

The Port Herman water department routinely monitors for contaminants in your drinking water according to Federal and State laws. The tables on the following pages show the results of our monitoring for the period of **January 1st to December 31st, 2017**. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewerage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and residential uses.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Definitions

In this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (u/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Annual Drinking Water Quality Report
Port Herman Beach
2017 Consumer Confidence Report (Page 2)**

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of the report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not frequently change.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range	Sample Date	Violation	Typical Source
Disinfectants & Disinfection by-products (There is evidence that addition of a disinfectant is necessary for control of microbial contaminants)							
Total Coliform	0	0	0 positive	NA	2017	NO	Naturally present in the environment
TTHMs (Total Trihalomethanes) (ppb)	NA	80.0 ppb	4.2 ppb	NA	2017	No	By-product of drinking water disinfection
HAA5(Haloacetic Acids)	NA	60.0 ppb	4.63 ppb	NA	2017	NO	By-product of drinking water disinfection
Chlorine	4.0	4.0 ppm	1.3	0.3-1.3	2017	NO	Water Additive to control microbes
Combined Radium	0 pCi/L	5.0 pCi/L	0.8 pCi/L	NA	2013	NO	Erosion of natural deposits
Gross Alpha excluding radon and uranium	0	15.0 pCi/L	5.1	NA	2013	NO	Erosion of natural deposits
Barium	2	2 ppm	ND	NA	2015	NO	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	NA	100 ppb	ND	NA	2015	No	Discharge from steel and pulp mills; erosion of natural deposits
Inorganic and Organic Contaminants							
Copper (ppm)	1.3mg/L	AL	2.05	NA	2017	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppm)	0.015 mg/L	AL	0	NA	2017	No	Corrosion of household plumbing systems; Erosion of natural deposits
Nitrate (measured as Nitrogen) (ppm)	10	10	2.0	NA	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (ug/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: not detected
NR	NR: Monitoring not required, but recommended

Important Drinking Water Definitions	
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
AL	AL: Action Level: the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

As you can see by the table, our system had no violations. We are proud that our drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The copper results in 2017 were higher than usual and an "Optimal Corrosion Control Plan" was initiated to reduce the copper level in the water. The EPA has determined that your water IS SAFE at these levels. However, we did receive a reporting violation because results from lead and copper monitoring were not submitted prior to the reporting deadline. We have since been returned to compliance for this violation.

Non-Detected Contaminants

Port Herman Beach Condominium, Inc. is only required to provide information on those contaminants it has detected.

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Port Herman Beach Condominium, Inc. is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>."

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, **including bottled water**, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791).

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Usted puede obtener informacion en espanol por llamar por telefono la casa del ayuntamiento de Port Herman Beach Condominium a (410) 620-2598 extension 4002

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Port Herman Beach Condominium, Inc. is dedicated to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life.

**Port Herman Beach Condominium, Inc.
101 Port Herman Drive
Chesapeake City, Maryland 21915
Phone (410) 620-2598 extension 4002**