

# **2018 Annual Drinking Water Quality Report**

## **Cedarhurst Mobile Home Park**

### **PWSID #MD0220216**

In compliance with Safe Drinking Water Act amendments by Congress of 1996 and subsequent Federal and State regulations, Cedarhurst MHP is pleased to provide this annual water quality report for calendar year 2017. Cedarhurst MHP routinely monitors for contaminants in your drinking water. For more information on the source of your water and the significant potential sources of contamination, contact the Maryland Water Supply Program at the Maryland Department of the Environment at (410) 537-3714 or visit on the web:

[http://www.mde.state.md.us/programs/Water/Water\\_Supply/Source\\_Water\\_Assessment\\_Program/Pages/programs/waterprograms/water\\_supply/sourcewaterassessment/by\\_county.aspx](http://www.mde.state.md.us/programs/Water/Water_Supply/Source_Water_Assessment_Program/Pages/programs/waterprograms/water_supply/sourcewaterassessment/by_county.aspx)

#### **Is my water safe?**

We are very pleased to provide you with this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to enduring the quality of your water, as Local Water vigilantly safeguards its water. We are proud to report that our system is not in violation of a maximum contaminant level or any other water quality standard.

#### **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

#### **How do we monitor for contaminants?**

Cedarhurst MHP routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2017. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk.

#### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

#### **Educational Statement for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cedarhurst MHP is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at: <http://www.epa.gov/safewater/lead>

# Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

## Regulated Contaminants

### Inorganic Contaminants

Contaminant, units	MCLG	MCL	Result	Range		Sample Date	Violation	Typical Source	Health Effects
				Low	High				
Fluoride, ppm	4	4	0.8	-	-	11/07/2016	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

### Disinfectants and Disinfection By-Products

Contaminant, units	MCLG	MCL	Result	Range		Sample Date	Violation	Typical Source	Health Effects
				Low	High				
Chlorine, ppm	4	4	-	0.6	0.8	2017	No	Water additive used to control microbes.	Eye/nose irritation; stomach discomfort.

### Inorganic Contaminants

Contaminant, units	MCLG	MCL	Result	Range		Sample Date	Violation	Typical Source	Health Effects
				Low	High				
Copper, ppm	1.3	AL 1.3	0.04*	0	Exceeded AL	08/19/2016	No	Corrosion of household plumbing systems; Erosion of natural deposits	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Lead, ppb	0	AL 15	1.0*	0	Exceeded AL	08/19/2016	No	Corrosion of household plumbing systems; Erosion of natural deposits	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

\*= result is the 90<sup>th</sup> Percentile reading

**Units Description:**

NA: Not applicable

ND: Not detected

NR: Not reported

MNR: Monitoring not required, but recommended.

ppm: parts per million, or milligrams per liter (mg/L)

ppb: parts per billion, or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radioactivity)

# of monthly positive samples: Number of samples taken monthly that were found to be positive

**Important Drinking Water Definitions:**

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**For more information contact:****Cedarhurst Mobile Home Park****Onsite Manager: Deborah Steward****c/o Sunrise Communities****410 S. Aurora Avenue****Clearwater, Florida 33765****Email: [deborah.steward@mysunrisecommunity.com](mailto:deborah.steward@mysunrisecommunity.com)****Or Regional Owners:****Brian Spear: [brian.spear@mysunrisecommunity.com](mailto:brian.spear@mysunrisecommunity.com)****Kevin Bupp: [kevin@kevinbupp.com](mailto:kevin@kevinbupp.com)**