

Year Ending 2018 **CONSUMER CONFIDENCE** **REPORT**

For Residents of
TAYLORSVILLE MHP

A Report of Your Water Quality

Prepared by Fountain Valley Analytical Lab, Inc.
1413 Old Taneytown Rd., Westminster, MD 21158

Annual Drinking Water Quality Report

MD0060216

TAYLORSVILLE MOBILE HOME PARK

Annual Water Quality Report for the period of January 1 to December 31, 2018

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name: Mr. Michael Ball

Phone: (410) 848-1297

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que lo entienda bien.

TAYLORSVILLE MOBILE HOME PARK is Ground Water

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

The Maryland Department of the Environment has prepared an assessment of the source water. To view the source water assessment report, go to http://www.mde.state.md.us/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/cl.aspx.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

SWA = Source Water Assessment

Source Water Name

TAYLORSVILLE 2 NOPERMIT

TAYLORSVILLE 3 CL739766

CL739766

Type of Water	Report Status	Location
GW	Y	
GW	Y	NEAR 0 MI TAYLORSVILLE APPROX. 250 FT W OF RT 27

Lead and Copper

Definitions:
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Lead and Copper	Likely Source of Contamination
Copper	09/18/2015	1.3	1.3	0.289	0	ppm	Copper	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/18/2015	0	15	3	0	ppb	Lead	Corrosion of household plumbing systems; Erosion of natural deposits.

Water Quality Test Results

Definitions:
Avg:
Maximum Contaminant Level or MCL:
Level 1 Assessment:
Maximum Contaminant Level Goal or MCLG:
Level 2 Assessment:
Maximum residual disinfectant level or MRDL:
Maximum residual disinfectant level goal or MRDLG:
na:
mrem:
ppb:
ppm:
Treatment Technique or TT:

The following tables contain scientific terms and measures, some of which may require explanation.
Regulatory compliance with some MCLs are based on running annual average of monthly samples.
The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
not applicable.
millirems per year (a measure of radiation absorbed by the body)
micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

<u>Disinfectants and Disinfection By-Products</u>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2018	1.1	0.7 - 1.1	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Total Trihalomethanes (TTHM)	09/27/2017	2.6	2.6 - 2.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
<u>Inorganic Contaminants</u>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2018	0.09	0 - 0.09	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2018	3	1.03 - 3.14	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
<u>Radioactive Contaminants</u>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	08/20/2015	4.1	4.1 - 4.1	0	50	pCi/L	N	Decay of natural and man-made deposits.
Combined Radium 226/228	08/20/2015	0.9	0.9 - 0.9	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	08/20/2015	2.2	2.2 - 2.2	0	15	pCi/L	N	Erosion of natural deposits.