



## **CONSUMER CONFIDENCE REPORT**

**Thayerville Water System  
PWSID # 0110024  
301-334-6976**

**In Accordance With: The U.S.  
Environmental Agency National  
Primary Drinking Water Regulation 40  
CFR Parts 141 and 140**

### **Introduction:**

It is our pleasure to provide you with our 2018 Water Quality Report. This annual report is a summary of last year's water quality produced at the Thayerville water treatment plant. Included are details about where your water comes from, water quality tests results, how they compare to standards set by the US Environmental Protection Agency (USEPA), and answers to frequently asked questions. We are committed to providing you with information because informed customers are our best allies. We hope you find this

report informative and helpful. Please contact us with any questions or comments.

### **Where Does Your Drinking Water Originate:**

The source of the Thayerville water supply is the Greenbrier Formation. The Thayerville Water System obtains all of its raw water from two separate wells (ground water). The wells are both 220 feet deep.

### **How Your Water is Treated:**

The raw water is pumped from the wells to the Thayerville water treatment plant. The water is disinfected with chlorine to kill harmful bacteria and viruses. The water is then pumped into the distribution system and two storage tanks.

### **Testing Parameters:**

The Thayerville Water System analyzes its finished drinking water for all parameters outlined in the National Primary Drinking Water Regulation 40 CFR Parts 141 and 142 unless a waiver has been granted by Maryland Department of the Environment. The system also analyzes for many unregulated chemical compounds. The Water Quality Data table on the back shows all of the contaminants detected in Thayerville's drinking water between January 1 and December 31, 2018 unless dated otherwise. In 2018, once again, all the water

produced at the Thayerville Water Treatment Plant exceeded all state and federal guidelines for safe drinking water.

### **General Drinking Water Information:**

The sources of drinking water (both tap and bottled) include rivers, lakes, streams, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, inorganic contaminants, pesticides and herbicides, organic chemical contaminants and radioactive contaminants. To ensure tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants

and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at (800-426-4791).

### **The Bottom Line:**

Some individuals may be more vulnerable than the general population to contaminants in drinking water. Immuno-compromised individuals such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/Aids or other immune system disorders, some elderly and infants may be particularly at risk from infections. Those individuals should seek advice about drinking water from their health care provider. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA Safe Drinking Water Hotline at (800-426-4791).

### **For More Information:**

Please contact the Garrett County Department of Public Works Utilities Division at 301-334-6983 or the Laboratory Director at 301-387-6162 for additional information regarding the data in this report. The Board of Garrett County Commissioners holds regularly scheduled public meetings every Tuesday at 9:00am. The public meeting room is located in the Court House at 203 South 4<sup>th</sup> Street, Oakland, MD. Please call to schedule your topic on the agenda for discussion at any regularly scheduled meeting.

### THAYERVILLE WATER QUALITY DATA TABLE

Regulated Contaminants	Units	Thayerville Distribution System	Thayerville Water	Range of Levels Detected	MCL	MCLG	Sample Date	Typical Sources of Contaminant
Lead	ppb	4			AL = 15	0	2016	corrosion of household plumbing systems
Copper	ppm	0.858			AL = 1.3	1.3	2016	corrosion of household plumbing systems
Chlorine	ppm	1.5		1.3 - 1.5	4	4	2018	Water additive to control microbes
Nitrates	ppm		3.0	2.52 - 2.52	10	10	2018	run-off from fertilizer and leaching from septic tanks
Arsenic*	ppb		1.61	1.61 - 1.61	10	0	2017	erosion of natural deposits
Selenium	ppb		6.11	6.11 - 6.11	100	100	2017	discharge from mines; erosion of natural deposits
Barium	ppm		0.104	.104 - .104	2	2	2017	Discharge from drilling waste and metal refineries. Erosion of natural deposits
Unregulated Contaminants								
Sodium	ppm		4.07	not regulated			2017	

### LEAD IN DRINKING WATER

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Department of Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

#### Terms and Units Defined:

**AL - Action Level:** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements for the water system.

**ppm - parts per million:** Corresponds to one penny in \$10,000.      **ppb - parts per billion:** Corresponds to one penny in \$10,000,000.

**MCL - Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using best available treatment technology.

**MCLG - Maximum Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. **Unregulated contaminants** are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

**\*ARSENIC:** While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high levels and is linked to other health effects such as skin damage and circulatory problems.

The Maryland Dept. of the Environment requires monitoring for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, may be more than one year old.