



City of Frostburg

2020 Drinking Water Quality Report

PWSID: 001-0011

Important Information Concerning Your Drinking Water:

We're pleased to present to you the Annual Water Quality Report for 2020. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service, an Agency of the State of Maryland, began operating the water treatment facility in January 2002 and prepared this report on behalf of the City of Frostburg.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate, identifies several hundred drinking water contaminants and establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely conducts sanitary surveys, inspections and monitoring for all public water systems. MES provides safe, dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney at 410-729-8350, e-mail jjanney@menv.com**.

Stay Informed
on Water
Quality

Public Meeting Information:

For the opportunity to ask questions or participate in decisions that may affect your drinking water quality, please visit the City's webpage at www.frostburgcity.org to find upcoming meetings of the Mayor and Council. Customers may also call 301-689-6000 for more information.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Inside This Issue:

Definitions	2
Special Points of Interest	2
Water Quality Report	3
Lead in Drinking Water	4
Sources of Drinking Water	4
TOC Removal	4

The Maryland Environmental Service (MES) operates and maintains the water treatment facility for the City of Frostburg. The facility is rated to treat 3.0 million gallons per day (MGD) and currently averages 1.2 MGD. The Frostburg water treatment facility receives raw water from numerous sources. MES maintains 29 springhouses with related collection and transmission equipment, and two deep wells in the Pocono aquifer. The balance of raw water is pumped from the Piney Dam reservoir in Garrett County. All raw water sources are commingled in a one million gallon supply reservoir which feeds the water treatment facility. The raw water is treated using a surface water treatment plant which consists of four basic components: coagulation, flocculation, sedimentation and filtration. These processes are specifically designed to treat the water at Frostburg. The treated water is stored in two finished water reservoirs. The last steps of treatment include the addition of Chlorine for disinfection, fluoride for dental protection and a corrosion inhibitor to help maintain the distribution system.

The Maryland Environmental Service provides personnel who are properly trained and licensed to operate and maintain the water treatment facility and related equipment in accordance with all applicable regulations. The operational tasks include daily visits to the water treatment facility, checking the facility, performing daily process testing, performing daily, weekly, and monthly calibrations/maintenance, performing all outside grounds maintenance, and continuing on-going quality control and preventative maintenance programs. The Maryland Environmental Service procures all necessary supplies and materials outlined in the operating budget for the efficient control of treatment, compiles and submits all reports required by Local, State, and Federal Regulatory Agencies and provides response 24 hours per day in the event of emergency situations such as an equipment malfunction.

Special points of interest:

- The water at Frostburg is tested for over 100 different compounds.
- The City of Frostburg's Drinking Water met all of the State and Federal requirements.

Definitions:

- Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
- Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- Action Level - The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.
- Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.
- Turbidity - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of "cloudiness" of the water.
- NTU - Nephelometric Turbidity Units. Units of measurement used to report the level of turbidity or "cloudiness" in the water.
- ppb - Parts per billion or micrograms per liter.
- ppm - parts per million or milligrams per liter



City of Frostburg Treated Water Quality Report 2020

Contaminant	Highest Level Allowed EPAs MCL	Highest Level Detected	Ideal Goal (EPA's MCLG)
Regulated at the Treatment Plant			
Nitrate	10 ppm	1.1 ppm	10 ppm
Typical Sources of Contaminant: Runoff from the use of fertilizer		Range (0.65 to 1.71 ppm)	
Fluoride	4.0 ppm	0.29 ppm	4.0 ppm
Typical Sources of Contaminant: Added for dental protection		Range (0.0 to 0.29 ppm)	
Barium	2 ppm	0.05 ppm	2 ppm
Typical Sources of Contaminant: Erosion of natural deposits		Range (0.0 to 0.05 ppm)	
Chlorine	4 ppm	1.07*	4 ppm
Typical Sources of Contaminant: Added for microbial protection		Range (1.01 to 1.12) * Average	
Ethylene dibromide (2018 Testing)	50 ppt	10 ppt	0 ppt
Typical Sources of Contaminant: Discharge from petroleum refineries			
Regulated in the Distribution System			
Total Trihalomethanes (TTHM)	80 ppb	(Range 20.7 -72.5)* 49 ppb**	N/A
Haloacetic Acids (HAA5)	60 ppb	(Range 4.8 - 21.0)* 14 ppb**	N/A
Typical Source of Contaminants: By-product of drinking water disinfection			
* Highest Individual Result from a Single Location			
** Four monitoring sites are individually averaged and reported quarterly. Compliance is determined on a Locational Rolling Annual Average (LRAA) of the individual sites. Value reported is the highest LRAA during 2020.			
Treatment Technique			
Turbidity	TT = filtration 0.3 NTU (Range 0.02- 0.15) Average 0.07 NTU		
Typical Source of Contaminant: Soil Runoff			
Turbidity cannot exceed 1.0 NTU and must be less than or equal to 0.3 NTU taken each month-in at least 95% of the measurements.			
The water plant consistently met all of the turbidity requirements in 2020.			
Regulated at the Consumer's Tap			
Copper - (2018 Testing)	1.3 ppm	0.09 ppm*	1.3 ppm
Lead - (2018 Testing)	15 ppb	0.0 ppb*	0.0 ppb
Typical Source of Contaminant: Corrosion of household plumbing		* 90th Percentile	

The table above lists all the drinking water contaminants that were detected during the 2020 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2020. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

Total Organic Carbon (TOC)

The percentage of Total Organic Carbon (TOC) removal was measured each quarter and the system met all TOC removal requirements. During 2020 the minimum required TOC removal rate was between 45% to 72%. The average removal rate during 2020 was 54%.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791)

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Source Water Assessment

The Maryland Department of the Environment completed a source water assessment. You may read this source water assessment by contacting the City office.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Frostburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Contaminants That May Be Present in Source Water:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Thank you for another great year of Water Quality!



**MARYLAND
ENVIRONMENTAL
SERVICE**

IMPORTANT INFORMATION

The following pages comprise the Annual Consumer Confidence Report (CCR) for your water system.

To download the CCR into your word processing program, follow these steps. Remember you must have the document set up in Landscape Orientation.

- * Choose Select All from the edit drop down MENU. (it will highlight all the information)
- * Choose Edit from the Menu, select Copy from the edit dropdown Menu.
- * Open your word processing program.
- * Choose Edit from the MENU, select Paste from the edit dropdown MENU and the information will transfer.
- * Choose Edit from the Menu.

In order to meet all the requirements of the CCR, you must include the following additional information if it pertains to your water system.

- * The report must include the telephone number of the owner, operator, or designee of the community water system as a source of additional information concerning the report.
- * In communities with a large proportion of non-English speaking residents, as determined by the Primacy Agency, the report must contain information in the appropriate language(s) regarding the importance of the report or contains a telephone number or address where such residents may contact the system to obtain a translated copy of the report and/or assistance in the appropriate language.
- * The report must include information about opportunities for public participation in decisions that may affect the quality of the water (e.g., time and place of regularly scheduled board meetings).
- * If your water system purchases water from another source, you are required to include the current CCR year's Regulated Contaminants Detected table from your source water supply.
- * If your water system had any violations during the current CCR Calendar year, you are required to include an explanation of the corrective action take by the water system.
- * If your water system is going to use the CCR to deliver a Public Notification, you must include the full notice and return a copy of the CCR and Public Notice with the public Notice. This is in addition to the copy and certification form required by the CCR Rule.
- * The information about likely sources of contamination provided in the CCR is generic. Specific information regarding contaminants may be available in sanitary surveys and source water assessments and should be used when available to the operator.
- * If a community water system distributes water to its customers from multiple hydraulically independent distribution systems fed by different raw water sources, the table should contain a separate column for each service area, and the report should identify each separate distribution system. Alternatively, systems may produce separate reports tailored to include data for each service area.

- * Detections of unregulated contaminants for which monitoring is required are not included in the CCR and must be added. When added, the information must include the average and range at which the contaminant was detected.
- * If a water system has performed any monitoring for Cryptosporidium, including monitoring performed to satisfy the requirements of the Information Collection Rule [ICR] (141.143), which indicates that Cryptosporidium may be present in the source water or the finished water, the report must include: (a) a summary of the results of the monitoring; and (b) an explanation of the significance of the results.
- * If a water system has performed any monitoring for radon which indicate that radon may be present in the finished water, the report must include: (a) The results of the monitoring; and (b) An explanation of the significance of the results.
- * If a water system has performed additional monitoring which indicates the presence of other contaminants in the finished water, EPA strongly encourages systems to report any results which may indicate a health concern. To determine if results may indicate a health concern, EPA recommends that systems find out if EPA has proposed an NPDWR or issued a health advisory for that contaminant by calling the Safe Drinking Water Hotline (800-426-4791). EPA considers detects above a proposed MCL or health advisory level to indicate possible health concerns. For such contaminants, EPA recommends that the report include: (a) the results of the monitoring; and (b) an explanation of the significance of the results noting the existence of a health advisory or a proposed regulation.
- * If you are a groundwater system that receives notice from a state of a significant deficiency, you must inform your customers in your CCR report of any significant deficiencies that are not corrected by December 31 of the year covered by it. The CCR must include the following information:
 - The nature of the significant deficiency and the date it was identified by the state.
 - If the significant deficiency was not corrected by the end of the calendar year, include information regarding the State-approved plan and schedule for correction, including interim measures, progress to date, and any interim measures completed.
 - If the significant deficiency was corrected by the end of the calendar year, include information regarding how the deficiency was corrected and the date it was corrected.

Annual Drinking Water Quality Report

MD0010009

WESTERN REGION ALLEGANY DISTRIB. SYSTEM

Annual Water Quality Report for the period of January 1 to December 31, 2020

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name James L. Klebber, P.E.

Phone 4/3/21

WESTERN REGION ALLEGANY DISTRIB. SYSTEM is Purchased Surface Water

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

SWA = Source Water Assessment

Source Water Name

Type of Water

Report Status

Location

CC-MD0010011-TP01

PURCHASED - MD0010011

SW

A source water assessment has been performed by the Maryland Department of the Environment and is accessible on their website

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2020	0.6	0.5 - 0.6	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2020	16	1.33 - 30.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2020	65	28.1 - 80.5	No goal for the total	80	ppb	N	By-product of drinking water disinfection.