



1751-1 Pulaski Highway Havre De Grace, MD 21078 (410) 939-5550

Supplemental Groundwater Monitoring and UST System Evaluation Report

Site Location:

Urbana Pike BP
1904 Urbana Pike
Clarksburg, MD
Facility # 87

Prepared For:

Herb Meade
Carroll Motor Fuels
18 Loveton Circle
Sparks MD 21152

August 8, 2025

SIGNATURE SHEET

Prepared by:

Name: Greg Beal

Company: Advanced Environmental Concepts, Inc.

Address: 5292 Enterprise Street, Suite C

City/State/Zip: Eldersburg, Maryland 21784

Telephone: (410) 795-5955

Table of Contents

1.0 Introduction	2
1.1 Purpose	2
2.0 Groundwater Sampling & Methods	2
2.1 Monitoring Well Sampling	2
3.0 Results of Water Sampling	2
3.1 Groundwater Elevation	2
3.2 Monitoring Well Sampling Results	2
4.0 Underground Storage Tank (UST) System Evaluation	3
4.1 Precision Leak Testing	3
4.2 Dispenser Calibration	3
4.3 Sump Testing	3
5.0 Conclusion	4
6.0 Appendices	4
Appendix A	5
Site Maps	5
Appendix B	6
Groundwater Gauging & Analytical Tables	6
Appendix C	7
Report of Analysis & Chain of Custody Record	7
Appendix D	8
Precision Testing 6/29/2025 Report	8
Petroleum Standards 8/4/2025 Report	8
Hydrostatic Sump Testing Data	8

1.0 Introduction

1.1 Purpose

This Report of Groundwater Sampling and Underground Storage Tank (UST) System Tightness Testing has been prepared to satisfy the requirements set forth by the Maryland Department of the Environment (MDE) for the Carroll Motor Fuels (CMF) Urbana Pike facility which is located at 1904 Urbana Pike Clarksburg, MD; referred to herein as the "site".

This **multifaceted approach** was employed to evaluate the integrity of the UST system. This approach included:

- **Precision tank and line tightness testing,**
- **Dispenser calibration** to ensure accurate inventory reconciliation, and
- **Hydrostatic sump testing** for all UST system sumps, all of which passed and were found to be tight.
- **Confirmation of groundwater sampling data**

2.0 Groundwater Sampling & Methods

2.1 Monitoring Well Sampling

On 07/25/2025 AEC personnel arrived on site to gauge and sample three site monitoring wells. Prior to sampling, each well was gauged for presence/absence of liquid phase hydrocarbons (LPH) as well as depth to groundwater with an electronic oil/water interface meter. LPH was not detected in any of the site wells. After gauging, each well was purged a total of three well volumes of water. Purged groundwater was treated with activated carbon prior to being discharged to the ground. After purging, groundwater was allowed to recover to a minimum of 90% pre purge levels prior to sample collection. Groundwater samples were collected using pre-packaged, single use, disposable bailers and placed in laboratory supplied VOAs and then placed in a cooler with ice and chain of custody record for delivery to the laboratory.

Groundwater samples were collected from MW-3, MW-4, and MW-5. Groundwater samples collected on 07/25/2025 were delivered to AECs laboratory to be analyzed by EPA Method 8260 for Volatile Organic Compounds (VOCs).

3.0 Results of Water Sampling

3.1 Groundwater Elevation

Groundwater elevation observed during the 07/25/2025 sampling event ranged from 87.26 feet in MW-4 (highest) to 83.94 in MW-3 (lowest). AEC has constructed groundwater elevation contours based upon the depth to groundwater measurements collected on 07/25/2025 and previously established top of casing elevations which depict groundwater flow on site to be to the south. A groundwater elevation contour map can be found in Appendix A.

3.2 Monitoring Well Sampling Results

Method detectable concentrations were observed in the groundwater samples collected and submitted for analysis. The following table summarizes the detectable concentrations of VOCs. There were no detectable concentrations of VOCs observed in the MW-3 sample.

Location	Sample Date	Depth to Water (ft)	Water Elevation (ft)	MTBE (ug/l)	DIPE	BENZENE (ug/l)	TOLUENE (ug/l)	ETHYL-BENZENE (ug/l)	XYLENES (TOTAL) (ug/l)
MW-4	06/18/25	10.45	89.81	3.40	13.6	86.70	1.52	<1	3.56
	07/25/25	13.00	87.26	1.16	6.33	30.80	<1	<1	<1
Duplicate	07/25/25	13.00	87.26	<5	<25	21.00	<5	<1	<10
MW-5	06/18/25	13.49	89.24	2.40	13.6	76.6	13.4	2.12	<1
	07/25/25	16.12	86.61	20.30	116	366	32.7	1.69	6.98
Duplicate	07/25/25	16.12	86.61	20	71	310	24	2	<10

Historical analytical results from the monitoring well sampling events are summarized in the analytical summary table found in Appendix B. A full Report of Analysis and Chain of Custody Record can be found in Appendix C.

The detected concentrations were reported to MDE and documented in Spill Report #22879.

4.0 Underground Storage Tank (UST) System Evaluation

4.1 Precision Leak Testing

Following the identification of VOCs in monitoring wells MW-4 and MW-5, Carroll Motor Fuels was contacted to review recent UST system testing data to determine whether the detected concentrations could be attributed to a system leak.

Precision Testing conducted UST system testing on June 29, 2025 —11 days after the groundwater sampling event. The UST system tested tight, indicating no evidence of a current release. A copy of the UST system test is provided in Appendix D.

4.2 Dispenser Calibration

On August 4, 2025, all eight (8) dispensers at the site were calibrated by **Petroleum Standards** to ensure the accuracy of product dispensing and inventory reconciliation. The **Dispenser Calibration Report** is provided in **Appendix D**.

This calibration was conducted to verify that petroleum inventory data collected from the site reflects actual product volumes dispensed, thereby enhancing the reliability of leak detection and inventory control systems.

4.3 Sump Testing

The site is equipped with **secondary containment sumps** designed to capture potential leaks from dispensers, product lines, and other transitional connections. These sumps serve as a critical line of defense in preventing environmental releases from the UST system.

As part of the comprehensive system evaluation, **all sumps were inspected and tested using hydrostatic testing methods**. The results of the hydrostatic testing confirmed that **all sumps were free of leaks** and functioning as intended.

Furthermore, during the visual inspection of the sumps, **no evidence of petroleum staining, product accumulation, or system leakage** was observed. These findings provide further support that the UST system is not currently contributing to groundwater impacts at the site.

Sump Testing data is provided in Appendix D.

5.0 Conclusion

The results of this thorough evaluation indicate that the UST system is operating properly and is not the source of a current release. Inventory control records and UST system testing and sump testing, support a finding that there has been no recent loss of product.

Analytical data from the July 25, 2025 groundwater sampling event confirmed the presence of oxygenated fuel additives, including **methyl tert-butyl ether (MTBE)** and **diisopropyl ether (DIPE)**. These compounds were widely used as gasoline oxygenates from the **late 1970s through the early 2000s**, with MTBE being phased out in Maryland beginning in the early 2000s due to environmental concerns.

The detection of these legacy compounds, in the absence of any evidence of a current release, strongly suggests that the contamination observed in monitoring wells MW-4 and MW-5 is the result of a **historical release** that occurred during the time when MTBE and DIPE were in regular use.

6.0 Appendices

- Appendix A - Site Maps
- Appendix B - Groundwater Gauging & Analytical Tables
- Appendix C - Report of Analysis & Chain of Custody Record
- Appendix D - Precision Testing 6/29/2025
 - Report Petroleum Standards
 - Report
 - SUMP Testing Report

Appendix A

Site Maps



Appendix B
Groundwater Gauging & Analytical Tables

TABLE 1
GROUNDWATER ANALYTICAL DATA SUMMARY
URBANA PIKE BP
1904 URBANA PIKE
CLARKSBURG, MARYLAND

Location ID	Top of Casing (ft)	Sample Date	Depth to Water (ft)	Water Elevation (ft)	MTBE (ug/l)	TBA (ug/l)	DIPE	BENZENE (ug/l)	TOLUENE (ug/l)	ETHYL-BENZENE (ug/l)	XYLENES (TOTAL) (ug/l)	Cumene	Naphthalene	TPH-DRO (ug/l)	TPH-GRO (ug/l)
MDE GNCS, Type I and II Aquifers					20	NG	NG	5	1,000	700	10,000	77	10	47	47
MW-1	101.55	08/08/05	17.35	84.20	33,000	--		23 J	<14	<14	<16	NA	NA	--	--
TD=35'		01/25/06	--	--	400	< 250		< 10	< 10	< 10	< 30	NA	NA	340	< 2,000
		06/15/06	--	--	1,400	3,800		< 100	< 100	< 100	< 300	NA	NA	240	1,000
		12/29/06	--	-	2.8	< 4.0		< 0.5	< 0.5	< 0.5	< 1.5	NA	NA	< 160	241
		09/26/07	21.16	80.39	33	1,000		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	440 J	75
Well Abandoned															
MW-2	99.37	08/08/05	15.08	84.29	27,000	--		160	24 J	67 J	78 J	NA	NA	--	--
TD=25'		01/25/06	--	--	6,700	3,600		81	47	< 20	< 60	NA	NA	840	14,000
		06/15/06	--	--	4,700	18,000		< 100	< 100	< 100	< 100	NA	NA	2,300	11,000
		12/29/06	--	-	40.7	2,010		2.8	0.6	2.4	6.3	NA	NA	550	< 100
		09/26/07	18.06	81.31	460	37,000		51	1 J	41	8	NA	NA	1,100	3,600
Well Abandoned															
MW-3	100.17	08/08/05	18.33	81.84	8	--		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	--	--
TD=25'		01/25/06	--	--	1	< 25		< 1.0	< 1.0	< 1.0	< 3.0	NA	NA	780	< 200
		06/15/06	--	--	< 1.0	< 25		< 1.0	< 1.0	< 1.0	< 1.0	NA	NA	< 220	< 200
		12/29/06	--	--	< 0.5	< 4.0		< 0.5	< 0.5	< 0.5	< 1.5	NA	NA	< 170	< 100
		09/26/07	21.84	78.33	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	130	< 20
		01/25/08	12.53	87.64	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	110	< 20
		4/14/2008	7.41	92.76	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	140	< 20
		10/9/2008	20.11	80.06	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	--	--
		4/6/2009	4.25	95.92	< 1.00	< 5.00		< 1.00	< 1.00	< 1.00	< 1.00	NA	NA	--	--
		4/26/2010	6.10	94.07	< 1.00	--		< 1.00	< 1.00	< 1.00	< 1.00	NA	NA	--	--
		06/22/11	15.82	84.35	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/27/12	17.81	82.36	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/18/13	9.00	91.17	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/03/14	8.22	91.95	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/29/15	6.56	93.61	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/23/16	9.51	90.66	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/02/17	12.10	88.07	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/07/18	5.93	94.24	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/08/20	6.03	94.14	<5	<50		<5	<5	<5	<5	<5	<5	NA	NA
		06/02/21	15.00	85.17	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/16/22	14.63	85.54	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/06/23	19.40	80.77	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		07/01/24	17.31	82.86	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA
		06/18/25	6.94	93.23	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA
		07/25/25	16.23	83.94	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA
Duplietae		07/25/25	16.23	83.94	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA

TABLE 1
GROUNDWATER ANALYTICAL DATA SUMMARY
URBANA PIKE BP
1904 URBANA PIKE
CLARKSBURG, MARYLAND

Location ID	Top of Casing (ft)	Sample Date	Depth to Water (ft)	Water Elevation (ft)	MTBE (ug/l)	TBA (ug/l)	DIPE	BENZENE (ug/l)	TOLUENE (ug/l)	ETHYL-BENZENE (ug/l)	XYLENES (TOTAL) (ug/l)	Cumene	Naphthalene	TPH-DRO (ug/l)	TPH-GRO (ug/l)
MDE GNCS, Type I and II Aquifers					20	NG	NG	5	1,000	700	10,000	77	10	47	47
MW-4	100.26	01/25/08	12.92	87.34	150	1,800		4 J	2 J	43	58	NA	NA	1,200	1,500
		4/14/2008	10.19	90.07	61	530		2 J	0.9 J	54	35	NA	NA	850	880
		10/9/2008	15.17	85.09	15	620		0.6 J	< 0.7	9	< 0.8	NA	NA	--	--
		4/6/2009	10.27	89.99	9.10	240		< 2.00	2.56	45.9	25.64	NA	NA	--	--
		4/26/2010	11.49	88.77	< 1.00	--		< 1.00	< 1.00	1.49	< 1.00	NA	NA	--	--
		06/22/11	13.06	87.20	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/27/12	14.14	86.12	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/18/13	10.18	90.08	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/03/14	9.26	91.00	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/29/15	10.90	89.36	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/23/16	12.71	87.55	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/02/17	11.64	88.62	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/07/18	9.30	90.96	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/08/20	10.60	89.66	<5	<50		<5	<5	<5	<5	<5	<5	NA	NA
		06/02/21	13.73	86.53	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/16/22	12.77	87.49	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/06/23	14.31	85.95	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		07/01/24	14.16	86.10	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA
	MW-4	06/18/25	10.45	89.81	3.40	<25	13.6	86.70	1.52	<1	3.56	<1	<1	NA	NA
		07/25/25	13.00	87.26	1.16	<25	6.33	30.80	<1	<1	<1	<1	<1	NA	NA
Caliber	Duplicate	07/25/25	13.00	87.26	<5	<25	<25	21.00	<5	<1	<10	<5	<10	NA	NA

TABLE 1
GROUNDWATER ANALYTICAL DATA SUMMARY
URBANA PIKE BP
1904 URBANA PIKE
CLARKSBURG, MARYLAND

Location ID	Top of Casing (ft)	Sample Date	Depth to Water (ft)	Water Elevation (ft)	MTBE (ug/l)	TBA (ug/l)	DIPE	BENZENE (ug/l)	TOLUENE (ug/l)	ETHYL-BENZENE (ug/l)	XYLENES (TOTAL) (ug/l)	Cumene	Naphthalene	TPH-DRO (ug/l)	TPH-GRO (ug/l)
MDE GNCS, Type I and II Aquifers					20	NG	NG	5	1,000	700	10,000	77	10	47	47
MW-5	102.73	01/25/08	15.68	87.05	0.7 J	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	190	< 20
		4/14/08	13.13	89.60	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	110	< 20
		10/9/08	20.37	82.36	4 J	160		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	--	--
		4/6/09	13.31	89.42	< 1.00	< 5.00		< 1.00	< 1.00	< 1.00	< 1.00	NA	NA	--	--
		4/26/10	13.90	88.83	< 1.00	--		< 1.00	< 1.00	< 1.00	< 1.00	NA	NA	--	--
		6/22/11	15.54	87.19	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		6/27/12	17.28	85.45	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		6/18/2013	12.23	90.50	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		6/3/2014	12.11	90.62	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		6/29/2015	13.70	89.03	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/23/16	15.25	87.48	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/02/17	14.32	88.41	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/07/18	11.96	90.77	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND
		06/08/20	13.25	89.48	<5	<50		<5	<5	<5	<5	<5	<5	NA	NA
		06/02/21	16.53	86.2	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/16/22	15.41	87.32	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/16/22	14.31	88.42	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		06/06/23	17.93	84.80	<1	<25		<1	<1	<1	<1	<1	<1	NA	NA
		07/01/24	17.50	85.23	<1	<25	<1	<1	<1	<1	<1	<1	<1	NA	NA
	MW-5	06/18/25	13.49	89.24	2.40	<25	13.6	76.6	13.4	2.12	<1	<1	<1	NA	NA
		07/25/25	16.12	86.61	20.30	<25	116	366	32.7	1.69	6.98	<1	<1	NA	NA
Caliber	Duplicate	07/25/25	16.12	86.61	20	<25	71	310	24	2	<10	<5	<10	NA	NA

TABLE 1
GROUNDWATER ANALYTICAL DATA SUMMARY
URBANA PIKE BP
1904 URBANA PIKE
CLARKSBURG, MARYLAND

Location ID	Top of Casing (ft)	Sample Date	Depth to Water (ft)	Water Elevation (ft)	MTBE (ug/l)	TBA (ug/l)	DIPE	BENZENE (ug/l)	TOLUENE (ug/l)	ETHYL-BENZENE (ug/l)	XYLENES (TOTAL) (ug/l)	Cumene	Naphthalene	TPH-DRO (ug/l)	TPH-GRO (ug/l)
MDE GNCS, Type I and II Aquifers					20	NG	NG	5	1,000	700	10,000	77	10	47	47
TF-1	--	01/25/08	12.31	--	22	100		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	220	53
		4/14/2008	9.94	--	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	< 28	< 20
		10/9/2008	14.85	--	--	--		--	--	--	--	--	--	--	--
		4/6/2009	10.01	--	--	--		--	--	--	--	--	--	--	--
		4/26/2010	11.28	--	--	--		--	--	--	--	--	--	--	--
Former TF-2	--	01/25/06	--	--	28,000	39,000		< 100	< 100	< 100	< 300	NA	NA	980	40,000
		09/26/07	DRY		--	--		--	--	--	--	--	--	--	--
TF-2	--	01/25/08	BLOCKED		--	--		--	--	--	--	--	--	--	--
		4/14/2008	12.11	--	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	61 J	< 20
		10/9/2008	DRY		--	--		--	--	--	--	--	--	--	--
		4/6/2009	12.17	--	--	--		--	--	--	--	--	--	--	--
		4/26/2010	13.45	--	--	--		--	--	--	--	--	--	--	--
TF-3		01/25/08	13.90	--	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	350	< 20
		4/14/2008	11.57	--	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	79 J	< 20
		10/9/2008	DRY		--	--		--	--	--	--	--	--	--	--
		4/6/2009	11.58	--	--	--		--	--	--	--	--	--	--	--
		4/26/2010	12.85	--	--	--		--	--	--	--	--	--	--	--
TF-4		01/25/08	12.62	--	0.7 J	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	350	< 20
		4/14/2008	10.23	--	< 0.5	< 10		< 0.5	< 0.7	< 0.8	< 0.8	NA	NA	< 28	< 20
		10/9/2008	15.12	--	--	--		--	--	--	--	--	--	--	--
		4/6/2009	10.28	--	--	--		--	--	--	--	--	--	--	--
		4/26/2010	11.56	--	--	--		--	--	--	--	--	--	--	--

ND = Not Detected
NG = No Guideline
-- = Not Applicable / Not Available
J = Estimated Value
ft = feet

Concentrations in ug/l = micrograms per liter
Concentration in mg/l = milligrams per liter
Top of casing elevation based on arbitrary datum of 100 feet.
< = Concentration less than the method detection limit
Values exceeding the specified MDE criteria are **bolded**.

Volatile organic compound (VOC) analysis conducted in accordance with EPA Method 8260B; only BTEX and oxygenates are summarized

TPH analysis conducted in accordance with EPA Method 8015B.

MDE GNCS = Maryland Department of the Environment Generic Numeric Cleanup Standards, February 2003

* = Represents the sum of o-Xylenes and m,p-Xylenes

MTBE = Methyl-tertiary butyl-ether
TBA = Tert-Butyl Alcohol
TAME = Tert-Amyl Methyl Ether
DIPE = Di-Isopropyl Ether
ETBE = Ethyl T-Butyl Ether
TPH = Total petroleum hydrocarbons
GRO = gasoline-range organics
DRO = diesel-range organics

TABLE 2
POTABLE WELL ANALYTICAL DATA SUMMARY
URBANA PIKE BP
1904 URBANA PIKE
CLARKSBURG, MARYLAND

Location ID	Sample Date	MTBE	TBA	BENZENE	TOLUENE	ETHYL-BENZENE	XYLENES (TOTAL)
MDE GNCS, Type I and II Aquifers	NA	20	NG	5	1,000	700	10,000
PW-1	09/15/05	0.4 J	--	< 0.1	< 0.1	< 0.1	< 0.3
	01/25/06	0.6	< 5	< 0.5	< 0.5	< 0.5	< 1.5
	06/15/06	< 0.5	< 5	< 0.5	< 0.5	< 0.5	< 1.5
	09/27/07	0.2 J	< 5	< 0.1	< 0.1	< 0.1	< 0.2
	4/17/2008	< 0.1	< 5	< 0.1	< 0.1	< 0.1	< 0.2
	10/9/2008	< 0.1	< 5	< 0.1	< 0.1	< 0.1	< 0.2
	4/6/2009	< 0.5	< 2.5	< 0.5	< 0.5	< 0.5	< 0.5*
	4/26/2010	< 0.500	< 2.50	< 0.500	< 0.500	< 0.500	< 0.500
	6/22/2011	ND	ND	ND	ND	ND	ND
	6/27/2012	ND	ND	ND	ND	ND	ND
	6/13/2013	ND	ND	ND	ND	ND	ND
	6/3/2014	ND	ND	ND	ND	ND	ND
	6/29/2015	ND	ND	ND	ND	ND	ND
	6/23/2016	ND	ND	ND	ND	ND	ND
	6/2/2017	ND	ND	ND	ND	ND	ND
	6/7/2018	ND	ND	ND	ND	ND	ND
	6/8/2020	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5
	6/2/2021	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5
	6/16/2022	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5
	6/6/2023	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5
	7/1/2024	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5
	6/18/2025	< 0.5	< 10	< 0.5	< 0.5	< 0.5	< 0.5

ND = Not Detected

NG = No Guideline

--- = Not Applicable / Not Available

J = Estimated Value

Values exceeding the specified MDE criteria are **bolded**.

Concentrations in ug/l = micrograms per liter

< = Concentration less than the method detection limit

Volatile organic compound (VOC) analysis conducted in accordance with 524.2; only BTEX, and oxygenates are summarized.

MTBE = Methyl-tertiary butyl-ether

TBA = Tert-amyl alcohol

Appendix C
Report of Analysis & Chain of Custody Record

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification:	MW-3	Project Identification:	CMF URBANA PIKE
MATRIX:	water	Client Identification:	CARROLL FUEL
Sample Date:	7/25/2025	Client Telephone:	
Date Received:	7/28/2025	Client Fax:	
Extraction Date:	na	Analyst:	MM
Analysis Date:	7/28/2025	Lab File:	72825A009

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
Dichlorodifluoromethane	1	ug/L	ND	EPA 8260
Chloromethane	1	ug/L	ND	EPA 8260
Vinyl Chloride	1	ug/L	ND	EPA 8260
Bromomethane	1	ug/L	ND	EPA 8260
Chloroethane	1	ug/L	ND	EPA 8260
Trichlorofluoromethane	1	ug/L	ND	EPA 8260
1,1-Dichloroethene	1	ug/L	ND	EPA 8260
tert-Butyl Alcohol (TBA)	10	ug/L	ND	EPA 8260
Methylene Chloride	1	ug/L	ND	EPA 8260
trans-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Methyl tert-Butyl Ether (MtBE)	1	ug/L	ND	EPA 8260
1,1-Dichloroethane	1	ug/L	ND	EPA 8260
Diisopropyl Ether (DIPE)	1	ug/L	ND	EPA 8260
cis-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Bromochloromethane	1	ug/L	ND	EPA 8260
Chloroform	1	ug/L	ND	EPA 8260
2,2-Dichloropropane	1	ug/L	ND	EPA 8260
Ethyl tert-Butyl Ether (EtBE)	1	ug/L	ND	EPA 8260
1,2-Dichloroethane	1	ug/L	ND	EPA 8260
tert-Amyl Alcohol (TAA)	10	ug/L	ND	EPA 8260
1,1,1-Trichloroethane	1	ug/L	ND	EPA 8260
1,1-Dichloropropene	1	ug/L	ND	EPA 8260
Carbon tetrachloride	1	ug/L	ND	EPA 8260
Benzene	1	ug/L	ND	EPA 8260
tert-Amyl Methyl Ether (TAME)	1	ug/L	ND	EPA 8260
Dibromomethane	1	ug/L	ND	EPA 8260
1,2-Dichloropropane	1	ug/L	ND	EPA 8260
Trichloroethene	1	ug/L	ND	EPA 8260
Bromodichloromethane	1	ug/L	ND	EPA 8260
tert-Amyl Ethyl Ether (TAEE)	1	ug/L	ND	EPA 8260
cis-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
trans-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
1,1,2-Trichloroethane	1	ug/L	ND	EPA 8260
Toluene	1	ug/L	ND	EPA 8260
1,3-Dichloropropane	1	ug/L	ND	EPA 8260
Dibromochloromethane	1	ug/L	ND	EPA 8260
1,2-Dibromoethane	1	ug/L	ND	EPA 8260
Tetrachloroethene	1	ug/L	ND	EPA 8260
1,1,1,2-Tetrachloroethene	1	ug/L	ND	EPA 8260
Chlorobenzene	1	ug/L	ND	EPA 8260
Ethylbenzene	1	ug/L	ND	EPA 8260

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification: MATRIX: Sample Date: Date Received: Extraction Date: Analysis Date:	MW-3 water 7/25/2025 7/28/2025 na 7/28/2025	Project Identification: Client Identification: Client Telephone: Client Fax: Analyst: Lab File:	CMF URBANA PIKE CARROLL FUEL MM 72825A009
---	--	--	--

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
m&p-Xylene	2	ug/L	ND	EPA 8260
Bromoform	1	ug/L	ND	EPA 8260
Styrene	1	ug/L	ND	EPA 8260
o-Xylene	1	ug/L	ND	EPA 8260
1,1,2,2-Tetrachloroethane	1	ug/L	ND	EPA 8260
1,2,3-Trichloropropane	1	ug/L	ND	EPA 8260
Isopropylbenzene	1	ug/L	ND	EPA 8260
Bromobenzene	1	ug/L	ND	EPA 8260
n-Propylbenzene	1	ug/L	ND	EPA 8260
2-Chlorotoluene	1	ug/L	ND	EPA 8260
4-Chlorotoluene	1	ug/L	ND	EPA 8260
1,3,5-Trimethylbenzene	1	ug/L	ND	EPA 8260
tert-Butylbenzene	1	ug/L	ND	EPA 8260
1,2,4-Trimethylbenzene	1	ug/L	ND	EPA 8260
sec-Butylbenzene	1	ug/L	ND	EPA 8260
1,3-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,4-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,2-Dichlorobenzene	1	ug/L	ND	EPA 8260
p-iso-Propyltoluene	1	ug/L	ND	EPA 8260
n-Butylbenzene	1	ug/L	ND	EPA 8260
1,2-Dibromo-3-chloropropane	1	ug/L	ND	EPA 8260
1,2,4-Trichlorobenzene	1	ug/L	ND	EPA 8260
Naphthalene	1	ug/L	ND	EPA 8260
Hexachlorobutadiene	1	ug/L	ND	EPA 8260
1,2,3-Trichlorobenzene	1	ug/L	ND	EPA 8260

SURROGATE SPIKE

1,2-Dichloroethane-d4	%	105	EPA 8260
Dibromofluoromethane	%	105	EPA 8260
Toluene-d8	%	101	EPA 8260
Bromofluorobenzene	%	97	EPA 8260

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification:	MW-4	Project Identification:	CMF URBANA PIKE
MATRIX:	water	Client Identification:	CARROLL FUEL
Sample Date:	7/25/2025	Client Telephone:	
Date Received:	7/28/2025	Client Fax:	
Extraction Date:	na	Analyst:	MM
Analysis Date:	7/28/2025	Lab File:	72825A010

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
Dichlorodifluoromethane	1	ug/L	ND	EPA 8260
Chloromethane	1	ug/L	ND	EPA 8260
Vinyl Chloride	1	ug/L	ND	EPA 8260
Bromomethane	1	ug/L	ND	EPA 8260
Chloroethane	1	ug/L	ND	EPA 8260
Trichlorofluoromethane	1	ug/L	ND	EPA 8260
1,1-Dichloroethene	1	ug/L	ND	EPA 8260
tert-Butyl Alcohol (TBA)	10	ug/L	ND	EPA 8260
Methylene Chloride	1	ug/L	ND	EPA 8260
trans-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Methyl tert-Butyl Ether (MtBE)	1	ug/L	1.16	EPA 8260
1,1-Dichloroethane	1	ug/L	ND	EPA 8260
Diisopropyl Ether (DIPE)	1	ug/L	6.33	EPA 8260
cis-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Bromochloromethane	1	ug/L	ND	EPA 8260
Chloroform	1	ug/L	ND	EPA 8260
2,2-Dichloropropane	1	ug/L	ND	EPA 8260
Ethyl tert-Butyl Ether (EtBE)	1	ug/L	ND	EPA 8260
1,2-Dichloroethane	1	ug/L	ND	EPA 8260
tert-Amyl Alcohol (TAA)	10	ug/L	ND	EPA 8260
1,1,1-Trichloroethane	1	ug/L	ND	EPA 8260
1,1-Dichloropropene	1	ug/L	ND	EPA 8260
Carbon tetrachloride	1	ug/L	ND	EPA 8260
Benzene	1	ug/L	30.8	EPA 8260
tert-Amyl Methyl Ether (TAME)	1	ug/L	ND	EPA 8260
Dibromomethane	1	ug/L	ND	EPA 8260
1,2-Dichloropropane	1	ug/L	ND	EPA 8260
Trichloroethene	1	ug/L	ND	EPA 8260
Bromodichloromethane	1	ug/L	ND	EPA 8260
tert-Amyl Ethyl Ether (TAEE)	1	ug/L	ND	EPA 8260
cis-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
trans-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
1,1,2-Trichloroethane	1	ug/L	ND	EPA 8260
Toluene	1	ug/L	ND	EPA 8260
1,3-Dichloropropane	1	ug/L	ND	EPA 8260
Dibromochloromethane	1	ug/L	ND	EPA 8260
1,2-Dibromoethane	1	ug/L	ND	EPA 8260
Tetrachloroethene	1	ug/L	ND	EPA 8260
1,1,1,2-Tetrachloroethene	1	ug/L	ND	EPA 8260
Chlorobenzene	1	ug/L	ND	EPA 8260
Ethylbenzene	1	ug/L	ND	EPA 8260

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification: MATRIX: Sample Date: Date Received: Extraction Date: Analysis Date:	MW-4 water 7/25/2025 7/28/2025 na 7/28/2025	Project Identification: Client Identification: Client Telephone: Client Fax: Analyst: Lab File:	CMF URBANA PIKE CARROLL FUEL MM 72825A010
---	--	--	--

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
m&p-Xylene	2	ug/L	ND	EPA 8260
Bromoform	1	ug/L	ND	EPA 8260
Styrene	1	ug/L	ND	EPA 8260
o-Xylene	1	ug/L	ND	EPA 8260
1,1,2,2-Tetrachloroethane	1	ug/L	ND	EPA 8260
1,2,3-Trichloropropane	1	ug/L	ND	EPA 8260
Isopropylbenzene	1	ug/L	ND	EPA 8260
Bromobenzene	1	ug/L	ND	EPA 8260
n-Propylbenzene	1	ug/L	ND	EPA 8260
2-Chlorotoluene	1	ug/L	ND	EPA 8260
4-Chlorotoluene	1	ug/L	ND	EPA 8260
1,3,5-Trimethylbenzene	1	ug/L	ND	EPA 8260
tert-Butylbenzene	1	ug/L	ND	EPA 8260
1,2,4-Trimethylbenzene	1	ug/L	ND	EPA 8260
sec-Butylbenzene	1	ug/L	ND	EPA 8260
1,3-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,4-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,2-Dichlorobenzene	1	ug/L	ND	EPA 8260
p-iso-Propyltoluene	1	ug/L	ND	EPA 8260
n-Butylbenzene	1	ug/L	ND	EPA 8260
1,2-Dibromo-3-chloropropane	1	ug/L	ND	EPA 8260
1,2,4-Trichlorobenzene	1	ug/L	ND	EPA 8260
Naphthalene	1	ug/L	ND	EPA 8260
Hexachlorobutadiene	1	ug/L	ND	EPA 8260
1,2,3-Trichlorobenzene	1	ug/L	ND	EPA 8260

SURROGATE SPIKE

1,2-Dichloroethane-d4	%	109	EPA 8260
Dibromofluoromethane	%	105	EPA 8260
Toluene-d8	%	102	EPA 8260
Bromofluorobenzene	%	98	EPA 8260

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification:	MW-5	Project Identification:	CMF URBANA PIKE
MATRIX:	water	Client Identification:	CARROLL FUEL
Sample Date:	7/25/2025	Client Telephone:	
Date Received:	7/28/2025	Client Fax:	
Extraction Date:	na	Analyst:	MM
Analysis Date:	7/28/2025	Lab File:	72825A011

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
Dichlorodifluoromethane	1	ug/L	ND	EPA 8260
Chloromethane	1	ug/L	ND	EPA 8260
Vinyl Chloride	1	ug/L	ND	EPA 8260
Bromomethane	1	ug/L	ND	EPA 8260
Chloroethane	1	ug/L	ND	EPA 8260
Trichlorofluoromethane	1	ug/L	ND	EPA 8260
1,1-Dichloroethene	1	ug/L	ND	EPA 8260
tert-Butyl Alcohol (TBA)	10	ug/L	ND	EPA 8260
Methylene Chloride	1	ug/L	ND	EPA 8260
trans-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Methyl tert-Butyl Ether (MtBE)	1	ug/L	20.3	EPA 8260
1,1-Dichloroethane	1	ug/L	ND	EPA 8260
Diisopropyl Ether (DIPE)	1	ug/L	116	EPA 8260
cis-1,2-Dichloroethene	1	ug/L	ND	EPA 8260
Bromochloromethane	1	ug/L	ND	EPA 8260
Chloroform	1	ug/L	ND	EPA 8260
2,2-Dichloropropane	1	ug/L	ND	EPA 8260
Ethyl tert-Butyl Ether (EtBE)	1	ug/L	ND	EPA 8260
1,2-Dichloroethane	1	ug/L	ND	EPA 8260
tert-Amyl Alcohol (TAA)	10	ug/L	ND	EPA 8260
1,1,1-Trichloroethane	1	ug/L	ND	EPA 8260
1,1-Dichloropropene	1	ug/L	ND	EPA 8260
Carbon tetrachloride	1	ug/L	ND	EPA 8260
Benzene	1	ug/L	366	EPA 8260
tert-Amyl Methyl Ether (TAME)	1	ug/L	6.21	EPA 8260
Dibromomethane	1	ug/L	ND	EPA 8260
1,2-Dichloropropane	1	ug/L	ND	EPA 8260
Trichloroethene	1	ug/L	ND	EPA 8260
Bromodichloromethane	1	ug/L	ND	EPA 8260
tert-Amyl Ethyl Ether (TAEE)	1	ug/L	ND	EPA 8260
cis-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
trans-1,3-Dichloropropene	1	ug/L	ND	EPA 8260
1,1,2-Trichloroethane	1	ug/L	ND	EPA 8260
Toluene	1	ug/L	32.7	EPA 8260
1,3-Dichloropropane	1	ug/L	ND	EPA 8260
Dibromochloromethane	1	ug/L	ND	EPA 8260
1,2-Dibromoethane	1	ug/L	ND	EPA 8260
Tetrachloroethene	1	ug/L	ND	EPA 8260
1,1,1,2-Tetrachloroethene	1	ug/L	ND	EPA 8260
Chlorobenzene	1	ug/L	ND	EPA 8260
Ethylbenzene	1	ug/L	1.69	EPA 8260

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

Laboratory Services 1751 Pulaski Highway, Havre de Grace, MD 21078 Phone:410-939-5550 Fax:410-939-5552

Certificate of Analysis

Sample Identification: MATRIX: Sample Date: Date Received: Extraction Date: Analysis Date:	MW-5 water 7/25/2025 7/28/2025 na 7/28/2025	Project Identification: Client Identification: Client Telephone: Client Fax: Analyst: Lab File:	CMF URBANA PIKE CARROLL FUEL MM 72825A011
---	--	--	--

COMPOUND	DETECTION LIMIT	TEST UNIT	TEST VALUE	METHOD
m&p-Xylene	2	ug/L	2.63	EPA 8260
Bromoform	1	ug/L	ND	EPA 8260
Styrene	1	ug/L	ND	EPA 8260
o-Xylene	1	ug/L	4.35	EPA 8260
1,1,2,2-Tetrachloroethane	1	ug/L	ND	EPA 8260
1,2,3-Trichloropropane	1	ug/L	ND	EPA 8260
Isopropylbenzene	1	ug/L	ND	EPA 8260
Bromobenzene	1	ug/L	ND	EPA 8260
n-Propylbenzene	1	ug/L	ND	EPA 8260
2-Chlorotoluene	1	ug/L	ND	EPA 8260
4-Chlorotoluene	1	ug/L	ND	EPA 8260
1,3,5-Trimethylbenzene	1	ug/L	ND	EPA 8260
tert-Butylbenzene	1	ug/L	ND	EPA 8260
1,2,4-Trimethylbenzene	1	ug/L	ND	EPA 8260
sec-Butylbenzene	1	ug/L	ND	EPA 8260
1,3-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,4-Dichlorobenzene	1	ug/L	ND	EPA 8260
1,2-Dichlorobenzene	1	ug/L	ND	EPA 8260
p-iso-Propyltoluene	1	ug/L	ND	EPA 8260
n-Butylbenzene	1	ug/L	ND	EPA 8260
1,2-Dibromo-3-chloropropane	1	ug/L	ND	EPA 8260
1,2,4-Trichlorobenzene	1	ug/L	ND	EPA 8260
Naphthalene	1	ug/L	ND	EPA 8260
Hexachlorobutadiene	1	ug/L	ND	EPA 8260
1,2,3-Trichlorobenzene	1	ug/L	ND	EPA 8260

SURROGATE SPIKE

1,2-Dichloroethane-d4	%	101	EPA 8260
Dibromofluoromethane	%	97	EPA 8260
Toluene-d8	%	103	EPA 8260
Bromofluorobenzene	%	97	EPA 8260




ADVANCED ENVIRONMENTAL CONCEPTS, INC.

1751-1 Pulaski Hwy., Havre de Grace, MD 21078-2207

Phone: 410-939-5550 Fax: 410-939-5552

www.AECEnviro.com

Chain of Custody RecordPage 1 of 1

Client: CIFCO		Project Name: CMF Urbana Pike		SDG#								
Address:		Project Location: 1904 Urbana Pike Clarksburg, MD		Preservatives								
		Phone: Fax:		Requested Analysis								
Contact: Herb Meade		Email:				Observation						
Sample By: GB		Receive Completed Report Via (Circle One) U.S. Mail Email Fax		8260								
	Sample #	Sample ID	Date	Time	Matrix	pH						
1			7/25/25		H2O		X					
2		MW-3										
3		MW-4										
4		MW-5										
5												
6												
7												
8												
9												
10												
Relinquished/Received By Signature			Date	Time	Delivery Method	Lab Use Only						
Relinquished By: 						Temp of Cooler						
Received By: 						Ice Present (Y/N) <u>4°C</u>						
Relinquished By: 						Custody Seal (Y/N)						
Received By:						Date of Extraction <u>7/28/25</u>						
Matrix Codes: SO = Soil, GW = Ground Water, WW = Waste Water, VP = Vapor, SL = Sludge, DW = Drinking Water, O = Other												
Special Instructions / Comments / QC Requirements:						Turn Around Time: <u>STD</u> 1 Day 2 Day 3 Day Other						



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-3	Matrix:	Water	Lab ID:	25072902-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Ethanol by GCMS						Batch: 30554	
Ethanol	ND	ug/L	1000	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Target Compound List - VOLATILES						Batch: 30554	
Dichlorodifluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Chloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Vinyl chloride	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Bromomethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Chloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Trichlorofluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1,2-Trichlorotrifluoroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Acetone	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Carbon disulfide	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Methyl acetate	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Methylene chloride	ND	ug/L	10	EPA 8260B	07/29/25	07/29/25 21:53	GFH
trans-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Methyl t-butyl ether (MTBE)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1-Dichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
cis-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
2-Butanone (MEK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Chloroform	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1,1-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Cyclohexane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Carbon tetrachloride	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Benzene	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2-Dichloroethane (EDC)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Trichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Methylcyclohexane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2-Dichloropropane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Bromodichloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
cis-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
4-Methyl-2-pentanone (MIBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Toluene	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 21:53	GFH
trans-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1,2-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Tetrachloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
2-Hexanone (MBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Dibromochloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2-Dibromoethane (EDB)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Chlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Ethylbenzene	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 21:53	GFH
m&p-Xylene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-3			Matrix:	Water	Lab ID:	25072902-01
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Target Compound List - VOLATILES							Batch: 30554
o-Xylene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Styrene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Bromoform	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Isopropylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,1,2,2-Tetrachloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,3,5-Trimethylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2,4-Trimethylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,3-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,4-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2-Dibromo-3-chloropropane (DBCP)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
1,2,4-Trichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Naphthalene	ND	ug/L	10	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Ethyl t-butyl ether (ETBE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
tert-Butanol (TBA)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
Diisopropyl ether (DIPE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
tert-Amyl methyl ether (TAME)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
tert-Amyl alcohol (TAA)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH
tert-Amyl ethyl ether (TAE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 21:53	GFH

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-4	Matrix:	Water	Lab ID:	25072902-02		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Ethanol by GCMS						Batch: 30554	
Ethanol	ND	ug/L	1000	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Target Compound List - VOLATILES						Batch: 30554	
Dichlorodifluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Chloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Vinyl chloride	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Bromomethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Chloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Trichlorofluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1,2-Trichlorotrifluoroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Acetone	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Carbon disulfide	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Methyl acetate	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Methylene chloride	ND	ug/L	15	EPA 8260B	07/29/25	07/29/25 22:25	GFH
trans-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Methyl t-butyl ether (MTBE)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1-Dichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
cis-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
2-Butanone (MEK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Chloroform	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1,1-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Cyclohexane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Carbon tetrachloride	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Benzene	21	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2-Dichloroethane (EDC)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Trichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Methylcyclohexane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2-Dichloropropane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Bromodichloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
cis-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
4-Methyl-2-pentanone (MIBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Toluene	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:25	GFH
trans-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1,2-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Tetrachloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
2-Hexanone (MBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Dibromochloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2-Dibromoethane (EDB)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Chlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Ethylbenzene	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:25	GFH
m&p-Xylene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-4	Matrix:	Water	Lab ID:	25072902-02		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Target Compound List - VOLATILES							Batch: 30554
o-Xylene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Styrene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Bromoform	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Isopropylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,1,2,2-Tetrachloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,3,5-Trimethylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2,4-Trimethylbenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,3-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,4-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2-Dichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2-Dibromo-3-chloropropane (DBCP)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
1,2,4-Trichlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Naphthalene	ND	ug/L	10	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Ethyl t-butyl ether (ETBE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
tert-Butanol (TBA)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
Diisopropyl ether (DIPE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
tert-Amyl methyl ether (TAME)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
tert-Amyl alcohol (TAA)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH
tert-Amyl ethyl ether (TAE)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:25	GFH

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-5	Matrix:	Water	Lab ID:	25072902-03		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Ethanol by GCMS							Batch: 30554
Ethanol	ND	ug/L	1000	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Target Compound List - VOLATILES							Batch: 30554
Dichlorodifluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Chloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Vinyl chloride	ND	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Bromomethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Chloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Trichlorofluoromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1,2-Trichlorotrifluoroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Acetone	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Carbon disulfide	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Methyl acetate	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Methylene chloride	ND	ug/L	15	EPA 8260B	07/29/25	07/29/25 22:57	GFH
trans-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Methyl t-butyl ether (MTBE)	20	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1-Dichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
cis-1,2-Dichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
2-Butanone (MEK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Chloroform	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1,1-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Cyclohexane	10	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Carbon tetrachloride	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Benzene	310	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2-Dichloroethane (EDC)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Trichloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Methylcyclohexane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2-Dichloropropane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Bromodichloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
cis-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
4-Methyl-2-pentanone (MIBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Toluene	24	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:57	GFH
trans-1,3-Dichloropropene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1,2-Trichloroethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Tetrachloroethene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
2-Hexanone (MBK)	ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Dibromochloromethane	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2-Dibromoethane (EDB)	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Chlorobenzene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Ethylbenzene	2	ug/L	1	EPA 8260B	07/29/25	07/29/25 22:57	GFH
m&p-Xylene	ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Advanced Environmental Concepts
1751 Pulaski Highway
Havre de Grace, MD 21078

Date Sampled: 07/25/25
Date Received: 07/29/25 10:25
Date Issued: 08/05/25

Project: CMF Urbana Pike
Site Location: 1904 Urbana Pike, Clarksburg, MD

SDG Number: 25072902

Field Sample ID:	MW-5			Matrix:	Water		Lab ID:	25072902-03
		Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Target Compound List - VOLATILES								Batch: 30554
o-Xylene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Styrene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Bromoform		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Isopropylbenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,1,2,2-Tetrachloroethane		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,3,5-Trimethylbenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2,4-Trimethylbenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,3-Dichlorobenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,4-Dichlorobenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2-Dichlorobenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2-Dibromo-3-chloropropane (DBCP)		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
1,2,4-Trichlorobenzene		ND	ug/L	5	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Naphthalene		ND	ug/L	10	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Ethyl t-butyl ether (ETBE)		ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
tert-Butanol (TBA)		ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
Diisopropyl ether (DIPE)		71	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
tert-Amyl methyl ether (TAME)		ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
tert-Amyl alcohol (TAA)		ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH
tert-Amyl ethyl ether (TAE)		ND	ug/L	25	EPA 8260B	07/29/25	07/29/25 22:57	GFH

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist

ADVANCED ENVIRONMENTAL CONCEPTS, INC.

1751-1 Pulaski Hwy., Havre de Grace, MD 21078-2207

Phone: 410-939-5550 Fax: 410-939-5552

www.AECEnviro.com

Chain of Custody RecordPage 1 of 1

Client: CIFCO			Project Name: CMF Urbana Pike			SDG# 25072902						
Address:			Project Location:			Preservatives						
			1904 Urbana Pike Clarksburg, MD			Requested Analysis						
Contact: Herb Meade			Phone: Fax:									8260
Sample By: GB			Email:			Observation						
			Receive Completed Report Via (Circle One) U.S. Mail Email Fax									
	Sample #	Sample ID	Date	Time	Matrix	pH						
1			7/25/25		H2O		X					
2		MW-3										
3		MW-4										
4		MW-5										
5												
6												
7												
8												
9												
10												
Relinquished/Received By Signature			Date	Time	Delivery Method		Lab Use Only					
Relinquished By: 			7/25/25	1025			Temp of Cooler					
Received By: 			7/25/25	1025			3.2°C					
Relinquished By:							Ice Present (Y/N)					
Received By:												
Relinquished By:							Custody Seal (Y/N)					
Received By:							Date of Extraction					
Matrix Codes: SO = Soil, GW = Ground Water, WW = Waste Water, VP = Vapor, SL = Sludge, DW = Drinking Water, O = Other												
Special Instructions / Comments / QC Requirements:												
Turn Around Time: <u>STD</u> 1 Day 2 Day 3 Day Other												

Appendix D
Precision Testing 6/29/2025 Report
Petroleum Standards 8/4/2025 Report
Hydrostatic Sump Testing Data

Precision Testing, Inc



4530 Graphics Drive White Plains, MD 20695

Phone 301/638-7800 Fax 301/638-7801

Customer Carroll Independent Fuel LLC

Address 18 Loveton Circle
Sparks, MD 21152

Date: 6/29/2025

Facility ID#: 87

Site Name CMF 2137

Address 1904 Urbana Pike
Clarksburg, MD 20871

Tech: Ryan Garcia

Weather: 85 degrees & sunny

Phone 301/363-8678

Site Contact Tae Chung

Work Authorized by Herb Meade

Phone 410/261-5450

WORK PERFORMED

Product (s)

Regular
Super
Diesel
Regular Vapor
Veeder Root
Inspection

Test(s) Performed

Product line, leak detector, pressure decay, catch basin, shear valves
Product line, leak detector, pressure decay, catch basin, shear valves
Product line, leak detector, catch basin, shear valves
Catch basin
Certification
Annual UST System Walkthrough

MATERIALS USED

Is Job Complete? **Yes**

WORK REQUIRED TO FINISH

Test Sheets are located in tabs along the bottom of the spreadsheet.

ONLY TABS PERTAINING TO YOUR SITE WILL APPEAR

Tab abbreviations are as follos:

Any tab name followed by (2) indicates additional page

CS	Cover Sheet - This Page	TT2	Tank Test Tank 2
RS	Result Sheet	TT3	Tank Test Tank 3
ATG	Automatic Tank Gauge	TT4	Tank Test Tank 4
LD	Leak Detector Test	TT5	Tank Test Tank 5
PD	Pressure Decay Test	TT6	Tank Test Tank 6
L1	Line Test	TTF1	Tank Test Tank 1 Final Report
L2	Line Test - Flex Line	TTF2	Tank Test Tank 2 Final Report
CB	Catch Basin Test	TTF3	Tank Test Tank3 Final Report
Block	Blockage Test	TTF4	Tank Test Tank4 Final Report
Aol	Air to Liquid Test	TTF5	Tank Test Tank 5 Final Report
Aol2	Air to Liquid Test Page 2	TTF6	Tank Test Tank 6 Final Report
Haol	Air to Liquid Test (Healy)	Hel	Helium Test Page 1
HAol2	Air to Liquid Test Page 2 (Healy)	Hel2	Helium Test Page 2
Healy	Healy System Test	Hel3	Helium Site Drawing
CP1	Cathodic Protection Test	Sump1	Submersible Sump Hydrostatic Test Form
CP2	Cathodic Protection Site Drawing	Sump2	Dispenser Sump Hydrostatic Test Form
TT	Tank Test Tank 1	SDL	Sump Drawing Lay Out

4530 Graphics Drive White Plains, MD 20695
Phone 301/638-7800 Fax 301/638-7801

TEST RESULTS

Facility ID#: 87
Facility Name: CMF 2137
Address: 1904 Urbana Pike
Clarksburg, MD 20871

Customer: Carroll Independent Fuel LLC
Date: 6/29/2025
Tester Name: Ryan Garcia
Site Phone: 301/363-8678

PRESSURE

[illegible]

VAPOR TEST

Pressure Decay	Pass
Tie in test	Pass
Helium	

Manufacturer	result
Veeder Root	Pass

Manufacturer	result
OPW	Pass

[illegible]

CATHODIC

PROTECTION									
Product	result	result	result	result	result	result	result	result	result
Tank	NA	NA	Diesel						
Line	NA	NA	NA						



Maryland
Department of
the Environment

Maryland Annual UST System Walkthrough Inspection

MDE Facility I.D. #: 87		
Facility Name: CMF 2137		
Facility Address: 1904 Urbana Pike		
City: Clarksburg	State: MD	Zip: 20871
Telephone Number: 410/261-5450		
Person Performing Walkthrough Inspection: I certify that I have personally examined the walkthrough inspection as established in COMAR 26.10.04 described below for this facility and I further certify that the information in this document is true, accurate, and complete.		Print: Ryan Garcia Sign: <i>Ryan Garcia</i>
Date of Inspection (mm/dd/yyyy): <u>6</u> / <u>29</u> / <u>2025</u>		

Instructions: Annually inspect all containment sumps and hand-held release detection equipment as applicable. Where no problem is observed, √ P (pass). If a deficiency is found, √ F (fail), and describe the problem in the Describe Deficiencies / Corrective Actions section and notify the UST system owner or designated Class A or Class B operator. If certain equipment is not required and/or not present, √ N/A. If evidence of a spill, release, discharge or other unusual operating conditions are observed, notify the Oil Control Program within 2-hours at 410-537-3442 during normal business hours, or at 1-866-633-4686 24 hours a day.

Annual inspections must be conducted in conjunction with a monthly inspection and inspection records must be maintained at the facility for 1 year and at least 5 years at a location designated by owner.

Hand-held Release Detection Equipment

Storage Tank Gauge Stick		
	A tank gauge stick is present and accessible on site	☒ P ☐ F
	Stick is in good condition and is not cracked, faded, or otherwise damaged	☒ P ☐ F
	Gauging stick capable of measuring the full height of the tank to nearest 1/8 inch	☒ P ☐ F
Groundwater Bailers (only complete this section if your facility uses Groundwater Monitoring as a form of Release Detection)		
	Groundwater bailers are present and accessible on site	☐ P ☐ F
	Groundwater bailers are in good condition and are not damaged	☐ P ☐ F

Containment Sump Inspection

Tank Top Containment Sumps		Tank:	Tank # 5	Tank # 6	Tank # 7	Tank #	Tank #
Product:			Regular	Diesel	Super		
Containment sump manway cover is present, is in good condition, and is not in contact with sump lid	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F	☐ P ☐ F
Sump sensor is properly mounted within 1" of sump bottom	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F	☐ P ☐ F
Containment sump and sump lid do not show any cracks, holes, or other signs of damage	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F	☐ P ☐ F
Containment sump free from water, product, and debris	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F	☐ P ☐ F
No visual leaks or weeps observed inside sump	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F	☐ P ☐ F
Double-walled containment sump - No evidence of a release in interstice	☒ N/A	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F
Under-Dispenser Containment Sumps			1 & 2	3 & 4	5 & 6	7 & 8	
The dispenser cover is present and is not damaged	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Sump sensor is properly mounted within 1" of sump bottom	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Containment sump does not show any cracks, holes, or other signs of damage	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Containment sump free from water, product, and debris	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
No visual leaks or weeps observed inside sump	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Double-walled containment sump - No evidence of a release in interstice	☒ N/A	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F
Other/Additional Containment Sumps		Label:	R ATG Ext Sump	S ATG Ext Sump	D ATG Ext Sump	Vent Sump	
Containment sump manway cover is present, is in good condition, and is not in contact with sump lid	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Sump sensor is properly mounted within 1" of sump bottom	☒ N/A	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F
Containment sump and sump lid do not show any cracks, holes, or other signs of damage	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Containment sump free from water, product, and debris	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
No visual leaks or weeps observed inside sump	☐ N/A	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☒ P ☐ F	☐ P ☐ F
Double-walled containment sump - No evidence of a release in interstice	☒ N/A	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F	☐ P ☐ F

DESCRIBE DEFICIENCIES / CORRECTIVE ACTIONS:

Precision Testing, Inc



4530 Graphics Drive White Plains, MD 20695

Phone 301/638-7800 Fax 301/638-7801

Periodic ATG System Maintenance Checklist

Facility ID#: 87

Date: 6/29/2025

Facility Name: CMF 2137

Address: 1904 Urbana Pike

Clarksburg, MD 20871

Manufacturer: Veeder Root

Tester Name: Ryan Garcia

Model#: TLS 450

Tech Cert#: B40727

Serial #: N06226005605004

CMF 2137 environmental monitoring systems installed in accordance with requirements are designed to detect and report conditions that inhibit proper operation.

CMF 2137 systems self-diagnose essential components, and if a component failure is detected, will not complete and report tank and line tests. The system will issue an audible and visual alarm when a failed or disconnected sensor is detected.

The periodic ATG System Maintenance Checklist, if followed, may extend the life of the system, but is not required for proper operation.

Maintenance Operation	When to Perform	What To Do	
Console	Yearly	1. Check printer for paper if equipped	Pass
		2. Print out or check system inventory and verify to actual inventory.	Pass
		3. Print out or record system setup values, then verify if battery backup is working by powering the unit down and then back up with the circuit breaker. If programming is lost the battery is bad and the unit needs service.	Pass
		4. Verify in-tank tests are being performed as required by printing reports.	Pass
		5. Press Alarm/Test button to verify power, warning and alarm indicators light and audible alarm sounds.	Pass
		6. Verify line leak tests are being performed (if line leak installed)	NA

6/29/2025

Maintenance Operation	When to Perform	What To Do	
Mag Probes	Yearly	Owner or Station Attendant	
		1. Inspect probe cables for any cracking and swelling	Pass
		Service Contractor	NA
		1. Replace probe cables (Ref item #1)	
		2. Verify epoxy kits have been installed on field wiring.	Pass
		3. Mag probes only - inspect floats and probe shaft for any residue build-up. Clean with mineral spirits as necessary.	Pass
		Mag probes used in products such as waste oil should be checked more frequently than yearly since products of this type can leave deposits on the probe shaft and float assemblies that may restrict the probe's measurement capability.	NA
VLLD	Yearly	Owner or Station Attendant	
		1. During or immediately after running a 3.0 gph (11.3 lph) self test, visually inspect the flexible fuel lines for leakage.	NA
		2. Check flexible fuel control lines for any chafing or excessive corrosion.	NA
		Service Contractor	
		1. Replace check valve filters (Diesel products only) per VLLD Troubleshooting Manual No. 576013-849.	NA
		2. Verify epoxy kits have been installed on field wiring.	NA
PLLD	Yearly	Owner or Station Attendant	
		1. Check submersible pump head for leakage at PLLD port and functional element with pump on.	NA
		2. Check line leak transducer cable for any cracking or damage.	NA
		Service Contractor	
		1. Verify epoxy kits have been installed on field wiring.	NA
		2. Replace cable if cracked or damaged (Ref Item #2)	NA
WPLLD	Yearly	Owner or Station Attendant	
		1. Check submersible pump head for leakage at WPLLD port and functional element with pump on.	NA

Maintenance Operation	When to Perform	What To Do	
Piping Sump Sensor (Float)	Yearly	Owner or Station Attendant	Pass
		1. Inspect Sensors to verify float moves freely	
		2. Turn sensor upside down to verify the monitor liquid is activated.	Pass
Dispenser Pan Sensor	Yearly	Service Contractor	Pass
		1. Verify epoxy kits have been installed on field wiring.	
		Owner or Station Attendant	Pass
		1. Inspect sensor cables for any cracking or swelling.	
		2. Verify sensor is firmly secured in an upright position on the pan.	Pass
Containment Sump Sensor	Yearly	Service Contractor	Pass
		1. Verify epoxy kits have been installed on field wiring.	
		2. Replace sensor if cables are cracked or damaged (Ref Item #1)	NA
		Owner or Station Attendant	NA
		1. Inspect sensor cables for any cracking or swelling.	
Interstitial Tank Sensor	Yearly	2. Verify sensor is firmly secured in an upright position on the bottom of the containment sump	NA
		Service Contractor	NA
		1. Verify epoxy kits have been installed on field wiring.	
		2. Replace sensor if cables are cracked or damaged (Ref Item #1)	NA
		Owner or Station Attendant	Pass
Interstitial Tank Sensor	Yearly	1. Inspect sensor cables for any cracking or swelling.	
		Service Contractor	Pass
		1. Verify epoxy kits have been installed on field wiring.	
		2. Replace sensor if cables are cracked or damaged (Ref Item #1)	NA

6/29/2025

Maintenance Operation	When to Perform	What To Do	
Groundwater Sensor	Yearly	Owner or Station Attendant	
		1. Inspect probe cables for any cracking or swelling	NA
		2. Lift sensor above water level in the well and verify the system activates a "Water Out" alarm	NA
		Service Contractor	
		1. Verify epoxy kits have been installed on field wiring.	NA
		2. Replace sensor if cables are cracked or damaged (Ref Item #1)	NA
		3. If sensor does not alarm (Ref Item # 2) replace the sensor.	NA
Hydrostatic Sensor (Brine)	Yearly	Owner or Station Attendant	
		1. Inspect probe cables for any cracking or swelling	NA
		Service Contractor	
		1. Remove sensor from Brine reservoir and verify floats moves freely. With sensor in its upright position, the system should activate a "Fuel Alarm". Turn the sensor upside down to be sure the system activates a "Water Alarm". If the sensor does not alarm in both conditions, replace the sensor.	NA
		2. Verify epoxy kits have been installed on field wiring.	NA
		3. Replace sensor if cables are cracked or damaged (Ref Item #1)	NA
Mag Sensor	Yearly	Owner or Station Attendant	
		1. Inspect probe cables for any cracking or swelling	NA
		Service Contractor	
		1. Replace Mag sensor cable (Ref Item #1)	NA
		2. Verify epoxy kits have been installed on field wiring.	NA

Precision Testing, Inc.



4530 Graphics Drive White Plains, MD 20695

Phone 301/638-7800 Fax 301/638-7801

LDT-890 Leak Detector Test Record

Facility ID#: 87

Facility Name: CMF 2137

Address: 1904 Urbana Pike
Clarksburg, MD 20871

Date: 6/29/2025

Tester Name: Ryan Garcia

Site Phone: 301/363-8678

Submersible Pump Identification

Manufacturer: Red Jacket

Model No.

Serial No.

Leak Detector Identification

Manufacturer: Red Jacket

Description: PLD

Product	Regular
Leak Detector in Submersible Pump	Red Jacket
Test at Dispenser	# 3
Operating Pump Pressure	28 psi
Gallons per hour rate	3
Line pressure with pump off	20 psi
Bleedback test with pump off	125 ml
Step-through time to full flow	4 seconds
Leak detector stays in leak search position	Yes
LEAK DETECTOR TEST	Pass
Serial #	041007 - 2996

Product	Super
Leak Detector in Submersible Pump	Red Jacket
Test at Dispenser	# 3
Operating Pump Pressure	29 psi
Gallons per hour rate	3
Line pressure with pump off	18 psi
Bleedback test with pump off	125 ml
Step-through time to full flow	2 seconds
Leak detector stays in leak search position	Yes
LEAK DETECTOR TEST	Pass
Serial #	041007 - 3033

Product	Diesel
Leak Detector in Submersible Pump	Red Jacket
Test at Dispenser	# 3
Operating Pump Pressure	31 psi
Gallons per hour rate	3
Line pressure with pump off	11 psi
Bleedback test with pump off	300 ml
Step-through time to full flow	5 seconds
Leak detector stays in leak search position	Yes
LEAK DETECTOR TEST	Pass
Serial #	040707 - 0330

Test Conducted by

Ryan Garcia

Date of Test

6/29/2025

Precision Testing, Inc



4530 Graphics Drive White Plains, MD 20695

Phone 301/638-7800 Fax 301/638-7801

PRESSURE DECAY LOG

Facility ID#: 87
Facility Name: CMF 2137
Address: 1904 Urbana Pike
Clarksburg, MD 20871

Date: 6/29/2025
Tester Name: Ryan Garcia
Site Phone: 301/363-8678

PHASE I SYSTEM TYPE

Pressure vent cap: Pass

Wayne Dispensers

No Nozzle 8

Manifold Yes

Applicable Regulations:

Source Test Results and Comments

	<u>1</u>	<u>2</u>	
Tank #	<u>5</u>	<u>7</u>	
Product Grade	<u>Regular</u>	<u>Super</u>	
Actual Tank Capacity, gallons	<u>12033</u>	<u>8021</u>	
Gasoline volume, gallons	<u>5827</u>	<u>3320</u>	
Ullage, gallons	<u>6206</u>	<u>4701</u>	Total Ullage <u>10907</u>
			Allowance <u>1.90</u>

Initial Pressure, inches H2O 2.00

Pressure after 1 minute, inches H2O 1.99

Vapor tie in test: Pass

Pressure after 2 minutes, inches H2O 1.99

Pressure after 3 minutes, inches H2O 1.98

Pressure after 4 minutes, inches H2O 1.98

Final pressure 5 minutes, inches H2O 1.98 **PASS**

Test Conducted by Ryan Garcia

Date of Test 6/29/2025

Precision Testing, Inc.



4530 Graphics Drive White Plains, MD 20695

Phone 301/638-7800 Fax 301/638-7801

Facility ID#: 87

Facility Name: CMF 2137

Address: 1904 Urbana Pike
Clarksburg, MD 20871

Weather: 85 degrees & sunny

Date: 6/29/2025

Tester Name: Ryan Garcia

Site Phone: 410/261-5450

Maryland Catch Basin & Containment Sump Test Report

Product:	Regular	Regular Vapor	Super
Testing: ☒ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump Manufacturer OPW # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump Other (Describe):	Check One: ☐ Spill Bucket ☒ Stage I Bucket ☐ Dispenser Sump OPW # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump Other (Describe):	Check One: ☒ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump OPW # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump Other (Describe):	
Construction: ☒ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)	☒ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)	☒ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)	
Start Level:	8 5/8"	10 3/4"	8 3/8"
Start Time:	8:45	8:45	8:45
End Level:	8 5/8"	10 3/4"	8 3/8"
End Time:	9:45	9:45	9:45
Level Change:	0 "	0 "	0 "
Test Results:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Test Failure:	☐ Reported to MDE	Date:	Time:

Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

A liquid level drop of 1/8 " or greater in 1 hour is considered a test failure.

Maryland Catch Basin & Containment Sump Test Report

Product:	Diesel		
Testing:	<u>Check One:</u>	<u>Check One:</u>	<u>Check One:</u>
	☒ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump	☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump	☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump
Manufacturer	OPW		
	#	#	#
	☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump	☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump	☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump
	Other (Describe):	Other (Describe):	Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)	☐ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)	☐ Single-walled ☐ Double-walled (Vacuum test method must be in accordance with manufacturer or PEI/RP1200)
Start Level:	8 3/8"		
Start Time:	8:45		
End Level:	8 3/8"		
End Time:	9:45		
Level Change:	0 "		
Test Results:	☒ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Test Failure:	☐ Reported to MDE		
	Date:		Time:

Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.
 A liquid level drop of 1/8 " or greater in 1 hour is considered a test failure.

Tester Certification (check one):

- ☐ MDE Technician
- ☐ MDE Inspector
- ☒ Precision Tester:

Test Method: Estabrook

Certification Expiration Date:

3/21/2027

Tester's Name: Ryan Garcia

Comments:

1. Location:

1904 Urbana Pike

Clarksburg, MD 20871

301/363-8678

Street No. and/or Corner

City, State Zip Code

Telephone No.

2. Owner:

Carroll Independent Fuel LLC

18 Loveton Circle

Sparks, MD 21152

410/261-5450

Name

City, State Zip Code

Telephone No.

3. Operator:

Tae Chung

Same

301/363-8678

Telephone No.

Name

Address (if different than location)

Telephone No.

4. Reason for test:

Annual Testing

5. Test requested by:

Herb Meade

Environmental Director

410/261-5450

Telephone No.

Name

Position

6. Special instructions:

7. Contractor or company making test

Precision Testing, Inc.

Ryan Garcia

171367fe

Expires: 5/16/2027

Mechanic Name:

8. Is a tank test to be made with this line test?

NO

9. Make and type of pump or dispensers (suction or subs)

Wayne dispensers / Red Jacket units

10. Weather:

85 degrees & sunny

Temp in tanks

Cover over lines

Concrete

Approx. burial depth

52"

11. Identify each line as tested	12. Time (military)	13. Log of Test Procedures, ambient temperature, weather, etc.	14. Pressure psi or kPa		15. Volume reading		16. Remarks size, length & type of line , # flex connectors conclusions, repairs and comments
			before	after	before	after	
	7:15	Arrive on Site					
	8:00	Pretest Bleed Back	50	0	0.0600	0.0990	0.0390
Regular							
DISP	8:15	1st	50	50	0.0110	0.0110	0.0000
# 3	8:30	2nd	50	50	0.0110	0.0110	0.0000
	8:45	3rd	50	50	0.0110	0.0110	0.0000
	9:00	4th	50	50	0.0110	0.0110	0.0000
		Bleed Back	50	0	0.0340	0.0740	0.0400
							ok
	8:00	Pretest Bleed Back	50	0	0.0340	0.0710	0.0370
Super							
DISP	8:15	1st	50	50	0.0110	0.0110	0.0000
# 3	8:30	2nd	50	50	0.0110	0.0110	0.0000
	8:45	3rd	50	50	0.0110	0.0110	0.0000
	9:00	4th	50	50	0.0110	0.0110	0.0000
		Bleed Back	50	0	0.0600	0.0980	0.0380
							ok
							0.0000 gph

Precision Testing, Inc.



4530 Graphics Drive White Plains, MD 20695
Phone 301/638-7800 Fax 301/638-7801

SHEAR VALVE OPERATION INSPECTION

Facility Name: CMF 2137				Owner: Carroll Independent Fuel LLC			
Address: 1904 Urbana Pike				Address: 18 Loveton Circle			
City, State, Zip Code: Clarksburg, MD 20871				City, State, Zip Code: Sparks, MD 21152			
Facility I.D.#: 87				Phone: 301/363-8678			
Testing Company: Precision Testing, Inc				Phone: 301/638-7800			
This date sheet is for inspection shear valves located inside dispensers. See PE/RP1200, Section 10 for the inspection procedure.							
Product Grade	Regular	Super	Regular	Super	Diesel	Regular	Super
Dispenser ID#	# 1 & 2	# 1 & 2	# 3 & 4	# 3 & 4	# 3 & 4	# 5 & 6	# 5 & 6
Shear Valve Type (Product/Vapor)	Product	Product	Product	Product	Product	Product	Product
1. Is the shear valve rigidly anchored to the dispenser box frame or dispenser island?	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N
2. Is the shear section positioned between 1/2 inch above or below the top surface of the dispenser island?	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N
3. Is the lever arm free to move?	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA
4. Does the lever arm snap shut the poppet valve?	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA
5. Can any product be dispensed when the product shear valve is closed?	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA
5 indicates a test failure.							
Test Results	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Comments:							

Tester's Name: Ryan Garcia

Tester's Signature: *Ryan Garcia*

Precision Testing, Inc.



4530 Graphics Drive White Plains, MD 20695
Phone 301/638-7800 Fax 301/638-7801

SHEAR VALVE OPERATION INSPECTION

Facility Name: CMF 2137			Owner: Carroll Independent Fuel LLC		
Address: 1904 Urbana Pike			Address: 18 Loveton Circle		
City, State, Zip Code: Clarksburg, MD 20871			City, State, Zip Code: Sparks, MD 21152		
Facility I.D.#: 87			Phone: 301/363-8678		
Testing Company: Precision Testing, Inc			Phone: 301/638-7800		
This date sheet is for inspection shear valves located inside dispensers. See PE/RP1200, Section 10 for the inspection procedure.					
Product Grade	Regular	Super	Diesel		
Dispenser ID#	# 7 & 8	# 7 & 8	# 7 & 8		
Shear Valve Type (Product/Vapor)	Product	Product	Product		
1. Is the shear valve rigidly anchored to the dispenser box frame or dispenser island?	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☐ Y ☐ N	☐ Y ☐ N
2. Is the shear section positioned between 1/2 inch above or below the top surface of the dispenser island?	☒ Y ☐ N	☒ Y ☐ N	☒ Y ☐ N	☐ Y ☐ N	☐ Y ☐ N
3. Is the lever arm free to move?	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☐ Y ☐ N ☐ NA	☐ Y ☐ N ☐ NA
4. Does the lever arm snap shut the poppet valve?	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☒ Y ☐ N ☐ NA	☐ Y ☐ N ☐ NA	☐ Y ☐ N ☐ NA
5. Can any product be dispensed when the product shear valve is closed?	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☒ N ☐ NA	☐ Y ☐ N ☐ NA	☐ Y ☐ N ☐ NA
5 indicates a test failure.					
Test Results	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Comments:					

Tester's Name: Ryan Garcia

Tester's Signature: *Ryan Garcia*

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 7:18 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

P/U VALVE TEST: EVR

POSITIVE LEAK RATE

MEASURED @ 1.95 "H2O

MEASURED: .005 CFH

PASSED .17 CFH

PASSED .05 CFH

POSITIVE CRACKING

MEASURED @ .255 CFH

MEASURED: 4.14 "H2O

PASSED 2.5/6.0 "H2O

NEGATIVE LEAK RATE

MEASURED @ -4.01 "H2O

MEASURED: -.006 CFH

PASSED -.63 CFH

PASSED -.21 CFH

NEGATIVE CRACKING

MEASURED @ -.423 CFH

MEASURED: -8.58 "H2O

PASSED -6.0/-10.0 "H2O

TESTED ON 06/29/25

BY: Ryan

STATION: CMF 2137

NOTE: TESTER CALIBRATION
NEXT DUE BY 10/15/25

CURRENT INVENTORY REPORT

TANK 1: Regular

VOLUME = 5827 GALS
100% ULLAGE = 6206 GALS
90% ULLAGE = 5003 GALS
HEIGHT = 46.81 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 70.04 DEG F

TANK 2: Supreme

VOLUME = 3320 GALS
100% ULLAGE = 4701 GALS
90% ULLAGE = 3899 GALS
HEIGHT = 41.49 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 67.50 DEG F

TANK 3: Diesel

VOLUME = 2969 GALS
100% ULLAGE = 7057 GALS
90% ULLAGE = 6054 GALS
HEIGHT = 32.35 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 64.93 DEG F

MARYLAND LOTTERY

MARYLAND LOTTERY

MARYLAND LOTTERY

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 8:20 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Active Alarm Report

ID	=	L 10
LABEL	=	Disp 7/8
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:19A
CLEAR	=	

ID	=	L 9
LABEL	=	Disp 5/6
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:19A
CLEAR	=	

ID	=	L 8
LABEL	=	Disp 3/4
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:17A
CLEAR	=	

ID	=	L 7
LABEL	=	Disp 1/2
DESCRIPTION	=	HIGH LIQUID ALARM
ACTIVE	=	06/29/25 8:16A
CLEAR	=	

ID	=	L 6
LABEL	=	Diesel Annular
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:15A
CLEAR	=	

ID	=	L 3
LABEL	=	Diesel STP Sump
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:15A
CLEAR	=	

ID	=	L 5
LABEL	=	Supreme Annular
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:15A
CLEAR	=	

ID	=	L 2
LABEL	=	Supreme STP Sump
DESCRIPTION	=	HIGH LIQUID ALARM
ACTIVE	=	06/29/25 8:14A
CLEAR	=	

ID	=	L 4
LABEL	=	Regular Annular
DESCRIPTION	=	FUEL ALARM
ACTIVE	=	06/29/25 8:14A
CLEAR	=	

ID	=	L 1
LABEL	=	Regular STP Sump
DESCRIPTION	=	HIGH LIQUID ALARM
ACTIVE	=	06/29/25 8:13A
CLEAR	=	

06/29/25 8:20 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Sensor Status Report - All Sensors

#	Sensor Location	Status
L 1	Regular STP Sump	HIGH LIQUID ALAR
L 2	Supreme STP Sump	HIGH LIQUID ALAR
L 3	Diesel STP Sump	FUEL ALARM
L 4	Regular Annular	FUEL ALARM
L 5	Supreme Annular	FUEL ALARM
L 6	Diesel Annular	FUEL ALARM
L 7	Disp 1/2	HIGH LIQUID ALAR
L 8	Disp 3/4	FUEL ALARM
L 9	Disp 5/6	FUEL ALARM
L 10	Disp 7/8	FUEL ALARM

06/29/25 8:25 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Active Alarm Report

NO DATA AVAILABLE

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 8:26 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	Regular STP Sump	NORMAL
L 2	Supreme STP Sump	NORMAL
L 3	Diesel STP Sump	NORMAL
L 4	Regular Annular	NORMAL
L 5	Supreme Annular	NORMAL
L 6	Diesel Annular	NORMAL
L 7	Disp 1/2	NORMAL
L 8	Disp 3/4	NORMAL
L 9	Disp 5/6	NORMAL
L 10	Disp 7/8	NORMAL

06/29/25 8:26 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Active Alarm Report

NO DATA AVAILABLE

06/29/25 9:21 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

Selected Range:

06/01/25 12:00 AM - 06/29/25 11:59 PM

Sensor Status History Report -
All Sensors

#	Sensor Location	Status
L 1	Regular STP Sump	HIGH LIQUID ALAR
ACTIVE: 06/29/25 8:13A		
CLEAR: 06/29/25 8:24A		
L 2	Supreme STP Sump	HIGH LIQUID ALAR
ACTIVE: 06/29/25 8:14A		
CLEAR: 06/29/25 8:24A		
L 3	Diesel STP Sump	FUEL ALARM
ACTIVE: 06/29/25 8:15A		
CLEAR: 06/29/25 8:24A		
L 4	Regular Annular	FUEL ALARM
ACTIVE: 06/29/25 8:14A		
CLEAR: 06/29/25 8:24A		
L 5	Supreme Annular	FUEL ALARM
ACTIVE: 06/29/25 8:15A		
CLEAR: 06/29/25 8:24A		
L 6	Diesel Annular	FUEL ALARM
ACTIVE: 06/29/25 8:15A		
CLEAR: 06/29/25 8:24A		
L 7	Disp 1/2	HIGH LIQUID ALAR
ACTIVE: 06/29/25 8:16A		
CLEAR: 06/29/25 8:24A		
L 8	Disp 3/4	FUEL ALARM
ACTIVE: 06/29/25 8:17A		
CLEAR: 06/29/25 8:24A		
L 8	Disp 3/4	FUEL ALARM
ACTIVE: 06/16/25 12:21P		
CLEAR: 06/18/25 1:09P		
L 9	Disp 5/6	FUEL ALARM
ACTIVE: 06/29/25 8:19A		
CLEAR: 06/29/25 8:24A		
L 10	Disp 7/8	FUEL ALARM
ACTIVE: 06/29/25 8:19A		
CLEAR: 06/29/25 8:24A		
L 10	Disp 7/8	FUEL ALARM
ACTIVE: 06/18/25 10:25A		
CLEAR: 06/18/25 1:20P		

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 9:21 AM

Urbana cmf

1904 Urbana Pike

Urbana, MD 20871

N06226005605004

Sensor Status Report - All Sensors

#	Sensor Location	Status
L 1	Regular STP Sump	NORMAL
L 2	Supreme STP Sump	NORMAL
L 3	Diesel STP Sump	NORMAL
L 4	Regular Annular	NORMAL
L 5	Supreme Annular	NORMAL
L 6	Diesel Annular	NORMAL
L 7	Disp 1/2	NORMAL
L 8	Disp 3/4	NORMAL
L 9	Disp 5/6	NORMAL
L 10	Disp 7/8	NORMAL

06/29/25 9:21 AM

Urbana cmf

1904 Urbana Pike

Urbana, MD 20871

N06226005605004

Active Alarm Report

NO DATA AVAILABLE



Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 9:19 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 1: Regular

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/29/25 6:17
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 7096
% VOLUME = 59.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/04/25 1:37
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 7925
% VOLUME = 65.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/01/25 3:06
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 8300
% VOLUME = 69.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/27/25 5:45
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 8463
% VOLUME = 70.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/12/25 3:52
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 7988
% VOLUME = 66.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/17/25 4:21
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 8156
% VOLUME = 67.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/25 0:57
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 7773
% VOLUME = 64.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/02/24 1:12
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 8823
% VOLUME = 73.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/25/24 4:01
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 9030
% VOLUME = 75.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/25/24 3:58
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 8708
% VOLUME = 72.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/12/24 1:03
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 8707
% VOLUME = 72.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/02/24 4:36
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 8888
% VOLUME = 73.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/18/24 4:16
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 9186
% VOLUME = 76.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/04/24 1:22
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 8291
% VOLUME = 68.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/02/24 0:57
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 7907
% VOLUME = 65.7

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/30/24 3:30
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8107
% VOLUME = 67.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/18/24 1:24
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 8618
% VOLUME = 71.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/24 3:59
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 7545
% VOLUME = 62.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/08/24 4:41
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 7569
% VOLUME = 62.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/10/23 7:13
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8055
% VOLUME = 66.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/23 1:03
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 8551
% VOLUME = 71.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/21/23 3:02
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8658
% VOLUME = 72.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/30/23 5:30
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8514
% VOLUME = 70.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/13/23 1:25
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 8996
% VOLUME = 74.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/06/23 4:02
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 8996
% VOLUME = 74.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/14/23 1:05
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 8961
% VOLUME = 74.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/22/23 4:07
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 8902
% VOLUME = 74.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/30/23 7:15
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 8441
% VOLUME = 70.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/02/23 2:06
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 8300
% VOLUME = 69.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/27/23 4:01
METHOD = CSLD Periodic Test
HOURS = 25
AVG. VOLUME = 8573
% VOLUME = 71.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/27/23 2:18
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 8442
% VOLUME = 70.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/05/22 2:22
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 8789
% VOLUME = 73.0



Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/27/22 4:49
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 8184
% VOLUME = 68.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/09/22 5:25
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 7726
% VOLUME = 64.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/03/22 4:58
METHOD = CSLD Periodic Test
HOURS = 17
AVG. VOLUME = 8367
% VOLUME = 69.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/24/22 2:23
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 8261
% VOLUME = 68.7

06/29/25 9:19 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: Supreme

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/29/25 6:53
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 4484
% VOLUME = 55.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/26/25 3:55
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 4756
% VOLUME = 59.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/03/25 3:11
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 4243
% VOLUME = 52.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/02/25 3:54
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 4838
% VOLUME = 60.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 0:52
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 6026
% VOLUME = 75.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/26/25 2:38
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 6115
% VOLUME = 76.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/10/25 5:07
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6246
% VOLUME = 77.9



Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/03/24 2:08
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6150
% VOLUME = 76.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/26/24 4:51
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 6275
% VOLUME = 78.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/24 1:01
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 5804
% VOLUME = 72.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/10/24 4:51
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 5784
% VOLUME = 72.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/31/24 22:28
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 5400
% VOLUME = 67.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/14/24 7:31
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 5690
% VOLUME = 70.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/21/24 0:41
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 6170
% VOLUME = 76.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/24 4:18
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 5001
% VOLUME = 62.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/01/24 20:41
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 3861
% VOLUME = 48.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/31/24 0:53
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3876
% VOLUME = 48.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/01/24 13:51
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 2927
% VOLUME = 36.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/19/24 21:18
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 4847
% VOLUME = 60.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/31/23 16:54
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 3506
% VOLUME = 43.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/01/23 0:59
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3852
% VOLUME = 48.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/31/23 3:37
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 3815
% VOLUME = 47.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/30/23 5:41
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3553
% VOLUME = 44.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/23 0:24
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 3894
% VOLUME = 48.5

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/22/23 5:47
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 4207
% VOLUME = 52.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/04/23 0:48
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 3559
% VOLUME = 44.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/23 6:28
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3468
% VOLUME = 43.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/06/23 4:37
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 3588
% VOLUME = 44.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/22/23 4:17
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3610
% VOLUME = 45.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/06/23 22:54
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 4386
% VOLUME = 54.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/31/23 4:19
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 3908
% VOLUME = 48.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/17/22 23:20
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 4293
% VOLUME = 53.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/22 5:23
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3491
% VOLUME = 43.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/22 20:57
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 4037
% VOLUME = 50.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/05/22 0:30
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 4308
% VOLUME = 53.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/19/22 2:51
METHOD = CSLD Periodic Test
HOURS = 26
AVG. VOLUME = 4218
% VOLUME = 52.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/31/22 8:37
METHOD = CSLD Periodic Test
HOURS = 10
AVG. VOLUME = 3302
% VOLUME = 41.2

MARYLAND LOTTERY

MARYLAND LOTTERY

MARYLAND LOTTERY

MARYLAND LOTTERY

MARYLAND LOTTERY

MARYLAND LOTTERY

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137
1904 Urbana Pike
Clarksburg, MD 20871

06/29/25 9:20 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

T 3: Diesel

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/29/25 9:10
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 3434
% VOLUME = 34.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/29/25 2:00
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 3533
% VOLUME = 35.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/01/25 0:52
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 3514
% VOLUME = 35.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/06/25 23:12
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 5547
% VOLUME = 55.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/31/25 21:05
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 4561
% VOLUME = 45.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/21/25 18:23
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 4930
% VOLUME = 49.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/18/25 21:01
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 6069
% VOLUME = 60.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/19/24 23:16
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 8206
% VOLUME = 81.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/23/24 6:18
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 6091
% VOLUME = 60.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/06/24 1:05
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 5621
% VOLUME = 56.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/21/24 3:03
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 6769
% VOLUME = 67.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/01/24 6:44
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 6735
% VOLUME = 67.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/27/24 15:23
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 7330
% VOLUME = 73.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/08/24 17:28
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 7948
% VOLUME = 79.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/24 19:14
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 5585
% VOLUME = 55.7

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/04/24 18:48
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 3828
% VOLUME = 38.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/02/24 7:28
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 3957
% VOLUME = 39.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/24 23:15
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 3244
% VOLUME = 32.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/10/24 16:32
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 3745
% VOLUME = 37.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/04/23 10:18
METHOD = CSLD Periodic Test
HOURS = 46
AVG. VOLUME = 2946
% VOLUME = 29.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/04/23 5:52
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 3867
% VOLUME = 38.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/23 14:36
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 3989
% VOLUME = 39.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/08/23 12:48
METHOD = CSLD Periodic Test
HOURS = 44
AVG. VOLUME = 3910
% VOLUME = 39.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/25/23 14:58
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 4332
% VOLUME = 43.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/08/23 20:37
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 6580
% VOLUME = 65.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/09/23 0:18
METHOD = CSLD Periodic Test
HOURS = 37
AVG. VOLUME = 4705
% VOLUME = 46.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/31/23 23:04
METHOD = CSLD Periodic Test
HOURS = 33
AVG. VOLUME = 3843
% VOLUME = 38.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/22/23 16:41
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 3984
% VOLUME = 39.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/04/23 22:16
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 4923
% VOLUME = 49.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/03/23 22:03
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 4872
% VOLUME = 48.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/31/23 23:20
METHOD = CSLD Periodic Test
HOURS = 39
AVG. VOLUME = 4692
% VOLUME = 46.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/08/22 20:59
METHOD = CSLD Periodic Test
HOURS = 36
AVG. VOLUME = 4540
% VOLUME = 45.3

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/30/22 23:52
METHOD = CSLD Periodic Test
HOURS = 43
AVG. VOLUME = 3686
% VOLUME = 36.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/22 2:09
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 3507
% VOLUME = 35.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/02/22 15:40
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 5375
% VOLUME = 53.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/27/22 13:21
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 5567
% VOLUME = 55.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/31/22 6:24
METHOD = CSLD Periodic Test
HOURS = 13
AVG. VOLUME = 4203
% VOLUME = 41.9

MARYLAND LOTTERY

MARYLAND LOTTERY

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

06/29/25 9:12 AM

Urbana cmf
1904 Urbana Pike
Urbana, MD 20871
N06226005605004

*** DISPLAY SETUP - LANGUAGE AND UNITS ***

SYSTEM LANGUAGE: ENGLISH
SYSTEM UNITS: US

*** SYSTEM DATE AND TIME ***

DATE AND TIME: JUN 29, 2025 09:12
TIME ZONE: (UTC -04:00) US/Eastern
NTP STATUS: DISABLED
NTP SERVER ADDRESS: pool.ntp.org

*** DISPLAY SETUP - DATE AND TIME FORMAT ***

DATE FORMAT: mm_dd_yyyy
DATE SEPARATOR: /
TIME FORMAT: 12-hour xM

*** DISPLAY SETUP - NUMBER FORMAT ***

DECIMAL SEPARATOR: .
THOUSANDS SEPARATOR: None

*** HEADERS SETUP ***

HEADER 1: Urbana cmf
HEADER 2: 1904 Urbana Pike
HEADER 3: Urbana, MD 20871
HEADER 4: N06226005605004
FAX NAME:
FAX NUMBER:

*** SYSTEM SETUP - ALARM FILTERING ***

ALARM FILTERING: ENABLED

*** COMMUNICATION SETUP - HOSTNAME ***

SYSTEM HOSTNAME: t1s450

*** COMMUNICATION SETUP - ETHERNET PORT ***

--- ID 13 ---

SLOT #: 4
PORT #: 1
IP ADDRESS TYPE: STATIC
IP ADDRESS: 10.4.38.250
IP SUBNET MASK: 255.255.255.192
IP GATEWAY ADDRESS: 10.4.38.193
IP DEFAULT GATEWAY: ENABLED
PRIMARY DNS SERVER:
SECONDARY DNS SERVER:
MAC ADDRESS: 00:50:83:12:41:ae
SERIAL COMMAND PORT: 8001
SSH PORT: 22
HTTPS PORT: 443
SERIAL COMMAND SECURITY: DISABLED
RS232 END OF MESSAGE: DISABLED

--- ID 14 ---

SLOT #: 4
PORT #: 2
IP ADDRESS TYPE: STATIC
IP ADDRESS: 192.168.1.100
IP SUBNET MASK: 255.255.255.0
IP GATEWAY ADDRESS: 10.4.38.193
IP DEFAULT GATEWAY: DISABLED
PRIMARY DNS SERVER:
SECONDARY DNS SERVER:
MAC ADDRESS: 00:50:83:12:41:af
SERIAL COMMAND PORT: 10001
SSH PORT: 22
HTTPS PORT: 443
SERIAL COMMAND SECURITY: DISABLED
RS232 END OF MESSAGE: DISABLED

*** COMMUNICATION SETUP - INTERNAL MODEM ***

--- NO INTERNAL MODEM DEFINED ---

*** COMMUNICATION SETUP - CDIM PORT ***

--- NO CDIM PORT DEFINED ---

*** COMMUNICATION SETUP - TDIM PORT ***

--- ID 16 ---

SLOT #: 4
PORT #: 1
LABEL:
TDIM PORT: 35555
PROTOCOL: UNKNOWN
UNITS REPORTED: UNKNOWN

*** COMMUNICATION SETUP - IFSF ***

IFSF DEVICE: ETHERNET
IFSF PROTOCOL: IFSF-CHINA1
TLG IFSF: DISABLED
TLG NODE ID: 1
LEAK DETECT IFSF: DISABLED
LEAK DETECT NODE ID: 1
IFSF UDP PORT: 3486
IFSF TCP PORT: 9000

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

*** COMMUNICATION SETUP - SERIAL PORT ***

--- ID 1 ---
SLOT #: 1
PORT #: 1
CONFIGURED: ENABLED
LABEL:
USAGE: RS232
BAUD RATE: 9600
DATA BITS: 7
PARITY: ODD PARITY
STOP BITS: 1
USE HANDSHAKING: NO HANDSHAKING
SERIAL COMMAND SECURITY: DISABLED
RS232 END OF MESSAGE: DISABLED

--- ID 2 ---
SLOT #: 1
PORT #: 2
CONFIGURED: ENABLED
LABEL:
USAGE: RS232
BAUD RATE: 9600
DATA BITS: 7
PARITY: ODD PARITY
STOP BITS: 1
USE HANDSHAKING: NO HANDSHAKING
SERIAL COMMAND SECURITY: DISABLED
RS232 END OF MESSAGE: DISABLED

*** COMMUNICATION SETUP - SMTP RELAY ***

SENDER NAME:
SENDER EMAIL ADDRESS:
USE SYSTEM HOSTNAME: YES
EMAIL RELAY: DISABLED
RELAY REQUIRES SSL: NO

*** DEVICE SETUP - PROBE ***

--- PROBE 1 ---
CONFIGURED: ENABLED
LABEL: Regular
ADDRESS: B1.S1.1
SERIAL NUMBER: 807798
PROBE TYPE: MAG7
FLOAT TYPE: 4.0 IN. PHASE SEPARATION
WATER MINIMUM: 0.000 INCHES

--- PROBE 2 ---
CONFIGURED: ENABLED
LABEL: Supreme
ADDRESS: B1.S1.2
SERIAL NUMBER: 748405
PROBE TYPE: MAG7
FLOAT TYPE: 4.0 IN. PHASE SEPARATION
WATER MINIMUM: 0.000 INCHES

--- PROBE 3 ---
CONFIGURED: ENABLED
LABEL: Diesel
ADDRESS: B1.S1.3
SERIAL NUMBER: 748395
PROBE TYPE: MAG7
FLOAT TYPE: 4.0 IN.
WATER MINIMUM: 0.000 INCHES

*** DEVICE SETUP - RELAY ***

--- RELAY 1 ---
CONFIGURED: ENABLED
LABEL: Overfill
ADDRESS: B1.S7.1
TYPE: Standard
ORIENTATION: Normally Open

*** DEVICE SETUP - EXTERNAL INPUT ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - LIQUID SENSOR ***

--- LIQUID SENSOR 1 ---
CONFIGURED: ENABLED
LABEL: Regular STP Sump
ADDRESS: B1.S1.4
MODEL: Dual Float Discriminatio
CATEGORY: STP Sump

--- LIQUID SENSOR 2 ---
CONFIGURED: ENABLED
LABEL: Supreme STP Sump
ADDRESS: B1.S1.5
MODEL: Dual Float Discriminatio
CATEGORY: STP Sump

--- LIQUID SENSOR 3 ---
CONFIGURED: ENABLED
LABEL: Diesel STP Sump
ADDRESS: B1.S1.6
MODEL: Tri-State(Single Float)
CATEGORY: STP Sump

--- LIQUID SENSOR 4 ---
CONFIGURED: ENABLED
LABEL: Regular Annular
ADDRESS: B1.S1.9
MODEL: Tri-State(Single Float)
CATEGORY: Annular Space

--- LIQUID SENSOR 5 ---
CONFIGURED: ENABLED
LABEL: Supreme Annular
ADDRESS: B1.S1.10
MODEL: Tri-State(Single Float)
CATEGORY: Annular Space

--- LIQUID SENSOR 6 ---
CONFIGURED: ENABLED
LABEL: Diesel-Annular
ADDRESS: B1.S1.11
MODEL: Tri-State(Single Float)
CATEGORY: Annular Space

--- LIQUID SENSOR 7 ---
CONFIGURED: ENABLED
LABEL: Disp 1/2
ADDRESS: B1.S1.13
MODEL: Dual Float Discriminatio
CATEGORY: Dispenser Pan

--- LIQUID SENSOR 8 ---
CONFIGURED: ENABLED
LABEL: Disp 3/4
ADDRESS: B1.S1.12
MODEL: Dual Float High Vapor
CATEGORY: Dispenser Pan

Precision Testing, Inc
4530 Graphics Drive, White Plains, MD 20695
Phone 301.638.7800 / Fax 301.638.7801
Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137
1904 Urbana Pike
Clarksburg, MD 20871

--- LIQUID SENSOR 9 ---
CONFIGURED: ENABLED
LABEL: Disp 5/6
ADDRESS: B1.S1.14
MODEL: Tri-State(Single Float)
CATEGORY: Dispenser Pan

--- LIQUID SENSOR 10 ---
CONFIGURED: ENABLED
LABEL: Disp 7/8
ADDRESS: B1.S1.15
MODEL: Dual Float High Vapor
CATEGORY: Dispenser Pan

*** DEVICE SETUP - VAPOR SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - GROUND WATER SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - TYPE A SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - TYPE B SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - TEMPERATURE SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - LVDIM ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - AIR FLOW METER ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - VAPOR PRESS SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - MAG SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - VACUUM SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - ATMOSPHERIC SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - HC SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - LINE P SENSOR ***

--- NO DEVICE DEFINED ---

*** DEVICE SETUP - VAPOR VALVE ***

--- NO DEVICE DEFINED ---

*** BIR SETUP - GENERAL ***

PRODUCT THRESHOLD ALARM:	DISABLED
DAILY CLOSE TIME:	2:00 AM
WEEK CLOSE DAY:	SUNDAY
ALARM THRESHOLD DELIVERY TYPE:	STANDARD
TEMPERATURE COMPENSATION:	STANDARD
METER CALIBRATION OFFSET %:	0.00
BIR STATUS WARNING ENABLE:	DISABLED
BIR DAILY CLOSE WARNING ENABLE:	DISABLED
BIR SHIFT CLOSE WARNING ENABLE:	DISABLED

*** BIR SETUP - THRESHOLD ALARMS ***

--- TEST 1 ---

TEST TYPE:	MONTHLY
THROUGHPUT:	ENABLED
PERCENT:	1.00
VOLUME OFFSET:	130
CAPACITY:	DISABLED
DELIVERY:	DISABLED
FIXED:	DISABLED

Precision Testing, Inc
4530 Graphics Drive, White Plains, MD 20695
Phone 301.638.7800 / Fax 301.638.7801
Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137
1904 Urbana Pike
Clarksburg, MD 20871

*** TANK SETUP - GENERAL SETUP ***

--- TANK 1 ---
CONFIGURED: ENABLED
LABEL: Regular
PRODUCT CODE: 1
PROBE NUMBER: Pb 1: Regular
PROBE OFFSET: 0.00 INCHES
FULL VOLUME: 12033 GALLONS
DIAMETER: 96.0 INCHES
TILT: 0.50 INCHES
THERMAL COEFFICIENT: 0.000692
METER DATA PRESENT: ENABLED
DELIVERY DELAY: 5 MINUTES
GROSS TEST FAIL: ALARMS ENABLED
PERIODIC TEST FAIL: ALARMS ENABLED
ANNUAL TEST FAIL: ALARMS DISABLED
GOST VOLUME CORRECTION: DISABLED

--- TANK 2 ---
CONFIGURED: ENABLED
LABEL: Supreme
PRODUCT CODE: 2
PROBE NUMBER: Pb 2: Supreme
PROBE OFFSET: 0.00 INCHES
FULL VOLUME: 8021 GALLONS
DIAMETER: 96.0 INCHES
TILT: 0.00 INCHES
THERMAL COEFFICIENT: 0.000692
METER DATA PRESENT: ENABLED
DELIVERY DELAY: 5 MINUTES
GROSS TEST FAIL: ALARMS ENABLED
PERIODIC TEST FAIL: ALARMS ENABLED
ANNUAL TEST FAIL: ALARMS DISABLED
GOST VOLUME CORRECTION: DISABLED

--- TANK 3 ---
CONFIGURED: ENABLED
LABEL: Diesel
PRODUCT CODE: 3
PROBE NUMBER: Pb 3: Diesel
PROBE OFFSET: 0.00 INCHES
FULL VOLUME: 10026 GALLONS
DIAMETER: 96.0 INCHES
TILT: 0.00 INCHES
THERMAL COEFFICIENT: 0.000450
METER DATA PRESENT: ENABLED
DELIVERY DELAY: 5 MINUTES
GROSS TEST FAIL: ALARMS ENABLED
PERIODIC TEST FAIL: ALARMS ENABLED
ANNUAL TEST FAIL: ALARMS DISABLED
GOST VOLUME CORRECTION: DISABLED

*** TANK SETUP - LIMITS ***

--- TANK 1 ---
MAX VOLUME: 12033 GALLONS
HIGH PRODUCT: 95%
DELIVERY OVERFILL: 90%
DELIVERY LIMIT: 15%
LOW PRODUCT: 600 GALLONS
HIGH WATER WARNING: 1.00 INCHES
HIGH WATER ALARM: 2.00 INCHES
WATER ALARM FILTER LEVEL: LOW
LEAK ALARM LIMIT: 10 GALLONS
SUDDEN LOSS LIMIT: 25 GALLONS
FUEL LOW TEMP LIMIT: -58.000 DEG F
FUEL HIGH TEMP LIMIT: 140.000 DEG F

--- TANK 2 ---
MAX VOLUME: 8021 GALLONS
HIGH PRODUCT: 95%
DELIVERY OVERFILL: 90%
DELIVERY LIMIT: 15%
LOW PRODUCT: 400 GALLONS
HIGH WATER WARNING: 1.00 INCHES
HIGH WATER ALARM: 2.00 INCHES
WATER ALARM FILTER LEVEL: LOW
LEAK ALARM LIMIT: 10 GALLONS
SUDDEN LOSS LIMIT: 25 GALLONS
FUEL LOW TEMP LIMIT: -58.000 DEG F
FUEL HIGH TEMP LIMIT: 140.000 DEG F

--- TANK 3 ---
MAX VOLUME: 10026 GALLONS
HIGH PRODUCT: 95%
DELIVERY OVERFILL: 90%
DELIVERY LIMIT: 15%
LOW PRODUCT: 500 GALLONS
HIGH WATER WARNING: 1.00 INCHES
HIGH WATER ALARM: 2.00 INCHES
WATER ALARM FILTER LEVEL: LOW
LEAK ALARM LIMIT: 10 GALLONS
SUDDEN LOSS LIMIT: 99 GALLONS
FUEL LOW TEMP LIMIT: -58.000 DEG F
FUEL HIGH TEMP LIMIT: 140.000 DEG F

*** TANK SETUP - ENVIRONMENTAL TESTS ***

--- TANK 1 ---
TANK TEST METHOD: CSLD
PROBABILITY OF DETECTION: 95%
CLIMATE FACTOR: MODERATE
CSLD EVAPORATION
COMPENSATION: DISABLED
STAGE II VAPOR RECOVERY: DISABLED

--- TANK 2 ---
TANK TEST METHOD: CSLD
PROBABILITY OF DETECTION: 95%
CLIMATE FACTOR: MODERATE
CSLD EVAPORATION
COMPENSATION: DISABLED
STAGE II VAPOR RECOVERY: DISABLED

--- TANK 3 ---
TANK TEST METHOD: CSLD
PROBABILITY OF DETECTION: 95%
CLIMATE FACTOR: MODERATE
CSLD EVAPORATION
COMPENSATION: DISABLED
STAGE II VAPOR RECOVERY: DISABLED

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

*** TANK SETUP - PROFILE ***

TANK PROFILE: --- TANK 1 ---
ONE POINT
FULL VOLUME: 12033
ENDSHAPE: 0.000
TANK PROFILE: --- TANK 2 ---
ONE POINT
FULL VOLUME: 8021
ENDSHAPE: 0.000
TANK PROFILE: --- TANK 3 ---
ONE POINT
FULL VOLUME: 10026
ENDSHAPE: 0.000

*** TANK CHART SETUP - CHARTS ***

--- TANK 1 - CHART 1 ---

LABEL: TYPE: ONE POINT
SOURCE: USER ENTERED
LAST CHANGE: 2016-04-04
STATUS: ACTIVE
CAPACITY: 12033
ENDSHAPE: 0.000
OFFSET: 0.00
TILT: 0.50
DIAMETER: 96.00
--- TANK 2 - CHART 1 ---

LABEL: TYPE: ONE POINT
SOURCE: USER ENTERED
LAST CHANGE: 2013-07-25
STATUS: ACTIVE
CAPACITY: 8021
ENDSHAPE: 0.000
OFFSET: 0.00
TILT: 0.00
DIAMETER: 96.00
--- TANK 3 - CHART 1 ---

LABEL: TYPE: ONE POINT
SOURCE: USER ENTERED
LAST CHANGE: 2013-07-25
STATUS: ACTIVE
CAPACITY: 10026
ENDSHAPE: 0.000
OFFSET: 0.00
TILT: 0.00
DIAMETER: 96.00

*** TANK SETUP - HRM LIMITS ***

--- TANK 1 ---
WARNING LIMIT: 1 GALLONS
ALARM LIMIT: 1 GALLONS
MAXIMUM VOLUME LIMIT: 132 GALLONS
--- TANK 2 ---
WARNING LIMIT: 1 GALLONS
ALARM LIMIT: 1 GALLONS
MAXIMUM VOLUME LIMIT: 132 GALLONS
--- TANK 3 ---
WARNING LIMIT: 1 GALLONS
ALARM LIMIT: 1 GALLONS
MAXIMUM VOLUME LIMIT: 132 GALLONS

*** TANK SETUP - SIPHON SETS ***

--- NO SIPHON SET DEFINED ---

*** TANK SETUP - ALL TANKS ***

ULLAGE DISPLAY MODE: FULL ULLAGE
FULL ULLAGE LABEL: USER ULLAGE
USER ULLAGE: 100% ULLAGE
PRINT TC VOLUMES: 90%
TC REFERENCE TEMPERATURE: DISABLED
PERIODIC TEST NEEDED: 60 DEG F
WARNINGS: ENABLED
DAYS BEFORE PERIODIC WARNING: 25
DAYS BEFORE PERIODIC ALARM: 30
ANNUAL TEST NEEDED WARNINGS: DISABLED
DAYS BEFORE ANNUAL WARNING: 355
DAYS BEFORE ANNUAL ALARM: 365
TC DENSITY: DISABLED
STICK HEIGHT: DISABLED
LEAK TEST REPORT FORMAT: STANDARD
LEAK TEST REGION: EPA

*** PRODUCT LABEL ***

--- PRODUCT 1 ---
LABEL: Regular
--- PRODUCT 2 ---
LABEL: Supreme
--- PRODUCT 3 ---
LABEL: Diesel

*** TANK PRODUCT MAPPING ***

TANK(S)	PRODUCT
T 1: Regular	F 1: Regular
T 2: Supreme	F 2: Supreme
T 3: Diesel	F 3: Diesel

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

*** TANK CHART SETUP - ACCUCHART ***

--- TANK 1 ---
UPDATE SCHEDULE: NEVER
CALIBRATION PERIOD: 60 DAYS
WARNINGS: ENABLED
MIN OPERATING LEVEL: 0%
MAX OPERATING LEVEL: 99%

--- TANK 2 ---
UPDATE SCHEDULE: NEVER
CALIBRATION PERIOD: 60 DAYS
WARNINGS: ENABLED
MIN OPERATING LEVEL: 0%
MAX OPERATING LEVEL: 99%

--- TANK 3 ---
UPDATE SCHEDULE: NEVER
CALIBRATION PERIOD: 60 DAYS
WARNINGS: ENABLED
MIN OPERATING LEVEL: 0%
MAX OPERATING LEVEL: 99%

*** PUMPS AND LINES - PUMP ***

--- NO DEVICE DEFINED ---

*** PUMPS AND LINES - LINE ***

--- NO DEVICE DEFINED ---

*** PUMPS AND LINES - PLLD ***

--- NO DEVICE DEFINED ---

*** PUMPS AND LINES - ALL LINES ***

RESTART ON ALARM CLEAR: DISABLED
LINE LOCKOUT SCHEDULE: Disabled

*** PUMPS AND LINES - ALL PLLD ***

LINE RE-ENABLE METHOD: PASS LINE TEST
PERIODIC TEST WARNINGS: DISABLED
DAYS BEFORE PERIODIC WARNING: 25
DAYS BEFORE PERIODIC ALARM: 30
ANNUAL TEST WARNINGS: DISABLED
DAYS BEFORE ANNUAL WARNING: 355
DAYS BEFORE ANNUAL ALARM: 365
PRECISION TEST DELAY: 12 HOURS

*** INVENTORY SETUP - REPORT TIMES ***

INVENTORY LOG INTERVAL: DISABLED
STORAGE LENGTH: 720

*** INVENTORY SETUP - SHIFT CLOSE METHOD ***

CLOSE METHOD: TIMED

*** INVENTORY SETUP - SHIFT TIMES ***

--- NO ACTIVE SHIFTS DEFINED ---

*** DELIVERY SETUP ***

DELIVERY METHOD: Standard Automatic
TICKETED DELIVERY: DISABLED
TANK IDLE DELIVERY: DISABLED

*** AUTOMATIC EVENTS - ADDRESS BOOK ***

--- CONTACT 1 ---

NAME: test
E-MAIL: dblades@bladestrek.com
E-MAIL TYPE: PLAIN TEXT E-MAIL
MODEM # (COMPUTER):
MODEM COM PORT: NOT ASSIGNED
MODEM DIAL-OUT STRING:
MODEM NUMBER OF RETRIES: 3
MODEM RETRY DELAY TIME: 3
MODEM IS HANGUP REQD: NO
FAX # (COMPUTER):
FAX COM PORT: NOT ASSIGNED
FAX DIAL-OUT STRING:
FAX NUMBER OF RETRIES: 3
FAX RETRY DELAY TIME: 3
REMOTE TCP / IP ADDRESS: 0.0.0.0
REMOTE TCP / IP PORT: 20001
LOCAL TCP/IP COM PORT: Co 5
TCP/IP NUMBER OF RETRIES: 3
TCP/IP RETRY DELAY TIME: 3
TCP/IP IS HANGUP REQD: NO
SATELLITE CONNECTION STRING:
SATELLITE COM PORT: NOT ASSIGNED
SATELLITE NUMBER OF RETRIES: 3
SATELLITE RETRY DELAY TIME: 3
SATELLITE IS HANGUP REQD: NO

*** AUTOMATIC EVENTS - AUTOXMIT TASKS ***

--- EVENT ID 1 ---

EVENT - Leak Alarm: Disabled
EVENT - High Water Alarm: Disabled
EVENT - Overfill Alarm: Disabled
EVENT - Low Limit Alarm: Disabled
EVENT - Theft Alarm: Disabled
EVENT - Delivery Start: Disabled
EVENT - Delivery Stop: Disabled
EVENT - External Input On: Disabled
EVENT - External Input Off: Disabled
EVENT - Sensor Fuel Alarm: Disabled
EVENT - Sensor Water Alarm: Disabled
EVENT - Sensor Out Alarm: Disabled
ACTION: AutoXmit
DEVICE: Co 1
DELAY TIME: 5 SECONDS
REPEAT TIME: 60 MINUTES

*** AUTOMATIC EVENTS - AUTOCONNECT TASKS ***

--- NO AUTO EVENTS DEFINED ---

Precision Testing, Inc
4530 Graphics Drive, White Plains, MD 20695
Phone 301.638.7800 / Fax 301.638.7801
Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137
1904 Urbana Pike
Clarksburg, MD 20871

*** AUTOMATIC EVENTS - DEVICE TASKS ***

--- EVENT ID 2 ---
EVENT - OVERFILL ALARM: ALL TANKS
ACTION:
DEVICE: R 1: Overfill

*** AUTOMATIC EVENTS - PRINT TASKS ***

--- EVENT ID 3 ---
EVENT - Delivery Complete: ALL TANKS
REPORT: Current Inventory Report
DEVICE: TLSIntegralPrinter

--- EVENT ID 4 ---
TIME: Daily, 1:30 AM
REPORT: Current Inventory Report
DEVICE: TLSIntegralPrinter

--- EVENT ID 5 ---
TIME: Daily, 5:00 AM
REPORT: CSLD Daily Test Results
DEVICE: TLSIntegralPrinter

*** AUTOMATIC EVENTS - ADDRESS BOOK ***

--- CONTACT 1 ---
NAME: test
E-MAIL: dbiades@bladestrek.com
E-MAIL TYPE: PLAIN TEXT E-MAIL
MODEM # (COMPUTER):
MODEM COM PORT: NOT ASSIGNED
MODEM DIAL-OUT STRING:
MODEM NUMBER OF RETRIES: 3
MODEM RETRY DELAY TIME: 3
MODEM IS HANGUP REQD: NO
FAX # (COMPUTER):
FAX COM PORT: NOT ASSIGNED
FAX DIAL-OUT STRING:
FAX NUMBER OF RETRIES: 3
FAX RETRY DELAY TIME: 3
REMOTE TCP / IP ADDRESS: 0.0.0.0
REMOTE TCP / IP PORT: 20001
LOCAL TCP/IP COM PORT: Co 5
TCP/IP NUMBER OF RETRIES: 3
TCP/IP RETRY DELAY TIME: 3
TCP/IP IS HANGUP REQD: NO
SATELLITE CONNECTION STRING:
SATELLITE COM PORT: NOT ASSIGNED
SATELLITE NUMBER OF RETRIES: 3
SATELLITE RETRY DELAY TIME: 3
SATELLITE IS HANGUP REQD: NO

*** AUTOMATIC EVENTS - ALL TASKS ***

--- EVENT ID 1 ---
EVENT - Leak Alarm: Disabled
EVENT - High Water Alarm: Disabled
EVENT - Overfill Alarm: Disabled
EVENT - Low Limit Alarm: Disabled
EVENT - Theft Alarm: Disabled
EVENT - Delivery Start: Disabled
EVENT - Delivery Stop: Disabled
EVENT - External Input On: Disabled
EVENT - External Input Off: Disabled
EVENT - Sensor Fuel Alarm: Disabled
EVENT - Sensor Water Alarm: Disabled
EVENT - Sensor Out Alarm: Disabled
ACTION: AutoXmit
DEVICE: Co 1
DELAY TIME: 5 SECONDS
REPEAT TIME: 60 MINUTES

--- EVENT ID 2 ---
EVENT - OVERFILL ALARM: ALL TANKS
ACTION:
DEVICE: R 1: Overfill

--- EVENT ID 3 ---
EVENT - Delivery Complete: ALL TANKS
REPORT: Current Inventory Report
DEVICE: TLSIntegralPrinter

--- EVENT ID 4 ---
TIME: Daily, 1:30 AM
REPORT: Current Inventory Report
DEVICE: TLSIntegralPrinter

--- EVENT ID 5 ---
TIME: Daily, 5:00 AM
REPORT: CSLD Daily Test Results
DEVICE: TLSIntegralPrinter

*** SYSTEM ADMINISTRATION - ROLES ADMIN ***

--- PREDEFINED ROLES ---
Administrator
Operator
Service Provider

--- CUSTOM ROLES ---
Regulator

*** SYSTEM ADMINISTRATION - USERS ADMIN ***

--- NO USERS DEFINED ---

*** SYSTEM SETUP - SECURITY ***

FRONT PANEL SECURITY: DISABLED
SERIAL COMMAND PORT: ENABLED
SSH PORT: ENABLED
SERIAL COMMAND OVER SSH: DISABLED
HTTPS PORT (WEB ACCESS): ENABLED
USER ADMIN VIA WEB: ENABLED

*** COMMUNICATION SETUP - USB PORT ***

--- NO USB PORT DEFINED ---

Precision Testing, Inc

4530 Graphics Drive, White Plains, MD 20695

Phone 301.638.7800 / Fax 301.638.7801

Email: precisiontestinginc@msn.com

June 29, 2025

CMF 2137

1904 Urbana Pike

Clarksburg, MD 20871

```
-----
*** COMMUNICATION SETUP - PROTOCOLS ***
-----
EURO PROTOCOL PREFIX:      S
H-PROTOCOL DATA FORMAT:   HEIGHT
-----

*** CUSTOM ALARM LABELS ***
-----
CUSTOM ALARMS:             DISABLED
-----

*** OVERVIEW - TANK OVERVIEW ***
-----
FUEL VOLUME:               ENABLED
FULL ULLAGE:               ENABLED
USER ULLAGE:               DISABLED
FUEL TC VOLUME:            DISABLED
TEMPERATURE:               ENABLED
FUEL HEIGHT:               ENABLED
WATER VOLUME:              DISABLED
WATER HEIGHT:              ENABLED
DENSITY:                   DISABLED
TC DENSITY:                DISABLED
MASS:                      DISABLED
STICK HEIGHT:              DISABLED
DELIVERED QTY:             DISABLED
MANIFOLD DEL.:             DISABLED
TEMPERATURE ON TANK:       DISABLED
VOLUME ON TANK:            DISABLED
-----

*** PRINTERS - SETUP ***
-----

      --- PRINTER 1 ---
CONFIGURED:                ENABLED
PRINTER:                   APS_CP324HRS_640_USB_1
IS DEFAULT:                YES
LABEL:                     TLSIntegralPrinter
URI:                       aps:/dev/bus/usb?type=u
                           +vid=6868+pid=4
DRIVER SELECTION:          MANUAL
DRIVER:                    APS CP324HRS, 0.16.0
PAPER SIZE:                Roll182.5mm
LINE FEED COUNT:           0
-----

*** BIR SETUP - HRM ***
-----
HRM FEATURE:               DISABLED
-----

*** SYSTEM SETUP - SENSOR HISTORY BY PERIOD ***
-----
PERIOD TYPE:               BY MONTH
-----
```



Maryland
Department of
the Environment

Maryland Catchment Basin and Containment Sump Test Report

MDE Facility I.D. #: #87	Carroll Independent Fuel LLC
Facility Name: URBANA PIKE CMF	UST Owner:
Facility Address: 904 URBANA PIKE	Owner Address: 18 Loveton Circle
City: CLARKSBURG State: MD Zip: 20871	City: Sparks State: MD Zip: 21152
Testing Company: CIF	Owner Telephone Number: 410-261-5450
Company Telephone Number: 443-506-5186	

Test Date: 8-8-25	Weather Condition: SUNNY	Temperature: 90°
-------------------	--------------------------	------------------

Product:	# 7-#8	DIESEL FILL	SUPER FILL
Testing:	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☒ Dispenser Sump # 7-8 ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☐ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:	19 3/4	12 1/8	11 7/8
Start Time:	1:45	3:30	3:30
End Level:	19 3/4	12 1/8	11 7/8
End Time:	2:45	4:30	4:30
Level Change:	NONE	NONE	NONE
Test Results:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Test Failure:	☐ Reported to MDE Date: Time:		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

MDE #87

Product:	REGULAR FILL	VAPOR	
Testing:	☒ Check One ☒ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☒ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☐ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☐ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:	11 3/4	12 1/4	
Start Time:	3:30	3:30	
End Level:	11 3/4	12 1/4	
End Time:	4:30	4:30	
Level Change:	NONE	NONE	
Test Result:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☐ Pass ☐ Fail
Test Failure	☐ Reported to MDE Date: _____ Time: _____		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

Tester Certification (check one):

- ☐ MDE Technician MDIC- - - T
☐ MDE Inspector MDIC- - - I
☐ Precision Tester: Test Method _____

Certification Expiration Date: _____

Tester's Name (print): _____ Tester's Signature: _____

Comments:

Copy of the test report must be maintained by the owner/operator for a period of 5 years and made available to the Department upon request and during UST inspections.

2 of 5

Page 2 of 2

MDE #87

Product:	#1 - #2	#3 - #4	#5 - #6
Testing:	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☒ Dispenser Sump #1-2 ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☒ Dispenser Sump #3-4 ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☒ Dispenser Sump #5-6 ☐ STP Sump ☐ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:	21 1/4	19 3/8	24 1/2
Start Time:	12:15	12:30	2:00
End Level:	21 1/4	19 3/8	24 1/2
End Time:	1:15	1:30	3:00
Level Change:	NONE	NONE	NONE
Test Result:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Test Failure	☐ Reported to MDE Date: _____ Time: _____		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

Tester Certification (check one):

- ☐ MDE Technician MDIC- - - T
☐ MDE Inspector MDIC- - - I
☐ Precision Tester: Test Method _____

Certification Expiration Date: _____

Tester's Name (print): _____ Tester's Signature: _____

Comments:

Copy of the test report must be maintained by the owner/operator for a period of 5 years and made available to the Department upon request and during UST inspections.

MDE #87

Product:	<u>DIESEL VENT</u>	<u>REG VENT</u>	<u>SUPER VENT</u>
Testing:	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:	<u>19 1/2"</u>	<u>25 1/4"</u>	<u>21 3/8"</u>
Start Time:	<u>9:45</u>	<u>10:30</u>	<u>11:45</u>
End Level:	<u>19 1/2"</u>	<u>25 1/4"</u>	<u>21 3/8"</u>
End Time:	<u>10:45</u>	<u>11:30</u>	<u>12:45</u>
Level Change:	<u>NONE</u>	<u>NONE</u>	<u>NONE</u>
Test Result:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Test Failure	☐ Reported to MDE Date: _____ Time: _____		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

Tester Certification (check one):

- ☐ MDE Technician MDIC- - - T
☐ MDE Inspector MDIC- - - I
☐ Precision Tester: Test Method _____ Certification Expiration Date: _____

Tester's Name (print): _____ Tester's Signature: _____

Comments:

Copy of the test report must be maintained by the owner/operator for a period of 5 years and made available to the Department upon request and during UST inspections.

MDE #87

Product:	REG STP	SUPER STP	DIESEL STP
Testing:	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):	☒ Check One ☐ Spill Bucket ☐ Stage I Bucket ☐ Dispenser Sump # ☐ STP Sump ☒ Tank Top Sump ☐ Transition Sump ☐ Vent Riser Sump ☐ Other (Describe):
Construction:	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)	☒ Single-walled ☐ Double-walled (vacuum test method must be performed in accordance with manufacturer or PEI/ RP1200)
Start Level:	24"	24 1/2"	23 7/8"
Start Time:	9:15	9:30	9:00
End Level:	24"	24 1/2"	23 7/8"
End Time:	10:15	10:30	10:00
Level Change:	NONE	NONE	NONE
Test Result:	☒ Pass ☐ Fail	☒ Pass ☐ Fail	☒ Pass ☐ Fail
Test Failure	☐ Reported to MDE Date: Time:		

- Hydrostatic and vacuum test failures must be reported to MDE immediately and within 2 hours of the test.

- A liquid level drop of 1/8 inch or greater in 1 hour is considered a test failure.

Tester Certification (check one):

☐ MDE Technician

MDIC-2024 1295

☐ MDE Inspector

MDIC-

8/8/2025

☐ Precision Tester: Test Method

HYDRO
INCHES OF WATER

Certification Expiration Date:

Tester's Name (print): JONATHAN CHANEY

Tester's Signature: 

Comments:

HYDRO INCHES OF WATER FROM BOTTOM OF SUMP.

Copy of the test report must be maintained by the owner/operator for a period of 5 years and made available to the Department upon request and during UST inspections.

A vertical number line with a red circle at 0.

Date: 8/4/2025

www.Petroleumstandards.com

Tech # 276-02

60-gal J Prover ser# 09-49173-02

Dispenser	Serial #	Product	Before	After	Gallons Pumped	Seal #
1	B12/3220D6	RUL	+7	0	15	21772
	91729C	PREM	+4	0	15	21784
2		RUL	+5	0	20	21775
		PREM	+4	0	20	21792
3	B23/4220D6	RUL	+14	0	15	21160
	917306	PREM	+3	0	25	21104
4		RUL	+10	0	15	21131
		PREM	+2	0	20	21100
5	B12/3220D6	RUL	0	0	5	*
	91728C	PREM	0	0	5	*
6		RUL	+2	0	15	21125
		PREM	0	0	5	*
7	B23/4220D6	RUL	0	0	5	*
	10515E	PREM	-2	0	15	21169
8		DSL	0	0	5	*
		RUL	0	0	10	*
		PREM	-2	0	20	21115
		DSL	+2	0	20	21141
3		DSL	0	0	5	21107
4		DSL	+2	0	15	21139