



February 14, 2025

Ms. Kathleen Thompson
Oil Control Program
Maryland Department of the Environment
1800 Washington Blvd, Suite 620
Baltimore, Maryland 21230

RE: **FOURTH QUARTER 2024 MONITORING REPORT**
Carroll Independent Fuel/Former Green Valley Citgo
11791 Fingerboard Road
Monrovia, Maryland
OCP Case #2005-0834-FR

Dear Ms. Thompson:

Groundwater & Environmental Services, Inc. (GES), on behalf of Carroll Independent Fuel Company, Inc. (CIFC), is pleased to submit the Fourth Quarter 2024 Monitoring Report for the Carroll/Former Green Valley Citgo facility (Site). In summary, the following activities were conducted at the Site this monitoring period:

- Quarterly fluid-level gauging of nine (9) monitoring wells and six (6) tank field wells was completed November 11, 2024;
- Sampling of five (5) quarterly and four (4) annual monitoring wells was completed November 11 and 12, 2024;
- Quarterly sampling at two (2) residential point-of-entry (POET) systems, 3994 and 3992 Farm Lane, was completed on November 11 and 12, 2024, respectively; and,
- Semiannual sampling of the Green Valley Plaza (GVP) supply well system (influent only) was completed on November 11, 2024.

The 3990 Farm Lane POET system was not sampled in the Fourth Quarter 2024 as the resident was unavailable.

GES will be submitting the Annual Remedial Evaluation Report for 2024 concurrently with this Fourth Quarter 2024 Monitoring Report. The Annual Report includes requests for reduction of the site monitoring program as discussed during the Administrative Consent Order status meeting held between CIFC, GES and MDE on November 19, 2024.

If you have any questions or would like additional information, please contact the undersigned at 800-220-3606, extension 3726, or Herb Meade at 410-261-5450.

Sincerely,

Pete Reichardt
Senior Project Manager



Ms. Kathleen Thompson
OCP Case #2005-0834-FR
February 14, 2025
Page 2 of 2

Enclosures

- c: Jim Richmond – MDE (1 additional copy & eCopy)
- Herb Meade – Carroll (e-copy)
- Barry Glotfelty – Frederick County Health Department (CD)
- Jennifer and Samir Andrawos – Timbercrest Limited Partnership (CD)
- File – GES, MD (PSID# 1014964)



MDE Contacts: Ms. Kathleen Thompson, Maryland Dept. of the Environment
Mr. Jim Richmond, Maryland Dept. of the Environment

Consultant Contact: Mr. Peter Reichardt, Groundwater & Environmental Services, Inc. (GES)

Client Contact: Mr. Herb Meade, Carroll Independent Fuel Company, Inc. (CIFIC)

SITE DESCRIPTION

Site Use: Carroll Motor Fuels-Branded Retail Service Station adjacent to Green Valley Plaza (shopping center)

Surrounding Area: Commercial shopping centers and residential properties

Sensitive Receptors: Potable Wells – The Site has historically contained up to nine (9) onsite supply wells. However, for the reported quarter, only one supply well was noted active (FR-13-0386).

Surrounding commercial and residential properties are all served by potable wells.

Basements/Underground Receptors – GVP pump room

Surface Water/Wetlands – Fahrney Branch is located approximately 2,400 feet to the south.

Hospitals/Childcare/Schools – Best Brains Learning Center (Green Valley Plaza)

Date of Most Recent Regulatory Directive Correspondence/Activities: Nov. 19, 2024 – CIFIC, GES and MDE meet for an Admin. Consent Order status meeting.

Regulatory correspondence is documented in **Appendix A – Historical Activities Summary**.

SCHEDULE OF ROUTINE ACTIVITIES

Groundwater Sampling: -Quarterly – Wells MW-7, MW-14D, MW-17, MW18S-R, and MW-18D

-Annually – Wells MW-1, MW-4, MW-5, and MW-13

*Wells MW-2, 6, 8, 9, 10, 11, 12, 14S, 15D, and MW-16 were abandoned and removed from the current monitoring program in 4Q 2017 with MDE approval granted October 17, 2017.

Laboratory Analyses: Full-suite volatile organic compounds (VOCs), oxygenates including methyl tert-butyl ether (MTBE), and naphthalene via EPA Method 8260.



SCHEDULE OF ROUTINE ACTIVITIES (cont.)

Table 1 summarizes current and historical analytical results from monitoring wells in the sampling program. **Figure 1** presents a Site Map that includes the locations of the monitoring wells, adjacent residences, and important land features.

- Monitoring Well Field Data:**
- Dissolved Oxygen (DO)
 - Oxidation Reduction Potential (ORP)
 - pH
 - Temperature
 - Specific Conductivity

Table 2 presents current and historical field parameters measurements from monitoring wells in the sampling program. The supporting Fourth Quarter 2024 monitoring well sampling data sheets are attached as **Appendix B**.

Non-Transient, Non-Community Supply Well Sampling

<u>Location</u>	<u>Well Number(s)</u>	<u>Sampling Frequency:</u>
Green Valley Plaza (GVP):	FR-13-0386 ^A	Quarterly
	FR-94-1281 ^B	Quarterly
	FR-94-1233 ^B	Quarterly

^A Supply well FR-13-0386 appears to be the only single, active source well for GVP system and therefore is represented by the GVP “Influent” potable well sample.

^B Supply wells that appear disconnected from current treatment system and cannot be sampled.

Laboratory Analyses: Target VOCs List, including oxygenates and naphthalene, via EPA Method 524.2.

Note: FR-81-5955, FR-88-1394, FR-88-1366, FR-73-4918, FR-73-6674, and FR-73-7687 were removed from the current monitoring program with MDE approval granted July 29, 2015.

Non-Transient, Non-Community Point-of-Entry Treatment (POET) System Sampling

<u>Location</u>	<u>System Sample Location</u>	<u>Sampling Frequency:</u>
Green Valley Plaza (GVP):	-Influent (“Inf”) *	Semi-annually

Laboratory Analyses: Full VOCs List, including oxygenates and naphthalene, via EPA Method 524.2.

Note: CIFC was released from POET of the GVP by the MDE in a directive dated January 18, 2023. The influent water at this location is now sampled semi-annually. A Water Filtration System Offer of Ownership or Removal letter was sent to the GVP ownership dated March 27, 2023. No response from GVP ownership has been received.

Table 3 summarizes current and historical analytical data for the Green Valley Plaza potable supply wells and the Influent, Midfluent, and Effluent diagnostic samples associated to the GVP POET treatment system.



SCHEDULE OF ROUTINE ACTIVITIES (cont.)

Residential Potable Well POET System Sampling

<u>Location</u>	<u>Well Number(s)</u>	<u>Sampling Frequency:</u>
3990 Farm Lane:	FR-73-5449	Quarterly
3992 Farm Lane:	Unknown	Quarterly
3994 Farm Lane:	FR-73-2625	Quarterly

Laboratory Analyses: Target VOC list including oxygenates (with MTBE) and naphthalene via EPA Method 524.2.

Notes: CIFC was released from POET maintenance at 3997 Farm Lane and 3923 Rosewood Road by the MDE on May 24, 2018. CIFC was released from potable sampling requirements at 3997 Farm Lane and 3923 Rosewood Road on January 18, 2023.

CIFC was released from POET maintenance and sampling requirements for the 3996 Farm Lane residence in MDE directive correspondence dated January 18, 2023. The 3996 Farm Lane POET system was sampled during the First Quarter 2023 and was discontinued of sampling and POET maintenance in the Second Quarter 2023.

Table 4 summarizes the current and historical analytical results for the offsite residential POET systems.

POET System Carbon Change-out Summary:

- No carbon change outs were performed during the Fourth Quarter 2024



Residential Potable Well Sampling:

*Note: Resident location 3829 Greenridge Road has been removed from the routine sampling schedule at the request of the property owner. The following residential potable well locations were removed from the current monitoring program with MDE approval granted July 29, 2015:

- 3979, 3981, 3983, 3984A, 3984, 3985, 3987, and 3989 Farm Lane
- 3833, 3835, and 3837 Greenridge Road
- 3737 and 3739 Blueberry Court
- 3992, 3994, 3996, and 3998 Rye Lane

The following residential potable well locations were removed from the current monitoring program with MDE approval granted September 11, 2018:

- 3991, 3993, 3995, and 3998 Farm Lane
- 3740 Blueberry Court

The following residential potable well locations were removed from the current monitoring program with MDE approval granted January 18, 2023:

- 3996 and 3997 Farm Lane
- 3923 Rosewood Road

Figure 2 presents a Local Area Map noting the various on and offsite potable and supply wells within the current study area. **Table 5** summarizes the current and historical analytical results for the offsite residential potable wells. All Fourth Quarter 2024 laboratory reports and chain-of-custody (COC) documentation are attached as **Appendix C**.

FIELD ACTIVITIES

Quarterly Groundwater Sampling Data Summary:

Quarterly Groundwater Sampling Dates:	November 11 and 12, 2024
# of Monitoring Wells in study area / # Sampled:	9 / 9 (quarterly & annual frequency wells)
Groundwater Sampling and Analyses Notes:	The revised routine sampling program outlined in the MDE's response letter, <i>Site Status and Modifications to Sampling Program</i> dated October 17, 2017 began implementation in the Fourth Quarter 2017. The revised routine sampling program outlined in the MDE's response letter, <i>Site Status and Modifications to Sampling Program</i> dated January 18, 2023 began implementation during Second Quarter 2023.
Apparent Groundwater Flow Direction:	Local groundwater flow is mapped to move south to southwest across the site and interpreted to move regionally toward the south-southwest.



FIELD ACTIVITIES (cont.)

Figure 3 presents an interpretation of groundwater contours based on water elevations gauged from overburden/weathered rock monitoring wells on November 11, 2024. **Figure 4** presents the Fourth Quarter 2024 MTBE concentration levels for onsite monitoring wells and both on and offsite potable supply wells. Groundwater and supply well monitoring graphs are attached as **Appendix D** and **Appendix E**, respectively. **Table 6** provides a summary of monitoring well construction details.

Maximum Monitoring Well Concentrations:

Benzene: Non-detect (method detection limit of 0.10 µg/L)
MTBE: 29 µg/L (MW-18S-R) on November 12, 2024
Naphthalene: Non-detect (method detection limit of 0.10 µg/L)

REMEDIAL SYSTEM STATUS

No remedial activities took place during the Fourth Quarter 2024. Past remedial activities can be referenced in the *ISCO System Comprehensive Summary & Update to the Conceptual Site Model (CSM)* submitted to the MDE on September 28, 2012.

REMEDIAL PERMITS

No remedial permits currently in effect.

FUTURE ACTIVITIES

First Quarter 2025:

- GES to submit the Annual Remedial Summary Report for 2024 which will request reductions to the current monitoring program.
- GES to continue quarterly sampling of monitoring wells and residential POET systems during the First Quarter 2025 monitoring period, unless otherwise directed by the MDE.



ATTACHMENTS

LIST OF FIGURES

Figure 1	Site Map
Figure 2	Local Area Map
Figure 3	Groundwater Contour Map, Fourth Quarter 2024
Figure 4	Onsite and Residential POET System MTBE Concentration Map, Fourth Quarter 2024

LIST OF TABLES


Table 1	Historical Monitoring Well Analytical Data Summary
Table 2	Historical Monitoring Well Field Parameters Data Summary
Table 3	Historical GVP Potable Well and POET System Data Summary
Table 4	Historical Residential POET System Data Summary
Table 5	Historical Residential Potable Well Data Summary
Table 6	Monitoring Well Construction Details

APPENDICES

Appendix A	Historical Activities Summary
Appendix B	Monitoring Well Sampling Data Sheets
Appendix C	Laboratory Reports and Chain of Custody Documentation (See Files on eCopy)
Appendix D	Monitoring Well Concentration Hydrographs
Appendix E	Supply Well Concentration Hydrographs

FIGURES

L:\Projects\Carroll\Fuels\Monrovia\GIS\Maps\2018_Q2\CarrollFuels_Monrovia_Fig1_SM.mxd - Scale: 1:600 - Date: 07-19-18 - Time: [12:08 PM] - GStewart




Legend			

Source:
NAIP aerial photograph for Frederick Co. Based on GIS data provided by Environmental Alliance, Inc.



Site Map

Monrovia BP
(Former Green Valley Citgo)
11791 Fingerboard Road
Monrovia, Maryland


<p>Drawn GKS</p> <p>Designed DMC</p> <p>Approved LK</p>	<p>Date 7-19-18</p> <p>Figure 1</p>
--	---



Scale In Feet (Approximate)

Groundwater & Environmental Services, Inc.




Legend

- | | | | | | | | | | | | |
|--|-----------------|--|----------------------------|--|-----------------------------|--|------------------|--|------------|--|-------------|
| | Abandoned Well | | Tank Field Well | | Topographic Contour (10 ft) | | Building | | Stream | | Wooded Area |
| | Monitoring Well | | Abandoned Soil Vapor Point | | Intermediate Contour (2 ft) | | Paved Road/Drive | | Ditch | | |
| | Potable Well | | Fence | | Property Boundary | | Unpaved Drive | | Water Body | | |

Local Area Map


**Monrovia BP
(Former Green Valley Citgo)
11791 Fingerboard Road
Monrovia, Maryland**

Drawn AM		Date 6-12-13
Designed JW		Figure 2
Approved GR		



Source:
Frederick County GIS

N:\Blacksburg\Projects\Carroll\Fuels\Monrovia\GIS\Maps\2024\04\CarrollFuels_Monrovia_GWE_Fig3.mxd - Date: 01-21-25 - Time: [01:38 PM] - jbarnard



Legend

- | | | | | | |
|-----------------|---------------------------------|------------------|------------|-------------|-------------------------------|
| Abandoned Well | Abandoned Soil Vapor Point | Fence | Building | Propane AST | Groundwater Elevation Contour |
| Monitoring Well | Abandoned Injection Well | Storm Sewer | Canopy | Pump Room | Dashed Where Inferred |
| Potable Well | Nested Obs Well | Curb Catch Basin | Dispenser | Transformer | Groundwater Elevation |
| Tank Field Well | Abandoned Vapor Extraction Well | Catch Basin | Tank Field | Dumpster | |

Source:
NAIP aerial photograph for Frederick Co. Based on GIS data provided by Environmental Alliance, Inc.

Groundwater Contour Map
Fourth Quarter 2024

Monrovia BP
(Former Green Valley Citgo)
11791 Fingerboard Road
Monrovia, Maryland

Drawn
J.B.
Designed
P.R.
Approved
P.R.

Date
1/21/25
Figure
3




Scale In Feet (Approximate)




Groundwater & Environmental Services, Inc.

N:\Blackburg\Projects\Carroll\Fuels\Monrovia\GIS\Maps\2024-Q4\CarrollFuels_Monrovia_Onsite and ResidentialPOET System_Fig4.mxd - Scale 1:1,200 - Date: 01-21-25 - Time: [04:30 PM] - jbarnard



- Legend**
- Building
 - Canopy
 - Tank Field
 - Monitoring Well
 - Nested Obs Well
 - Potable Well
 - Abandoned Well
 - Index Contour
 - Intermediate Contour
 - 6.9 MTBE Concentration (ug/L)
 - NS Not Sampled

Notes:
 All concentrations reported in micrograms per liter (ug/L)
 < = Not Detected above laboratory reporting limit
 J = Estimated value
 MTBE = Methyl tert-butyl ether

Source:
 Based on GIS data provided by
 Environmental Alliance, Inc.

**Onsite and Residential MTBE
 Concentration Map - Fourth Quarter 2024**

**Monrovia BP
 (Former Green Valley Citgo)
 11791 Fingerboard Road
 Monrovia, Maryland**

Drawn
J.B.
 Designed
P.R.
 Approved
P.R.

Date
1/21/25
 Figure
4

Scale In Feet (Approximate)
 0 100

GES
 Groundwater & Environmental Services, Inc.

TABLES

**Table 1
HISTORICAL MONITORING WELL ANALYTICAL DATA SUMMARY**

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Sample Method	Top of Casing (ft)	Depth to Water (ft)	Depth to Bottom (Measured Depth) (ft)	GW Elevation (ft)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Diisopropyl ether (µg/L)	Ethyl tert-butyl ether (µg/L)	Tert-amyl methyl ether (µg/L)	Tert-Butyl Alcohol (µg/L)	TPH-DRO (µg/L)	TPH-GRO (µg/L)	Carbon Disulfide (ug/L)	Chloroform (ug/L)	Naphthalene (µg/L)
GW Clean-up Standards*							5	1,000	700	10,000	20	NA	NA	NA	NA	47	47	81	80	0.17
MW-1	11/21/2022	-	99.19	51.03	-	48.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	11/22/2022	LF(60)	99.19	51.03	-	48.16	<0.10	<0.080	<0.080	<0.070	1.0	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.23 J	<0.080
MW-1	02/08/2023	-	99.19	49.72	-	49.47	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	05/11/2023	-	99.19	49.62	-	49.57	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	07/28/2023	-	99.19	53.38	-	45.81	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	11/28/2023	LF(60)	99.19	53.53	-	45.66	<0.10	<0.080	<0.080	<0.070	0.96	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.20 J	<0.080
MW-1	01/24/2024	-	99.19	46.17	-	53.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	05/08/2024	-	99.19	46.83	-	52.36	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	08/14/2024	-	99.19	45.02	-	54.17	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-1	11/11/2024	LF(60)	99.19	53.95	-	45.24	< 0.10	< 0.080	< 0.080	< 0.070	0.41 J	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	0.24 J	< 0.10
MW-4	11/21/2022	-	97.84	59.18	-	38.66	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	11/22/2022	P&S	97.84	59.18	60.65	38.66	<0.10	<0.080	<0.080	<0.070	<0.080	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	<0.090	<0.080
MW-4	02/08/2023	-	97.84	58.83	-	39.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	05/11/2023	-	97.84	58.98	-	38.86	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	07/28/2023	-	97.84	59.40	-	38.44	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	11/28/2023	P&S	97.84	59.44	60.65	38.40	<0.10	<0.080	<0.080	<0.070	<0.080	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	<0.090	<0.080
MW-4	01/24/2024	-	97.84	56.22	-	41.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	05/08/2024	-	97.84	53.30	-	44.54	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	08/14/2024	-	97.84	57.67	-	40.17	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-4	11/11/2024	P&S	97.84	59.13	60.58	38.71	< 0.10	< 0.080	< 0.080	< 0.070	0.088 J	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	< 0.090	< 0.10
MW-5	11/21/2022	-	99.60	65.55	-	34.05	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	11/22/2022	LF(68)	99.60	65.55	-	34.05	<0.10	0.23 J	<0.080	<0.070	<0.080	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.17 J	<0.080
MW-5	02/08/2023	-	99.60	59.11	-	40.49	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	05/11/2023	-	99.60	61.01	-	38.59	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	07/28/2023	-	99.60	65.70	-	33.90	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	11/28/2023	LF(68)	99.60	65.77	-	33.83	<0.10	<0.080	<0.080	<0.070	<0.080	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	<0.090	<0.080
MW-5	01/24/2024	-	99.60	51.55	-	48.05	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	05/08/2024	-	99.60	51.52	-	48.08	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	08/14/2024	-	99.60	52.79	-	46.81	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-5	11/11/2024	LF(68)	99.60	65.63	-	33.97	< 0.10	< 0.080	< 0.080	< 0.070	< 0.080	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	0.18 J	< 0.10
MW-7	11/21/2022	-	97.66	65.85	-	31.81	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-7	11/22/2022	LF(69)	97.66	65.85	-	31.81	<0.10	<0.080	<0.080	<0.070	0.75	0.14 J	<0.080	<0.20	<3.0	-	-	<0.10	0.25 J	<0.080
MW-7	02/08/2023	LF(69)	97.66	62.28	-	35.38	<0.10	<0.080	<0.080	<0.070	1.2	0.14 J	<0.080	<0.20	<3.0	-	-	<0.10	0.23 J	<0.080
MW-7	05/11/2023	LF(69)	97.66	63.35	-	34.31	<0.10	<0.080	<0.080	<0.070	0.59	0.11 J	<0.080	<0.20	<3.0	-	-	<0.10	0.24 J	<0.080
MW-7	07/28/2023	LF(69)	97.66	67.67	-	29.99	<0.10	<0.080	<0.080	<0.070	0.34 J	0.12 J	<0.080	<0.20	<3.0	-	-	<0.10	0.19 J	<0.080
MW-7	11/29/2023	LF(69)	97.66	68.72	-	28.94	<0.10	<0.080	<0.080	<0.070	0.47 J	0.21 J	<0.080	<0.20	<3.0	-	-	<0.10	0.24 J	<0.080
MW-7	01/24/2024	LF(69)	97.66	59.47	-	38.19	< 0.10	< 0.080	< 0.080	< 0.070	1.1	0.12 J	< 0.080	< 0.20	< 3.0	-	-	< 0.10	0.18 J	< 0.080
MW-7	05/08/2024	LF(69)	97.66	56.33	-	41.33	< 0.10	< 0.080	< 0.080	< 0.070	2.1	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	0.34 J	< 0.10
MW-7	08/14/2024	LF(69)	97.66	60.80	-	36.86	<0.10	<0.080	<0.080	<0.070	0.66	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.18 J	<0.10
MW-7	11/11/2024	LF(69)	97.66	66.20	-	31.46	< 0.10	< 0.080	< 0.080	< 0.070	0.60	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	0.26 J	< 0.10



**Table 1
HISTORICAL MONITORING WELL ANALYTICAL DATA SUMMARY**

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Sample Method	Top of Casing (ft)	Depth to Water (ft)	Depth to Bottom (Measured Depth) (ft)	GW Elevation (ft)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Diisopropyl ether (µg/L)	Ethyl tert-butyl ether (µg/L)	Tert-amyl methyl ether (µg/L)	Tert-Butyl Alcohol (µg/L)	TPH-DRO (µg/L)	TPH-GRO (µg/L)	Carbon Disulfide (ug/L)	Chloroform (ug/L)	Naphthalene (µg/L)
GW Clean-up Standards*							5	1,000	700	10,000	20	NA	NA	NA	NA	47	47	81	80	0.17
MW-13	11/21/2022	-	98.11	63.77	-	34.34	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	11/22/2022	LF(73)	98.11	63.77	-	34.34	<0.10	0.36 J	<0.080	<0.070	0.82	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.21 J	<0.080
MW-13	02/08/2023	-	98.11	60.94	-	37.17	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	05/11/2023	-	98.11	61.84	-	36.27	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	07/28/2023	-	98.11	65.77	-	32.34	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	11/28/2023	LF(73)	98.11	66.30	-	31.81	<0.10	<0.080	<0.080	<0.070	0.39 J	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.12 J	<0.080
MW-13	01/24/2024	-	98.11	57.58	-	40.53	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	05/08/2024	-	98.11	55.42	-	42.69	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	08/14/2024	-	98.11	57.10	-	41.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-13	11/11/2024	LF(73)	98.11	64.92	-	33.19	<0.10	<0.080	<0.080	<0.070	0.40 J	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	0.22 J	<0.10
MW-14D	11/21/2022	-	92.07	58.98	-	33.09	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-14D	11/22/2022	LF(212)	92.07	58.98	-	33.09	<0.10	<0.080	<0.080	<0.070	0.095 J	<0.10	<0.080	<0.20	<3.0	-	-	<0.10	<0.090	<0.080
MW-14D	02/08/2023	LF(212)	92.07	54.99	-	37.08	<0.10	<0.080	<0.080	<0.070	20	0.32 J	<0.080	0.30 J	5.9 J	-	-	0.34 J	<0.090	<0.080
MW-14D	05/11/2023	LF(212)	92.07	55.80	-	36.27	<0.10	<0.080	<0.080	<0.070	18	0.39 J	<0.080	<0.20	6.8 J	-	-	0.31 J	<0.090	<0.080
MW-14D	07/28/2023	LF(212)	92.07	60.45	-	31.62	<0.10	<0.080	<0.080	<0.070	20	0.38 J	<0.080	0.28 J	6.9 J	-	-	0.28 J	<0.090	<0.080
MW-14D	11/29/2023	LF(212)	92.07	61.98	-	30.09	<0.10	<0.080	<0.080	<0.070	18	0.34 J	<0.080	0.27 J	4.2 J	-	-	0.22 J	<0.090	<0.080
MW-14D	01/24/2024	LF(212)	92.07	53.08	-	38.99	<0.10	<0.080	<0.080	<0.070	18	0.27 J	<0.080	0.27 J	4.3 J	-	-	0.24 J	<0.090	<0.080
MW-14D	05/08/2024	LF(212)	92.07	47.84	-	44.23	<0.10	<0.080	<0.080	<0.070	16	0.27 J	<0.080	0.21 J	5.6 J	-	-	0.27 JB	<0.090	<0.10
MW-14D	08/15/2024	LF(212)	92.07	53.43	-	38.64	<0.10	<0.080	<0.080	<0.070	17	0.28 J	<0.080	0.23 J	6.4 J	-	-	0.23 J	<0.090	<0.10
MW-14D	11/12/2024	LF(212)	92.07	58.07	-	34.00	<0.10	<0.080	<0.080	<0.070	15	0.29 J	<0.080	0.26 J	5.4 J	-	-	0.13 J	<0.090	<0.10
MW-17	11/21/2022	-	92.84	61.05	-	31.79	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-17	11/22/2022	LF(68)	92.84	61.05	-	31.79	<0.10	<0.080	<0.080	<0.070	0.52	0.25 J	<0.080	<0.20	<3.0	-	-	<0.10	0.30 J	<0.080
MW-17	02/08/2023	LF(68)	92.84	56.86	-	35.98	<0.10	<0.080	<0.080	<0.070	0.41 J	0.11 J	<0.080	<0.20	<3.0	-	-	<0.10	0.24 J	<0.080
MW-17	05/11/2023	LF(68)	92.84	58.24	-	34.60	<0.10	<0.080	<0.080	<0.070	0.55	0.18 J	<0.080	<0.20	<3.0	-	-	<0.10	0.27 J	<0.080
MW-17	07/28/2023	LF(68)	92.84	62.70	-	30.14	<0.10	<0.080	<0.080	<0.070	0.35 J	0.18 J	<0.080	<0.20	<3.0	-	-	<0.10	0.34 J	<0.080
MW-17	11/28/2023	LF(68)	92.84	64.20	-	28.64	<0.10	<0.080	<0.080	<0.070	0.28 J	0.22 J	<0.080	<0.20	<3.0	-	-	<0.10	0.27 J	<0.080
MW-17	01/24/2024	LF(68)	92.84	54.40	-	38.44	<0.10	<0.080	<0.080	<0.070	0.35 J	0.14 J	<0.080	<0.20	<3.0	-	-	<0.10	0.23 J	<0.080
MW-17	05/08/2024	LF(68)	92.84	50.65	-	42.19	<0.10	<0.080	<0.080	<0.070	0.62	0.17 J	<0.080	<0.20	<3.0	-	-	<0.10	0.33 J	<0.10
MW-17	08/14/2024	LF(68)	92.84	56.75	-	36.09	<0.10	<0.080	<0.080	<0.070	0.66	0.14 J	<0.080	<0.20	<3.0	-	-	<0.10	0.35 J	<0.10
MW-17	11/12/2024	LF(68)	92.84	61.07	-	31.77	<0.10	<0.080	<0.080	<0.070	0.40 J	0.10 J	<0.080	<0.20	<3.0	-	-	<0.10	0.38 J	<0.10
MW-18S-R	11/21/2022	-	97.72	65.16	-	32.56	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-18S-R	11/22/2022	LF(68)	97.72	65.16	-	32.56	<0.10	<0.080	<0.080	<0.070	24	2.1	<0.080	0.20 J	<3.0	-	-	<0.10	0.22 J	<0.080
MW-18S-R	02/09/2023	LF(68)	97.72	61.90	-	35.82	<0.10	<0.080	<0.080	<0.070	2.8	0.14 J	<0.080	<0.20	<3.0	-	-	<0.10	0.18 J	<0.080
MW-18S-R	05/11/2023	LF(68)	97.72	63.02	-	34.70	<0.10	<0.080	<0.080	<0.070	3.9	0.17 J	<0.080	<0.20	<3.0	-	-	0.16 J	0.18 J	<0.080
MW-18S-R	07/28/2023	LF(68)	97.72	67.02	-	30.70	<0.10	<0.080	<0.080	<0.070	78	2.2	<0.080	1.6	17	-	-	<0.10	0.15 J	<0.080
MW-18S-R	11/29/2023	LF(68)	97.72	67.92	-	29.80	<0.10	<0.080	<0.080	<0.070	32	2.9	<0.080	0.30 J	<3.0	-	-	<0.10	0.15 J	<0.080
MW-18S-R	01/25/2024	LF(68)	97.72	58.69	-	39.03	<0.10	<0.080	<0.080	<0.070	3.0	0.21 J	<0.080	<0.20	<3.0	-	-	<0.10	0.10 J	<0.080
MW-18S-R	05/09/2024	LF(68)	97.72	55.98	-	41.74	<0.10	<0.080	<0.080	<0.070	8.4	0.10 J	<0.080	<0.20	<3.0	-	-	<0.10	0.39 J	<0.10
MW-18S-R	08/15/2024	LF(68)	97.72	59.57	-	38.15	<0.10	<0.080	<0.080	<0.070	1.8	<0.10	<0.080	<0.20	<3.0	-	-	0.19 J	0.19 J	<0.10
MW-18S-R	11/12/2024	LF(68)	97.72	65.85	-	31.87	<0.10	<0.080	<0.080	<0.070	29	0.85	<0.080	0.56	<3.0	-	-	<0.10	0.15 J	<0.10



**Table 1
HISTORICAL MONITORING WELL ANALYTICAL DATA SUMMARY**

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Sample Method	Top of Casing (ft)	Depth to Water (ft)	Depth to Bottom (Measured Depth) (ft)	GW Elevation (ft)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Diisopropyl ether (µg/L)	Ethyl tert-butyl ether (µg/L)	Tert-amyl methyl ether (µg/L)	Tert-Butyl Alcohol (µg/L)	TPH-DRO (µg/L)	TPH-GRO (µg/L)	Carbon Disulfide (ug/L)	Chloroform (ug/L)	Naphthalene (µg/L)	
GW Clean-up Standards*							5	1,000	700	10,000	20	NA	NA	NA	NA	47	47	81	80	0.17	
MW-18D	11/21/2022	-	98.31	61.20	-	37.11	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
MW-18D	11/22/2022	LF(125)	98.31	61.20	-	37.11	<0.10	0.16 J	<0.080	<0.070	18.0	0.16 J	<0.080	0.37 J	4.2 J	-	-	<0.10	<0.090	<0.080	
MW-18D	02/09/2023	LF(125)	98.31	53.53	-	44.78	<0.10	<0.080	<0.080	<0.070	16.0	0.12 J	<0.080	0.30 J	<3.0	-	-	<0.10	<0.090	<0.080	
MW-18D	05/11/2023	LF(125)	98.31	60.76	-	37.55	<0.10	<0.080	<0.080	<0.070	15.0	0.16 J	<0.080	0.31 J	4.0 J	-	-	0.27 J	<0.090	<0.080	
MW-18D	07/28/2023	LF(125)	98.31	63.27	-	35.04	<0.10	<0.080	<0.080	<0.070	16.0	0.16 J	<0.080	0.30 J	4.6 J	-	-	<0.10	<0.090	<0.080	
MW-18D	11/29/2023	LF(125)	98.31	64.53	-	33.78	<0.10	<0.080	<0.080	<0.070	16	0.16 J	<0.080	0.31 J	4.7 J	-	-	<0.10	<0.090	<0.080	
MW-18D	01/25/2024	LF(125)	98.31	57.40	-	40.91	< 0.10	< 0.080	< 0.080	< 0.070	15	0.12 J	< 0.080	0.29 J	< 3.0	-	-	0.19 J	< 0.090	< 0.080	
MW-18D	05/09/2024	LF(125)	98.31	51.41	-	46.90	< 0.10	< 0.080	< 0.080	< 0.070	< 0.080	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	< 0.090	< 0.10	
MW-18D	08/15/2024	LF(125)	98.31	55.68	-	42.63	<0.10	<0.080	<0.080	<0.070	0.71	<0.10	<0.080	<0.20	<3.0	-	-	0.12 J	<0.090	<0.10	
MW-18D	11/12/2024	LF(125)	98.31	60.85	-	37.46	< 0.10	< 0.080	< 0.080	< 0.070	0.086 J	< 0.10	< 0.080	< 0.20	< 3.0	-	-	< 0.10	< 0.090	< 0.10	
TF-3	11/21/2022	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	02/08/2023	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	05/11/2023	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	07/28/2023	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	01/24/2024	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	05/08/2024	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	08/14/2024	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-3	11/11/2024	-	NR	DRY	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	11/21/2022	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	02/08/2023	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	05/11/2023	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	07/28/2023	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	11/27/2023	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	01/24/2024	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	05/08/2024	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	08/14/2024	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-4	11/11/2024	-	NR	DRY	14.02	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	11/21/2022	-	NR	14.23	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	02/08/2023	-	NR	14.22	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	05/11/2023	-	NR	14.25	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	07/28/2023	-	NR	14.27	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	11/28/2023	-	NR	14.28	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	01/24/2024	-	NR	14.25	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	05/08/2024	-	NR	14.27	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	08/14/2024	-	NR	14.32	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-5	11/11/2024	-	NR	14.32	14.35	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	11/21/2022	-	NR	13.44	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	02/08/2023	-	NR	13.46	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	05/11/2023	-	NR	13.50	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-



**Table 1
HISTORICAL MONITORING WELL ANALYTICAL DATA SUMMARY**

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Sample Method	Top of Casing (ft)	Depth to Water (ft)	Depth to Bottom (Measured Depth) (ft)	GW Elevation (ft)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Diisopropyl ether (µg/L)	Ethyl tert-butyl ether (µg/L)	Tert-amyl methyl ether (µg/L)	Tert-Butyl Alcohol (µg/L)	TPH-DRO (µg/L)	TPH-GRO (µg/L)	Carbon Disulfide (ug/L)	Chloroform (ug/L)	Naphthalene (µg/L)
GW Clean-up Standards*							5	1,000	700	10,000	20	NA	NA	NA	NA	47	47	81	80	0.17
TF-6	07/28/2023	-	NR	13.52	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	11/28/2023	-	NR	13.52	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	01/24/2024	-	NR	13.48	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	05/08/2024	-	NR	13.51	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	08/14/2024	-	NR	13.55	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-6	11/11/2024	-	NR	13.56	13.60	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	11/21/2022	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	02/08/2023	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	05/11/2023	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	07/28/2023	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	11/28/2023	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	01/24/2024	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	05/08/2024	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	08/14/2024	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-7	11/11/2024	-	NR	DRY	12.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	11/21/2022	-	NR	11.48	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	02/08/2023	-	NR	11.48	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	05/11/2023	-	NR	11.52	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	07/28/2023	-	NR	11.54	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	11/28/2023	-	NR	11.54	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	01/24/2024	-	NR	11.49	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	05/08/2024	-	NR	11.50	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	08/14/2024	-	NR	11.54	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
TF-8	11/11/2024	-	NR	11.58	11.62	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Notes:

Compounds of concern and detected compounds are summarized in the data table and all analytical results can be found in the Laboratory Reports and Chain of Custody Documentation.

* Maryland Department of the Environment (MDE) Groundwater Clean-up Standards for Type I and II Aquifers (2018)

LF (##) = Low Flow ground water sampling method (depth that the sample was taken at in feet)

GRAB = Grab sample method

DRY = No water for sampling

P&S = Purge & Sample method

<# = Less than the method detection limit

µg/L = Micrograms per liter

J = Detected between the Method Detection Limit (MDL) and the Reporting Limit (RL); therefore, result is an estimated value.

MTBE = Methyl Tertiary Butyl Ether

NA(-) = Not Available or Not Analyzed for that specific compound

NR(-) = Not recorded

TPH-DRO = Total Petroleum Hydrocarbons - Diesel Range Organics

TPH-GRO = Total Petroleum Hydrocarbons - Gasoline Range Organics

VOC = Volatile Organic Compounds



Table 2
HISTORICAL MONITORING FIELD PARAMETERS DATA SUMMARY

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Well Temperature (°C)	Specific Conductance (µS/cm)	Dissolved Oxygen (mg/L)	Well pH	ORP (mV)
MW-1	11/22/2022	15.10	726	4.70	4.77	207.6
MW-1	11/28/2023	13.68	868	6.30	5.26	263.9
MW-1	11/11/2024	18.20	798	6.08	5.02	212.3
MW-4	11/21/2022	15.90	309	6.10	5.21	185.5
MW-4	11/29/2023	14.72	408	7.56	5.48	185.6
MW-4	11/11/2024	18.20	531	6.85	5.07	203.1
MW-5	11/21/2022	16.00	858	4.27	5.09	192.4
MW-5	11/28/2023	15.81	953	7.43	5.42	231.4
MW-5	11/11/2024	19.18	812	8.82	5.07	219.2
MW-7	11/22/2022	16.20	905	5.31	5.32	197.9
MW-7	02/08/2023	14.29	989	7.27	5.33	-51.1
MW-7	05/11/2023	16.21	986	4.81	5.73	232.1
MW-7	07/28/2023	18.12	905	6.24	5.70	213.8
MW-7	11/28/2023	15.08	1,175	4.67	5.62	236.8
MW-7	01/24/2024	15.03	932	5.80	5.28	254.8
MW-7	05/08/2024	16.62	1,040	6.51	5.21	239.1
MW-7	08/14/2024	18.68	800	6.35	5.39	165.4
MW-7	11/11/2024	16.61	875	4.94	5.33	198.6
MW-13	11/22/2022	16.70	1,060	4.63	4.95	203.3
MW-13	11/28/2023	16.50	1,184	6.45	5.25	273.6
MW-13	11/11/2024	17.49	1,021	8.19	5.05	232.5
MW-14D	11/22/2022	16.50	256	0.83	6.94	97.4
MW-14D	02/08/2023	15.54	326	0.67	7.89	-100.0
MW-14D	05/11/2023	16.87	320	0.50	8.04	-81.3
MW-14D	07/28/2023	16.87	323	0.37	6.79	-159.3
MW-14D	11/29/2023	15.04	366	0.77	7.59	-176.1
MW-14D	01/24/2024	14.55	323	0.68	8.06	-146.8
MW-14D	05/08/2024	17.13	316	0.20	7.83	-161.5
MW-14D	08/15/2024	17.17	309	0.51	7.97	-184.9
MW-14D	11/12/2024	16.78	301	0.78	7.92	-167.7
MW-17	11/22/2022	15.70	988	3.93	5.53	183.7
MW-17	02/08/2023	15.37	1,049	5.25	5.69	-60.9
MW-17	05/11/2023	16.42	1,064	2.74	5.71	251.9
MW-17	07/28/2023	16.33	1,075	2.76	5.00	221.6
MW-17	11/28/2023	14.25	1,195	4.77	3.60	243.1
MW-17	01/24/2024	13.88	1,000	4.11	5.56	208.7
MW-17	05/08/2024	16.14	978	1.99	5.53	231.1
MW-17	08/14/2024	17.02	1,013	4.15	5.55	148.7
MW-17	11/12/2024	15.63	987	5.53	5.53	141.0

Table 2
HISTORICAL MONITORING FIELD PARAMETERS DATA SUMMARY

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Well Temperature (°C)	Specific Conductance (µS/cm)	Dissolved Oxygen (mg/L)	Well pH	ORP (mV)
MW-18S-R	11/22/2022	17.50	1,699	0.53	5.79	112.7
MW-18S-R	02/09/2023	16.04	1,026	6.10	5.19	-44.9
MW-18S-R	05/11/2023	18.92	1,035	4.17	5.04	241.1
MW-18S-R	07/28/2023	19.96	1,760	0.44	5.05	170.1
MW-18S-R	11/29/2023	15.32	1,540	1.65	5.74	186.2
MW-18S-R	01/24/2024	16.06	2,762	4.29	5.23	217.1
MW-18S-R	05/09/2024	17.02	1,020	6.55	5.14	257.3
MW-18S-R	08/15/2024	19.91	786	5.79	5.08	192.1
MW-18S-R	11/12/2024	17.93	1,803	0.73	5.60	101.4
MW-18D	11/22/2022	16.20	3,124	0.25	7.55	-129.7
MW-18D	02/09/2023	15.51	3,301	0.31	7.72	-83.6
MW-18D	05/11/2023	18.59	3,069	0.91	7.57	-88.2
MW-18D	07/28/2023	19.54	2,938	0.22	7.06	-141.7
MW-18D	11/29/2023	15.19	3,055	0.61	7.45	-139.2
MW-18D	01/25/2024	15.80	2,504	0.77	7.67	-137.0
MW-18D	05/09/2024	17.16	2,532	1.16	7.45	149.3
MW-18D	08/15/2024	20.09	2,450	1.07	7.60	-49.6
MW-18D	11/12/2024	18.42	2,264	0.51	7.50	-35.6

Notes:

- °C = Degrees Celsius
- µS/cm = Microsiemens per centimeter
- mg/L = Milligrams per liter
- mV = Millivolts



Table 3

HISTORICAL GVP POTABLE WELL AND POET SYSTEM DATA SUMMARY

Carroll - Monrovia MD - Former Green Valley Citgo
 11791 Fingerboard Rd
 Monrovia, MD

Monitoring Well	Date	Carbon Change	POET Totalizer (gal)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Diisopropyl ether (µg/L)	Ethyl tert-butyl ether (µg/L)	Tert-amyl methyl ether (µg/L)	Tert-Butyl Alcohol (µg/L)	Naphthalene (µg/L)	TPH-DRO (µg/L)	TPH-GRO (µg/L)	Chloroform (µg/L)
GW Clean-up Standards*				5	1,000	700	10,000	20	NL	NL	NL	NL	0.17	47	47	80
GVP-INF ^A	11/21/2022		-	<0.10	<0.10	<0.10	<0.10	0.36 J	<0.10	<0.10	<0.10	<2.5	<0.20	NA	NA	NA
GVP-INF ^A	05/11/2023		-	<0.10	<0.10	<0.10	<0.10	0.23 J	<0.10	<0.10	<0.10	<5.0	<0.20	NA	NA	0.12 J
GVP-INF ^A	11/28/2023		-	<0.10	<0.10	<0.10	<0.10	0.40 J	<0.10	<0.10	<0.10	<5.0	<0.20	NA	NA	0.16 J
GVP-INF ^A	05/08/2024		-	<0.10	<0.10	<0.10	<0.10	0.13 J	<0.10	<0.10	<0.10	<5.0	<0.20	NA	NA	<0.10
GVP-INF ^A	11/11/2024		-	<0.10	<0.10	<0.10	<0.10	0.25 J	<0.10	<0.10	<0.10	<5.0	<0.20	NA	NA	0.15 J
GVP-EFF	11/21/2022		13,397,000	-	-	-	-	-	-	-	-	-	-	-	-	-
GVP-EFF	05/11/2023		202,040	-	-	-	-	-	-	-	-	-	-	-	-	-
GVP-EFF	11/11/2024		891,043	-	-	-	-	-	-	-	-	-	-	-	-	-

Notes:

* Maryland Department of the Environment (MDE) Groundwater Clean-up Standards for Type I and II Aquifers (2018)

- GVP-INF^A = GVP INF conc. also reflects the conc. for GVP supply well FR-13-0386
- <# = Less than the method detection limit of #
- µg/L = Micrograms per liter
- EFF = Effluent sample location
- gal = Gallons
- GVP = Green Valley Plaza
- INF = Influent sample location
- J = Detected between the Method Detection Limit (MDL) and the Reporting Limit (RL); therefore, result is an estimated value.
- MTBE = Methyl Tertiary Butyl Ether
- NL = No Limit (Screening)
- NA = Not Analyzed
- POET = Point of Entry Treatment
- = No Data Available
- TPH-DRO = Total Petroleum Hydrocarbons - Diesel Range Organics
- TPH-GRO = Total Petroleum Hydrocarbons - Gasoline Range Organics



**Table 4
HISTORICAL RESIDENTIAL POET SYSTEM DATA SUMMARY**

Carroll Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	CARBON CHANGE	POET Totalizer (gal)	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Naphthalene (µg/L)	tert-Butyl Alcohol (µg/L)	Diisopropyl ether (µg/L)	ethyl tert-butyl ether (µg/L)	tert-amyl methyl ether (µg/L)	Tetrachloroethene (ug/L)
GW Clean-up Standards*				5	1,000	700	10,000	20	0.17	NL	NL	NL	NL	5
3994-FARM-INF	09/20/2024	-	-	< 0.10	<0.10	< 0.10	< 0.10	2.4	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-INF	11/11/2024	-	-	< 0.10	<0.10	< 0.10	< 0.10	1.8	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-MID2	11/21/2022	-	-	<0.10	0.22 J	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-MID2	02/08/2023	-	-	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-MID2	05/11/2023	-	-	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-MID2	07/27/2023	-	-	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-MID2	11/28/2023	-	-	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	2.9 J	<0.10	<0.10	<0.10	<0.10
3994-FARM-MID2	01/24/2024	-	-	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-MID2	05/08/2024	-	-	< 0.10	0.17 J	< 0.10	< 0.10	< 0.10	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-MID2	09/20/2024	-	-	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-MID2	11/11/2024	-	-	< 0.10	< 0.10	< 0.10	< 0.10	< 0.10	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-EFF	11/04/2022	CARBON CHL	-	-	-	-	-	-	-	-	-	-	-	-
3994-FARM-EFF	11/21/2022	-	633,004	< 0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	02/08/2023	-	640,329	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	05/11/2023	-	647,557	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	07/27/2023	-	654,012	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	11/28/2023	-	663,597	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	01/04/2024	CARBON CHL	-	-	-	-	-	-	-	-	-	-	-	-
3994-FARM-EFF	01/24/2024	-	667,980	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	05/08/2024	-	676,054	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	09/20/2024	-	685,531	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-EFF	11/11/2024	-	690,075	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10

- Notes:**
 * Maryland Department of the Environment (MDE) Groundwater Clean-up Standards for Type I and II Aquifers (2018)
- <# = less than the method detection limit of #
 - µg/L = Micrograms/Liter
 - J = Result is between the method detection and reporting limits; therefore, result is estimated.
 - EFF = Effluent sample location
 - INF = Influent sample location
 - MID2 = Second midfluent sample location
 - MTBE = Methyl Tertiary Butyl Ether
 - NA = Not Available or Not Analyzed for that specific compound
 - POU = Point-of-use sample location
 - NL = No Limit (screening)
 - = No Data Available
 - NT = Not Tabulated, historical laboratory analytical report available for specified date.
 - <#¹ = less than the method reporting limit of #
 - (#)² = Totalizer Reading incorrectly recorded in the field.
 - VOC = Volatile Organic Compounds



Table 5

HISTORICAL RESIDENTIAL POTABLE WELL DATA SUMMARY

Carroll - Monrovia - Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

Monitoring Well	Date	Benzene (µg/L)	Toluene (µg/L)	Ethylbenzene (µg/L)	Total Xylenes (µg/L)	MTBE (µg/L)	Naphthalene (µg/L)	tert-Butyl Alcohol (µg/L)	Diisopropyl ether (µg/L)	ethyl tert-butyl ether (µg/L)	tert-amyl methyl ether (µg/L)	Tetrachloroethene (ug/L)
GW Clean-up Standards*		5	1,000	700	10,000	20	0.17	NL	NL	NL	NL	5
3923-ROSE-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	0.33 J	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3990-FARM-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	24	<0.20	<2.5	0.20 J	<0.10	0.56	<0.10
3990-FARM-INF	2/8/2023	<0.10	<0.10	<0.10	<0.10	16	<0.20	<2.5	0.20 J	<0.10	0.38 J	<0.10
3990-FARM-INF	7/27/2023	<0.10	<0.10	<0.10	<0.10	18	<0.20	5.6 J	0.17 J	<0.10	0.33 J	<0.10
3990-FARM-INF	11/28/2023	<0.10	<0.10	<0.10	<0.10	19	<0.20	3.8 J	0.18 J	<0.10	0.33 J	<0.10
3990-FARM-INF	1/24/2024	< 0.10	< 0.10	< 0.10	< 0.10	15	< 0.20	4.6 J	< 0.10	< 0.10	0.40 J	<0.10
3990-FARM-INF	05/08/2024	< 0.10	< 0.10	< 0.10	< 0.10	12	< 0.20	< 2.5	< 0.10	< 0.10	0.24 J	< 0.10
3990-FARM-INF	08/14/2024	<0.10	<0.10	<0.10	<0.10	13	<0.20	< 2.5	0.11 J	<0.10	0.27 J	<0.10
3992-FARM-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	12	<0.20	<2.5	<0.10	<0.10	0.25 J	<0.10
3992-FARM-INF	2/9/2023	<0.10	<0.10	<0.10	<0.10	12	<0.20	<2.5	0.10 J	<0.10	0.29 J	<0.10
3992-FARM-INF	5/11/2023	<0.10	<0.10	<0.10	<0.10	9.7	<0.20	<2.5	<0.10	<0.10	0.20 J	<0.10
3992-FARM-INF	11/28/2023	<0.10	<0.10	<0.10	<0.10	9.5	<0.20	<2.5	<0.10	<0.10	0.17 J	<0.10
3992-FARM-INF	1/25/2024	< 0.10	< 0.10	< 0.10	< 0.10	8.2	< 0.20	< 2.5	< 0.10	< 0.10	0.22 J	<0.10
3992-FARM-INF	5/15/2024	<0.10	<0.10	<0.10	<0.10	7.0	<0.20	<2.5	<0.10	<0.10	0.14 J	<0.10
3992-FARM-INF	8/14/2024	<0.10	<0.10	<0.10	<0.10	8.1	<0.20	<2.5	<0.10	<0.10	0.17 J	<0.10
3992-FARM-INF	11/12/2024	<0.10	<0.10	<0.10	<0.10	6.9	<0.20	<2.5	<0.10	<0.10	0.17 J	<0.10
3994-FARM-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	2.6	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-INF	2/8/2023	<0.10	<0.10	<0.10	<0.10	2.6	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-INF	5/11/2023	<0.10	<0.10	<0.10	<0.10	3.0	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-INF	7/27/2023	<0.10	<0.10	<0.10	<0.10	2.8	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-INF	11/28/2023	<0.10	<0.10	<0.10	<0.10	2.6	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3994-FARM-INF	1/24/2024	< 0.10	< 0.10	< 0.10	< 0.10	3.0	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	<0.10
3994-FARM-INF	5/8/2024	< 0.10	0.18 J	< 0.10	< 0.10	3.1	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-INF	9/20/2024	< 0.10	<0.10	< 0.10	< 0.10	2.4	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3994-FARM-INF	11/11/2024	< 0.10	<0.10	< 0.10	< 0.10	1.8	< 0.20	< 2.5	< 0.10	< 0.10	< 0.10	< 0.10
3996-FARM-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	0.84	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3996-FARM-INF	2/8/2023	<0.10	<0.10	<0.10	<0.10	0.86	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10
3997-FARM-INF	11/21/2022	<0.10	<0.10	<0.10	<0.10	<0.10	<0.20	<2.5	<0.10	<0.10	<0.10	<0.10

* Maryland Department of the Environment (MDE) Groundwater Clean-up Standards for Type I and II Aquifers (2018)

- = No Data Available

INF = Influent sample location

<# = Less than the method detection limit of #

µg/L = Micrograms/Liter

MTBE = Methyl Tertiary Butyl Ether

NA = Not Analyzed

J = Detected between the Method Detection Limit (MDL) and the Reporting Limit (RL); so result is an estimated value.

NT = Not Tabulated, historical laboratory analytical report available for specified date.

NL = No Limit (screening)

Table 6

MONITORING WELL CONSTRUCTION DETAILS

Carroll - Monrovia MD - Green Valley Citgo
11791 Fingerboard Road
Monrovia, MD

Monitoring Well	Well Permit #	Date Well Drilled	Date Well Installed	Well Diameter (inches)	TOC Elevation	Date of Last Survey	Total Depth of Well (from Ground Surface)	DTB of Steel Casing (feet)	TOS from Ground Surface	BOS from Ground Surface	Comments
MW-1	FR-94-5045	2/7/06	2/7/2006	2	99.19	2/27/2006	61.5	--	40	61.5	
MW-2	FR-94-5046	2/7/06	2/7/2006	2	99.47	2/27/2006	61.5	--	40	61.5	Well abandoned 12/21/17
MW-3	FR-94-5047	2/7/06	2/7/2006	2	99.16	2/27/2006	81.5	--	40	64	Drilled to 81.5 feet, backfilled and set at 64 feet; well abandoned 5/15/08
MW-4	FR-94-5048	2/7/06	2/7/2006	2	97.84	2/27/2006	61.5	--	40	61.5	
MW-5	FR-95-0982	5/12/08	2/23/2009	4	99.60	3/18/2009	70	14	40	70	
MW-6	FR-95-0983	5/12/08	2/23/2009	4	98.09	3/18/2009	59.5	14	40	59.5	boring caved to 59.5 feet; well abandoned 12/20/17
MW-7	FR-95-0984	5/12/08	2/24/2009	4	97.66	3/18/2009	80	19.5	53	80	
MW-8	FR-95-0985	5/12/08	2/23/2009	4	97.93	3/18/2009	70	15	45	70	Well abandoned 12/20/17
MW-9	FR-95-1216	2/26/09	3/11/2009	4	88.48	3/18/2009	78	10	48	78	Well abandoned 12/20/17
MW-10	FR-95-1217	2/26/09	3/11/2009	4	91.64	3/18/2009	80	10	40	80	Well abandoned 12/20/17
MW-11	FR-95-1219	2/27/09	3/11/2009	4	94.28	3/18/2009	77	10	47	77	Well abandoned 12/20/17
MW-12	FR-95-1218	3/2/09	3/12/2009	4	95.33	3/18/2009	84	10	44	82	Well abandoned 12/20/17
MW-13	FR-95-1215	3/2/09	3/12/2009	4	98.11	3/18/2009	84	10	49	84	
MW-14S	FR-95-1599	7/20/10	7/22/2010	4	91.21	7/22/2010	100	11.0	40	100	Well abandoned 12/20/17
MW-14D	FR-95-1418	9/24/09	7/22/2010	4	92.07	7/22/2010	221	10.5	201	221	
MW-15D	FR-95-1419	9/28/09	7/19/2010	4	97.67	7/22/2010	133.5	10	45.5	133.5	Well abandoned 12/20/17
MW-16	FR-95-1420	9/25/09	7/20/2010	4	89.78	7/22/2010	121	9.75	35.5	121	Well abandoned 12/20/17
MW-17	FR-95-1421	9/25/09	7/20/2010	4	92.84	7/22/2010	121	10.5	35	121	
MW-18S	FR-95-1674	11/17/10	11/17/2010	2	98.29	1/4/2011	70	--	45	70	MW-18S and MW-18D nested in one borehole; MW-18S abandoned on 11/10/15
MW-18D			11/18/2010	2	98.31	1/4/2011	130	--	120	130	
MW-18S-R	FR-95-2578	1/27/15	1/27/2015	4	97.72	1/27/2015	70	--	25	70	
VE-1	FR-95-1673	11/19/10	11/17/2010	4	98.40	1/4/2011	25	--	5	25	Abandoned 12/21/17
IW-1S	FR-95-1672	11/18/10	11/18/2010	0.60	98.52	1/4/2011	67	--	63	67	IW-1S and IW-1D nested in one borehole - stainless steel screen and casing; abandoned 12/21/17
IW-1D			11/19/2010	0.60	98.60	1/4/2011	73	--	69	73	
IW-2S	FR-95-1671	11/18/10	11/18/2010	0.60	98.63	1/4/2011	91	--	87	91	IW-2S and IW-2D nested in one borehole - stainless steel screen and casing; abandoned 12/21/17
IW-2D			11/19/2010	0.60	98.71	1/4/2011	103	--	99	103	
IW-3S	FR-95-1670	11/18/10	11/18/2010	0.60	98.51	1/4/2011	127	--	123	127	IW-3S and IW-3D nested in one borehole - stainless steel screen and casing; abandoned 12/21/17
IW-3D			11/19/2010	0.60	98.62	1/4/2011	134	--	130	134	
IW-4	FR-95-2019	5/30/12	5/30/12	0.75	NA	NA	92	--	85	89	Abandoned 12/21/17

BOS =Bottom of screen
NA = Not Available

TOS =Top of screen
TOC =Top of casing

U =Unknown



APPENDIX A

Historical Activities Summary



HISTORICAL ACTIVITY SUMMARY (key / relevant dates):

- 1990 – 2000: The facility was operated by Timbercrest LP.
2000: Underground storage tanks (USTs) were registered to Carroll Independent Fuel Company (Carroll).
- June 13, 2001: Three soil borings (SB-1AR, SB-2AR and SB-3) were advanced onsite and soil samples were collected by ATC Associates (ATC) as part of a Phase II Environmental Assessment.
- July 24, 2001: ATC completed a *Phase II Environmental Assessment* report.
- January 28, 2005: The Maryland Department of the Environment (MDE) Oil Control Program (OCP) conducted a compliance inspection, during which elevated levels of petroleum vapors were detected in the vicinity of the tank field, around tank top components, and in the tank field monitoring wells.
- June 1, 2005: MDE correspondence required vapor leak testing, containment sump and catchment basin testing, the installation of groundwater monitoring wells to comply with High-Risk Groundwater Use Area (HRGUA) Regulations, and the submittal of a *Subsurface Investigation Work Plan* to assess the vertical and lateral extent of any contamination of soil and/or groundwater. OCP Case #2005-0834-FR was assigned to the site.
- July 8, 2005: A *Work Plan – Subsurface Investigation and Emergency Regulation Compliance* was submitted to the MDE by Environmental Alliance (Alliance), proposing a soil boring event, installation of four monitoring wells, groundwater sampling, slug tests, and a sensitive receptor search.
- August 18, 2005: The MDE approved the *Work Plan*, with modifications, and required a drinking water well survey within a half-mile radius of the site be conducted.
- September 14-15, 2005: Ten soil borings (GP-1 through GP-10) were advanced.
- February 6-7, 2006: Four bedrock monitoring wells (MW-1 through MW-4) were installed.
- March 28, 2006: Methyl-tertiary butyl ether (MTBE) was detected at a concentration of 14 micrograms per liter ($\mu\text{g/L}$) in a blended influent sample collected from two onsite drinking water wells supplying the shopping center, Green Valley Plaza (GVP), which house the gas station.
- April 2006: Mr. Arshad Ranjha, doing business as Saaba Corporation, registered as the new UST owner.
- May 24, 2006: An *Assessment for the Emergency Regulations Compliance Report* was submitted to the MDE, detailing the soil boring event, the monitoring well installation, groundwater sampling, sampling of the onsite potable wells, and a sensitive receptor survey.
- July 7, 2006: The MDE responded to the *Assessment Report*, and required semi-annual sampling of the monitoring wells, the tank field wells, and the Site's supply wells, and submittal of boring logs for the onsite drinking water supply wells and the bedrock monitoring wells.
- September 19, 2006: MTBE was detected in a blended influent sample from the GVP's supply wells at a concentration of 42 $\mu\text{g/L}$.
- November 17, 2006: A *Semi-Annual Sampling Report* was submitted to the MDE detailing the results of groundwater sampling and the potable well sampling, and the intention to install a point of entry treatment (POET) system on GVP's water supply.



HISTORICAL ACTIVITY SUMMARY (Continued):

- January 22, 2007: The MDE issued a *Request for Interim Corrective Action Plan (ICAP) and Supplemental Investigation*, requiring the submittal of an ICAP to reduce vapor concentrations in the tank field, including a soil-vapor extraction (SVE) test on the tank field and monitoring well MW-3, an investigation of surface drains, and increased frequency of monitoring well and tank field well sampling from semi-annually to quarterly. The submittal of a *Site Conceptual Model (SCM)* and a supplemental *Work Plan* to further develop the SCM were also required. Quarterly sampling of GVP's and the adjacent Green Valley Shopping Center's (GVSC's) potable wells, initial sampling of several private offsite potable wells, and a detailed drinking water well survey within a half-mile radius of the site was required.
- March 23, 2007: An extension request for the submittal of the ICAP was submitted to the MDE, noting that there was more than one potentially responsible party at the Site.
- April 5, 2007: MDE correspondence acknowledged that more than one potentially responsible party existed at the Site.
- April 5, 2007: The MDE issued *Notice of Violation (NOV) NV-2007-069* to all potentially responsible parties for failure to meet the requirements of the January 22, 2007 directive letter within the specified deadlines. The MDE also sent correspondence regarding the case to the Frederick County Health Department (FCHD).
- April 5-6, 2007: An initial round of samples was collected from select offsite residential potable wells.
- April 11, 2007: Alliance met with the MDE's Water Supply Division to discuss installing a POET system on GVP's water supply.
- April 12, 2007: Email correspondence to MDE proposed sampling of additional select residential potable wells. The proposal was approved.
- April 19, 2007: Email correspondence to MDE proposed sampling of additional select residential potable wells. The proposal was approved.
- April 25, 2007: An ICAP was submitted to the MDE proposing SVE feasibility testing.
- April 25, 2007: A *Sampling Results and Work Plan* was submitted to the MDE detailing the results of sampling of offsite residential potable wells, the GVP supply wells and the GVSC supply wells, and included plans for future sampling.
- April 30, 2007: A *Drinking Water Well Survey* detailing the results of a search for potable wells within a half-mile radius of the site was submitted to the MDE.
- April 30, 2007: Granular activated carbon (GAC) POET systems were installed at two residences (3996 and 3994 Farm Lane) where MTBE was detected above the MDE's action level of 20 µg/L.
- May 7, 2007: The MDE approved the ICAP, with modifications, and required monthly sampling of certain residential potable wells. Alliance submitted *Site Conceptual Model and Supplemental Work Plan* to the MDE. A POET system was installed at 3990 Farm Lane.
- May 11, 2007: A POET system was installed at 3923 Rosewood Road.
- May 17, 2007: A *Surface Drain Evaluation* was submitted to the MDE.
- May 22, 2007: *Modifications to the Work Plan and the ICAP* was submitted to the MDE via email.
- May 23, 2007: A POET system was installed at 3992 Farm Lane.
- May 31 – June 1, 2007: Soil vapor monitoring points SV-1, SV-2 and SV-3 were installed around the tank field in preparation for SVE testing. Soil boring SB-1 was also advanced.
- June 9, 2007: A POET system was installed at 3997 Farm Lane.



HISTORICAL ACTIVITY SUMMARY (Continued):

- June 21-22, 2007: SVE feasibility testing was performed onsite.
- June 27, 2007: The MDE approved the *Supplemental Work Plan*.
- July 27, 2007: The MDE sent *Request to Sample Drinking Water Supply Well* notices to seven residences surrounding the Site.
- August 8, 2007: The MDE issued the directive *Off-Site Domestic Well Sampling Frequencies* requiring monthly sampling of 25 residences with potable wells and the submission of *Monthly Status Reports*, and quarterly sampling of 14 residences with potable wells and the submission of *Quarterly Drinking Water Supply Well Sampling Reports*.
- October 15, 2007: A *Potable Well Sampling Report* was submitted to the MDE. A *Quarterly Sampling Report* was also submitted, and included details of the SVE testing.
- March 27, 2008: The MDE issued *Modifications to Off-Site Domestic Well Sampling Frequencies and Request for Site Status*, reducing the reporting frequency for all data and the sampling frequency of certain potable wells to quarterly, but still required monthly sampling of wells outfitted with POET systems. The MDE requested an update on the proposed installation of a POET system on the GVSC supply wells, and the installation of five monitoring wells required in the April 5, 2007 NOV.
- May 6, 2008: A *Supplemental Work Plan Addendum* was submitted to the MDE proposing changes to the construction and installation of monitoring wells.
- May 12-15 2008: Four shallow groundwater monitoring wells (MW-5 through MW-8) were installed. The monitoring wells were left as open boreholes in the water-bearing zone. Monitoring well MW-3 was abandoned in anticipation of upcoming UST removal activities.
- May 28, 2008: The MDE approved the *Supplemental Work Plan Addendum*.
- June 2008: Down-hole geophysical testing of monitoring wells MW-6, MW-7 and MW-8, and drinking water wells FR-88-1356 and FR-94-1233 was conducted.
- June 20, 2008: A *Response to Directive* was submitted to the MDE, proposing the installation of four monitoring wells rather than five.
- July 21-25, 2008: One 2,000-gallon diesel UST and three 10,000-gallon gasoline USTs were removed from the Site. MDE was onsite to observe UST removal activities. Over 1,100 tons of soil, approximately 523 tons were petroleum-impacted, were removed from the Site. Soil vapor point SV-3 and tank field wells TF-1 and TF-2 were destroyed during UST removal activities. Site surface water discharge was reconfigured during Site upgrade activities.
- August 2008: A new UST system, consisting of two 10,000-gallon gasoline USTs, one 10,000-gallon diesel UST and one 4,000-gallon diesel UST, was installed at the Site. SVE piping was installed, connected to the tank field monitoring wells.
- August 2008: Water treatment permit was approved for modifications to the GVP supply well.
- August 22, 2008: A *UST System Closure Report* was submitted to the MDE.
- September 2008: A POET system was installed on the GVP water supply.
- September 16, 2008: A *Hydrogeologic Investigation Update Report and Work Plan* was submitted to the MDE, and included results of the down-hole geophysical well testing. The Work Plan proposed the installation of monitoring wells within the open boreholes of monitoring wells MW-5 through MW-8, installation of additional shallow monitoring wells, additional SVE testing, modifications to the potable well sampling plan, and preparation of an updated SCM.



HISTORICAL ACTIVITY SUMMARY (Continued):

- December 12, 2008: The MDE approved the *Work Plan* with modifications. The MDE did not approve the installation of new shallow monitoring wells, but requested the evaluation of need for deep monitoring wells near the tank field and offsite to the south and southeast; frequency of sampling POET systems at three residential addresses was increased to semi-monthly, frequency of the other three residential POET systems remained monthly; frequency of sampling at certain residences with potable wells was changed to quarterly, and others were changed to semi-annually. The MDE sent letters to area residents to inform them of the sampling frequency change.
- December 16, 2008: The need for installation of shallow monitoring wells in order to better place deep monitoring wells was verbally discussed with Jim Richmond of MDE.
- December 17, 2008: Susan Bull of MDE approved, via email, the installation of shallow monitoring wells if the data from them was needed in order to place deep monitoring wells.
- December 30, 2008: A *Response to Directive* was sent to the MDE.
- January 16, 2009: SVE feasibility testing was conducted.
- February 3, 2009: The MDE issued *Work Plan Clarification*, approving the installation of shallow wells in order to better place deep monitoring wells, and clarified the frequency of monitoring of the GVP and CVSC supply wells and residential potable wells.
- February 2009: Permanent screened monitoring wells were constructed in the open boreholes of monitoring wells MW-5 through MW-8.
- February 27, 2009: Alliance submitted *Soil Vapor Extraction (SVE) Pilot Testing Results* to the MDE.
- March 12, 2009: Five shallow monitoring wells (MW-9 through MW-13) were installed.
- May 20, 2009: The MDE issued *Changes to Off-Site Sampling Frequency*, changing the frequency of sampling residential POET systems to quarterly, and restating the required frequency of sampling offsite residential potable wells. The MDE also sent letters to area residents to inform them of the sampling frequency changes.
- June 5, 2009: A *Hydrogeologic Investigation Update and Work Plan* was submitted to MDE, detailing recent monitoring well installation, groundwater and potable well sampling, and updating the SCM. The *Work Plan* proposed the installation and geophysical testing of one deep monitoring well, installation of five shallow monitoring wells to help monitoring pump testing, packer testing of the deep monitoring well, pump testing of monitoring well MW-10, installation of an injection well, and injection testing of that well.
- August 21, 2009: A meeting was conducted with representatives of Carroll, Alliance, and MDE to discuss monitoring well installation and aquifer testing activities proposed in the *Work Plan*. It was decided that additional investigation in the vicinity of the tank field was necessary, and that short-term and long-term aquifer testing would be completed on monitoring wells close to the tank field in order to determine hydraulic conductivity and determine if any of the selected wells could function as recovery wells.
- August 26, 2009: *Work Plan Update* was submitted to the MDE, proposing installation of two deep monitoring wells, installation of two shallow monitoring wells, down-hole geophysical testing, packer testing of deep monitoring well PMW-14D, a 72-hour pumping test on deep monitoring well PMW-15D, and 4-hour pumping tests on monitoring wells MW-10, MW-13, PMW-16, and PMW-17.
- September 22, 2009: The MDE approved the *Work Plan Update*, but required a brief report be submitted prior to packer testing, and a brief report be submitted prior to the short-term pumping tests.



HISTORICAL ACTIVITY SUMMARY (Continued):

- September 21–25, 2009: Deep monitoring wells MW-14D and MW-15D and shallow monitoring wells MW-16 and MW-17 were installed. The monitoring wells were left as open boreholes.
- October 8, 2009: Alliance submitted *Response to September 22, 2009 Directive*, and included the required details of the planned short-term pumping tests.
- October 19, 2009: Pumping tests were performed onsite, including a step-drawdown test and subsequent 72-hour pumping test on monitoring well MW-15D.
- November 2, 2009: Geophysical testing of monitoring wells MW-14D, MW-16 and MW-17 was performed.
- November 4, 2009: *Packer Testing Work Plan* was submitted to the MDE.
- November 5-6, 2009: Packer testing was completed on monitoring well MW-14D.
- March 15, 2010: Alliance submitted *Update Report and Work Plan* to the MDE detailing monitoring well installation, step testing, pump testing, geophysical well testing and packer testing. The *Work Plan* proposed the installation of 2-inch wells within monitoring well MW-14D, conversion of monitoring wells MW-15D, MW-16 and MW-17 to permanent screened wells, and the submittal of a *Corrective Action Plan (CAP)*.
- June 17, 2010: MDE issued *Request for Corrective Action Plan*, requiring the submittal of a CAP by August 6, 2010. The MDE also required that monitoring well MW-14D be finished as a 4-inch well, and a new 4-inch well, MW-14S be installed adjacent to it; and approved the completion of monitoring wells MW-15D, MW-16, and MW-17 as permanent screened wells, continued quarterly groundwater sampling, the initiation of quarterly sampling of the GVP POET system, continued quarterly sampling of residential POET systems, continued quarterly sampling of 14 residential potable wells, continued semi-annual sampling of 8 residential potable wells.
- July 9, 2010: Carroll submitted a response to the MDE's request for a CAP, requesting an extension of the deadline for the submittal of a CAP to October 31, 2010.
- July 19-21, 2010: Monitoring well MW-14S was installed onsite. Monitoring wells MW-15D, MW-16, and MW-17 were converted to permanent screened wells.
- August 9, 2010: The MDE approved the extension of the deadline for CAP submittal.
- August 10, 2010: A meeting was conducted between GES, Carroll, and the MDE.
- September 2010: The case was transferred from Alliance to GES.
- September 9, 2010: GES submitted *In Situ Chemical Oxidation (ISCO) Pilot Test Work Plan* to the MDE, proposing the installation of three nested injection wells, a nested observation well, and a vapor extraction well; and the injection of hydrogen peroxide and ozone at three subsurface intervals during a two-day pilot test.
- October 13, 2010: A *Proposed Groundwater and Potable Well Sampling Program* was submitted to the MDE, proposing low-flow sampling methods and the collection of field measurements to replace the current purge and sample method for groundwater sampling; and the removal of Total Petroleum Hydrocarbons – Diesel Range Organics (TPH-DRO) from the list of parameters analyzed for all monitoring and non-transient, non-community supply wells. All POET system sampling, non-transient, non-community supply well sampling and residential potable well sampling was to remain on the schedule previously followed.
- November 16-19, 2010: Nested monitoring wells MW-18S and MW-18D, vapor extraction well VE-1 and injection wells IW-1S/D, IW-2S/D and IW-3S/D were installed onsite.



HISTORICAL ACTIVITY SUMMARY (Continued):

- November 18, 2010: The MDE approved the *ISCO Pilot Test Work Plan*, with slight modifications, and the use of low-flow sampling techniques at the Site. The MDE approved the elimination of TPH-DRO and TPH-Gasoline Range Organics (GRO) from analysis of samples collected from the GVP POET system, the GVP supply wells, and the GVSC supply wells. The MDE stated that the request to eliminate TPH-DRO from the analysis of groundwater would be considered pending a review of low-flow sampling data and pilot testing activities.
- November 30, 2010: ISCO pilot testing was conducted onsite.
- December 1, 2010: Carroll informed the MDE of the results of the pilot testing via email, and included a proposed plan to redevelop the injection wells and introduce air to see if they could be used for further injection testing. Carroll also requested to modify the post ISCO pilot test groundwater sampling plan proposed in the *ISCO Pilot Test Work Plan*. Monitoring wells sampled prior to the pilot testing (with the exception of MW-18S and MW-18D) would be omitted from additional groundwater sampling in December 2010. The MDE approved both proposals via email.
- December 8, 2010: Injection wells IW-1S/D, IW-2S/D and IW-3S/D were re-developed.
- December 15, 2010: Slug testing was conducted on monitoring wells MW-18S and MW-18D.
- January 4, 2011: Monitoring wells MW-18S and MW-18D, vapor extraction well VE-1 and injection wells IW-1S/D, IW-2S/D and IW-3S/D were surveyed into the existing well network.
- March 15, 2011: A CAP was submitted to the MDE proposing the installation of an ISCO remediation system, and an eight-week pilot program.
- June 1, 2011: The MDE issued *Extended Pilot Testing Approval* in response to the CAP, approving the ISCO pilot program, and requiring expanded groundwater monitoring during the pilot program.
- June 3, 2011: Carroll requested clarifications of two points in the *Extended Pilot Testing Approval* via email.
- June 6, 2011: The MDE responded via email to Carroll's questions, and issued an updated *Site Management Schedule*, requiring the submission of a *CAP Implementation Plan* by July 1, 2011.
- July 1, 2011: A *CAP Implementation Plan* was submitted to the MDE.
- August 28, 2011: The MDE approved the *CAP Implementation Plan* and required an *Extended ISCO Pilot Testing Reports* be submitted during operation of the system and after completion of the pilot test period.
- September 14, 2011: The ISCO system was activated and GES began groundwater and POET System monitoring as per the schedule outlined in the MDE approved *CAP Implementation Plan*.
- October 14, 2011: An *Extended ISCO Pilot Testing – Week 3 Operation Report* was submitted to the MDE.
- November 11, 2011: ISCO system operation stopped, completing the 8 week ISCO Pilot Test.
- November 18, 2011: An *Extended ISCO Pilot Testing – Week 7 Operation Report* was submitted to the MDE.
- December 19, 2011: An *Extended ISCO Pilot Testing – Comprehensive Summary Report* was submitted to the MDE.
- February 10, 2012: GES received from the MDE a *Corrective Action Plan (CAP) Approval* letter.
- February 20, 2012: The ISCO system was activated and GES began groundwater and POET System monitoring as per the schedule outlined in the MDE *Corrective Action Plan (CAP) Approval* letter and subsequent correspondence.



HISTORICAL ACTIVITY SUMMARY (Continued):

April 2, 2012: An *ISCO Injection Well Installation Work Plan* was submitted to the MDE.
May 5, 2012: An *ISCO System Operation Report* was submitted to the MDE.
May 21-30, 2012: Completion of a rock coring and hydraulic pressure testing investigation and the construction of injection well IW-4.
May 31-June 5, 2012: Injection well IW-4 trenching, system connections, development and testing were completed, followed by the well being added to the injection well network for ISCO system operation.
June 25, 2012: An *ISCO System Operation Report* was submitted to the MDE.
July 31, 2012: The MDE requested that the ISCO system be shut down at the site pending further groundwater sampling.
August 1, 2012: The ISCO system was deactivated.
August 1, 2012: GES received from the MDE a *Modification to the Corrective Action Plan* letter.
August 3, 2012: GES sent a letter to the MDE in response to the *Modification to the Corrective Action Plan* letter received.
August 9-23 and September 4, 2012: GES emailed laboratory analytical results to the MDE that included hexavalent and chromium data.
August 31, 2012: Monitoring well slug testing conducted at select monitoring wells.
September 12, 2012: GES received from the MDE an email requesting additional information regarding lead analysis.
September 18, 2012: GES received from the MDE an email regarding remediation system equipment removal.
September 21, 2012: Carroll sent an email to the MDE regarding additional monitoring and sampling to be conducted during the 4th quarter sampling event and the timing of the event.
September 27, 2012: The ISCO system trailer was removed from the site.
September 28, 2012: An *ISCO System Comprehensive Summary Report and Update to the Conceptual Site Model* and *Supplemental Chromium and Lead Investigation Summary* were submitted to the MDE.
November 21, 2012: GES submitted an *October 2012 Sampling Data Transmittal Letter* to the MDE.
December 1, 2012: The FCHD and the MDE's contractor sampled the drinking water supply at 3833 Greenridge Drive.
December 20, 2012: The MDE sent a letter to Mr. and Mrs. Gray in regards to the additional investigation of 11712 Serene Court.
December 21, 2012: The MDE sent a letter to Mr. Schlessinger in regards to the sampling results for 3833 Greenridge Drive.
March 1, 2013: GES submitted a *January 2013 Sampling Data Transmittal Letter* to the MDE.
March 14, 2013: GES submitted an attachment to the January 2013 Sampling Data Transmittal Letter to the MDE.
April 19, 2013: The MDE sent a letter to Mr. and Mrs. Gray in regards to the additional investigation of 11712 Serene Court.
May 22, 2013: GES submitted a *Request to Revise the Monitoring Well Sampling Plan*.
May 29, 2013: GES submitted an *April 2013 Sampling Data Transmittal Letter* to the MDE.
June 17, 2013: GES submitted a *May 2013 Sampling Data Transmittal Letter* to the MDE.
October 18, 2013: GES received a response from the MDE regarding the *Request to Revise Sampling Plan*. The MDE denied the request to eliminate TPH-DRO from the monitoring well sampling program. The MDE has requested an additional supplemental sampling event during the fourth quarter of 2013 and a *Revised CAP* by January 31, 2014.
November 15, 2013: GES submitted an *October 2013 Sampling Data Transmittal Letter* to the MDE.



HISTORICAL ACTIVITY SUMMARY (Continued):

- December 5, 2013: A conference call with the MDE to discuss metals analytical results from select wells collected during the fourth quarter 2013.
- December 18, 2013: MW-18S and potable well GVP-FR815955 were resampled for metals, including chromium and lead, as requested by the MDE.
- January 31, 2014: GES submitted a *Revised CAP* to the MDE.
- February 18, 2014: Based on a correspondence with the MDE, well FR-73-1687 may have been misidentified, and the actual well identification is FR-73-7687.
- May 2014: The MDE issued a *Report of Results for Lead and Hexavalent Chromium Groundwater Investigation*.
- September 16, 2014: The property owner of 3829 Greenridge Drive requested (via telephone) GES to discontinue all future sampling of their property. A confirmation letter of this request was sent to the resident on September 26, 2014.
- October 3, 2014: An approval response to the January 31, 2014 *Revised Corrective Action Plan (CAP)* was received from the MDE. The routine monitoring and potable well sampling program was revised.
- October 7, 2014: CIFIC issued a notice of dispute to the MDE regarding the requirement for additional metals sampling as outlined in the MDE approval of the Revised CAP.
- October 27, 2014: GES submitted a *Monitoring Well MW-18S Replacement Work Plan*.
- November 7, 2014: The MDE responded to the dispute regarding metals sampling, reducing the number of wells required for metals sampling and requiring that 2 sampling events occur six months apart. The letter also acknowledged that the property owner of 3829 Greenridge Drive requested to discontinue sampling at the property.
- November 12, 2014: The MDE confirmed with the property owner of 3829 Greenridge Drive that they would no longer like to be sampled in the future.
- December 12, 2014: A response from the MDE to the October 27, 2014 *Monitoring Well MW-18S Replacement Work Plan* was received.
- December 12, 2014: The MDE issued a letter to the property owner of 3829 Greenridge Drive regarding the discontinuation of potable sampling.
- January 14, 2015: A *Request for MW-18S-R Report Submittal Deadline Extension* was submitted to the MDE.
- January 27, 2015: The replacement monitoring well for MW-18S was installed and identified as MW-18S-R.
- February 10, 2015: The MDE approved the extension request for the MW-18S-R report.
- February 13, 2015: The annual *Data Trends Analysis & Revised Monitoring Plan* was submitted with the *Fourth Quarter 2014 Monitoring Report*.
- March 17, 2015: The *MW-18S Replacement Well Installation Report* was submitted to the MDE.
- May 12, 2015: The *First Quarter 2015 Monitoring Report* was submitted to the MDE.
- June 8, 2015: GES follows up with the MDE on sampling reduction requests discussed in the *Fourth Quarter 2014 Monitoring Report with Data Trend Analysis and Revised Monitoring Plan – February 15, 2015*, the *MW-18S-Replacement Well Installation Report – March 17, 2015*, and the *First Quarter 2015 Monitoring Report – May, 15, 2015*. The MDE responds to GES follow-up correspondence indicating a response letter is being drafted.
- July 14, 2015: GES requests and is permitted from the MDE postponement of the third quarter sampling event until August 2015 while waiting on the MDE's letter responding to GES's sampling reduction requests.



HISTORICAL ACTIVITY SUMMARY (Continued):

July 30, 2015: GES received MDE's response letter *Site Status and Modifications to Sampling Program – July 29, 2015*. GES was permitted to discontinue sampling several monitoring and potable wells.

August 4, 2015: GES submitted correspondence *Response to Green Valley Citgo Letter – 07.29.15* regarding July 30, 2015 MDE letter requesting clarification.

August 11, 2015: GES received MDE response to Aug. 4, 2015 GES correspondence.

August 14, 2015: GES submitted *Second Quarter 2015 Monitoring Report* to the MDE, requesting MW-18S abandonment within the report.

October 6, 2015: GES notifies the MDE of Michael Pensario's, owner of 3996 Farm Lane, potable sampling inquiry, and GES requests the MDE to confirm with Mr. Pensario that his well was removed from GES' sampling program.

October 21, 2015: GES confirms receiving the MDE's notification (via phone call) of contact with Mr. Pensario, confirming his removal from GES's potable sampling program.

October 30, 2015: GES received the MDE's *Approval for Monitoring Well Abandonment* letter, dated October 27, 2015, approving abandonment of well MW-18S.

November 10, 2015: GES abandoned monitoring well MW-18S per the MDE's requirements stated in their *Approval for Monitoring Well Abandonment* letter.

November 13, 2015: GES submitted *Third Quarter 2015 Monitoring Report* to the MDE.

December 29, 2015: GES submitted *Completion of MW-18S Well Abandonment*, dated December 30, 2015, letter to the MDE.

February 12, 2016: GES submitted *Fourth Quarter 2015 Monitoring Report* to the MDE with *Annual Monitored Natural Attenuation (MNA) Evaluation*. GES also requested, in this correspondence, reductions of specific monitoring points and sampling frequency for select monitoring and potable wells for the case.

May 13, 2016: GES submitted *First Quarter 2016 Monitoring Report* to the MDE.

June 23, 2016: The MDE confirms the Case Status Meeting with GES scheduled for August 9, 2016.

August 9, 2016: GES met with the MDE at the MDE Headquarters in Baltimore to discuss future sampling reduction and monitoring well abandonment requests and required documents for the MDE to consider requests.

August 11, 2016: GES submitted *Second Quarter 2016 Monitoring Report* to the MDE.

September 9, 2016: The MDE sent a *Request for Potable Well Sampling – September 9, 2016* to 3991 Farm Lane.

October 21, 2016: GES submitted *Request for Monitoring Reduction* letter and the *Third Quarter 2016 Monitoring Report* to the MDE.

February 1, 2017: The MDE informed CIFC that the Department was working on a response to the *Request for Monitoring Reduction* letter from GES and to supplement the response, the MDE requested individual time-series data tables for specific private residential properties, including the EPA Method 524.2 analytical results. GES confirmed the MDE's request.

February 15, 2017: GES submitted the *Fourth Quarter 2016 Monitoring Report* and *2016 Annual Remedial Evaluation*.

April 25, 2017: GES submits individual time-series data tables with EPA Method 524.2 analytical results, including First Quarter 2017 results, to the MDE.

May 12, 2017: GES submitted the *First Quarter 2017 Monitoring Report* to the MDE.

August 11, 2017: GES submitted the *Second Quarter 2017 Monitoring Report* to the MDE.

October 17, 2017: GES received MDE's response letter *Site Status and Modifications to Sampling Program – October 17, 2017*.



HISTORICAL ACTIVITY SUMMARY (Continued):

November 14, 2017: GES submitted the *Third Quarter 2017 Monitoring Report* to the MDE.
December 20-21, 2017: GES abandoned MW-2, MW-6, MW-8, MW-10, MW-11, MW-12, MW-14S, MW-15D, MW16, IW-1S, IW-1D, IW-2S, IW-2D, IW-3S, IW-3D, IW-14, VE-1, SV-1 and SV-2 as approved in MDE correspondence dated October 17, 2017.
February 15, 2018: GES submitted the *Fourth Quarter 2017 Monitoring Report* to the MDE.
May 15, 2018: GES submitted the *First Quarter 2018 Monitoring Report* to the MDE.
May 24, 2018: GES received MDE's response letter *POET Treatment System Discontinuation Approval – May 24, 2018*.
May 25, 2018: GES submitted *Addendum - First Quarter 2018 Monitoring Report*
July 13, 2018: The POET systems from 3997 Farm Lane and 3923 Rosewood Road were removed.
August 15, 2018: GES submitted the *Second Quarter 2018 Monitoring Report* to the MDE.
September 17, 2018: GES received MDE's response letter *Site Status and Modifications to Sampling Program, September 11, 2018*.
November 14, 2018: GES submitted the *Third Quarter 2018 Monitoring Report* to the MDE.
February 15, 2019: GES submitted the *Fourth Quarter 2018 Monitoring Report* and *2018 Annual Remedial Evaluation Report* to the MDE under separate cover.
April 16, 2019: GES submitted the *Request for Release from POET System Maintenance Responsibility 3996 Farm Lane, Monrovia* to the MDE.
April 29, 2019: GES submitted the *First Quarter 2019 Monitoring Report* to the MDE.
May 1, 2019: GES received MDE's *Report of Observations* from site visit this day.
May 10, 2019: GES received MDE's response letter *Poet System Maintenance Responsibility* dated May 7, 2019.
August 5, 2019: GES submitted the *Second Quarter 2019 Monitoring Report* to the MDE.
November 1, 2019: GES submitted the *Third Quarter 2019 Monitoring Report* to the MDE.
December 10, 2019: GES received MDE's *Monitored Natural Attenuation Sampling Discontinuation Approval* date December 6, 2019.
February 13, 2020: GES submitted the *Fourth Quarter 2019 Monitoring Report* to the MDE.
April 30, 2020: GES submitted the *First Quarter 2020 Monitoring Report* to the MDE.
August 14, 2020: GES submitted the *Second Quarter 2020 Monitoring Report* to the MDE.
November 13, 2020: GES submitted the *Third Quarter 2020 Monitoring Report* to the MDE.
February 12, 2021: GES submitted the *Fourth Quarter 2020 Monitoring Report* and the *Annual Remedial Evaluation - 2020* report to the MDE.
May 14, 2021: GES submitted the *First Quarter 2021 Monitoring Report* to the MDE.
August 13, 2021: GES submitted the *Second Quarter 2021 Monitoring Report* to the MDE.
November 10, 2021: GES submitted the *Third Quarter 2021 Monitoring Report* to the MDE.
February 15, 2022: GES submitted the *Fourth Quarter 2021 Monitoring Report* and the *Annual Remedial Evaluation - 2020* report to the MDE.
February 18, 2022: GES submitted *Notification Regarding Cessation of GVP Treatment System Diagnostic Sampling and Maintenance* to Timbercrest LP and MDE.
May 15, 2022: GES submitted the *First Quarter 2022 Monitoring Report* to the MDE.
August 5, 2022: GES submitted the *Second Quarter 2022 Monitoring Report* to the MDE.
November 18, 2022: GES submitted the *Third Quarter 2022 Monitoring Report* to the MDE.
January 23, 2023: GES received MDE's *Site Status and Modifications to Sampling Program* dated January 18, 2023.
February 9, 2023: GES completed the First Quarter 2023 sampling event.
February 15, 2023: GES submitted the *Fourth Quarter 2022 Monitoring Report* to the MDE.
May 11, 2023: GES completed the Second Quarter 2023 sampling event.
May 15, 2023: GES submitted the *First Quarter 2023 Monitoring Report* to the MDE.



HISTORICAL ACTIVITY SUMMARY (Continued):

July 27-28, 2023	GES completed Third Quarter 2023 monitoring event.
August 15, 2023	GES submitted the <i>Second Quarter 2023 Monitoring Report</i> to the MDE.
November 15, 2023	GES submitted the <i>Third Quarter 2023 Monitoring Report</i> to the MDE.
Dec. 28-29, 2023	GES completed Fourth Quarter 2023 sampling event.
January 25, 2024	GES completed the First Quarter 2024 sampling event.
February 15, 2024	GES submitted the <i>Fourth Quarter 2023 Monitoring Report</i> and the <i>Annual Remedial Evaluation - 2023</i> to the MDE.
May 8-9, 2024	GES completed the Second Quarter 2024 sampling event.
May 15, 2024	GES submitted the <i>First Quarter 2024 Monitoring Report</i> to the MDE.
August 14, 2024	GES submitted the <i>Second Quarter 2024 Monitoring Report</i> to the MDE.
August 14-15, 2024	GES completed the Third Quarter 2024 sampling event.
Nov. 11-12, 2024	GES completed the Fourth Quarter 2024 sampling event.
Nov. 19, 2024	Carroll Fuels and GES attend an Administrative Consent Order status meeting at MDE Headquarters.

APPENDIX B

Monitoring Well Sampling Data

GROUNDWATER SAMPLING/LIQUID LEVEL DATA SHEET

CLIENT/PROJECT: **Carroll Fuel - Monrovia**

DATE: **11-11-24**

ADDRESS/SITE NUMBER: **11791 Fingerboard Road**

GES PERSONNEL: **Jeff Plummer**

WEATHER: **overcast 58°**

WELL	DTW	DTP	TDW	Well Dia.	P	B	S	Vol	DO	pH	Temp °C	ORP	NTU	Cond.	Time	Comments
MW-1	53.95	—														
MW-4	59.13	—														
5	65.63	—														
7	66.20	—														
13	64.92	—														
14D	58.07	—														
17	61.07	—														
18D	60.85	—														
185R	65.85	—														
TP-3	dry	—	14.35													
4	dry	—	14.02													
5	14.32	—	14.35													
6	13.56	—	13.60													
7	dry	—	12.16													
8	11.58	—	11.62													

KEY: DTW = depth to water P = pump in well S = sorbent sock in well
DTP = depth to product B = bailer in well Vol = volume bailed (gallons)

Additional Comments: _____

Groundwater Sampling Data Collection Sheet



Well ID:	MW-13		Site ID:	Carroll Fuel - Monrovia	Sample Date:	11-1-24
Initial DTW / Time:	4"	Sample Method (circle one) Low Flow Purge/sample Grab/No Pruge	Address:			
Well Diameter:			Sampling Tech(s):	Jeff Summers		
Total Well Depth:			Weather Conditions:	Partly cloudy 64°		
Water Column Length:			Air Temp =			
Pump Intake depth:						

Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1 s.u.	± 10 mV	± 10%**			
0915	64.92	Just prior to lowering any equipment into well								
0925	64.90	After lowering equipment into the well & before turning on the pump								
0925		Purge Start Time								
0930	65.04	17.95	1.023	8.55	5.07	205.8	—	300 ml/min		
0935	65.04	17.58	1.027	8.20	5.00	224.0	—			
0940	65.04	17.54	1.027	8.16	5.02	229.8	—			
0945	65.04	17.51	1.025	8.15	5.04	232.2	—			
0950	65.04	17.49	1.021	8.19	5.05	232.5	—			2 gallons
0955		Sample Collection Time								
		Purge Stop Time								

Data Collection: Purge and Sample / Grab Sampling										
Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Temp	Conductivity	D.O.	pH	ORP	Turbidity			
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1	± 10 mV	± 10%**			
		Just prior to lowering any equipment into well								
		Sample Collection Time								
Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.										

General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well:
0.16 gal./ft x _____ (linear feet of water) = gallons of water
- 4-inch diameter well:
0.65 gal./ft x _____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-5	Site ID:	Address: Carroll Fuel - Monrovia	Sample Date: 11-11-24
Initial DTW / Time:	Sampling Tech(s): Jeff Plummer		
Well Diameter: 4"	Sample Method (circle one) Low Flow		Weather Conditions: Sunny - clear 65°
Total Well Depth:	Purge/sample		Air Temp =
Water Column Length:	Grab/No Pruge		
Pump Intake depth:			

Data Collection: Low Flow

Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		____ Unit ± 3%	mg/L Unit ± 3%	mg/L Unit ± 10%*	(s.u. units) ± 0.1 s.u.	(mV units) ± 10 mV	(NTU units) ± 10%**			
		Just prior to lowering any equipment into well								
		After lowering equipment into the well & before turning on the pump								
		Purge Start Time								
1020	6548									
1025	6548	19.30	0.904	8.50	5.17	218.0	—	300ml/min		clear
1030	6602	18.73	0.830	8.65	5.07	220.6	—			
1035	6615	18.79	0.819	8.79	5.08	220.2	—			
1040	6629	19.06	0.814	8.80	5.08	219.4	—			
1045	6640	19.18	0.812	8.82	5.07	219.2	—	↓	2 gallons	↓
1050		Sample Collection Time								
		Purge Stop Time								

Data Collection: Purge and Sample / Grab Sampling

Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Temp	Conductivity	D.O.	pH	ORP	Turbidity			
		____ Unit ± 3%	____ Unit ± 3%	____ Unit ± 10%*	(s.u. units) ± 0.1	(mV units) ± 10 mV	(NTU units) ± 10%**			
		Just prior to lowering any equipment into well								
		Sample Collection Time								
		Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.								

General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well:
0.16 gal./ft x ____ (linear feet of water) = gallons of water
- 4-inch diameter well:
0.65 gal./ft x ____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-1		Site ID:		Address: Carroll Fuel-Monrovia		Sample Date: 11-11-24				
Initial DTW / Time:		Well Diameter: 2"		Sample Method (circle one): <input checked="" type="checkbox"/> Low Flow <input type="checkbox"/> Purge/sample <input type="checkbox"/> Grab/No Pruge		Sampling Tech(s): Jeff Plummer				
Total Well Depth:		Water Column Length:		Weather Conditions: SUNNY 66'		Air Temp =				
Pump Intake depth:										
Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		____ Unit ± 3%	mg/L/cm ± 3%	mg/L ± 10%*	(s.u. units) ± 0.1 s.u.	(mV units) ± 10 mV	(NTU units) ± 10%**			
1110	5345	Just prior to lowering any equipment into well								
1115	5360	After lowering equipment into the well & before turning on the pump								
1115	Purge Start Time									
1120	5440	18.80	0.885	7.17	5.79	187.9	—	300 ml/min		clear
1125	5477	17.66	0.911	5.24	5.59	187.6	—			
1130	5505	17.57	0.866	5.44	5.36	193.3	—			
1135	5527	17.51	0.821	5.71	5.16	203.0	—			
1140	5550	17.68	0.810	5.59	5.09	207.2	—			
1145	5570	17.97	0.801	5.69	5.04	210.2	—			
1150	5590	18.20	0.798	6.08	5.02	212.3	—		234 gallons	
1155	Sample Collection Time									
	Purge Stop Time									
Data Collection: Purge and Sample / Grab Sampling										
Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Temp ____ Unit ± 3%	Conductivity ____ Unit ± 3%	D.O. ____ Unit ± 10%*	pH (s.u. units) ± 0.1	ORP (mV units) ± 10 mV	Turbidity (NTU units) ± 10%**			
		Just prior to lowering any equipment into well								
		Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.								
		Sample Collection Time								
General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):										

Stabilization is achieved when three successive readings are within
 ± 3% for temperature,
 ± 0.1 for pH,
 ± 3% for specific conductivity,
 ± 10 for reduction-oxidation potential
 * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
 ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:
 2-inch diameter well:
 0.16 gal./ft x ____ (linear feet of water) = gallons of water
 4-inch diameter well:
 0.65 gal./ft x ____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-7		Site ID: Carroll Fuel-Monrovia		Sample Date: 11-1-24						
Initial DTW / Time:		Address:								
Well Diameter: 4"	Sample Method (circle one) Low Flow			Sampling Tech(s): Jeff Plummer						
Total Well Depth:				Weather Conditions: Sunny 68°						
Water Column Length:	Purge/sample			Air Temp =						
Pump Intake depth:	Grab/No Pruge									
Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		____ Unit ± 3%	mg/L/cm ± 3%	____ Unit ± 10%*	(s.u. units) ± 0.1 s.u.	(mV units) ± 10 mV	(NTU units) ± 10%**			
1220	66.20	Just prior to lowering any equipment into well								
1230	66.14	After lowering equipment into the well & before turning on the pump								
1230	Purge Start Time									
1235	66.25	17.24	0.841	6.89	5.28	208.4	—	300 ml/min - clear		
1240	66.25	16.79	0.871	5.58	5.30	203.3	—			
1245	66.28	16.65	0.876	5.17	5.32	200.7	—			
1250	66.30	16.61	0.875	5.01	5.33	199.3	—			
1255	66.32	16.61	0.875	4.94	5.33	198.6	—	↓ 2 gallons ↓		
1300	Sample Collection Time									
	Purge Stop Time									
Data Collection: Purge and Sample / Grab Sampling										
Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Temp ____ Unit ± 3%	Conductivity ____ Unit ± 3%	D.O. ____ Unit ± 10%*	pH (s.u. units) ± 0.1	ORP (mV units) ± 10 mV	Turbidity (NTU units) ± 10%**			
		Just prior to lowering any equipment into well								
		Sample Collection Time								
Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.										
General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):										

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well:
0.16 gal./ft x ____ (linear feet of water) = gallons of water
- 4-inch diameter well:
0.65 gal./ft x ____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-77		Site ID:		Address: Carroll Fuel Monrovia		Sample Date: 1/12/24				
Initial DTW / Time:		Well Diameter: 4"		Sample Method (circle one) <input checked="" type="radio"/> Low Flow		Sampling Tech(s): J. Plummer				
Total Well Depth:		Purge/sample		Weather Conditions: Partly Cloudy Windy 54'		Air Temp =				
Water Column Length:		Grab/No Pruge		Pump Intake depth:						
Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1 s.u.	± 10 mV	± 10%**			
0915	6107	Just prior to lowering any equipment into well								
0925	6107	After lowering equipment into the well & before turning on the pump								
0925	Purge Start Time									
0930	6110	16.01	0.986	6.25	5.56	137.2	—	300 ml/min	clear	
0935	6110	15.61	0.984	5.85	5.53	138.0	—			
0940	6110	15.63	0.983	5.69	5.53	139.1	—			
0945	6110	15.64	0.986	5.56	5.53	140.3	—			
0950	6110	15.63	0.987	5.53	5.53	141.0	—	↓	2 gallons	↓
0955	Sample Collection Time									
	Purge Stop Time									
Data Collection: Purge and Sample / Grab Sampling										
Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method of Sampling
		Temp	Conductivity	D.O.	pH	ORP	Turbidity			
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1	± 10 mV	± 10%**			
		Just prior to lowering any equipment into well								
		Sample Collection Time								
Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.										
General Comment & Type of Equipment Used (pumps/YSI meter/ect./calibration info):										

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well:
0.16 gal./ft x _____ (linear feet of water) = gallons of water
- 4-inch diameter well:
0.65 gal./ft x _____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-14D		Site ID: Carroll Fuel		Sample Date: 11-12-24						
Initial DTW / Time:		Address: Monrovia								
Well Diameter: 4"	Sample Method (cycle one) <input checked="" type="checkbox"/> Low Flow <input type="checkbox"/> Purge/sample <input type="checkbox"/> Grab/No Pruge			Sampling Tech(s): J. Plummer						
Total Well Depth:				Weather Conditions: Partly cloudy 56°						
Water Column Length:				Air Temp =						
Pump Intake depth:										
Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		____ Unit	____ Unit	____ Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1 s.u.	± 10 mV	± 10%**			
1015	58.07	Just prior to lowering any equipment into well								
1025	56.90	After lowering equipment into the well & before turning on the pump								
1025	Purge Start Time									
1030	57.80	16.13	0.329	3.91	7.19	-70.3	—	300ml/min clear ↓ 274 gallons		
1035	58.15	16.31	0.303	1.74	7.58	-125.9	—			
1040	58.50	16.30	0.301	1.28	7.78	-144.8	—			
1045	58.80	16.54	0.301	1.03	7.86	-156.1	—			
1050	59.15	16.60	0.301	0.94	7.89	-162.9	—			
1055	59.50	16.76	0.301	0.85	7.91	-165.9	—			
1100	59.85	16.78	0.301	0.78	7.92	-167.7	—			
1105	Sample Collection Time									
	Purge Stop Time									
Data Collection: Purge and Sample / Grab Sampling										
If Applicable										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Method Of Sampling
		____ Unit	____ Unit	____ Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1	± 10 mV	± 10%**			
		Just prior to lowering any equipment into well								
	Sample Collection Time			Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.						
General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):										

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

2-inch diameter well:
 0.16 gal./ft x ____ (linear feet of water) = gallons of water

4-inch diameter well:
 0.65 gal./ft x ____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID: MW-18D		Site ID: Carroll Fuel - Monrovia		Sample Date: 6-12-24						
Initial DTW / Time:		Address:								
Well Diameter: 2"	Sample Method (circle one) Low Flow		Sampling Tech(s): J. Plummer							
Total Well Depth:	Purge/sample		Weather Conditions: PHY cloudy 58°							
Water Column Length:	Grab/No Pruge		Air Temp =							
Pump Intake depth:										
Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1 s.u.	± 10 mV	± 10%**			
1125	6085	Just prior to lowering any equipment into well								
1135	5852	After lowering equipment into the well & before turning on the pump								
1135	Purge Start Time									
1140	6130	18.73	2.200	3.70	7.62	-31.9	—	300ml/min	clear	
1145	6345	17.93	2.259	1.53	7.53	-34.6	—			
1150	6520	17.64	2.265	1.04	7.51	-35.2	—			
1155	6720	17.80	2.269	0.80	7.50	-35.6	—			
1200	064 6360	17.91	2.272	0.63	7.50	-35.4	—			
1205	↓	18.10	2.270	0.59	7.50	-34.2	—			
1210	↓	18.30	2.265	0.54	7.50	-35.2	—			
1215	↓	18.42	2.264	0.51	7.50	-35.6	—	↓	3 gallons	↓
1220	Sample Collection Time									
	Purge Stop Time									
Data Collection: Purge and Sample / Grab Sampling										
If Applicable										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1	± 10 mV	± 10%**			
		Just prior to lowering any equipment into well								
		Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.								
		Sample Collection Time								
General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):										

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well:
0.16 gal./ft x _____ (linear feet of water) = gallons of water
- 4-inch diameter well:
0.65 gal./ft x _____ (linear feet of water) = gallons of water

Groundwater Sampling Data Collection Sheet



Well ID:	MMV-185-R	Site ID:	Carroll Fuel -	Sample Date:	11-12-29
Initial DTW / Time:		Address:	Monrovia		
Well Diameter:	4"	Sample Method (circle one)	J. Plummer		
Total Well Depth:		<u>Low Flow</u>	Weather Conditions:	Sunny 58°	
Water Column Length:		Purge/sample	Air Temp =		
Pump Intake depth:		Grab/No Purge			

Data Collection: Low Flow										
Time	DTW	Temp	Conductivity	D.O.	pH	ORP	Turbidity	Flow Rate	Cumulative Purge Volume	Comment
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1 s.u.	± 10 mV	± 10%**			
1225	65:05	Just prior to lowering any equipment into well								
1236	65:30	After lowering equipment into the well & before turning on the pump								
1236	Purge Start Time									
1240	66:05	19.32	1.810	3.22	5.76	66.9	—	300ml/min		clear
1243	66:20	18.12	1.824	0.90	5.62	82.0	—			
1250	66:30	18.00	1.822	0.70	5.61	89.4	—			
1255	66:40	17.91	1.812	0.69	5.61	96.5	—			
1300	66:50	18.00	1.800	0.71	5.60	99.8	—			
1305	66:60	17.93	1.803	0.73	5.60	101.4	—	↓	2 1/4 gallons ↓	
1310	Sample Collection Time									
	Purge Stop Time									

Data Collection: Purge and Sample / Grab Sampling										
Time	DTW	If Applicable						Flow Rate	Cumulative Purge Volume	Method Of Sampling
		Temp	Conductivity	D.O.	pH	ORP	Turbidity			
		Unit	Unit	Unit	(s.u. units)	(mV units)	(NTU units)			
		± 3%	± 3%	± 10%*	± 0.1	± 10 mV	± 10%**			
		Just prior to lowering any equipment into well								
		Note: Unless otherwise stated, field parameters collected during purge and sample or grab sampling were collected from the well with a sonde before purging or sampling.								
		Sample Collection Time								

General Comment & Type of Equipment Used (pumps/YSI meter/ect./caibration info):

Stabilization is achieved when three successive readings are within

- ± 3% for temperature,
- ± 0.1 for pH,
- ± 3% for specific conductivity,
- ± 10 for reduction-oxidation potential
- * ± 10% for DO-values that are greater 0.5 mg/L, if three values are <0.5 mg/L, consider the values stabilized.
- ** ± 10% for Turbidity for values greater than 10 NTU; if three values are <10 NTU, consider the values stabilized.

Purge Volumes:

- 2-inch diameter well: 0.16 gal./ft x _____ (linear feet of water) = gallons of water
- 4-inch diameter well: 0.65 gal./ft x _____ (linear feet of water) = gallons of water

Client/Site: Carroll Monrovia

NAME: Jeff Plummer
 DATE: 11-12-24 - 11-12-24
 COMPANY: GES

Potable Sampling Log

Address	Who granted access / Access letter Signed	Flush Location	Flush initiation time	Flush length (mins)	EFF (time)	MID (time)	INF / Non POET (time)	Totalizer Reading (gals)	Non POET Sample Location / General Notes
3994 Farm	Mr. Jackson	Utility sink	0830	10	0840	0845	0850	690075	Confirmed POET online
GVP Inf	Carroll Fuel	Sample port	1400	10	-	-	1410	891043	Confirmed POET online.
	11-12-24								
3992 Farm	Mr. Podliska	Utility sink	1400	10	1410	1415	1420	115914	Confirmed POET online.
FINAL CHECK LIST:	Access Letters: [] DUPLICATE: []		TRIP BLANK: [] TOTALIZER READINGS: []						NOTES:





INSTRUMENT CALIBRATION REPORT

Pine Environmental Services LLC

797 Cromwell Park Dr.
Suite Q
Glen Burnie, MD 21061


Pine Environmental Services, Inc.

Instrument ID 50235
Description YSI 600 XL
Calibrated 11/5/2024 4:19:16PM

Manufacturer YSI	State Certified
Model Number 600 XL	Status Pass
Serial Number/ Lot Number 06f2353	Temp °C 22
Location Maryland	Humidity % 48
Department	

Calibration Specifications

<u>Nom In Val / In Val</u>	<u>In Type</u>	<u>Out Val</u>	<u>Out Type</u>	<u>Fnd As</u>	<u>Lft As</u>	<u>Dev%</u>	<u>Pass/Fail</u>
Group # 1 Group Name PH Stated Accy Pct of Reading				Range Acc % 0.0000 Reading Acc % 3.0000 Plus/Minus 0.00			
7.00 / 7.00	PH	7.00	PH	7.29	7.00	0.00%	Pass
4.00 / 4.00	PH	4.00	PH	4.05	4.00	0.00%	Pass
10.00 / 10.00	PH	10.00	PH	9.94	10.00	0.00%	Pass
Group # 2 Group Name Conductivity Stated Accy Pct of Reading				Range Acc % 0.0000 Reading Acc % 3.0000 Plus/Minus 0.000			
1.413 / 1.413	ms/cm	1.413	ms/cm	1.458	1.413	0.00%	Pass
Group # 3 Group Name Redox (ORP) Stated Accy Pct of Reading				Range Acc % 0.0000 Reading Acc % 3.0000 Plus/Minus 0.00			
240.00 / 240.00	mv	240.00	mv	207.00	240.00	0.00%	Pass
Group # 4 Group Name Dissolved Oxygen Span Stated Accy Pct of Reading				Range Acc % 0.0000 Reading Acc % 3.0000 Plus/Minus 0.00			
100.00 / 100.00	%	100.00	%	105.60	100.00	0.00%	Pass
Group # 5 Group Name Dissolved Oxygen Zero Test Performed: N/A				As Found Result: As Left Result:			



INSTRUMENT CALIBRATION REPORT

Pine Environmental Services LLC

797 Cromwell Park Dr.
Suite Q
Glen Burnie, MD 21061

Pine Environmental Services, Inc.

Instrument ID 50235
Description YSI 600 XL
Calibrated 11/5/2024 4:19:16PM

<u>Test Instruments Used During the Calibration</u>					<u>(As Of Cal Entry Date)</u>	
<u>Test Standard ID</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Model Number</u>	<u>Serial Number / Lot Number</u>	<u>Last Cal Date/ Opened Date</u>	<u>Next Cal Date / Expiration Date</u>
MD COND 1.413 3GH1514	CA 1.413 COND (LOT# 4GB0749)	GFS	31986	1.413 COND (LOT# 4GB0749)		2/5/2025
MD ORP 240 4GE1370	MD ORP 240 4GE1370	AquaPhoenix Scientific	32001	4GE1370	6/24/2024	2/28/2025
MD PH10 4GB0253.	MD PH10 4GB0253	AquaPhoenix Scientific	32034	4GB0253		
MD PH4 3GB0637	MD PH4 3GI0465	AquaPhoenix Scientific	32017	3GB0637		9/30/2025
MD PH7 4GH0553	PH7 Solution	AquaPhoenix Scientific		4GH0553		8/31/2026

Notes about this calibration

Calibration Result Calibration Successful
Who Calibrated Chuck Wallace

All instruments are calibrated by Pine Environmental Services LLC according to the manufacturer's specifications, but it is the customer's responsibility to calibrate and maintain this unit in accordance with the manufacturer's specifications and/or the customer's own specific needs.

Notify Pine Environmental Services LLC of any defect within 24 hours of receipt of equipment
Please call 800-301-9663 for Technical Assistance

APPENDIX C

Laboratory Reports and Chain of Custody
Documentation (See Files on eCopy)

Eurofins Lancaster
Laboratories ID Numbers:

410-196696-1

410-196699-1



ANALYTICAL REPORT

PREPARED FOR

Attn: Peter Reichardt
Groundwater & Environmental Services Inc
1350 Blair Drive
Suite H-2
Odenton, Maryland 21113

Generated 11/18/2024 7:42:47 PM

JOB DESCRIPTION

Carroll Monrovia

JOB NUMBER


410-196696-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
11/18/2024 7:42:47 PM

Authorized for release by
Dana Kauffman, Project Manager
Dana.Kauffman@et.eurofinsus.com
Designee for
Amek Carter, Project Manager
Loran.Carter@et.eurofinsus.com
(717)556-7252

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.






Table of Contents

Cover Page	1
Table of Contents	4
Definitions/Glossary	5
Case Narrative	6
Detection Summary	7
Client Sample Results	8
Surrogate Summary	16
QC Sample Results	17
QC Association Summary	21
Lab Chronicle	22
Certification Summary	23
Method Summary	24
Sample Summary	25
Chain of Custody	26
Receipt Checklists	27

Definitions/Glossary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
cn	Refer to Case Narrative for further detail
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: Groundwater & Environmental Services Inc
Project: Carroll Monrovia

Job ID: 410-196696-1

Job ID: 410-196696-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-196696-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 11/13/2024 4:30 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.3°C.

Receipt Exceptions

A trip blank was not submitted for analysis with this sample shipment; and was not listed on the Chain of Custody (COC).

GC/MS VOA

Method 524.2_Preserved: Volatile compounds have been detected above the RL for the following samples: 3994-FARM-INF (410-196696-3) and 3992-FARM-INF (410-196696-7). Since a field reagent blank/trip blank was not submitted, any potential contamination from the sampling/transport process cannot be assessed.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3994-FARM-EFF

Lab Sample ID: 410-196696-1

No Detections.

Client Sample ID: 3994-FARM-MID2

Lab Sample ID: 410-196696-2

No Detections.

Client Sample ID: 3994-FARM-INF

Lab Sample ID: 410-196696-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	1.8	cn	0.50	0.10	ug/L	1		524.2	Total/NA

Client Sample ID: GVP-INF

Lab Sample ID: 410-196696-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloroform	0.15	J	0.50	0.10	ug/L	1		524.2	Total/NA
Methyl tertiary butyl ether	0.25	J	0.50	0.10	ug/L	1		524.2	Total/NA

Client Sample ID: 3992-FARM-EFF

Lab Sample ID: 410-196696-5

No Detections.

Client Sample ID: 3992-FARM-MID2

Lab Sample ID: 410-196696-6

No Detections.

Client Sample ID: 3992-FARM-INF

Lab Sample ID: 410-196696-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
t-Amyl methyl ether	0.17	J cn	0.50	0.10	ug/L	1		524.2	Total/NA
Methyl tertiary butyl ether	6.9	cn	0.50	0.10	ug/L	1		524.2	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3994-FARM-EFF

Lab Sample ID: 410-196696-1

Date Collected: 11/11/24 08:40

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
t-Butyl alcohol	ND		25	2.5	ug/L			11/15/24 21:48	1
Carbon tetrachloride	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 21:48	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Methyl tertiary butyl ether	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 21:48	1
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 21:48	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 21:48	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 21:48	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 21:48	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 21:48	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	98		80 - 120		11/15/24 21:48	1
1,2-Dichlorobenzene-d4 (Surr)	100		80 - 120		11/15/24 21:48	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3994-FARM-MID2

Lab Sample ID: 410-196696-2

Date Collected: 11/11/24 08:45

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
t-Butyl alcohol	ND		25	2.5	ug/L			11/15/24 22:11	1
Carbon tetrachloride	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 22:11	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Methyl tertiary butyl ether	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 22:11	1
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 22:11	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 22:11	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:11	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 22:11	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 22:11	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	97		80 - 120		11/15/24 22:11	1
1,2-Dichlorobenzene-d4 (Surr)	98		80 - 120		11/15/24 22:11	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3994-FARM-INF

Lab Sample ID: 410-196696-3

Date Collected: 11/11/24 08:50

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Benzene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
t-Butyl alcohol	ND	cn	25	2.5	ug/L			11/15/24 22:35	1
Carbon tetrachloride	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Chlorobenzene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,2-Dichlorobenzene	ND	cn	0.50	0.20	ug/L			11/15/24 22:35	1
1,3-Dichlorobenzene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,2-Dichloroethane	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,1-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
cis-1,2-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
trans-1,2-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,2-Dichloropropane	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Ethyl t-butyl ether	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Ethylbenzene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
di-Isopropyl ether	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Methyl tertiary butyl ether	1.8	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Methylene Chloride	ND	cn	0.50	0.20	ug/L			11/15/24 22:35	1
Naphthalene	ND	cn	0.50	0.20	ug/L			11/15/24 22:35	1
Styrene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Tetrachloroethene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Toluene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,2,4-Trichlorobenzene	ND	cn	0.50	0.20	ug/L			11/15/24 22:35	1
1,1,1-Trichloroethane	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
1,1,2-Trichloroethane	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Trichloroethene	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Vinyl chloride	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1
Xylenes, Total	ND	cn	0.50	0.10	ug/L			11/15/24 22:35	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	97	cn	80 - 120		11/15/24 22:35	1
1,2-Dichlorobenzene-d4 (Surr)	99	cn	80 - 120		11/15/24 22:35	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: GVP-INF

Lab Sample ID: 410-196696-4

Date Collected: 11/11/24 14:10

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,2,3-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
1,2,3-Trichloropropane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
1,2,4-Trimethylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,2-Dibromo-3-Chloropropane	ND		1.0	0.40	ug/L			11/15/24 22:58	1
1,2-Dibromoethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,3,5-Trimethylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,3-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
1,4-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
2,2-Dichloropropane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
2-Chlorotoluene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
4-Chlorotoluene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Acrylonitrile	ND		10	2.0	ug/L			11/15/24 22:58	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Bromobenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Bromochloromethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Bromodichloromethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Bromoform	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Bromomethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Carbon disulfide	ND		2.0	0.40	ug/L			11/15/24 22:58	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Chloroethane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Chloroform	0.15	J	0.50	0.10	ug/L			11/15/24 22:58	1
Chloromethane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Dibromochloromethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Dibromomethane	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Dichlorodifluoromethane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Hexachlorobutadiene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Isopropylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Methyl tertiary butyl ether	0.25	J	0.50	0.10	ug/L			11/15/24 22:58	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
n-Butylbenzene	ND		0.50	0.20	ug/L			11/15/24 22:58	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: GVP-INF

Lab Sample ID: 410-196696-4

Date Collected: 11/11/24 14:10

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
N-Propylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
p-Isopropyltoluene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
sec-Butylbenzene	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 22:58	1
t-Butyl alcohol	ND		25	5.0	ug/L			11/15/24 22:58	1
tert-Butylbenzene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
trans-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/15/24 22:58	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Trichlorofluoromethane	ND		0.50	0.20	ug/L			11/15/24 22:58	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 22:58	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 22:58	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichlorobenzene-d4 (Surr)	98		80 - 120		11/15/24 22:58	1
4-Bromofluorobenzene (Surr)	96		80 - 120		11/15/24 22:58	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3992-FARM-EFF

Lab Sample ID: 410-196696-5

Date Collected: 11/12/24 14:10

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
t-Butyl alcohol	ND		25	2.5	ug/L			11/15/24 23:21	1
Carbon tetrachloride	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 23:21	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Methyl tertiary butyl ether	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 23:21	1
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 23:21	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 23:21	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:21	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 23:21	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 23:21	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		80 - 120		11/15/24 23:21	1
1,2-Dichlorobenzene-d4 (Surr)	99		80 - 120		11/15/24 23:21	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3992-FARM-MID2

Lab Sample ID: 410-196696-6

Date Collected: 11/12/24 14:15

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
t-Butyl alcohol	ND		25	2.5	ug/L			11/15/24 23:44	1
Carbon tetrachloride	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 23:44	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Methyl tertiary butyl ether	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 23:44	1
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 23:44	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 23:44	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:44	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 23:44	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 23:44	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	99		80 - 120		11/15/24 23:44	1
1,2-Dichlorobenzene-d4 (Surr)	100		80 - 120		11/15/24 23:44	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3992-FARM-INF

Lab Sample ID: 410-196696-7

Date Collected: 11/12/24 14:20

Matrix: Water

Date Received: 11/13/24 16:30

Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
t-Amyl methyl ether	0.17	J cn	0.50	0.10	ug/L			11/16/24 00:08	1
Benzene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
t-Butyl alcohol	ND	cn	25	2.5	ug/L			11/16/24 00:08	1
Carbon tetrachloride	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Chlorobenzene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,2-Dichlorobenzene	ND	cn	0.50	0.20	ug/L			11/16/24 00:08	1
1,3-Dichlorobenzene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,2-Dichloroethane	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,1-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
cis-1,2-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
trans-1,2-Dichloroethene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,2-Dichloropropane	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Ethyl t-butyl ether	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Ethylbenzene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
di-Isopropyl ether	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Methyl tertiary butyl ether	6.9	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Methylene Chloride	ND	cn	0.50	0.20	ug/L			11/16/24 00:08	1
Naphthalene	ND	cn	0.50	0.20	ug/L			11/16/24 00:08	1
Styrene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Tetrachloroethene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Toluene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,2,4-Trichlorobenzene	ND	cn	0.50	0.20	ug/L			11/16/24 00:08	1
1,1,1-Trichloroethane	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
1,1,2-Trichloroethane	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Trichloroethene	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Vinyl chloride	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Xylenes, Total	ND	cn	0.50	0.10	ug/L			11/16/24 00:08	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
4-Bromofluorobenzene (Surr)	98	cn	80 - 120					11/16/24 00:08	1
1,2-Dichlorobenzene-d4 (Surr)	101	cn	80 - 120					11/16/24 00:08	1

Surrogate Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Matrix: Water

Prep Type: Total/NA

Percent Surrogate Recovery (Acceptance Limits)

Lab Sample ID	Client Sample ID	BFB	DCZ
		(80-120)	(80-120)
410-196696-1	3994-FARM-EFF	98	100
410-196696-2	3994-FARM-MID2	97	98
410-196696-3	3994-FARM-INF	97 cn	99 cn
410-196696-4	GVP-INF	96	98
410-196696-5	3992-FARM-EFF	99	99
410-196696-6	3992-FARM-MID2	99	100
410-196696-7	3992-FARM-INF	98 cn	101 cn
LCS 410-575662/4	Lab Control Sample	102	105
MB 410-575662/6	Method Blank	100	101

Surrogate Legend

BFB = 4-Bromofluorobenzene (Surr)

DCZ = 1,2-Dichlorobenzene-d4 (Surr)

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method: 524.2 - Volatile Organic Compounds (GC/MS)

Lab Sample ID: MB 410-575662/6
Matrix: Water
Analysis Batch: 575662

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Carbon tetrachloride	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2,3-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
1,2,3-Trichloropropane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2,4-Trimethylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2-Dibromo-3-Chloropropane	ND		1.0	0.40	ug/L			11/15/24 15:33	1
1,2-Dibromoethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2-Dichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
1,2-Dichloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,3,5-Trimethylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,3-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,3-Dichloropropane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,4-Dichlorobenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
2,2-Dichloropropane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
2-Chlorotoluene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
1,2,4-Trichlorobenzene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
4-Chlorotoluene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
1,1,1-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Acrylonitrile	ND		10	2.0	ug/L			11/15/24 15:33	1
1,1,2-Trichloroethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Benzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Bromobenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Bromochloromethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Bromodichloromethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Bromoform	ND		0.50	0.20	ug/L			11/15/24 15:33	1
Bromomethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Carbon disulfide	ND		2.0	0.40	ug/L			11/15/24 15:33	1
Chlorobenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Chloroethane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
Chloroform	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Chloromethane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
cis-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Dibromochloromethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Dibromomethane	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Dichlorodifluoromethane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Ethyl t-butyl ether	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Ethylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Hexachlorobutadiene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
Isopropylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Methyl tertiary butyl ether	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/15/24 15:33	1

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: MB 410-575662/6
Matrix: Water
Analysis Batch: 575662

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Naphthalene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
n-Butylbenzene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
p-Isopropyltoluene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
sec-Butylbenzene	ND		0.50	0.20	ug/L			11/15/24 15:33	1
Styrene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
t-Amyl methyl ether	ND		0.50	0.10	ug/L			11/15/24 15:33	1
t-Butyl alcohol	ND		25	2.5	ug/L			11/15/24 15:33	1
tert-Butylbenzene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Tetrachloroethene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Toluene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
trans-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/15/24 15:33	1
Trichloroethene	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Trichlorofluoromethane	ND		0.50	0.20	ug/L			11/15/24 15:33	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/15/24 15:33	1
Xylenes, Total	ND		0.50	0.10	ug/L			11/15/24 15:33	1

Surrogate	MB %Recovery	MB Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichlorobenzene-d4 (Surr)	101		80 - 120		11/15/24 15:33	1
4-Bromofluorobenzene (Surr)	100		80 - 120		11/15/24 15:33	1

Lab Sample ID: LCS 410-575662/4
Matrix: Water
Analysis Batch: 575662

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,1,1,2-Tetrachloroethane	5.00	5.44		ug/L		109	70 - 130
1,1,1,2,2-Tetrachloroethane	5.00	5.12		ug/L		102	70 - 130
Carbon tetrachloride	5.00	5.56		ug/L		111	70 - 130
1,1-Dichloroethane	5.00	5.05		ug/L		101	70 - 130
1,1-Dichloropropene	5.00	4.74		ug/L		95	70 - 130
1,2,3-Trichlorobenzene	5.00	4.92		ug/L		98	70 - 130
1,2,3-Trichloropropane	5.00	4.78		ug/L		96	70 - 130
1,1-Dichloroethene	5.00	5.20		ug/L		104	70 - 130
1,2,4-Trimethylbenzene	5.00	4.94		ug/L		99	70 - 130
1,2-Dibromo-3-Chloropropane	5.00	5.08		ug/L		102	70 - 130
1,2-Dibromoethane	5.00	5.03		ug/L		101	70 - 130
1,2-Dichlorobenzene	5.00	5.04		ug/L		101	70 - 130
1,2-Dichloroethane	5.00	5.07		ug/L		101	70 - 130
1,2-Dichloropropane	5.00	4.97		ug/L		99	70 - 130
1,3,5-Trimethylbenzene	5.00	4.99		ug/L		100	70 - 130
1,3-Dichlorobenzene	5.00	4.96		ug/L		99	70 - 130
1,3-Dichloropropane	5.00	4.86		ug/L		97	70 - 130
1,4-Dichlorobenzene	5.00	5.03		ug/L		101	70 - 130
2,2-Dichloropropane	5.00	5.00		ug/L		100	70 - 130
2-Chlorotoluene	5.00	4.91		ug/L		98	70 - 130

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 410-575662/4

Matrix: Water

Analysis Batch: 575662

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
1,2,4-Trichlorobenzene	5.00	4.95		ug/L		99	70 - 130
4-Chlorotoluene	5.00	4.89		ug/L		98	70 - 130
1,1,1-Trichloroethane	5.00	5.21		ug/L		104	70 - 130
Acrylonitrile	113	115		ug/L		103	70 - 130
1,1,2-Trichloroethane	5.00	5.03		ug/L		101	70 - 130
Benzene	5.00	4.82		ug/L		96	70 - 130
Bromobenzene	5.00	4.96		ug/L		99	70 - 130
Bromochloromethane	5.00	4.82		ug/L		96	70 - 130
Bromodichloromethane	5.00	5.29		ug/L		106	70 - 130
Bromoform	5.00	5.08		ug/L		102	70 - 130
Bromomethane	2.00	2.12		ug/L		106	70 - 130
Carbon disulfide	5.00	4.63		ug/L		93	70 - 130
Chlorobenzene	5.00	4.97		ug/L		99	70 - 130
Chloroethane	2.00	2.20		ug/L		110	70 - 130
Chloroform	5.00	5.02		ug/L		100	70 - 130
Chloromethane	2.00	2.25		ug/L		113	70 - 130
cis-1,2-Dichloroethene	5.00	4.86		ug/L		97	70 - 130
cis-1,3-Dichloropropene	5.00	4.86		ug/L		97	70 - 130
Dibromochloromethane	5.00	5.36		ug/L		107	70 - 130
Dibromomethane	5.00	4.97		ug/L		99	70 - 130
Dichlorodifluoromethane	2.00	2.31		ug/L		115	70 - 130
di-Isopropyl ether	5.00	4.50		ug/L		90	70 - 130
Ethyl t-butyl ether	5.00	4.52		ug/L		90	70 - 130
Ethylbenzene	5.00	4.87		ug/L		97	70 - 130
Hexachlorobutadiene	5.00	5.13		ug/L		103	70 - 130
Isopropylbenzene	5.00	5.54		ug/L		111	70 - 130
Methyl tertiary butyl ether	5.00	4.67		ug/L		93	70 - 130
Methylene Chloride	5.00	5.01		ug/L		100	70 - 130
Naphthalene	5.00	4.92		ug/L		98	70 - 130
n-Butylbenzene	5.00	4.97		ug/L		99	70 - 130
N-Propylbenzene	5.00	5.04		ug/L		101	70 - 130
p-Isopropyltoluene	5.00	4.87		ug/L		97	70 - 130
sec-Butylbenzene	5.00	5.00		ug/L		100	70 - 130
Styrene	5.00	5.03		ug/L		101	70 - 130
t-Amyl methyl ether	5.00	4.52		ug/L		90	70 - 130
t-Butyl alcohol	50.0	46.7		ug/L		93	70 - 130
tert-Butylbenzene	5.00	5.02		ug/L		100	70 - 130
Tetrachloroethene	5.00	4.90		ug/L		98	70 - 130
Toluene	5.00	4.88		ug/L		98	70 - 130
trans-1,2-Dichloroethene	5.00	4.99		ug/L		100	70 - 130
trans-1,3-Dichloropropene	5.00	5.04		ug/L		101	70 - 130
trans-1,4-Dichloro-2-butene	25.0	25.4		ug/L		102	70 - 130
Trichloroethene	5.00	4.81		ug/L		96	70 - 130
Trichlorofluoromethane	2.00	2.17		ug/L		109	70 - 130
Vinyl chloride	2.00	2.20		ug/L		110	70 - 130
Xylenes, Total	15.0	14.7		ug/L		98	70 - 130

QC Sample Results

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)

Lab Sample ID: LCS 410-575662/4

Matrix: Water

Analysis Batch: 575662

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Surrogate	LCS		Limits
	%Recovery	Qualifier	
1,2-Dichlorobenzene-d4 (Surr)	105		80 - 120
4-Bromofluorobenzene (Surr)	102		80 - 120

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

QC Association Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

GC/MS VOA

Analysis Batch: 575662

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-196696-1	3994-FARM-EFF	Total/NA	Water	524.2	
410-196696-2	3994-FARM-MID2	Total/NA	Water	524.2	
410-196696-3	3994-FARM-INF	Total/NA	Water	524.2	
410-196696-4	GVP-INF	Total/NA	Water	524.2	
410-196696-5	3992-FARM-EFF	Total/NA	Water	524.2	
410-196696-6	3992-FARM-MID2	Total/NA	Water	524.2	
410-196696-7	3992-FARM-INF	Total/NA	Water	524.2	
MB 410-575662/6	Method Blank	Total/NA	Water	524.2	
LCS 410-575662/4	Lab Control Sample	Total/NA	Water	524.2	

Lab Chronicle

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Client Sample ID: 3994-FARM-EFF

Lab Sample ID: 410-196696-1

Date Collected: 11/11/24 08:40

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 21:48

Client Sample ID: 3994-FARM-MID2

Lab Sample ID: 410-196696-2

Date Collected: 11/11/24 08:45

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 22:11

Client Sample ID: 3994-FARM-INF

Lab Sample ID: 410-196696-3

Date Collected: 11/11/24 08:50

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 22:35

Client Sample ID: GVP-INF

Lab Sample ID: 410-196696-4

Date Collected: 11/11/24 14:10

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 22:58

Client Sample ID: 3992-FARM-EFF

Lab Sample ID: 410-196696-5

Date Collected: 11/12/24 14:10

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 23:21

Client Sample ID: 3992-FARM-MID2

Lab Sample ID: 410-196696-6

Date Collected: 11/12/24 14:15

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/15/24 23:44

Client Sample ID: 3992-FARM-INF

Lab Sample ID: 410-196696-7

Date Collected: 11/12/24 14:20

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	524.2		1	575662	UJML	ELLE	11/16/24 00:08

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Eurofins Lancaster Laboratories Environment Testing, LLC

Accreditation/Certification Summary

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Maryland	State	100	06-30-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
524.2		Water	1,1,1,2-Tetrachloroethane
524.2		Water	1,1,2,2-Tetrachloroethane
524.2		Water	1,1-Dichloroethane
524.2		Water	1,1-Dichloropropene
524.2		Water	1,2,3-Trichlorobenzene
524.2		Water	1,2,3-Trichloropropane
524.2		Water	1,2,4-Trimethylbenzene
524.2		Water	1,2-Dibromo-3-Chloropropane
524.2		Water	1,2-Dibromoethane
524.2		Water	1,3,5-Trimethylbenzene
524.2		Water	1,3-Dichlorobenzene
524.2		Water	1,3-Dichloropropane
524.2		Water	2,2-Dichloropropane
524.2		Water	2-Chlorotoluene
524.2		Water	4-Chlorotoluene
524.2		Water	Acrylonitrile
524.2		Water	Bromobenzene
524.2		Water	Bromochloromethane
524.2		Water	Bromomethane
524.2		Water	Carbon disulfide
524.2		Water	Chloroethane
524.2		Water	Chloromethane
524.2		Water	cis-1,3-Dichloropropene
524.2		Water	Dibromomethane
524.2		Water	Dichlorodifluoromethane
524.2		Water	di-Isopropyl ether
524.2		Water	Ethyl t-butyl ether
524.2		Water	Hexachlorobutadiene
524.2		Water	Isopropylbenzene
524.2		Water	Methyl tertiary butyl ether
524.2		Water	Naphthalene
524.2		Water	n-Butylbenzene
524.2		Water	N-Propylbenzene
524.2		Water	p-Isopropyltoluene
524.2		Water	sec-Butylbenzene
524.2		Water	t-Amyl methyl ether
524.2		Water	t-Butyl alcohol
524.2		Water	tert-Butylbenzene
524.2		Water	trans-1,3-Dichloropropene
524.2		Water	trans-1,4-Dichloro-2-butene
524.2		Water	Trichlorofluoromethane

Method Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Method	Method Description	Protocol	Laboratory
524.2	Volatile Organic Compounds (GC/MS)	EPA-DW	ELLE

Protocol References:

EPA-DW = "Methods For The Determination Of Organic Compounds In Drinking Water", EPA/600/4-88/039, December 1988 And Its Supplements.

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Sample Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196696-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-196696-1	3994-FARM-EFF	Water	11/11/24 08:40	11/13/24 16:30
410-196696-2	3994-FARM-MID2	Water	11/11/24 08:45	11/13/24 16:30
410-196696-3	3994-FARM-INF	Water	11/11/24 08:50	11/13/24 16:30
410-196696-4	GVP-INF	Water	11/11/24 14:10	11/13/24 16:30
410-196696-5	3992-FARM-EFF	Water	11/12/24 14:10	11/13/24 16:30
410-196696-6	3992-FARM-MID2	Water	11/12/24 14:15	11/13/24 16:30
410-196696-7	3992-FARM-INF	Water	11/12/24 14:20	11/13/24 16:30

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15



410-196696 Chain of Custody

Environmental Analysis Request/Chain of Custody

Acct. # _____ Group # _____ Sample # _____

Client: Groundwater & Env. Services, Inc.				Matrix			Analyses Requested										For Lab Use Only								
Project Name#: Carroll Monrovia		Site ID #:		<input type="checkbox"/> Sediment	<input type="checkbox"/> Potable	<input type="checkbox"/> Ground	<input type="checkbox"/> Surface	Preservation Codes										SF #: _____							
Project Manager: Peter Reichardt		P.O. #: 0403470/06/209		<input checked="" type="checkbox"/> Water	<input type="checkbox"/> NPDES	<input type="checkbox"/> Other:											SCR #: _____								
Sampler: Jeff Plummer		PWSID #:		<input type="checkbox"/> Soil														Preservation Codes H = HCl T = Thiou sulfate N = HNO ₃ B = NaOH S = H ₂ SO ₄ P = H ₃ PO ₄ O = Other							
Phone #: 800-220-3606 x 3726		Quote #:																							
State where sample(s) were collected: 11791 Fingerboard Rd, Monrovia, MD																									
Sample Identification		Collection		Grab	Composite														Remarks						
		Date	Time			Soil	Water	Other:	Total # of Containers	Full Suite VOCs List plus oxygenates and Naphthalene (524.2) X		Target Suite VOCs List plus oxygenates and Naphthalene (524.2) X													
3994 Farm - EFF		11-11-24	0840	G			X		3															EQEDD file name:	
3994 Farm - Mid 2		11-11-24	0845																					Carroll Monrovia-lab	
3994 Farm - Inf		11-11-24	0850																					report #.17953.	
GVP - INF		11-11-24	1410							X														EQEDD.zip	
3992 Farm - EFF		11-12-24	1410																					Send invoice to:	
3992 Farm - MID 2		11-12-24	1415				X		3															ges-invoices@	
3992 Farm - INF		11-12-24	1420	G			X																	gesonline.com &	
Turnaround Time Requested (TAT) (please check): Standard <input checked="" type="checkbox"/> Rush <input type="checkbox"/>				Relinquished by: <i>Jeff Plummer</i>			Date: 11-13-24		Time: 0800		Received by: <i>Denise Weedin</i>			Date: 11-13-24		Time: 0800									
(Rush TAT is subject to laboratory approval and surcharges.)				Relinquished by: <i>Denise Weedin</i>			Date: 11-13-24		Time: 1212		Received by: <i>Tommy [Signature]</i>			Date: 11/13/24		Time: 1212									
Date results are needed:				Relinquished by: <i>Tommy [Signature]</i>			Date: 11/13/24		Time: 1630		Received by: <i>[Signature]</i>			Date:		Time:									
Rush results requested by (please check): E-Mail <input checked="" type="checkbox"/> Phone <input type="checkbox"/>				Relinquished by: <i>[Signature]</i>			Date:		Time:		Received by: <i>[Signature]</i>			Date:		Time:									
E-mail Address: <u>midatlantic@gesonline.com & ges@equisonline.com</u>				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
Phone:				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
Data Package Options (please check if required)				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
Type I (Validation/non-CLP) <input type="checkbox"/> MA MCP <input type="checkbox"/>				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
Type III (Reduced non-CLP) <input type="checkbox"/> CT RCP <input type="checkbox"/>				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
Type VI (Raw Data Only) <input type="checkbox"/> TX TRRP-13 <input type="checkbox"/>				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
NYSDEC Category <input type="checkbox"/> A or <input type="checkbox"/> B				Relinquished by:			Date:		Time:		Received by:			Date:		Time:									
EDD Required? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> If yes, format: <u>GES EQEDD</u>				Relinquished by Commercial Carrier:			Date:		Time:		Received by:			Date:		Time:									
EQEDD Name: Carroll Monrovia-lab report #.17953.EQEDD.zip				UPS _____ FedEx _____ Other <input checked="" type="checkbox"/>			Date:		Time:		Received by:			Date:		Time:									
											Temperature upon receipt <u>R: 1.2 C: 1.3</u> °C														

MP

MP

Login Sample Receipt Checklist

Client: Groundwater & Environmental Services Inc

Job Number: 410-196696-1

Login Number: 196696

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

List Number: 1

Creator: Reiff, Nicole L

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	N/A	
Samples were received on ice.	True	
Cooler Temperature acceptable, where thermal pres is required ($\leq 6^{\circ}\text{C}$, not frozen).	True	
Cooler Temperature is recorded.	True	
WV: Container Temp acceptable, where thermal pres is required ($\leq 6^{\circ}\text{C}$, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	N/A	
VOA sample vials do not have headspace $>6\text{mm}$ in diameter (none, if from WV)?	True	



ANALYTICAL REPORT

PREPARED FOR

Attn: Peter Reichardt
Groundwater & Environmental Services Inc
1350 Blair Drive
Suite H-2
Odenton, Maryland 21113

Generated 11/25/2024 10:29:59 AM

JOB DESCRIPTION

Carroll Monrovia

JOB NUMBER

410-196699-1

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.

Authorization



Generated
11/25/2024 10:29:59 AM

Authorized for release by
Amek Carter, Project Manager
Loran.Carter@et.eurofinsus.com
(717)556-7252

Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- QC results that exceed the upper limits and are associated with non-detect samples are qualified but further narration is not required since the bias is high and does not change a non-detect result. Further narration is also not required with QC blank detection when the associated sample concentration is non-detect or more than ten times the level in the blank.
- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD is performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Measurement uncertainty values, as applicable, are available upon request.

Test results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff. Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" and tested in the laboratory are not performed within 15 minutes of collection.

This report shall not be reproduced except in full, without the written approval of the laboratory.

WARRANTY AND LIMITS OF LIABILITY - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied, except as otherwise agreed. We disclaim any other warranties, expressed or implied, including a warranty of fitness for particular purpose and warranty of merchantability. In no event shall Eurofins Lancaster Laboratories Environmental, LLC be liable for indirect, special, consequential, or incidental damages including, but not limited to, damages for loss of profit or goodwill regardless of (A) the negligence (either sole or concurrent) of Eurofins Lancaster Laboratories Environmental and (B) whether Eurofins Lancaster Laboratories Environmental has been informed of the possibility of such damages. We accept no legal responsibility for the purposes for which the client uses the test results. Except as otherwise agreed, no purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.





Table of Contents

Cover Page	1
Table of Contents	4
Definitions/Glossary	5
Case Narrative	6
Detection Summary	7
Client Sample Results	8
Surrogate Summary	26
QC Sample Results	27
QC Association Summary	35
Lab Chronicle	36
Certification Summary	38
Method Summary	40
Sample Summary	41
Chain of Custody	42
Receipt Checklists	43

Definitions/Glossary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Qualifiers

GC/MS VOA

Qualifier	Qualifier Description
*1	LCS/LCSD RPD exceeds control limits.
cn	Refer to Case Narrative for further detail
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☼	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Case Narrative

Client: Groundwater & Environmental Services Inc
Project: Carroll Monrovia

Job ID: 410-196699-1

Job ID: 410-196699-1

Eurofins Lancaster Laboratories Environment

Job Narrative 410-196699-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Receipt

The samples were received on 11/13/2024 4:30 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 1.3°C.

Receipt Exceptions

A trip blank was not submitted for analysis with this sample shipment; and was not listed on the Chain of Custody (COC).

GC/MS VOA

Method 8260C_LL: The continuing calibration verification (CCV) associated with batch 410-577684 recovered outside acceptance criteria, low biased, for t-Butyl alcohol. A reporting limit (RL) standard was analyzed, and the target analyte was detected. Non-detections of the affected analytes are reported. Any detections are considered estimated..

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Detection Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-13

Lab Sample ID: 410-196699-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.40	J	0.50	0.080	ug/L	1		8260C LL	Total/NA
Chloroform	0.22	J	0.50	0.090	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-5

Lab Sample ID: 410-196699-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloroform	0.18	J	0.50	0.090	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-1

Lab Sample ID: 410-196699-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.41	J	0.50	0.080	ug/L	1		8260C LL	Total/NA
Chloroform	0.24	J	0.50	0.090	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-7

Lab Sample ID: 410-196699-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.60		0.50	0.080	ug/L	1		8260C LL	Total/NA
Chloroform	0.26	J	0.50	0.090	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-4

Lab Sample ID: 410-196699-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.088	J	0.50	0.080	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-17

Lab Sample ID: 410-196699-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.40	J	0.50	0.080	ug/L	1		8260C LL	Total/NA
Chloroform	0.38	J	0.50	0.090	ug/L	1		8260C LL	Total/NA
di-Isopropyl ether	0.10	J	0.50	0.10	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-14D

Lab Sample ID: 410-196699-7

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	15		0.50	0.080	ug/L	1		8260C LL	Total/NA
Carbon disulfide	0.13	J	1.0	0.10	ug/L	1		8260C LL	Total/NA
di-Isopropyl ether	0.29	J	0.50	0.10	ug/L	1		8260C LL	Total/NA
t-Amyl methyl ether	0.26	J	0.50	0.20	ug/L	1		8260C LL	Total/NA
t-Butyl alcohol	5.4	J cn	10	3.0	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-18D

Lab Sample ID: 410-196699-8

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Methyl tertiary butyl ether	0.086	J	0.50	0.080	ug/L	1		8260C LL	Total/NA

Client Sample ID: MW-18S-R

Lab Sample ID: 410-196699-9

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloroform	0.15	J	0.50	0.090	ug/L	1		8260C LL	Total/NA
di-Isopropyl ether	0.85		0.50	0.10	ug/L	1		8260C LL	Total/NA
t-Amyl methyl ether	0.56		0.50	0.20	ug/L	1		8260C LL	Total/NA
Methyl tertiary butyl ether - DL	29		5.0	0.80	ug/L	10		8260C LL	Total/NA

This Detection Summary does not include radiochemical test results.

Euofins Lancaster Laboratories Environment Testing, LLC

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-13

Lab Sample ID: 410-196699-1

Date Collected: 11/11/24 09:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 14:25	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 14:25	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 14:25	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 14:25	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Methyl tertiary butyl ether	0.40	J	0.50	0.080	ug/L			11/21/24 14:25	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Chloroform	0.22	J	0.50	0.090	ug/L			11/21/24 14:25	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 14:25	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 14:25	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 14:25	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 14:25	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 14:25	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:25	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 14:25	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-13

Lab Sample ID: 410-196699-1

Date Collected: 11/11/24 09:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 14:25	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 14:25	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 14:25	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 14:25	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 14:25	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:25	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 14:25	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		80 - 120					11/21/24 14:25	1
Dibromofluoromethane (Surr)	105		80 - 120					11/21/24 14:25	1
4-Bromofluorobenzene (Surr)	99		80 - 120					11/21/24 14:25	1
Toluene-d8 (Surr)	97		80 - 120					11/21/24 14:25	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-5

Lab Sample ID: 410-196699-2

Date Collected: 11/11/24 10:50

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 14:46	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 14:46	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 14:46	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 14:46	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Methyl tertiary butyl ether	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Chloroform	0.18	J	0.50	0.090	ug/L			11/21/24 14:46	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 14:46	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 14:46	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 14:46	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 14:46	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 14:46	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 14:46	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 14:46	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-5

Lab Sample ID: 410-196699-2

Date Collected: 11/11/24 10:50

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 14:46	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 14:46	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 14:46	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 14:46	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 14:46	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 14:46	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 14:46	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	104		80 - 120					11/21/24 14:46	1
Dibromofluoromethane (Surr)	105		80 - 120					11/21/24 14:46	1
4-Bromofluorobenzene (Surr)	98		80 - 120					11/21/24 14:46	1
Toluene-d8 (Surr)	98		80 - 120					11/21/24 14:46	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-1

Lab Sample ID: 410-196699-3

Date Collected: 11/11/24 11:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 15:06	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 15:06	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 15:06	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 15:06	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Methyl tertiary butyl ether	0.41	J	0.50	0.080	ug/L			11/21/24 15:06	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Chloroform	0.24	J	0.50	0.090	ug/L			11/21/24 15:06	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 15:06	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 15:06	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 15:06	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 15:06	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
1,1,1,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 15:06	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:06	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 15:06	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-1

Lab Sample ID: 410-196699-3

Date Collected: 11/11/24 11:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 15:06	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 15:06	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:06	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 15:06	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 15:06	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:06	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 15:06	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	99		80 - 120		11/21/24 15:06	1
Dibromofluoromethane (Surr)	105		80 - 120		11/21/24 15:06	1
4-Bromofluorobenzene (Surr)	98		80 - 120		11/21/24 15:06	1
Toluene-d8 (Surr)	98		80 - 120		11/21/24 15:06	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-7

Lab Sample ID: 410-196699-4

Date Collected: 11/11/24 13:00

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 15:26	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 15:26	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 15:26	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 15:26	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Methyl tertiary butyl ether	0.60		0.50	0.080	ug/L			11/21/24 15:26	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Chloroform	0.26 J		0.50	0.090	ug/L			11/21/24 15:26	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 15:26	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 15:26	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 15:26	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 15:26	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 15:26	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:26	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 15:26	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-7

Lab Sample ID: 410-196699-4

Date Collected: 11/11/24 13:00

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 15:26	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 15:26	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:26	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 15:26	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 15:26	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:26	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 15:26	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		80 - 120					11/21/24 15:26	1
Dibromofluoromethane (Surr)	106		80 - 120					11/21/24 15:26	1
4-Bromofluorobenzene (Surr)	96		80 - 120					11/21/24 15:26	1
Toluene-d8 (Surr)	98		80 - 120					11/21/24 15:26	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-4

Lab Sample ID: 410-196699-5

Date Collected: 11/11/24 13:40

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 15:46	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 15:46	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 15:46	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 15:46	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Methyl tertiary butyl ether	0.088	J	0.50	0.080	ug/L			11/21/24 15:46	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Chloroform	ND		0.50	0.090	ug/L			11/21/24 15:46	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 15:46	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 15:46	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 15:46	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 15:46	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 15:46	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 15:46	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 15:46	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-4

Lab Sample ID: 410-196699-5

Date Collected: 11/11/24 13:40

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 15:46	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 15:46	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 15:46	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 15:46	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 15:46	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 15:46	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 15:46	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		80 - 120					11/21/24 15:46	1
Dibromofluoromethane (Surr)	105		80 - 120					11/21/24 15:46	1
4-Bromofluorobenzene (Surr)	97		80 - 120					11/21/24 15:46	1
Toluene-d8 (Surr)	96		80 - 120					11/21/24 15:46	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-17

Lab Sample ID: 410-196699-6

Date Collected: 11/12/24 09:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 16:06	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 16:06	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 16:06	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 16:06	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Methyl tertiary butyl ether	0.40	J	0.50	0.080	ug/L			11/21/24 16:06	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Chloroform	0.38	J	0.50	0.090	ug/L			11/21/24 16:06	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 16:06	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 16:06	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 16:06	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 16:06	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
1,1,1,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 16:06	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:06	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 16:06	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-17

Lab Sample ID: 410-196699-6

Date Collected: 11/12/24 09:55

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 16:06	1
di-Isopropyl ether	0.10	J	0.50	0.10	ug/L			11/21/24 16:06	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:06	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 16:06	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 16:06	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:06	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 16:06	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	103		80 - 120					11/21/24 16:06	1
Dibromofluoromethane (Surr)	104		80 - 120					11/21/24 16:06	1
4-Bromofluorobenzene (Surr)	97		80 - 120					11/21/24 16:06	1
Toluene-d8 (Surr)	97		80 - 120					11/21/24 16:06	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-14D

Lab Sample ID: 410-196699-7

Date Collected: 11/12/24 11:05

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 16:27	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 16:27	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 16:27	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 16:27	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Methyl tertiary butyl ether	15		0.50	0.080	ug/L			11/21/24 16:27	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Chloroform	ND		0.50	0.090	ug/L			11/21/24 16:27	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 16:27	1
Carbon disulfide	0.13 J		1.0	0.10	ug/L			11/21/24 16:27	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 16:27	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 16:27	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 16:27	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:27	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 16:27	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-14D

Lab Sample ID: 410-196699-7

Date Collected: 11/12/24 11:05

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 16:27	1
di-Isopropyl ether	0.29	J	0.50	0.10	ug/L			11/21/24 16:27	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:27	1
t-Amyl methyl ether	0.26	J	0.50	0.20	ug/L			11/21/24 16:27	1
t-Butyl alcohol	5.4	J cn	10	3.0	ug/L			11/21/24 16:27	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:27	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 16:27	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	106		80 - 120		11/21/24 16:27	1
Dibromofluoromethane (Surr)	105		80 - 120		11/21/24 16:27	1
4-Bromofluorobenzene (Surr)	96		80 - 120		11/21/24 16:27	1
Toluene-d8 (Surr)	97		80 - 120		11/21/24 16:27	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-18D

Lab Sample ID: 410-196699-8

Date Collected: 11/12/24 12:20

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 16:47	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 16:47	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 16:47	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 16:47	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Methyl tertiary butyl ether	0.086	J	0.50	0.080	ug/L			11/21/24 16:47	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Chloroform	ND		0.50	0.090	ug/L			11/21/24 16:47	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 16:47	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 16:47	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 16:47	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 16:47	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 16:47	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 16:47	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 16:47	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-18D

Lab Sample ID: 410-196699-8

Date Collected: 11/12/24 12:20

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 16:47	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 16:47	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 16:47	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 16:47	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 16:47	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 16:47	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 16:47	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	105		80 - 120		11/21/24 16:47	1
Dibromofluoromethane (Surr)	104		80 - 120		11/21/24 16:47	1
4-Bromofluorobenzene (Surr)	96		80 - 120		11/21/24 16:47	1
Toluene-d8 (Surr)	96		80 - 120		11/21/24 16:47	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-18S-R

Lab Sample ID: 410-196699-9

Date Collected: 11/12/24 13:10

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 17:07	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 17:07	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 17:07	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 17:07	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Chloroform	0.15	J	0.50	0.090	ug/L			11/21/24 17:07	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 17:07	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 17:07	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 17:07	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 17:07	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 17:07	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 17:07	1
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1

Client Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-18S-R

Lab Sample ID: 410-196699-9

Date Collected: 11/12/24 13:10

Matrix: Water

Date Received: 11/13/24 16:30

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 17:07	1
di-Isopropyl ether	0.85		0.50	0.10	ug/L			11/21/24 17:07	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 17:07	1
t-Amyl methyl ether	0.56		0.50	0.20	ug/L			11/21/24 17:07	1
t-Butyl alcohol	ND	cn	10	3.0	ug/L			11/21/24 17:07	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 17:07	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 17:07	1

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	101		80 - 120		11/21/24 17:07	1
Dibromofluoromethane (Surr)	105		80 - 120		11/21/24 17:07	1
4-Bromofluorobenzene (Surr)	96		80 - 120		11/21/24 17:07	1
Toluene-d8 (Surr)	96		80 - 120		11/21/24 17:07	1

Method: SW846 8260C LL - Volatile Organic Compounds by GC/MS - DL

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Methyl tertiary butyl ether	29		5.0	0.80	ug/L			11/22/24 20:58	10

Surrogate	%Recovery	Qualifier	Limits	Prepared	Analyzed	Dil Fac
1,2-Dichloroethane-d4 (Surr)	102		80 - 120		11/22/24 20:58	10
Dibromofluoromethane (Surr)	104		80 - 120		11/22/24 20:58	10
4-Bromofluorobenzene (Surr)	97		80 - 120		11/22/24 20:58	10
Toluene-d8 (Surr)	97		80 - 120		11/22/24 20:58	10

Surrogate Summary

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS

Matrix: Water

Prep Type: Total/NA

Lab Sample ID	Client Sample ID	Percent Surrogate Recovery (Acceptance Limits)			
		DCA (80-120)	DBFM (80-120)	BFB (80-120)	TOL (80-120)
410-196699-1	MW-13	101	105	99	97
410-196699-2	MW-5	104	105	98	98
410-196699-3	MW-1	99	105	98	98
410-196699-4	MW-7	105	106	96	98
410-196699-5	MW-4	105	105	97	96
410-196699-6	MW-17	103	104	97	97
410-196699-7	MW-14D	106	105	96	97
410-196699-8	MW-18D	105	104	96	96
410-196699-9	MW-18S-R	101	105	96	96
410-196699-9 - DL	MW-18S-R	102	104	97	97
LCS 410-577684/4	Lab Control Sample	103	103	99	99
LCS 410-578576/4	Lab Control Sample	105	106	100	98
LCSD 410-578576/5	Lab Control Sample Dup	102	105	100	98
MB 410-577684/6	Method Blank	105	103	96	98
MB 410-578576/7	Method Blank	101	104	99	97

Surrogate Legend

- DCA = 1,2-Dichloroethane-d4 (Surr)
- DBFM = Dibromofluoromethane (Surr)
- BFB = 4-Bromofluorobenzene (Surr)
- TOL = Toluene-d8 (Surr)



QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS

Lab Sample ID: MB 410-577684/6

Matrix: Water

Analysis Batch: 577684

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/21/24 11:03	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Styrene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/21/24 11:03	1
Toluene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/21/24 11:03	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/21/24 11:03	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Methyl tertiary butyl ether	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Chloroform	ND		0.50	0.090	ug/L			11/21/24 11:03	1
Benzene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Bromomethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Chloromethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Chloroethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/21/24 11:03	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/21/24 11:03	1
Bromoform	ND		1.0	0.30	ug/L			11/21/24 11:03	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/21/24 11:03	1
Trichloroethene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/21/24 11:03	1

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: MB 410-577684/6

Client Sample ID: Method Blank

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 577684

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Bromobenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Dibromomethane	ND		0.50	0.080	ug/L			11/21/24 11:03	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/21/24 11:03	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
Naphthalene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/21/24 11:03	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/21/24 11:03	1
t-Butyl alcohol	ND		10	3.0	ug/L			11/21/24 11:03	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/21/24 11:03	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/21/24 11:03	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	105		80 - 120		11/21/24 11:03	1
Dibromofluoromethane (Surr)	103		80 - 120		11/21/24 11:03	1
4-Bromofluorobenzene (Surr)	96		80 - 120		11/21/24 11:03	1
Toluene-d8 (Surr)	98		80 - 120		11/21/24 11:03	1

Lab Sample ID: LCS 410-577684/4

Client Sample ID: Lab Control Sample

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 577684

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
cis-1,3-Dichloropropene	5.00	4.52		ug/L		90	67 - 121
trans-1,3-Dichloropropene	5.00	4.59		ug/L		92	61 - 129
Ethylbenzene	5.00	4.71		ug/L		94	80 - 120
Styrene	5.00	4.66		ug/L		93	80 - 120
1,4-Dichlorobenzene	5.00	4.75		ug/L		95	80 - 120
1,2-Dibromoethane	5.00	4.77		ug/L		95	80 - 120
1,1-Dichloropropene	5.00	4.77		ug/L		95	74 - 120
1,2-Dichloroethane	5.00	4.70		ug/L		94	69 - 122
1,2,3-Trichlorobenzene	5.00	5.04		ug/L		101	62 - 141
1,2,3-Trichloropropane	5.00	4.86		ug/L		97	80 - 125
Toluene	5.00	4.64		ug/L		93	80 - 120
Chlorobenzene	5.00	4.87		ug/L		97	80 - 120
1,2,4-Trimethylbenzene	5.00	4.68		ug/L		94	80 - 120
1,2,4-Trichlorobenzene	5.00	5.03		ug/L		101	68 - 122
Dibromochloromethane	5.00	4.97		ug/L		99	80 - 123
Xylenes, Total	15.0	14.2		ug/L		95	80 - 120
Tetrachloroethene	5.00	4.77		ug/L		95	80 - 120
cis-1,2-Dichloroethene	5.00	4.59		ug/L		92	80 - 122

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: LCS 410-577684/4

Matrix: Water

Analysis Batch: 577684

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
trans-1,2-Dichloroethene	5.00	4.85		ug/L		97	80 - 122
Methyl tertiary butyl ether	5.00	4.11		ug/L		82	69 - 120
1,3,5-Trimethylbenzene	5.00	4.79		ug/L		96	80 - 120
1,3-Dichlorobenzene	5.00	4.82		ug/L		96	80 - 120
1,3-Dichloropropane	5.00	4.62		ug/L		92	80 - 120
Chloroform	5.00	4.83		ug/L		97	80 - 120
Benzene	5.00	4.56		ug/L		91	80 - 120
1,1,1-Trichloroethane	5.00	4.90		ug/L		98	78 - 126
Bromomethane	5.00	5.07		ug/L		101	63 - 120
Chloromethane	5.00	4.37		ug/L		87	56 - 124
Chloroethane	5.00	4.90		ug/L		98	63 - 120
2,2-Dichloropropane	5.00	4.81		ug/L		96	77 - 128
Vinyl chloride	5.00	4.58		ug/L		92	60 - 125
Methylene Chloride	5.00	4.60		ug/L		92	80 - 120
Carbon disulfide	5.00	4.26		ug/L		85	67 - 130
Bromoform	5.00	5.35		ug/L		107	75 - 126
Bromodichloromethane	5.00	4.94		ug/L		99	80 - 123
1,1-Dichloroethane	5.00	4.86		ug/L		97	74 - 120
2-Chlorotoluene	5.00	4.87		ug/L		97	80 - 120
1,1-Dichloroethene	5.00	5.00		ug/L		100	80 - 131
Trichlorofluoromethane	5.00	5.53		ug/L		111	53 - 136
4-Chlorotoluene	5.00	4.79		ug/L		96	80 - 120
Dichlorodifluoromethane	5.00	5.30		ug/L		106	43 - 123
1,2-Dichloropropane	5.00	4.79		ug/L		96	80 - 120
1,1,2-Trichloroethane	5.00	4.67		ug/L		93	80 - 120
Acrylonitrile	25.0	23.9		ug/L		96	64 - 139
Trichloroethene	5.00	4.85		ug/L		97	80 - 120
1,1,1,2-Tetrachloroethane	5.00	4.73		ug/L		95	75 - 123
1,2-Dichlorobenzene	5.00	4.91		ug/L		98	80 - 120
1,2-Dibromo-3-Chloropropane	5.00	4.81		ug/L		96	75 - 124
Bromobenzene	5.00	4.70		ug/L		94	80 - 120
Bromochloromethane	5.00	4.71		ug/L		94	80 - 133
Isopropylbenzene	5.00	5.48		ug/L		110	80 - 120
Dibromomethane	5.00	4.78		ug/L		96	80 - 122
di-Isopropyl ether	5.00	4.13		ug/L		83	75 - 120
Ethyl t-butyl ether	5.00	4.09		ug/L		82	57 - 126
Hexachlorobutadiene	5.00	5.25		ug/L		105	72 - 132
Naphthalene	5.00	4.77		ug/L		95	64 - 135
n-Butylbenzene	5.00	5.03		ug/L		101	74 - 123
N-Propylbenzene	5.00	4.78		ug/L		96	74 - 122
p-Isopropyltoluene	5.00	4.82		ug/L		96	80 - 120
sec-Butylbenzene	5.00	4.85		ug/L		97	80 - 120
t-Amyl methyl ether	5.00	4.24		ug/L		85	55 - 146
t-Butyl alcohol	50.0	46.2		ug/L		92	62 - 138
tert-Butylbenzene	5.00	4.42		ug/L		88	79 - 120
trans-1,4-Dichloro-2-butene	25.0	23.9		ug/L		96	13 - 144

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: LCS 410-577684/4
Matrix: Water
Analysis Batch: 577684

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Surrogate	LCS	LCS	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	103		80 - 120
Dibromofluoromethane (Surr)	103		80 - 120
4-Bromofluorobenzene (Surr)	99		80 - 120
Toluene-d8 (Surr)	99		80 - 120

Lab Sample ID: MB 410-578576/7
Matrix: Water
Analysis Batch: 578576

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,1,1,2-Tetrachloroethane	ND		0.50	0.070	ug/L			11/22/24 19:58	1
cis-1,3-Dichloropropene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
trans-1,3-Dichloropropene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Ethylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Styrene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,4-Dichlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,2-Dibromoethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,1-Dichloropropene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
1,2-Dichloroethane	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,2,3-Trichlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,2,3-Trichloropropane	ND		1.0	0.10	ug/L			11/22/24 19:58	1
Toluene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Chlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,2,4-Trimethylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,2,4-Trichlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
Dibromochloromethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Xylenes, Total	ND		1.0	0.070	ug/L			11/22/24 19:58	1
Tetrachloroethene	ND		0.50	0.20	ug/L			11/22/24 19:58	1
cis-1,2-Dichloroethene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
trans-1,2-Dichloroethene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Methyl tertiary butyl ether	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,3,5-Trimethylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,3-Dichlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,3-Dichloropropane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Chloroform	ND		0.50	0.090	ug/L			11/22/24 19:58	1
Benzene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
1,1,1-Trichloroethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Bromomethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Chloromethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Chloroethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
2,2-Dichloropropane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Vinyl chloride	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Methylene Chloride	ND		0.50	0.20	ug/L			11/22/24 19:58	1
Carbon disulfide	ND		1.0	0.10	ug/L			11/22/24 19:58	1
Bromoform	ND		1.0	0.30	ug/L			11/22/24 19:58	1
Bromodichloromethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,1-Dichloroethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
2-Chlorotoluene	ND		0.50	0.080	ug/L			11/22/24 19:58	1

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: MB 410-578576/7

Matrix: Water

Analysis Batch: 578576

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB	MB	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
	Result	Qualifier							
1,1-Dichloroethene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Trichlorofluoromethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
4-Chlorotoluene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Dichlorodifluoromethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
1,2-Dichloropropane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
1,1,2-Trichloroethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Acrylonitrile	ND		5.0	0.40	ug/L			11/22/24 19:58	1
Trichloroethene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
1,1,2,2-Tetrachloroethane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
1,2-Dichlorobenzene	ND		0.50	0.070	ug/L			11/22/24 19:58	1
1,2-Dibromo-3-Chloropropane	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Bromobenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Bromochloromethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Isopropylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Dibromomethane	ND		0.50	0.080	ug/L			11/22/24 19:58	1
di-Isopropyl ether	ND		0.50	0.10	ug/L			11/22/24 19:58	1
Ethyl t-butyl ether	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Hexachlorobutadiene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
Naphthalene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
n-Butylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
N-Propylbenzene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
p-Isopropyltoluene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
sec-Butylbenzene	ND		0.50	0.10	ug/L			11/22/24 19:58	1
t-Amyl methyl ether	ND		0.50	0.20	ug/L			11/22/24 19:58	1
t-Butyl alcohol	ND		10	3.0	ug/L			11/22/24 19:58	1
tert-Butylbenzene	ND		0.50	0.080	ug/L			11/22/24 19:58	1
trans-1,4-Dichloro-2-butene	ND		5.0	2.0	ug/L			11/22/24 19:58	1

Surrogate	MB	MB	Limits	Prepared	Analyzed	Dil Fac
	%Recovery	Qualifier				
1,2-Dichloroethane-d4 (Surr)	101		80 - 120		11/22/24 19:58	1
Dibromofluoromethane (Surr)	104		80 - 120		11/22/24 19:58	1
4-Bromofluorobenzene (Surr)	99		80 - 120		11/22/24 19:58	1
Toluene-d8 (Surr)	97		80 - 120		11/22/24 19:58	1

Lab Sample ID: LCS 410-578576/4

Matrix: Water

Analysis Batch: 578576

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
cis-1,3-Dichloropropene	5.00	4.94		ug/L		99	67 - 121
trans-1,3-Dichloropropene	5.00	4.77		ug/L		95	61 - 129
Ethylbenzene	5.00	4.88		ug/L		98	80 - 120
Styrene	5.00	4.77		ug/L		95	80 - 120
1,4-Dichlorobenzene	5.00	4.81		ug/L		96	80 - 120
1,2-Dibromoethane	5.00	4.85		ug/L		97	80 - 120
1,1-Dichloropropene	5.00	5.18		ug/L		104	74 - 120
1,2-Dichloroethane	5.00	5.41		ug/L		108	69 - 122

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: LCS 410-578576/4

Matrix: Water

Analysis Batch: 578576

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS	LCS	Unit	D	%Rec	%Rec Limits
		Result	Qualifier				
1,2,3-Trichlorobenzene	5.00	4.90		ug/L		98	62 - 141
1,2,3-Trichloropropane	5.00	4.90		ug/L		98	80 - 125
Toluene	5.00	4.82		ug/L		96	80 - 120
Chlorobenzene	5.00	4.99		ug/L		100	80 - 120
1,2,4-Trimethylbenzene	5.00	4.80		ug/L		96	80 - 120
1,2,4-Trichlorobenzene	5.00	5.01		ug/L		100	68 - 122
Dibromochloromethane	5.00	5.12		ug/L		102	80 - 123
Xylenes, Total	15.0	14.7		ug/L		98	80 - 120
Tetrachloroethene	5.00	5.01		ug/L		100	80 - 120
cis-1,2-Dichloroethene	5.00	4.96		ug/L		99	80 - 122
trans-1,2-Dichloroethene	5.00	5.27		ug/L		105	80 - 122
Methyl tertiary butyl ether	5.00	4.57		ug/L		91	69 - 120
1,3,5-Trimethylbenzene	5.00	4.87		ug/L		97	80 - 120
1,3-Dichlorobenzene	5.00	4.81		ug/L		96	80 - 120
1,3-Dichloropropane	5.00	4.86		ug/L		97	80 - 120
Chloroform	5.00	5.21		ug/L		104	80 - 120
Benzene	5.00	4.93		ug/L		99	80 - 120
1,1,1-Trichloroethane	5.00	5.32		ug/L		106	78 - 126
Bromomethane	5.00	4.51		ug/L		90	63 - 120
Chloromethane	5.00	3.84		ug/L		77	56 - 124
Chloroethane	5.00	4.44		ug/L		89	63 - 120
2,2-Dichloropropane	5.00	5.26		ug/L		105	77 - 128
Vinyl chloride	5.00	4.05		ug/L		81	60 - 125
Methylene Chloride	5.00	4.99		ug/L		100	80 - 120
Carbon disulfide	5.00	4.55		ug/L		91	67 - 130
Bromoform	5.00	5.40		ug/L		108	75 - 126
Bromodichloromethane	5.00	5.20		ug/L		104	80 - 123
1,1-Dichloroethane	5.00	5.18		ug/L		104	74 - 120
2-Chlorotoluene	5.00	4.90		ug/L		98	80 - 120
1,1-Dichloroethene	5.00	5.22		ug/L		104	80 - 131
Trichlorofluoromethane	5.00	4.90		ug/L		98	53 - 136
4-Chlorotoluene	5.00	4.84		ug/L		97	80 - 120
Dichlorodifluoromethane	5.00	4.08		ug/L		82	43 - 123
1,2-Dichloropropane	5.00	5.08		ug/L		102	80 - 120
1,1,2-Trichloroethane	5.00	4.80		ug/L		96	80 - 120
Acrylonitrile	25.0	19.6		ug/L		78	64 - 139
Trichloroethene	5.00	5.17		ug/L		103	80 - 120
1,1,2,2-Tetrachloroethane	5.00	4.74		ug/L		95	75 - 123
1,2-Dichlorobenzene	5.00	4.91		ug/L		98	80 - 120
1,2-Dibromo-3-Chloropropane	5.00	4.74		ug/L		95	75 - 124
Bromobenzene	5.00	4.74		ug/L		95	80 - 120
Bromochloromethane	5.00	5.13		ug/L		103	80 - 133
Isopropylbenzene	5.00	5.54		ug/L		111	80 - 120
Dibromomethane	5.00	5.23		ug/L		105	80 - 122
di-Isopropyl ether	5.00	4.49		ug/L		90	75 - 120
Ethyl t-butyl ether	5.00	4.52		ug/L		90	57 - 126
Hexachlorobutadiene	5.00	5.25		ug/L		105	72 - 132
Naphthalene	5.00	4.86		ug/L		97	64 - 135
n-Butylbenzene	5.00	4.99		ug/L		100	74 - 123

Eurofins Lancaster Laboratories Environment Testing, LLC

QC Sample Results

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: LCS 410-578576/4

Matrix: Water

Analysis Batch: 578576

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
N-Propylbenzene	5.00	4.89		ug/L		98	74 - 122
p-Isopropyltoluene	5.00	4.82		ug/L		96	80 - 120
sec-Butylbenzene	5.00	4.90		ug/L		98	80 - 120
t-Amyl methyl ether	5.00	4.63		ug/L		93	55 - 146
t-Butyl alcohol	50.0	40.4		ug/L		81	62 - 138
tert-Butylbenzene	5.00	4.50		ug/L		90	79 - 120
trans-1,4-Dichloro-2-butene	25.0	18.9		ug/L		75	13 - 144

Surrogate	LCS %Recovery	LCS Qualifier	Limits
1,2-Dichloroethane-d4 (Surr)	105		80 - 120
Dibromofluoromethane (Surr)	106		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Toluene-d8 (Surr)	98		80 - 120

Lab Sample ID: LCSD 410-578576/5

Matrix: Water

Analysis Batch: 578576

Client Sample ID: Lab Control Sample Dup

Prep Type: Total/NA

Analyte	Spike Added	LCSD Result	LCSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
1,1,1,2-Tetrachloroethane	5.00	4.85		ug/L		97	80 - 122	4	30
cis-1,3-Dichloropropene	5.00	4.69		ug/L		94	67 - 121	5	30
trans-1,3-Dichloropropene	5.00	4.53		ug/L		91	61 - 129	5	30
Ethylbenzene	5.00	4.60		ug/L		92	80 - 120	6	30
Styrene	5.00	4.54		ug/L		91	80 - 120	5	30
1,4-Dichlorobenzene	5.00	4.59		ug/L		92	80 - 120	5	30
1,2-Dibromoethane	5.00	4.67		ug/L		93	80 - 120	4	30
1,1-Dichloropropene	5.00	4.86		ug/L		97	74 - 120	6	30
1,2-Dichloroethane	5.00	5.15		ug/L		103	69 - 122	5	30
1,2,3-Trichlorobenzene	5.00	4.61		ug/L		92	62 - 141	6	30
1,2,3-Trichloropropane	5.00	4.84		ug/L		97	80 - 125	1	30
Toluene	5.00	4.58		ug/L		92	80 - 120	5	30
Chlorobenzene	5.00	4.69		ug/L		94	80 - 120	6	30
1,2,4-Trimethylbenzene	5.00	4.57		ug/L		91	80 - 120	5	30
1,2,4-Trichlorobenzene	5.00	4.75		ug/L		95	68 - 122	5	30
Dibromochloromethane	5.00	4.87		ug/L		97	80 - 123	5	30
Xylenes, Total	15.0	14.0		ug/L		94	80 - 120	5	30
Tetrachloroethene	5.00	4.73		ug/L		95	80 - 120	6	30
cis-1,2-Dichloroethene	5.00	4.74		ug/L		95	80 - 122	5	30
trans-1,2-Dichloroethene	5.00	4.90		ug/L		98	80 - 122	7	30
Methyl tertiary butyl ether	5.00	4.43		ug/L		89	69 - 120	3	30
1,3,5-Trimethylbenzene	5.00	4.64		ug/L		93	80 - 120	5	30
1,3-Dichlorobenzene	5.00	4.67		ug/L		93	80 - 120	3	30
1,3-Dichloropropane	5.00	4.60		ug/L		92	80 - 120	5	30
Chloroform	5.00	4.89		ug/L		98	80 - 120	6	30
Benzene	5.00	4.69		ug/L		94	80 - 120	5	30
1,1,1-Trichloroethane	5.00	5.03		ug/L		101	78 - 126	6	30
Bromomethane	5.00	4.38		ug/L		88	63 - 120	3	30
Chloromethane	5.00	3.64		ug/L		73	56 - 124	5	30

QC Sample Results

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method: 8260C LL - Volatile Organic Compounds by GC/MS (Continued)

Lab Sample ID: LCSD 410-578576/5

Client Sample ID: Lab Control Sample Dup

Matrix: Water

Prep Type: Total/NA

Analysis Batch: 578576

Analyte	Spike	LCSD	LCSD	Unit	D	%Rec	%Rec	RPD	RPD
	Added	Result	Qualifier				Limits		Limit
Chloroethane	5.00	4.13		ug/L		83	63 - 120	7	30
2,2-Dichloropropane	5.00	4.85		ug/L		97	77 - 128	8	30
Vinyl chloride	5.00	3.76		ug/L		75	60 - 125	7	30
Methylene Chloride	5.00	4.66		ug/L		93	80 - 120	7	30
Carbon disulfide	5.00	4.26		ug/L		85	67 - 130	6	30
Bromoform	5.00	5.10		ug/L		102	75 - 126	6	30
Bromodichloromethane	5.00	5.00		ug/L		100	80 - 123	4	30
1,1-Dichloroethane	5.00	4.94		ug/L		99	74 - 120	5	30
2-Chlorotoluene	5.00	4.67		ug/L		93	80 - 120	5	30
1,1-Dichloroethene	5.00	5.02		ug/L		100	80 - 131	4	30
Trichlorofluoromethane	5.00	4.63		ug/L		93	53 - 136	6	30
4-Chlorotoluene	5.00	4.54		ug/L		91	80 - 120	6	30
Dichlorodifluoromethane	5.00	3.80		ug/L		76	43 - 123	7	30
1,2-Dichloropropane	5.00	4.91		ug/L		98	80 - 120	3	30
1,1,2-Trichloroethane	5.00	4.59		ug/L		92	80 - 120	4	30
Acrylonitrile	25.0	23.5		ug/L		94	64 - 139	18	30
Trichloroethene	5.00	4.80		ug/L		96	80 - 120	7	30
1,1,2,2-Tetrachloroethane	5.00	4.45		ug/L		89	75 - 123	6	30
1,2-Dichlorobenzene	5.00	4.75		ug/L		95	80 - 120	3	30
1,2-Dibromo-3-Chloropropane	5.00	4.25		ug/L		85	75 - 124	11	30
Bromobenzene	5.00	4.58		ug/L		92	80 - 120	4	30
Bromochloromethane	5.00	4.91		ug/L		98	80 - 133	4	30
Isopropylbenzene	5.00	5.31		ug/L		106	80 - 120	4	30
Dibromomethane	5.00	4.89		ug/L		98	80 - 122	7	30
di-Isopropyl ether	5.00	4.30		ug/L		86	75 - 120	4	30
Ethyl t-butyl ether	5.00	4.33		ug/L		87	57 - 126	4	30
Hexachlorobutadiene	5.00	4.85		ug/L		97	72 - 132	8	30
Naphthalene	5.00	4.52		ug/L		90	64 - 135	7	30
n-Butylbenzene	5.00	4.72		ug/L		94	74 - 123	6	30
N-Propylbenzene	5.00	4.62		ug/L		92	74 - 122	6	30
p-Isopropyltoluene	5.00	4.59		ug/L		92	80 - 120	5	30
sec-Butylbenzene	5.00	4.65		ug/L		93	80 - 120	5	30
t-Amyl methyl ether	5.00	4.45		ug/L		89	55 - 146	4	30
t-Butyl alcohol	50.0	40.2		ug/L		80	62 - 138	1	30
tert-Butylbenzene	5.00	4.25		ug/L		85	79 - 120	6	30
trans-1,4-Dichloro-2-butene	25.0	25.8	*1	ug/L		103	13 - 144	31	30

Surrogate	LCSD	LCSD	Limits
	%Recovery	Qualifier	
1,2-Dichloroethane-d4 (Surr)	102		80 - 120
Dibromofluoromethane (Surr)	105		80 - 120
4-Bromofluorobenzene (Surr)	100		80 - 120
Toluene-d8 (Surr)	98		80 - 120

QC Association Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

GC/MS VOA

Analysis Batch: 577684

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-196699-1	MW-13	Total/NA	Water	8260C LL	
410-196699-2	MW-5	Total/NA	Water	8260C LL	
410-196699-3	MW-1	Total/NA	Water	8260C LL	
410-196699-4	MW-7	Total/NA	Water	8260C LL	
410-196699-5	MW-4	Total/NA	Water	8260C LL	
410-196699-6	MW-17	Total/NA	Water	8260C LL	
410-196699-7	MW-14D	Total/NA	Water	8260C LL	
410-196699-8	MW-18D	Total/NA	Water	8260C LL	
410-196699-9	MW-18S-R	Total/NA	Water	8260C LL	
MB 410-577684/6	Method Blank	Total/NA	Water	8260C LL	
LCS 410-577684/4	Lab Control Sample	Total/NA	Water	8260C LL	

Analysis Batch: 578576

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
410-196699-9 - DL	MW-18S-R	Total/NA	Water	8260C LL	
MB 410-578576/7	Method Blank	Total/NA	Water	8260C LL	
LCS 410-578576/4	Lab Control Sample	Total/NA	Water	8260C LL	
LCSD 410-578576/5	Lab Control Sample Dup	Total/NA	Water	8260C LL	

Lab Chronicle

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-13

Date Collected: 11/11/24 09:55

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-1

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 14:25

Client Sample ID: MW-5

Date Collected: 11/11/24 10:50

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-2

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 14:46

Client Sample ID: MW-1

Date Collected: 11/11/24 11:55

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-3

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 15:06

Client Sample ID: MW-7

Date Collected: 11/11/24 13:00

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-4

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 15:26

Client Sample ID: MW-4

Date Collected: 11/11/24 13:40

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-5

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 15:46

Client Sample ID: MW-17

Date Collected: 11/12/24 09:55

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-6

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 16:06

Client Sample ID: MW-14D

Date Collected: 11/12/24 11:05

Date Received: 11/13/24 16:30

Lab Sample ID: 410-196699-7

Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 16:27

Lab Chronicle

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Client Sample ID: MW-18D

Lab Sample ID: 410-196699-8

Date Collected: 11/12/24 12:20

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 16:47

Client Sample ID: MW-18S-R

Lab Sample ID: 410-196699-9

Date Collected: 11/12/24 13:10

Matrix: Water

Date Received: 11/13/24 16:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Batch Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	8260C LL		1	577684	N7YK	ELLE	11/21/24 17:07
Total/NA	Analysis	8260C LL	DL	10	578576	JS6E	ELLE	11/22/24 20:58

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Accreditation/Certification Summary

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
Maryland	State	100	06-30-25

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
8260C LL		Water	1,1,1,2-Tetrachloroethane
8260C LL		Water	1,1,1-Trichloroethane
8260C LL		Water	1,1,2,2-Tetrachloroethane
8260C LL		Water	1,1,2-Trichloroethane
8260C LL		Water	1,1-Dichloroethane
8260C LL		Water	1,1-Dichloroethene
8260C LL		Water	1,1-Dichloropropene
8260C LL		Water	1,2,3-Trichlorobenzene
8260C LL		Water	1,2,3-Trichloropropane
8260C LL		Water	1,2,4-Trichlorobenzene
8260C LL		Water	1,2,4-Trimethylbenzene
8260C LL		Water	1,2-Dibromo-3-Chloropropane
8260C LL		Water	1,2-Dibromoethane
8260C LL		Water	1,2-Dichlorobenzene
8260C LL		Water	1,2-Dichloroethane
8260C LL		Water	1,2-Dichloropropane
8260C LL		Water	1,3,5-Trimethylbenzene
8260C LL		Water	1,3-Dichlorobenzene
8260C LL		Water	1,3-Dichloropropane
8260C LL		Water	1,4-Dichlorobenzene
8260C LL		Water	2,2-Dichloropropane
8260C LL		Water	2-Chlorotoluene
8260C LL		Water	4-Chlorotoluene
8260C LL		Water	Acrylonitrile
8260C LL		Water	Benzene
8260C LL		Water	Bromobenzene
8260C LL		Water	Bromochloromethane
8260C LL		Water	Bromodichloromethane
8260C LL		Water	Bromoform
8260C LL		Water	Bromomethane
8260C LL		Water	Carbon disulfide
8260C LL		Water	Chlorobenzene
8260C LL		Water	Chloroethane
8260C LL		Water	Chloroform
8260C LL		Water	Chloromethane
8260C LL		Water	cis-1,2-Dichloroethene
8260C LL		Water	cis-1,3-Dichloropropene
8260C LL		Water	Dibromochloromethane
8260C LL		Water	Dibromomethane
8260C LL		Water	Dichlorodifluoromethane
8260C LL		Water	di-Isopropyl ether
8260C LL		Water	Ethyl t-butyl ether
8260C LL		Water	Ethylbenzene
8260C LL		Water	Hexachlorobutadiene
8260C LL		Water	Isopropylbenzene



Accreditation/Certification Summary

Client: Groundwater & Environmental Services Inc
 Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC (Continued)

Unless otherwise noted, all analytes for this laboratory were covered under each accreditation/certification below.

Authority	Program	Identification Number	Expiration Date
-----------	---------	-----------------------	-----------------

The following analytes are included in this report, but the laboratory is not certified by the governing authority. This list may include analytes for which the agency does not offer certification.

Analysis Method	Prep Method	Matrix	Analyte
8260C LL		Water	Methyl tertiary butyl ether
8260C LL		Water	Methylene Chloride
8260C LL		Water	Naphthalene
8260C LL		Water	n-Butylbenzene
8260C LL		Water	N-Propylbenzene
8260C LL		Water	p-Isopropyltoluene
8260C LL		Water	sec-Butylbenzene
8260C LL		Water	Styrene
8260C LL		Water	t-Amyl methyl ether
8260C LL		Water	t-Butyl alcohol
8260C LL		Water	tert-Butylbenzene
8260C LL		Water	Tetrachloroethene
8260C LL		Water	Toluene
8260C LL		Water	trans-1,2-Dichloroethene
8260C LL		Water	trans-1,3-Dichloropropene
8260C LL		Water	trans-1,4-Dichloro-2-butene
8260C LL		Water	Trichloroethene
8260C LL		Water	Trichlorofluoromethane
8260C LL		Water	Vinyl chloride
8260C LL		Water	Xylenes, Total



Method Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Method	Method Description	Protocol	Laboratory
8260C LL	Volatile Organic Compounds by GC/MS	SW846	ELLE
5030C	Purge and Trap	SW846	ELLE

Protocol References:

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300




Sample Summary

Client: Groundwater & Environmental Services Inc
Project/Site: Carroll Monrovia

Job ID: 410-196699-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
410-196699-1	MW-13	Water	11/11/24 09:55	11/13/24 16:30
410-196699-2	MW-5	Water	11/11/24 10:50	11/13/24 16:30
410-196699-3	MW-1	Water	11/11/24 11:55	11/13/24 16:30
410-196699-4	MW-7	Water	11/11/24 13:00	11/13/24 16:30
410-196699-5	MW-4	Water	11/11/24 13:40	11/13/24 16:30
410-196699-6	MW-17	Water	11/12/24 09:55	11/13/24 16:30
410-196699-7	MW-14D	Water	11/12/24 11:05	11/13/24 16:30
410-196699-8	MW-18D	Water	11/12/24 12:20	11/13/24 16:30
410-196699-9	MW-18S-R	Water	11/12/24 13:10	11/13/24 16:30

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15



410-196699 Chain of Custody

Environmental Analysis Request/Chain of Custody

Environmental

Acct. # _____ Group # _____ Sample # _____

Client: Groundwater & Env. Services, Inc.				Matrix			Analyses Requested										For Lab Use Only						
Project Name/#: Carroll Monrovia		Site ID #:		<input type="checkbox"/> Sediment	<input checked="" type="checkbox"/> Ground	<input type="checkbox"/> Surface	Preservation Codes										SF #:						
Project Manager: Peter Reichardt		P.O. #: 0403470/06/206		<input type="checkbox"/> Potable	<input type="checkbox"/> NPDES	<input type="checkbox"/> Other:	H										SCR #:						
Sampler: Jeff Plummer		PWSID #:		<input type="checkbox"/> Soil	<input type="checkbox"/> Water	<input type="checkbox"/> Other:	Full Suite VOCs plus oxygenates and Naphthalene (8260)										Preservation Codes H = HCl T = Thiostate N = HNO ₃ B = NaOH S = H ₂ SO ₄ P = H ₃ PO ₄ O = Other						
Phone #: 800-220-3606 x 3726		Quote #:		Total # of Containers													Remarks						
State where sample(s) were collected: 11791 Fingerboard Rd, Monrovia, MD																							
Sample Identification		Date	Time	Grab	Composite																		
MW-13		11-11-24	0955	G			X			3	X											EQEDD file name:	
MW-5			1030																			Carroll Monrovia-lab	
MW-1			1155																			report #.17953.	
MW-7			1300																			EQEDD.zip	
MW-4		11-11-24	1340																			Send invoice to:	
MW-17		11-12-24	0955																			ges-invoices@	
MW-14D			1105																			gesonline.com &	
MW-18D			1220	✓																		include PO #	
MW-18S-R		11-12-24	1310	G			X			3	X												
Turnaround Time Requested (TAT) (please check): Standard <input checked="" type="checkbox"/> Rush <input type="checkbox"/>				Relinquished by: Jeff Plummer		Date: 11-13-24	Time: 0800	Received by: Denise Woodring		Date: 11-13-24	Time: 0800												
(Rush TAT is subject to laboratory approval and surcharges.)				Relinquished by: Denise Woodring		Date: 11-13-24	Time: 1212	Received by: Grant D. Deed		Date: 11/13/24	Time: 1212												
Date results are needed:				Relinquished by: Grant D. Deed		Date: 11/13/24	Time: 1630	Received by: [Signature]		Date: 11/13/24	Time: 1630												
Rush results requested by (please check): E-Mail <input checked="" type="checkbox"/> Phone <input type="checkbox"/>				Relinquished by: [Signature]		Date: _____	Time: _____	Received by: _____		Date: _____	Time: _____												
E-mail Address: midatlantic@gesonline.com & ges@equisonline.com				Relinquished by: _____		Date: _____	Time: _____	Received by: _____		Date: _____	Time: _____												
Phone: _____				Relinquished by: _____		Date: _____	Time: _____	Received by: _____		Date: _____	Time: _____												
Data Package Options (please check if required)				Relinquished by: _____		Date: _____	Time: _____	Received by: _____		Date: _____	Time: _____												
Type I (Validation/non-CLP) <input type="checkbox"/> MA MCP <input type="checkbox"/>				Relinquished by: _____		Date: _____	Time: _____	Received by: _____		Date: 11/13/24	Time: 1630												
Type III (Reduced non-CLP) <input type="checkbox"/> CT RCP <input type="checkbox"/>				Relinquished by: _____		Date: _____	Time: _____	Received by: _____															
Type VI (Raw Data Only) <input type="checkbox"/> TX TRRP-13 <input type="checkbox"/>				Relinquished by: _____		Date: _____	Time: _____	Received by: _____															
NYSDEC Category <input type="checkbox"/> A or <input type="checkbox"/> B				Relinquished by Commercial Carrier: _____																			
EQEDD Required? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> If yes, format: GES EQEDD				UPS _____ FedEx _____ Other X												Temperature upon receipt R: 1.2 C: 1.3 °C							
EQEDD Name: Carroll Monrovia-lab report #.17953.EQEDD.zip																							

MR

Login Sample Receipt Checklist

Client: Groundwater & Environmental Services Inc

Job Number: 410-196699-1

Login Number: 196699

List Source: Eurofins Lancaster Laboratories Environment Testing, LLC

List Number: 1

Creator: Reiff, Nicole L

Question	Answer	Comment
The cooler's custody seal is intact.	True	
The cooler or samples do not appear to have been compromised or tampered with.	N/A	
Samples were received on ice.	True	
Cooler Temperature acceptable,where thermal pres is required(</=6C, not frozen).	True	
Cooler Temperature is recorded.	True	
WV:Container Temp acceptable,where thermal pres is required (</=6C, not frozen).	N/A	
WV: Container Temperature is recorded.	N/A	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the containers received and the COC.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses.	True	
Is the Field Sampler's name present on COC?	True	
Sample custody seals are intact.	N/A	
VOA sample vials do not have headspace >6mm in diameter (none, if from WV)?	True	




APPENDIX D

Groundwater Monitoring Well Graphs

GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-1



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-1



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-4



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-4



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-5



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-5



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-7



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-7



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD


MW-13



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-13



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-14D



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-14D



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD


MW-17



GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD**


MW-17



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD


MW-18S-R



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
 11791 Fingerboard Rd
 Monrovia, MD

MW-18S-R




Note: 1. Non-detect results are plotted at the method detection/reporting limit (i.e., for TPH-GRO = ND<100 µg/L, 100 µg/L is plotted).

GROUNDWATER MONITORING GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD**


MW-18D



GROUNDWATER MONITORING GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd.
Monrovia, MD

MW-18D




APPENDIX E

Groundwater Supply Well Graphs

GROUNDWATER SUPPLY WELL GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD


3990-FARM-INF



GROUNDWATER SUPPLY WELL GRAPHS

**Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD**


3992-FARM-INF



GROUNDWATER SUPPLY WELL GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

3994-FARM-INF



GROUNDWATER SUPPLY WELL GRAPHS

Carroll - Monrovia BP/Former Green Valley Citgo
11791 Fingerboard Rd
Monrovia, MD

GVP-INF

