



Advanced Environmental Concepts, Inc.

1751-1 Pulaski Hwy. Havre De Grace MD 21078 (410)939-5550

**January 3, 2025**

**Oil Control Program**

Maryland Department of the Environment  
1800 Washington Blvd  
Baltimore, MD 21230

**RE: Request for Release from Sampling Requirements for POET System 2907 Churchville Rd.  
Case # 1993-0197HA- Facility ID 3851**

Dear Ms. Jackson,

On behalf of Carroll Independent Fuel Company (CIFCO), Advanced Environmental Concepts, Inc. (AEC) respectfully requests the release from the requirement to sample the granular activated carbon (GAC) filtration units currently in use at 2907 Churchville Rd. Churchville MD. This request is based on the following observations:

- The Maryland Department of the Environment's (MDE) Drinking Water Standard for Methyl-tert-Butyl-Ether (MTBE) is twenty (20) micrograms per liter ( $\mu\text{g/L}$ ).
- Influent (pre-treatment) concentrations of MTBE into the POET system servicing 2907 Churchville Road have been below the MDE action level of  $20\mu\text{g/L}$  for all sampling events since June 14, 2019.
- Influent (pre-treatment) concentrations of MTBE have been below detectable concentrations ( $.5\mu\text{g/L}$ ) in the last four quarterly sampling events.

**Request for Release of Sampling Requirements**

Based on the sustained compliance and monitoring results, we respectfully request that CIFCO be released from the requirement to perform further sampling of the POET system at 2907 Churchville Road. Churchville, MD.

If you have any questions or require additional information, please do not hesitate to contact me. We appreciate your time and consideration in reviewing this request.

*Gregory A Beal*

Sincerely,  
**Gregory Beal**  
Advanced Environmental Concepts, Inc.