




**MDE/LMA/OCP  
Report of Observation**

All MDE-OCP water samples will be analyzed for full suite VOCs, including fuel oxygenates, naphthalene, using EPA Method 8260 and TPH-DRO and TPH-GRO using EPA Method 8015. All sample containers were supplied by Maryland Spectral Laboratories and the samples collected by MDE-OCP were packaged on ice for transport to the lab with the associated chain of custody.

**NOTES**

- Report the following conditions to the Department immediately, but not later than 2 hours after the detection, at **410-537-3442** during normal business hours, or to the Emergency Response Division hotline at **1-866-633-4686**:
  - Evidence of a spill, release, or discharge of oil;
  - A release detection method, monitoring results, or investigation of an alarm indicates that a spill, release, or discharge may have occurred;
  - Investigation of an inventory variation reveals a leak;
  - If a storage tank system fails a test for tightness,;
  - Two consecutive inconclusive precision tightness test results;
  - A storage system (aboveground or underground) is determined to be leaking;
  - Test failure of spill catchment basins, containment sumps, or test of a cathodic protection resulting determination the system is inadequate;
  - Presence of liquid phase hydrocarbons; absorbed or free product in soil; vapors in soil, basement, sewer or utility line; or waters of the State;
  - Unusual operating conditions exist, such as erratic behavior of product dispensing equipment, the sudden loss of a regulated substance from a storage tank system, unexplained presence of water in a storage tank, or liquid in the interstitial space of a secondary containment system.
- Reports should **not** be made via voice messages to OCP case managers.
- Operating without a permit or in violation of a permit, regulation, or law may result in the assessment of civil or administrative penalties and or other legal sanctions.

<b>MDE Representative:</b> <b>Phone:</b> Jim Richmond/Susan Bull <b>Email:</b> <a href="mailto:susan.bull@maryland.gov">susan.bull@maryland.gov</a> <a href="mailto:Jim.richmond@maryland.gov">Jim.richmond@maryland.gov</a>	<b>Emailed:</b> <input checked="" type="checkbox"/> <b>Email:</b> [REDACTED] <b>Person Interviewed (print):</b> [REDACTED]
<b>Signature:</b> 	<b>Signature:</b>
<b>Date:</b> 6/24/2026	<b>Date:</b>