



DEPARTMENT OF THE NAVY
NAVAL SUPPORT ACTIVITY SOUTH POTOMAC
6509 SAMPSON ROAD, BLDG 101
DAHLGREN, VIRGINIA 22448

5090
Ser PRSI41ZM/099
October 30, 2025

Maryland Department of the Environment
Air and Radiation Management Administration
P.O. Box 2037
Baltimore, Maryland 21230-2037

To Whom it May Concern,

Naval Support Facility Indian Head (NSFIH) is submitting a Permit to Construct application to the Maryland Department of the Environment (MDE) for the installation of two new 41.8 MMBtu/hr, 1,000 HP boilers. The Building 712 facility (Steam B) will be demolished and renovated. All existing equipment will be decommissioned and removed, and the two new air emissions units will replace them. The following equipment will be removed:

- FBE-712-E1 MDE-ARA Registration Number 4-0081.
- FBE-712-ER, MDE-ARA Registration Number 5-0049 recently failed and was replaced. The final Permit to Construct was received on 10/1/2025. The new equipment will be relocated to the Strauss Avenue Primary Nodal Plant, Building 3163.
- FBE-712-E4 MDE-ARA Registration Number 5-0021. This boiler will be relocated to a different site; NSFIH will notify MDE separately when the new location is identified.
- FBE-712-E5 MDE-ARA Registration Number 5-0022. This equipment was never installed.

The boilers will be an addition to the decentralized nodal plant system and will maintain the synthetic minor limit of 25 tons per year for Volatile Organic Compounds. The attached documents include Form 11, calculations for stack emissions estimates, potential to emit calculations, and manufacturer specifications.

5090
Ser PRSI41ZM/099
October 30, 2025

Please mail all correspondence to:

ATTN: Director, Environmental Division
Department of the Navy, PWD South Potomac
3972 Ward Road, Suite 101
Indian Head, Maryland 20640-5157

If you have any questions or comments concerning this letter, please contact Zenovia Mitchell at (540) 840-9242 or by email at zenovia.a.mitchell.civ@us.navy.mil.

Sincerely,

K. R. ROBITAILLE
Environmental Program Director
By direction

Enclosures: 1. Form 11
2. Stack Emissions Estimates
3. Potential to Emit Calculations
4. Boiler Specifications



AIR QUALITY PERMIT TO CONSTRUCT APPLICATION CHECKLIST

OWNER OF EQUIPMENT/PROCESS	
COMPANY NAME:	Naval Support Activity South Potomac
COMPANY ADDRESS:	3972 Ward Road, Suite 101, Indian Head, MD 20640
LOCATION OF EQUIPMENT/PROCESS	
PREMISES NAME:	Naval Support Facility Indian Head
PREMISES ADDRESS:	Building 712, South Greenslade Road, Indian Head, MD 20640
CONTACT INFORMATION FOR THIS PERMIT APPLICATION	
CONTACT NAME:	Kenneth Robitaille
JOB TITLE:	Installation Environmental Program Director
PHONE NUMBER:	202-718-0682
EMAIL ADDRESS:	kenneth.r.robaille.civ@us.navy.mil
DESCRIPTION OF EQUIPMENT OR PROCESS	
Superior Boiler Power Flame, Model: MS7-5-5000-S300-PF-GA2	

Application is hereby made to the Department of the Environment for a Permit to Construct for the following equipment or process as required by the State of Maryland Air Quality Regulation, COMAR 26.11.02.09.

Check each item that you have submitted as part of your application package.

- Application package cover letter describing the proposed project
- Complete application forms (Note the number of forms included or NA if not applicable.)

No. _____ Form 5	No. <u> 1 </u> Form 11
No. _____ Form 5T	No. _____ Form 41
No. _____ Form 5EP	No. _____ Form 42
No. _____ Form 6	No. _____ Form 44
No. _____ Form 10	
- Vendor/manufacturer specifications/guarantees
- Evidence of Workman's Compensation Insurance
- Process flow diagrams with emission points
- Site plan including the location of the proposed source and property boundary
- Material balance data and all emissions calculations
- Material Safety Data Sheets (MSDS) or equivalent information for materials processed and manufactured.
- Certificate of Public Convenience and Necessity (CPCN) waiver documentation from the Public Service Commission ⁽¹⁾
- Documentation that the proposed installation complies with local zoning and land use requirements ⁽²⁾

⁽¹⁾ Required for emergency and non-emergency generators installed on or after October 1, 2001 and rated at 2001 kW or more.

⁽²⁾ Required for applications subject to Expanded Public Participation Requirements.

MARYLAND DEPARTMENT OF THE ENVIRONMENT

1800 Washington Blvd ▪ Baltimore, Maryland 21230
(410) 537-3230 ▪ 1-800-633-6101 ▪ www.mde.state.md.us

Air and Radiation Management Administration ▪ Air Quality Permits Program
APPLICATION FOR FUEL BURNING EQUIPMENT

Permit to Construct Registration Update Initial Registration

<p>1A. Owner of Equipment/Company Name Naval Support Activity South Potomac</p> <p>Mailing Address/Street 3972 Ward Road, Suite 101</p> <p>City Indian Head State MD Zip Code 20640</p> <p>Telephone Number 202-718-0682</p> <p>Print Name/Title J. C. NADDER</p> <p>Signature: <i>J. C. Nadder</i> Date: 20 OCT 2025</p>	<p align="center">DO NOT WRITE IN THIS BOX</p> <p>2. Registration Number</p> <table style="width:100%; border: none;"> <tr> <td style="text-align: center;">County No. <input type="text"/><input type="text"/> 1-2</td> <td style="text-align: center;">Premises No. <input type="text"/><input type="text"/><input type="text"/> 3-6</td> </tr> <tr> <td style="text-align: center;">Registration Class <input type="text"/> 7 Data Year</td> <td style="text-align: center;">Equipment No. <input type="text"/><input type="text"/><input type="text"/> 6-11</td> </tr> <tr> <td style="text-align: center;"><input type="text"/><input type="text"/> 12-13</td> <td style="text-align: center;">Application Date</td> </tr> </table>	County No. <input type="text"/> <input type="text"/> 1-2	Premises No. <input type="text"/> <input type="text"/> <input type="text"/> 3-6	Registration Class <input type="text"/> 7 Data Year	Equipment No. <input type="text"/> <input type="text"/> <input type="text"/> 6-11	<input type="text"/> <input type="text"/> 12-13	Application Date										
County No. <input type="text"/> <input type="text"/> 1-2	Premises No. <input type="text"/> <input type="text"/> <input type="text"/> 3-6																
Registration Class <input type="text"/> 7 Data Year	Equipment No. <input type="text"/> <input type="text"/> <input type="text"/> 6-11																
<input type="text"/> <input type="text"/> 12-13	Application Date																
<p>1B. Equipment Location (if different from above give Street Number and Name, City, State, Zip and Telephone Number): Building 712 South Greenslade Road, Indian Head, MD 20640</p> <p>Premises Name (if different from above):</p>																	
<p>3. Status</p> <table style="width:100%; border: none;"> <tr> <td style="width:25%;">A= New Equipment</td> <td style="width:25%;">New Construction Began (MM/YY)</td> <td style="width:25%;">New Construction Completed (MM/YY)</td> <td style="width:25%;">Existing Initial Operation (MM/YY)</td> </tr> <tr> <td>Status</td> <td><input type="text"/><input type="text"/><input type="text"/><input type="text"/></td> <td><input type="text"/><input type="text"/><input type="text"/><input type="text"/></td> <td><input type="text"/><input type="text"/><input type="text"/><input type="text"/></td> </tr> <tr> <td>B= Modification to Existing Equipment</td> <td>15</td> <td>16-19</td> <td>20-23</td> </tr> <tr> <td>C= Existing Equipment</td> <td></td> <td></td> <td></td> </tr> </table>		A= New Equipment	New Construction Began (MM/YY)	New Construction Completed (MM/YY)	Existing Initial Operation (MM/YY)	Status	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	B= Modification to Existing Equipment	15	16-19	20-23	C= Existing Equipment			
A= New Equipment	New Construction Began (MM/YY)	New Construction Completed (MM/YY)	Existing Initial Operation (MM/YY)														
Status	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>	<input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/>														
B= Modification to Existing Equipment	15	16-19	20-23														
C= Existing Equipment																	
<p>4. Describe this Equipment (Make, Model, Features, Manufacturer, etc.): Two new Power Flame boilers will be installed. Model: MS7-5-5000-S300-PF-GA2. 4-Pass</p>																	
<p>5. Workmen's Compensation Coverage: Binder/Policy Number: _____</p> <p>Company Name: NA Expiration Date _____</p> <p>NOTE: Before a Permit to Construct may be issued by the Department, the applicant must provide the Department with proof of worker's compensation coverage as required under Section 1-202 of the Worker's Compensation Act.</p>																	
<p>6. Number of Pieces of Identical Equipment to be Registered/Permitted at this Time: 2</p>																	
<p>7. Person Installing this Equipment (if different from above give Name/Title, Company Name, Mailing Address and Telephone Number):</p>																	
<p>8. Major Activity, Product or Service of Company at this Location: Provide steam support and redundancy to buildings at NSFIIH.</p>																	
<p>9. Control Devices Associated with this Equipment</p> <table style="width:100%; border: none;"> <tr> <td>None <input type="checkbox"/> 24-0</td> <td>Simple/Multiple Cyclones <input type="checkbox"/> 24-1</td> <td>Spray/Adsorb Tower <input type="checkbox"/> 24-2</td> <td>Venturi Scrubber <input type="checkbox"/> 24-3</td> <td>Carbon Adsorber <input type="checkbox"/> 24-4</td> <td>Electrostatic Precipitator <input type="checkbox"/> 24-5</td> <td>Bag-house <input type="checkbox"/> 24-6</td> </tr> <tr> <td>Thermal/Catalytic Afterburner <input type="checkbox"/> 24-7</td> <td>Dry Scrubber <input type="checkbox"/> 24-8</td> <td>Other <input checked="" type="checkbox"/> 24-9</td> <td colspan="4">Describe <u>Low NOx Burners, and Flue Gas Recirculation</u></td> </tr> </table>		None <input type="checkbox"/> 24-0	Simple/Multiple Cyclones <input type="checkbox"/> 24-1	Spray/Adsorb Tower <input type="checkbox"/> 24-2	Venturi Scrubber <input type="checkbox"/> 24-3	Carbon Adsorber <input type="checkbox"/> 24-4	Electrostatic Precipitator <input type="checkbox"/> 24-5	Bag-house <input type="checkbox"/> 24-6	Thermal/Catalytic Afterburner <input type="checkbox"/> 24-7	Dry Scrubber <input type="checkbox"/> 24-8	Other <input checked="" type="checkbox"/> 24-9	Describe <u>Low NOx Burners, and Flue Gas Recirculation</u>					
None <input type="checkbox"/> 24-0	Simple/Multiple Cyclones <input type="checkbox"/> 24-1	Spray/Adsorb Tower <input type="checkbox"/> 24-2	Venturi Scrubber <input type="checkbox"/> 24-3	Carbon Adsorber <input type="checkbox"/> 24-4	Electrostatic Precipitator <input type="checkbox"/> 24-5	Bag-house <input type="checkbox"/> 24-6											
Thermal/Catalytic Afterburner <input type="checkbox"/> 24-7	Dry Scrubber <input type="checkbox"/> 24-8	Other <input checked="" type="checkbox"/> 24-9	Describe <u>Low NOx Burners, and Flue Gas Recirculation</u>														

10. Annual Fuel Consumption for this Equipment Only

OIL-1000 GALLONS 26-31
 SULFUR % 32-33
 GRADE 34
 NATURAL GAS-1000 FT³ 35-41
 LP GAS-100 GALLONS 42-45
 GRADE

COAL- TONS 46-52
 SULFUR % 53-55
 ASH% 56-58
 WOOD-TONS 59-63
 MOISTURE % 64-65

OTHER FUELS ANNUAL AMOUNT CONSUMED (Specify Type) (Specify Units of Measure)
 OTHER FUEL ANNUAL AMOUNT CONSUMED (Specify Type) (Specify Units of Measure)
 1=Coke 2=COG 3=BFG 4=Other

11. Operating Schedule (for this equipment)

Comfort/Space Heating Only 67-1
 Process Heat Only 67-2
 Percent Process Heat 68-69
 Oil Burner Type 70
 1=Pressure Gun
 2=Air Atomizer
 3=Steam Atomizer
 4=Rotary Cup
 Coal Burner Type 71
 1=Cyclone
 2=Stoker
 3=Pulverized
 4=Hand Fired

SEASONAL VARIATION IN OPERATION (PERCENT):
 Days Per Week 72
 Days Per Year 73-75
 None 76
 Winter 77-78
 Spring 79-80
 Summer 81-82
 Fall 83-84

12. Exhaust Stack Information

Height Above Ground (ft) 86-88
 Inside Diameter at Top (inches) 89-91
 Exit Temperature (°F) 92-95
 Exit Velocity (ft/sec) 96-98

13. Total Stack Emissions (for this equipment only) in Pounds Per Operating Day

Particulate Matter 99-104
 Oxides of Sulfur 105-110
 Oxides of Nitrogen 111-116
 Carbon Monoxide 117-122
 Volatile Organic Compounds 123-128
 PM-10 129-134

14. Method Used to Determine Emissions (1=Estimate, 2=AP42, 3=Stack Test, 4=Other Emission Factor)

TSP 165
 SOx 166
 NOx 167
 CO 168
 VOC 169
 PM10 170

15. What is the Maximum Rated Heat Input of this Unit (Million Btu/hr)?

Air and Radiation Management Administration Use Only

16. Date Rec'd Local _____ Date Rec'd State _____
 Return to Local Jurisdiction Date _____ By _____
 Rev'd by Local Jurisdiction: Date _____ By _____ Rev'd by State: Date _____ By _____
 Acknowledgement Sent by State: Date _____ By _____

17. Inventory Date (MM/YY)

171-174

SCC Code

178-185

18. Annual Operating Rate

186-192

Maximum Design Hourly Rate

193-199

Permit to Operate Month

200-201

Transaction Date

202-207

Staff Code

208-210

VOC

211 212

SIP Code

213 214

Regulation Code

215-218

Confidentiality

219

Point Description

220-238

Action

239

A: Add
 C: Change



Total Stack Emissions in Pounds per Operating Day

Particulate Matter

$PM \text{ (lbs/day)} = \text{Emissions Factor (lbs/MMBtu)} \times \text{Heat Input (MMBtu/hr)} \times \text{Operating Hours}$

Where:

- Fuel: Natural Gas
- Boiler size: 41.8 MMBtu/hr
- Emissions Factor (from manufacturer): 0.0075 lbs PM-10/MMBtu
- Operating hours: 24

Calculation:

Multiply the emissions factor by the heat input rate

1. $(0.0075 \text{ lbs/MMBtu}) (41.8 \text{ MMBtu/hr}) = 0.31 \text{ lbs/hr}$

Multiply the hourly emissions rate by the operating hours

2. $(0.31 \text{ lbs/hr}) (24 \text{ hr/day}) = \underline{\underline{7.52 \text{ lbs/day}}}$

Nitrogen Oxides

$NO_x \text{ (lbs/day)} = \text{Fuel Consumption} \times \text{Emissions Factor} \times (1 - \text{Control Efficiency}) \times \text{Daily Operating Hours}$

Where:

- Fuel consumption rate: Boiler manufacturer data given in lb/MMBtu will be converted to lb/MMscf

Given:

Emissions factor: 0.037 lb/MMBtu (manufacturer data)

Heating value: 1,000 Btu/scf (manufacturer data)

Calculation: convert lb/MMBtu to lb/MMscf: $[\text{lb/MMscf}] = [\text{lb/MMBtu}] \times [\text{Btu/scf}] \times (1 \text{ MMBtu} / 1,000,000 \text{ Btu})$

$\text{lb/MMscf} = (0.037 \text{ lb/MMBtu}) (1,000 \text{ Btu/scf}) = 37 \text{ lb/MMscf}$

- Boiler heat input (from manufacturer): 41.8 MMBtu/hr
- Natural gas heating value (from manufacturer): 1,000 MMscf
- NO_x emission factor (from manufacturer): 37 lb/MMscf
- Control efficiency: boiler manufacturer data states there is flue gas recirculation but does not mention the percentage of NO_x removed, therefore the assumption will be 0% uncontrolled

Calculation:

Determine daily fuel consumption

Daily fuel consumption (MMscf/day) = (Boiler Heat Input (MMBtu/hr) / Fuel Heat Value (MMBtu/MMscf)) x Daily Operating Hours (hr/day)

1. $(41.8 \text{ MMBtu/hr} / 1,000 \text{ MMBtu/MMscf}) \times 24 \text{ hr/day} = 1.00 \text{ MMscf/day}$

Calculate daily NO_x emissions

NO_x (lbs/day) = Daily Fuel Consumption (MMscf/day) x Emission Factor (lb/MMscf)

2. (1.00 MMscf/day) (37 lb/MMscf) = **37 lbs/day**

Carbon Monoxide

CO Emissions (lb/hr) = Heat Input (MMBtu/hr) x CO Emission Factor (lb CO/MMBtu) x Operating Hours

Where:

- Heat input: 41.8 MMBtu/hr
- CO Emission Factor (from AP-42): 0.04 lb CO/MMBtu
- Operating hours: 24

Calculation:

Hourly emissions = (41.8 MMBtu/hr) (0.04 lb CO/MMBtu) = 1.672 lb CO/hr

Daily emissions = (1.672 lb CO/hr) (24 hrs/day) = **40.13 lbs/day**

Volatile Organic Chemicals

VOC (lb/day) = EF x FR x HR x (1 - CE/100)

Where:

- EF: manufacturer boiler emissions factor data given in lb/MMBtu will be converted to lb/MMscf

Given:

Emissions factor: 0.0054 lb/MMBtu (manufacturer data)

Heating value: 1,000 Btu/scf (manufacturer data)

Calculation: convert lb/MMBtu to lb/MMscf: [lb/MMscf] = [lb/MMBtu] x [Btu/scf] x (1 MMBtu / 1,000,000 Btu)

lb/MMscf = (0.0054 lb/MMBtu) (1,000 Btu/scf) = 5.4 lb/MMscf

- FR: to calculate fuel usage rate convert the heat input to MMscf/hr using the boilers heating value

FR = (41.8 MMBtu/hr) (1 MMscf/1,000 MMBtu) = 0.0418 MMscf/hr

- HR: operating hours will be 24 hours
- Control efficiency CE: boiler manufacturer data states there is flue gas recirculation but does not mention the percentage of NO_x removed, therefore the assumption will be 0% uncontrolled

Calculation:

Calculate the hourly VOC emissions:

1. (5.4 lb/MMscf) (0.0418 MMscf/hr) (1 - 0/100) = 0.226 lb/hr

Convert to daily VOC emissions:

2. (0.226 lbs/hr) (24 hr/day) = **5.4 lbs/day**

Permit To Construct Application

Building 712 Renovation

Emissions Calculations

Two new identical units will be installed for the Building 712 renovation

Location	Unit IDs	Rating (HP)	NG - Heat Input Capacity (MMBtu/hr)	#2 Fuel - Heat Input Capacity (MMBtu/hr)
Building 712	TBD	1,000	41.8	41.8

Primary Fuel: Natural Gas

1020 MMBtu/mmscf of natural gas (HHV, source: 40 CFR 98, Subpart C, Table C-1)

Backup Fuel: #2 Fuel Oil (emergency backup)

140 MMBtu/Kgal of Fuel Oil (HHV, source: 40 CFR 98, Subpart C, Table C-1)

Maximum Emissions Operating Scenario - Potential to Emit

New boilers will combust fuel oil only during periods of natural gas curtailment or supply emergencies. For the purposes of this PTE, fuel oil is estimated to be burned 1% of the time.

PTE Operating Schedule (hr/yr) - NG 8,672

PTE Operating Schedule (hr/yr) - #2 fuel oil 88

Pollutant	Natural Gas Emission Factor (lb/MMBtu)	Natural Gas Emissions (lb/hr) (ton/yr)		Note
CO	0.037	1.5	6.71	A
CO ₂	117.6	4917.6	21322.92	B
NO _x	0.037	1.5	6.71	A
Pb	4.9E-07	2.0E-05	8.9E-05	B
PM	0.008	0.3	1.36	A/D
PM ₁₀	0.008	0.3	1.36	A/D
PM _{2.5}	0.008	0.3	1.36	A/D
SO ₂	0.001	2.5E-02	0.11	B
VOC	0.005	0.2	0.98	A

A - Emission factor from Boiler Spec Sheet

B - Emission factor from AP-42, Ch. 1.3(Fuel Oil)/1.4 (NG)

C - Emission factor from 40 CFR 98, Subpart C, Table C-1

D - PM₁₀ and PM_{2.5} assumed equal to total PM as a conservative estimate

Pollutant	#2 Fuel Oil Emission Factor (lb/MMBtu)	#2 Fuel Oil Emissions (lb/hr) (ton/yr)		Total Potential to Emit (ton/yr)	Note
CO	0.037	1.5	0.07	6.77	A
CO ₂	163.0	6,814	299.80	21,622.72	C
NO _x	0.115	4.81	0.21	6.92	A
Pb	9.0E-06	0.0	0.00	0.00	B
PM	0.024	0.99	0.04	1.40	A/D
PM ₁₀	0.024	0.99	0.04	1.40	A/D
PM _{2.5}	0.024	0.99	0.04	1.40	A/D
SO ₂	1.014	42.4	1.87	1.97	B
VOC	0.200	8.4	0.37	1.35	B

HAPs: from Natural Gas combustion

Pollutant (HAPs)	Emission Factor (lb/MMBtu)	Potential to Emit (lb/hr) (ton/yr)		Note
1,3-Butadiene	NA	-	-	
Acetaldehyde	NA	-	-	
Acrolein	NA	-	-	
Benzene	2.1E-06	8.61E-05	3.73E-04	*
Ethylbenzene	NA	-	-	
Formaldehyde	7.4E-05	3.07E-03	1.33E-02	*
Naphthalene	6.0E-07	2.50E-05	1.08E-04	*
PAH	NA	-	-	
Propylene Oxide	NA	-	-	
Toluene	3.3E-06	1.39E-04	6.04E-04	*
Xylene	NA	-	-	
Arsenic	2.0E-07	8.20E-06	3.55E-05	*
Beryllium	1.2E-08	4.92E-07	2.13E-06	*
Cadmium	1.1E-06	4.51E-05	1.95E-04	*
Chromium	1.4E-06	5.74E-05	2.49E-04	*
Copper	8.3E-07	3.48E-05	1.51E-04	*
Lead	4.9E-07	2.05E-05	8.88E-05	*
Mercury	2.5E-07	1.07E-05	4.62E-05	*
Manganese	3.7E-07	1.56E-05	6.75E-05	*
Nickel	2.1E-06	8.61E-05	3.73E-04	*
Selenium	2.4E-08	9.84E-07	4.26E-06	*
HCl	NA	-	-	

NA - Not available

* Emission factor from AP-42, Ch. 1.4 (Natural Gas Combustion)

** Emission factor from AP-42, Ch. 1.3 (Fuel Oil Combustion)

- Emission factor equal to HCl emission limit listed in Table 1 of 40 CFR 63, Subpart DDDDD for new liquid fuel subcategory unit

Methodology

Emission Factor (lb SO₂/MMBtu) = AP-42 Emission Factor (lb/MMcf) x NG Higher Heating Value (MMcf/MMBtu)

Emission Factor (lb HAP/MMBtu NG) = AP-42 Emission Factor (lb/MMcf) x NG Higher Heating Value (MMcf/MMBtu)

Emission Factor (lb SO₂/MMBtu fuel oil) = 142 (AP-42 Factor, lb/kgal) x fuel oil Higher Heating Value (kgal/MMBtu) x S, where S = fuel oil % sulfur

Emission Factor (lb HAP/MMBtu fuel oil) = AP-42 Emission Factor (lb/kgal) x Fuel Oil Higher Heating Value (kgal/MMBtu)

Potential to Emit (lb/hr) = Emission Factor (lb/MMBtu) x Heat Input Capacity (MMBtu/hr)

Potential to Emit (ton/yr) = Potential to Emit (lb/hr) x Maximum Operating Schedule (hr/yr) x 1/2000 (ton/lb)

from Fuel Oil combustion

Emission Factor (lb/MMBtu)	Potential to Emit (lb/hr) (ton/yr)		Note
NA	-	-	
NA	-	-	
NA	-	-	
1.5E-06	6.4E-05	2.8E-06	**
4.5E-06	-	-	
NA	-	-	**
8.1E-06	3.4E-04	1.5E-05	**
NA	-	-	
NA	-	-	
4.4E-05	1.9E-03	8.1E-05	**
7.8E-07	3.3E-05	1.4E-06	**
4.0E-06	1.7E-04	7.4E-06	**
3.0E-06	1.3E-04	5.5E-06	**
3.0E-06	1.3E-04	5.5E-06	**
3.0E-06	1.3E-04	5.5E-06	**
6.0E-06	2.5E-04	1.1E-05	**
9.0E-06	3.8E-04	1.7E-05	**
3.0E-06	1.3E-04	5.5E-06	**
6.0E-06	2.5E-04	1.1E-05	**
3.0E-06	1.3E-04	5.5E-06	**
1.5E-05	6.3E-04	2.8E-05	**
4.40E-04	1.8E-02	8.1E-04	#

Total HAP PTE (ton/yr) 0.016



Typical Flue Product Emissions Data for Power Flame Burners

9/28/2006
Rev. 04/16/2024
Revision 13

Most analyzers today will provide a dry analysis of the Products of Combustion, PFI can guarantee NO_x & CO performance, by burner design; using premix, flue gas recirculation, staged combustion or a combination of the above. PFI cannot guarantee SO_x, PM_T, Hydrocarbons, VOC's or CO₂ values as these values are dependent on the actual fuel sample being consumed.

Per EPA AP-42 unless Noted	Natural Gas - Section 1.4	L.P. Gas - Section 1.5	# 2 Fuel Oil - Section 1.3 ⁽¹⁾
Carbon Monoxide - CO⁽⁶⁾ Per PFI Burner Testing	0.037 lb/MMBTU input (50 PPM)	0.037 lb/MMBTU input (50 PPM)	0.037 lb/MMBTU input (50 PPM)
Sulfur Dioxide - SO_x⁽⁷⁾ (SO ₂ & SO ₃)	0.0006 lb/MMBTU input (0.4 PPM)	0.0006 lb/MMBTU input (0.4 PPM)	(1.0550) x %S _w = lb/MMBTU input
Particulate Matter (Total)⁽⁸⁾ PM _T = PM _C + PM _F	0.0075 lb/MMBTU input	0.0075 lb/MMBTU input	0.0236 lb/MMBTU input
Hydrocarbons⁽⁹⁾	0.025 lb/MMBTU input	0.025 lb/MMBTU input	0.038 lb/MMBTU input
VOC's⁽¹⁰⁾	≈ 0.0054 lb/MMBTU input	≈ 0.0054 lb/MMBTU input	Based on actual #2 Oil sample
CO₂⁽¹¹⁾	9 % to 12%	10% to 12%	10% to 13%
Nitrogen Oxides - NO_x			
Standard JA, FDM & X4 Burners	0.091 lb/MM BTU input (75 PPM)	0.095 lb/MM BTU input (79 PPM)	N/A N/A
Standard C(R) Burners	0.091 lb/MM BTU input (75 PPM)	0.095 lb/MM BTU input (79 PPM)	0.115 lb/MM BTU Input (90) PPM ⁽²⁾
LNIC(R) Burners Fire box/Cast Iron boilers	0.037 lb/MM BTU input (30 PPM)	0.037 lb/MM BTU input (30 PPM)	0.115 lb/MM BTU Input (90) PPM ⁽²⁾
LNIC(R) Burners Water tube boilers	0.037 lb/MM BTU input (30 PPM)	0.037 lb/MM BTU input (30 PPM)	0.115 lb/MM BTU Input (90) PPM ⁽²⁾
LNIAC Burners	0.037 lb/MM BTU input (30 PPM)	0.037 lb/MM BTU input (30 PPM)	0.115 lb/MM BTU Input (90) PPM
CMAX Burners	0.085 lb/MM BTU input (70 PPM) ⁽⁴⁾	0.085 lb/MM BTU input (70 PPM) ⁽⁴⁾	0.141 lb/MM BTU Input (110) PPM
LNICM Burners Scotch Boiler	0.037 lb/MM BTU input (30) PPM	0.037 lb/MM BTU input (30) PPM	0.115 lb/MM BTU Input (90) PPM
LNICM Burners Fire box/Cast Iron boilers	0.030 lb/MM BTU input (25) PPM	0.030 lb/MM BTU input (25) PPM	0.115 lb/MM BTU Input (90) PPM
LNICM Burners Water tube boilers	0.024 lb/MM BTU input (20) PPM	0.030 lb/MM BTU input (25) PPM	0.115 lb/MM BTU Input (90) PPM
UCM Burners	0.010 lb/MM BTU input (9) PPM ⁽⁵⁾	0.015 lb/MM BTU input (12) PPM	0.077 lb/MM BTU Input (60) PPM
NPM Premix Burners	0.030 lb/MM BTU input (25) PPM	0.030 lb/MM BTU input (25) PPM	N/A N/A
NVC and NP2 Burners	0.010 lb/MM BTU input (9) PPM	0.015 lb/MM BTU input (12) PPM	N/A N/A
EVO™ Burners	0.037 lb/MM BTU input (30) PPM	N/A N/A	N/A N/A

- (1) NO_x emissions will vary based on the percent of fuel bound nitrogen (these are based on 0.02%) and boiler or heat exchanger configurations.
- (2) 90 PPM NO_x on cast iron sectional, fire box and water tube boiler, 120 PPM on fire tube boilers. (0.159 lb/MM BTU Input)
- (3) Not used
- (4) In some applications the CMAX will achieve less than 60 PPM without flue gas recirculation - consult factory.
- (5) In some applications the UCM burner will achieve less than 9 PPM with modifications - consult factory.
- (6) Based upon PFI Burner testing in lab and field. Consult factory if lower values needed, based on Burner & Boiler combination.
- (7) SO_x value shown has a value of 2,000 grains/10⁶ scf for Natural Gas and Propane. Oil is by weight, based on sample analysis.
- (8) Particulate Matter Total (PM_T) is the total is the Filterable (PM_F) and the Condensable (PM_C), this will vary based upon fuel analysis.
- (9) Hydrocarbon Emission Factors are determined from the (C_xH_y) Hydrocarbon Chains in natural gas composition, in general from (C₁H₄) Methane to (C₈H₁₄) Hexane. (C₇H₁₆) N-Heptane through (C₁₀H₂₂) Decane are often combined in the fuel as C₆+. This value is based upon your actual natural gas composition. #2 oil is based on the actual oil sample.
- (10) The VOC's are dependent on the gas or liquid fuel composition. It will vary based on the Hydrocarbon amount and all other constituents which will determine the calculated value.
- (11) The CO₂ percentage is dependent on the hydrocarbon value as well as excess air values.

These emission rates are general estimates and do not constitute guarantees by Power Flame Inc. In instances where guarantees are required, please consult the factory with the specific application information. All NO_x numbers stated are corrected to 3.0% O₂ (dry).

Superior Boiler

3524 E. 4th Ave.
Hutchinson, Ks. 67501

TEL: 800-444-6693
FAX: 620-662-7586

SUPERIOR BOILER PERFORMANCE

Reps:
Project:

Model: MS7-5-5000-S300-PF-GA2
Firing: Nat. Gas **HHV =** 1,000 Btu/Ft3

Boiler Type & Size	----- 4-Pass Wetback				
Radiant Heat'g Surface	-----	362		Ft2	
Tubes Heat'g Surface	-----	4588		Ft2	
Radiant Section Volum-	-----	324.2		Ft3	
Operating Conditions					
Steam Pressure	-----	200		psig	
Feedwater Temp	-----	227		Deg. F	From DA.
Combustion Air Temp	-----	80		Deg. F	
Relative Humidity	-----	60		%	
Blowdown	-----	3		%	
Steam Temperature	-----	387.7		Deg. F	
Steam Enthalpy	-----	1,199.2		Btu/Lb	
Boiler Water Enthalpy	-----	361.9		Btu/Lb	
Feedwater Enthalpy	-----	195.3		Btu/Lb	

Firing Rate	100	75	50	25	%
Excess Air	20	20	20	20	%
Flue Gas Recirculation	15	15	15	15	%
CO2 in Dry Flue Gas	9.6	9.6	9.6	9.6	% Vol
O2 in Dry Flue Gas	3.8	3.8	3.8	3.8	% Vol
Fuel Input	41,844	31,383	20,922	10,461	SCFH
	41,844	31,383	20,922	10,461	MBH
Combustion Air	35,939	26,954	17,970	8,985	Lb/hr
	8,054	6,040	4,027	2,013	SCFM
Flue Gas Flow	37,818	28,364	18,909	9,455	Lb/hr
	8,769	6,577	4,384	2,192	SCFM
LOSSES					
Flue Gas	17.56	17.44	17.32	17.22	%
Radiation&Convect.	0.26	0.35	0.53	1.05	%
EFFICIENCY (HHV)					
Thermal	82.44	82.56	82.68	82.78	%
Fuel to Steam	82.17	82.21	82.15	81.73	%
BOILER					
Heat Output	34,384	25,799	17,188	8,550	MBH
Net Steam Flow	33,222	24,927	16,606	8,260	Lb/hr
Stack Temp-	416.0	411.0	406.2	402.2	Deg. F
Furnace Heat Release	129,053	96,790	64,527	32,263	Btu/Ft3-hr
Furnace Heat Flux	115,547	86,660	57,773	28,887	Btu/Ft2-hr

- Notes:**
- 1- Boiler performance is based on the heat loss method.
 - 2- Jacket losses (radiation and convection losses) are calculated based on actual losses through boiler insulation and connections.

Superior Boiler

3524 E. 4th Ave.
Hutchinson, Ks. 67501

TEL: 800-444-6693
FAX: 620-662-7586

SUPERIOR BOILER PERFORMANCE

Reps:
Project:

Model: MS7-5-5000-S300-PF-GA2
Firing: #2 OIL HHV = 139,856 Btu/Gal

Boiler Type & Size	-----	4-Pass Wetback	
Radiant Heat'g Surface	-----	362	Ft2
Tubes Heat'g Surface	-----	4588	Ft2
Radiant Secion Volume	-----	324.2	Ft3
Operating Conditions			
Steam Pressure	-----	200	psig
Feedwater Temp	-----	227	Deg. F
Combustion Air Temp	-----	80	Deg. F
Relative Humidity	-----	60	%
Blowdown	-----	3	%
Steam Temperature	-----	387.7	Deg. F
Steam Enthalpy	-----	1,199.2	Btu/Lb
Boiler Water Enthalpy	-----	361.9	Btu/Lb
Feedwater Enthalpy	-----	195.3	Btu/Lb

From DA.

Firing Rate	100	75	50	25	%
Excess Air	20	20	20	20	%
Flue Gas Recirculation	15	15	15	15	%
CO2 in Dry Flue Gas	12.9	12.9	12.9	12.9	% Vol
O2 in Dry Flue Gas	3.7	3.7	3.7	3.7	% Vol
Fuel Input	299.2 41,844	224.4 31,383	149.6 20,922	74.8 10,461	GPH MBH
Combustion Air	37,360 8,372	28,020 6,279	18,680 4,186	9,340 2,093	Lb/hr SCFM
Flue Gas Flow	39,502 8,800	29,626 6,600	19,750 4,400	9,875 2,200	Lb/hr SCFM
LOSSES					
Flue Gas	14.11	13.98	13.86	13.76	%
Radiation&Convect.	0.26	0.35	0.53	1.05	%
EFFICIENCY (HHV)					
Thermal	85.89	86.02	86.14	86.24	%
Fuel to Steam	85.63	85.67	85.61	85.19	%
BOILER					
Heat Output	35,831	26,885	17,912	8,912	MBH
Net Steam Flow	34,620	25,976	17,306	8,611	Lb/hr
Stack Temp-	416.9	411.7	406.8	402.5	Deg. F
Furnace Heat Release	129,053	96,790	64,527	32,263	Btu/Ft3-hr
Furnace Heat Flux	115,547	86,660	57,773	28,887	Btu/Ft2-hr

- Notes:**
- 1- Boiler performance is based on the heat loss method.
 - 2- Jacket losses (radiation and convection losses) are calculated based on actual losses through boiler insulation and connections.



J.O. NO. 9000457
 SPEC SHEET - STEAM PAGE 1 OF 3
 S.O. NO. 249237 NAT. BOARD NO. _____
 DATE RECEIVED: 3/19/24 QTY 1
 STATUS: WA&R RELEASED DATE _____
 JOB: NAVAL SUPPORT FACILITY - INDIAN HEAD
 LOCATION: INDIAN HEAD, MD 20640
 SOLD TO: GREENLAND ENTERPRISES, INC.
11864 FISHING POINT DRIVE
NEWPORT NEWS, VA 23606

SUBMITTALS REQ'D: 1 SETS PROPOSAL 03380106
 R&D SHEET W.D. SUBMITTAL NO. _____
 BURNER GAS PIPING OIL PIPING
 DATE REQ'D: _____ MANUALS REQ'D: 2
 REP CONTACT: _____

MODEL: MS7-5-5000-S300-PF-GA2
 NOMINAL HP 1000 OUTPUT 33475 MBH
 SECTION I
 DESIGN PRESSURE 300 PSI STEAM
 OPERATING PRESSURE 200 PSI STEAM
 NAMEPLATE: SUPERIOR PAINT BLUE
 STACK DAMPER: W/LOCKING QUAD W/BEARINGS
 STACK THERMOMETER 50EI60E120 L
 DIAL 5.00" STEM 12.00" RANGE 100/800 °F
 BOILER J-BOX 14X12 NEMA 4X w/ SEALTITE LS RS
 GAUGE GLASS TRI-COCKS N/S CHAIN OPERATED
REFLEX
 PRIMARY L.W.C.O. LS RS TOP
 MODEL MAG W29-1B10-CLA M
 WATER COLUMN BLOWDOWN VALVE(S); M
 POWELL FIG. NO. GA08TA58GB SIZE 1.00"
 AUX. L.W.C.O.: LS RS TOP
 MODEL 26NMB1A0A / EA101 M
 HIGH WATER LS RS TOP
 CUTOFF ALARM
 MODEL 16MC1A0 / EA101 M
 PSI
 OPERATOR L404F1094 RANGE 20-300# M
 LIMIT L4079B 1066 RANGE 20-300 M
 FIRING RATE 2051TG3A2B21AS5B4E5Q4 RANGE 0-300 M
 RANGE _____
 STEAM GAUGE: W/GAUGE/TEST COCK
ASHCROFT FIG. NO. 1379AS L
 DIAL 8.5" RANGE 0-600# PSI W/SYPHON
 AIR VENT VALVE: N/S SIZE _____
 TURBULATORS: N/S TYPE _____

SAFETY VALVE(S): KUNKLE L
 6030JH SIZE 2.00" X 2.50" SET @ 300 PSIG
 SIZE _____ SET @ _____ PSIG
 DRIP PAN ELBOW(S): (2) 299-J, 2.5"
 FEEDWATER VALVE(S): LS RS M
 GATE POWELL FIG. NO. GA08TA58GB SIZE 2.00"
 CHECK: POWELL FIG. NO. SW08TA58GB SIZE 2.00"

 FEEDWATER CONTROL: ON-OFF _____ ELECT. MOD. X
 PNEUMATIC MOD. ATO _____ ATC _____
 LEVEL CONTROLLER 3051CD1A02A1AE5S5Q4 M
 VALVE MAKE 4446PMSE / 7285C SIZE 1.25"
 3-VALVE BY-PASS: P
 GATE POWELL FIG. NO. GA08TA58GB SIZE 2.00"
 GLOBE POWELL FIG. NO. GL08TA58GB SIZE 2.00"

 CHEMICAL FEED VALVES: LS RS
 N/S FIG. NO. _____ SIZE _____
 N/S FIG. NO. _____ SIZE _____
 CHEMICAL FEED CONNECTION WITH DIFFUSER
 SURFACE BLOWDOWN VALVE(S): LS RS M
 METERING AVP-3131 / NANO BO-W SIZE .75"
 STOP POWELL FIG. NO. GA08TA58GB SIZE 1.00"
 FULL LENGTH SKIMMER N/S
 BOTTOM BLOWOFF VALVE(S): LS RS M
 EVERLASTING FIG. NO. 4000-S(57) SIZE 2.00"
 EVERLASTING FIG. NO. 4060-S(57) SIZE 2.00"

COMPLETED BY: _____ SALES: <u>JB</u> <u>3/19/24</u> ENG.: <u>MM</u> <u>7/1/24</u> ACCOUNT MANAGER: <u>SCOTT AVERY</u>	BOILER TO MEET THE FOLLOWING CODES: UL LABEL <input type="checkbox"/> <input type="checkbox"/> LOW FIRE/ELECTRIALTEST ONLY <input checked="" type="checkbox"/> FULL FIRETEST <input type="checkbox"/>	REVISIONS														
	<input type="checkbox"/> M SHIPPED MOUNTED <input type="checkbox"/> N/A NOT APPLICABLE <input type="checkbox"/> L SHIPPED LOOSE <input type="checkbox"/> N/S NOT SUPPLIED <input type="checkbox"/> P PREPIPED/SHIPPED LOOSE <input type="checkbox"/> CF CUSTOMER FURNISHED	<table border="1"> <thead> <tr> <th>REV.</th> <th>DATE</th> <th>BY</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </tbody> </table>	REV.	DATE	BY											
REV.	DATE	BY														



J.O. NO. 9000457

SPEC SHEET

PAGE 2 OF 3

S.O. NO. 249237

BURNER S/N

BURNER ORDERED

P.O. NO.

BURNER MFG: POWER FLAME

MODEL LNICM12-GO-40

FUELS: GAS TYPE NATURAL

OIL: # 2 AIR ATOMIZING PRESSURE ATOMIZING

FIRING RATE: GAS 42000 CFH OF 1000 BTU/CF

300 GPH OF 140000 BTU/GAL

BURNER OPERATION: FULL MODULATION

OTHER

AVAILABLE GAS PRESSURE 25 PSIG

VOLTAGE: 480 VOLT 60 HZ 3 PH

CODES: UL CSD-1 X IRI FM

NFPA 85 X OTHER

GAS TRAIN: SIZE 4" MOUNTED LS RS X

OIL SIDE:

CONTROL PANEL: MOUNTED LS RS

CIRCULATING OIL PUMP: LS RS L

BOILER SKID BURNER REMOTE X

PRESSURE ATOMIZING OIL PUMP: SKID MOUNTED LS RS

FGR PIPING 12" LS RS X NOx 30PPM

BLOWER MOTOR 60 HP ODP TEFC X HI EFF X

AIR COMPRESSOR: LS RS L

FLAME SAFEGUARD FIREYE YB110

SPECIAL INSTRUCTIONS

BOILER COMBUSTION CONTROL SYSTEM ALLEN BRADLEY

COMPACTLOGIX

CONTROL PANEL IS 72" X 36" X 18" NEMA 4X

VFD (SHIPS LOOSE)

DRAFT PRESSURE GAUGE (Ashcroft 60 1189AS02L N10/10IW)

NATURAL GAS FLOW METER WITH BURNER SHIPS LOOSE

OIL FLOW METER WITH BURNER SHIPS LOOSE

Mitchell, Zenovia A CIV USN NAVFAC WASHINGTON DC (USA)

From: Kristen Lentz <klentz@greenlandenterprises.com>
Sent: Friday, August 29, 2025 3:44 PM
To: Matt Steele; Mitchell, Zenovia A CIV USN NAVFAC WASHINGTON DC (USA)
Subject: [Non-DoD Source] RE: Bldg. 712 Steam B - Boiler Submittal

Hi Matt,

Thank you!

@Mitchell, Zenovia A CIV USN NAVFAC WASHINGTON DC (USA) please see response from Superior's Engineer.



Kristen Lentz
Assistant Project Manager
Greenland Enterprises, Inc.
11864 Fishing Point Drive
Newport News, VA 23606
Email: klentz@greenlandenterprises.com
Mobile: 757-660-3398
Web: www.greenlandenterprises.com

From: Matt Steele <msteele@superiorboiler.com>
Sent: Friday, August 29, 2025 3:09 PM
To: Kristen Lentz <klentz@greenlandenterprises.com>
Subject: Fw: Bldg. 712 Steam B - Boiler Submittal

Kristen,

It is our standard to provide stack measurements in SCFM like you provided below. Since it is a standardized flow, flow rate in SCFM does not vary with temperature, elevation, duct size, or barometric pressure.

Using the 283°F out of the economizer, 60% relative humidity, and 105 FASL, actual volumetric flow is 12532 ACFM. The exit of the economizer is 31.5" x 19.5" for a cross sectional area of 4.26 ft². With this area, velocity is 49 ft/s.

If the duct size or operating conditions change, the flow rate will also change.

Thank you

Matt

From: Kristen Lentz <klentz@greenlandenterprises.com>
Sent: Friday, August 29, 2025 1:18 PM

To: Matt Steele <msteele@superiorboiler.com>
Subject: FW: Bldg. 712 Steam B - Boiler Submittal

Matt,

See Zenovia's question I can't answer. Can you shed some light here?



Kristen Lentz

Assistant Project Manager

Greenland Enterprises, Inc.

11864 Fishing Point Drive

Newport News, VA 23606

Email: klentz@greenlandenterprises.com

Mobile: 757-660-3398

Web: www.greenlandenterprises.com

From: Mitchell, Zenovia A CIV USN NAVFAC WASHINGTON DC (USA) <zenovia.a.mitchell.civ@us.navy.mil>

Sent: Friday, August 29, 2025 12:23 PM

To: Kristen Lentz <klentz@greenlandenterprises.com>

Subject: Re: Bldg. 712 Steam B - Boiler Submittal

Hi Kristen,

Thank you, however flue gas flow was already provided. I am looking for the exhaust exit velocity measured in ft/sec. Thank you!



Kristen Lentz
Assistant Project Manager
Greenland Enterprises, Inc.
11864 Fishing Point Drive
Newport News, VA 23606
Email: klentz@greenlandenterprises.com
Mobile: 757-660-3398
Web: www.greenlandenterprises.com

From: Matt Steele <msteele@superiorboiler.com>
Sent: Thursday, August 28, 2025 4:04 PM
To: Kristen Lentz <klentz@greenlandenterprises.com>
Subject: Re: Bldg. 712 Steam B - Boiler Submittal

Kristen,

Stack is 32" ID

Flue gas Flow is 8,769 SCFM@100%, 6577 SCFM @75%, 4,384 SCFM @ 50%, and 2192 SCFM@25% firing rates.

Thank you

Matt Steele
VP of Sales & Marketing
Superior Boiler
3524 E. 4th Ave
Hutchinson, KS 67501
www.superiorboiler.com

From: Kristen Lentz <klentz@greenlandenterprises.com>
Sent: Thursday, August 28, 2025 10:25 AM
To: Matt Steele <msteele@superiorboiler.com>
Subject: RE: Bldg. 712 Steam B - Boiler Submittal

Matt,

Disregard information previously requested. Zenovia located boiler specs but is not looking for Boiler stack diameter and velocity. Can you provide this? Thanks,

Kristen Lentz
Assistant Project Manager
Greenland Enterprises, Inc.
11864 Fishing Point Drive
Newport News, VA 23606
Email: klentz@greenlandenterprises.com
Mobile: 757-660-3398