

# Floodplain Permit – Final Inspection Checklist

Permit No.: \_\_\_\_\_

Address: \_\_\_\_\_

Flood Protection Elevation (FPE) for this structure is \_\_\_\_\_ ft. (BFE + freeboard)

- No basement; the floor is not subgrade on all sides.
- All living areas elevated to or above the FPE; areas below the FPE are used only for parking of vehicles, building access and limited storage.
- Flood openings on at least 2 on different walls; 1 sq. in. per sq. ft. of enclosed area, or engineered openings; bottom of opening is no more than 1 ft. above finished grade; will automatically equalize water pressure.
- All construction materials used in enclosed areas below the FPE are flood damage-resistant; the area is unfinished.
- All electrical equipment and connections elevated to or above the FPE (limited GFCI protected outlets may be permitted below the FPE).
- HVAC equipment elevated to or above the FPE.
- Fuel tanks elevated to or above the FPE, or anchored to prevent flotation (vent pipes must be elevated to or above the FPE).
- Attached garage and/or detached accessory structure anchored and vented, with no electrical equipment below the FPE.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

A final inspection has been conducted and the structure is found to be compliant with the above floodplain requirements. An Elevation Certificate is on file, and shows the lowest floor to be elevated to \_\_\_\_\_ ft.

Inspected By: \_\_\_\_\_

Date: \_\_\_\_\_