

PERMITTED ITEMS CHECKLIST: ITEMS BELOW BFE - ZONE A

PERMIT NO. _____ PROPERTY OWNER _____

MAP PANEL _____ MAP DATE _____ FLOOD ZONE _____

BASE FLOOD ELEVATION _____ FLOOD PROTECTION ELEVATION _____

PLAN REVIEWER _____ DATE OF REVIEW _____

<u>Zone A</u>	<u>Allowed</u>	<u>Plan Review Consistency</u>	<u>Inspection Consistency</u>	<u>Corrective Measures to be taken</u>
1. Enclosed area below the BFE [at least two water equalizing vents on different walls, 1 sq.in./ 1 sq.ft., no more than 1 ft. above grade]	<u>Yes</u>	_____	_____	_____
2. All construction material below BFE flood resistant	<u>Yes</u>	_____	_____	_____
3. Residential garage, unfinished walls, vented	<u>Yes</u>	_____	_____	_____
4. Limited unfinished storage areas, vented	<u>Yes</u>	_____	_____	_____
5. Floodproofed walls (non-residential only)	<u>Yes</u>	_____	_____	_____
6. Electrical outlets	<u>No</u>	_____	_____	_____
7. Electrical meters	<u>No</u>	_____	_____	_____
8. Clothes washer/dryer	<u>No</u>	_____	_____	_____
9. Air conditioning equipment/components	<u>No</u>	_____	_____	_____
10. Heating equipment/ components	<u>No</u>	_____	_____	_____
11. Hot water tank	<u>No</u>	_____	_____	_____
12. Water pressure tank (anchored) if electrical parts and connections are elevated	<u>Yes</u>	_____	_____	_____
13. 2nd refrigerator in storage area/garage	<u>No</u>	_____	_____	_____
14. Bathroom(s)	<u>No</u>	_____	_____	_____
15. Gas tanks (if anchored to prevent flotation)	<u>Yes</u>	_____	_____	_____

PERMITTED ITEMS CHECKLIST: ITEMS BELOW BFE - ZONE V

PERMIT NO. _____ PROPERTY OWNER _____

MAP PANEL _____ MAPDATE _____ FLOOD ZONE _____

BASE FLOOD ELEVATION _____ FLOOD PROTECTION ELEVATION _____

PLAN REVIEWER _____ DATE OF REVIEW _____

<u>Zone V</u>	<u>Allowed</u>	<u>Plan Review Consistency</u>	<u>Inspection Consistency</u>	<u>Corrective Measures to be taken</u>
1. Open area, below lowest Floor for parking/access	<u>Yes</u>	_____	_____	_____
2. Breakaway walls enclosing area below lowest floor, used for storage, parking, or access	<u>Yes</u>	_____	_____	_____
3. Minimal entrance foyer	<u>Yes</u>	_____	_____	_____
4. Floodproofed walls	<u>No</u>	_____	_____	_____
5. Electrical outlets	<u>No</u>	_____	_____	_____
6. Electrical meters	<u>No</u>	_____	_____	_____
7. Clothes washer/dryer	<u>No</u>	_____	_____	_____
8. Air conditioning equipment/components	<u>No</u>	_____	_____	_____
9. Heating equipment/components	<u>No</u>	_____	_____	_____
10. Hot water tank	<u>No</u>	_____	_____	_____
11. 2nd refrigerator in storage area/garage	<u>No</u>	_____	_____	_____
12. Bathroom(s) in garage, limited storage or building access	<u>No</u>	_____	_____	_____
13. Water pressure tank if anchored, provided that all electrical components and connections are elevated	<u>Yes</u>	_____	_____	_____