

*Dover Bridge Park*  
*Annual Drinking Water Quality Report for 2023*  
*PWSID #0050209*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two (2) potable groundwater wells: Mobil Manor 1 (identifier CO730188), near 1 mile east of Tanyard; approximately 300 feet south of Maryland route 331, which draws from the Federalsburg aquifer and Well 2 (identifier CO880191) near 2 miles west of Bethlehem, approximately 1,000 feet south of Maryland route 331, which draws from the Piney Point aquifer. We have a source water protection plan available from our office that provides more information such as potential sources of contamination. I'm pleased to report that our drinking water is safe and meets all federal and state requirements.

**The following report shows our water quality and what it means:**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water utility, please contact **Jack Bradshaw, Vice President of Operations for Prostart at 443-903-4758**. We want our valued customers to be informed about their water utility.

Dover Bridge Mobile Home Park management has contracted Prostart to be its water treatment plant operations firm. Prostart routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of **January 1 to December 31, 2023**. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.*

*Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.*

*Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.*

*Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a*

water system must follow.

**Maximum Contaminant Level** - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained at the Caroline County Library or by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1-800-426-4791. We’re proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

MCL’s are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink two liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

REGULATED CONTAMINANT TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>						
Beta/photon emitters (2021)	N	5.5	pCi/1	0	50	Decay of natural and man-made deposits
<b>Inorganic Contaminants</b>						
Chromium (2021)	N	16.1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride (2021)	N	2.3	ppm	4	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen) (2023)	N	<1	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Lead (distribution) (2023)	N	0	ppb	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits.
Copper (distribution) (2023)	N	0.03645	ppm	1.3	AL = 1.3	Erosion of Natural Deposits; leaching from wood preservatives; corrosion of household plumbing systems.

*Note: Test results are for 2023 unless otherwise noted; all contaminants do not require annual testing. These are the most recent available results.*

In addition to the contaminants listed above, Prostart also samples the water at the Dover Bridge Mobile Home Park monthly for bacteriology. I am pleased to report that throughout 2023, the results were completely negative for coliform and e. coli.

**Lead:** Prostart samples the water at the Dover Bridge Mobile Home Park every three years for lead and copper, most recently in 2023. Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Dover Bridge Mobile Home Park is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Prostart VP of Operations, Jack Bradshaw at 443-903-4758. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is

available at <http://www.epa.gov/safewater/lead>.

**PFAS** – or per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

The Maryland Department of the Environment (MDE) conducted a PFAS monitoring program for Community Water Systems from 2020 to 2022. The results are available on MDE's website: <https://mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx>.

The Environmental Protection Agency (EPA) proposed regulations for 6 PFAS compounds in drinking water in March 2023. The MCLs for PFOA and PFOS are proposed to be 4.0 parts per trillion (ppt). The proposal for HFPO-DA (GenX), PFBS, PFNA and PFHxS is to use a Hazard Index of 1.0 (unitless) to determine if the combined levels of these PFAS pose a risk and require action. The 5th Unregulated Contaminant Monitoring Rule (UCMR5) began testing for 29 PFAS compounds and lithium in 2023, and testing will run through 2025. The UCMR5 should test all community water systems with populations of at least 3300 people. Three randomly selected systems in Maryland with populations less than 3300 people will also be tested under the UCMR5. Detections greater than the minimum reporting levels for each constituent should be reported in the CCR.

The Dover Bridge Mobile Home Park operated continuously in 2023, delivering an excellent quality of water directly drawn from the Piney Point and Federalsburg aquifers. We are dedicated to providing reliable service to our residents. Notable improvements during 2023 include promptly responding to leaks as they occur and replacing a door on the water treatment plant.

Thank you for allowing us to continue providing your family with clean, quality water this year. To maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all our customers. Thank you in advance for your attention to this Water Quality Report (CCR) for 2023.