

Annual Drinking Water Quality Report for 2023
Pleasant Hill Mobile Home Park, LLC
PWSID 0070230
April, 2024
Fay Brown/Owner

We're very pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is the Port Deposit Gneiss Fractured Rock Aquifer. We have two (2) active wells located in Pleasant Hill MHP. One of these draws from a depth of 75 feet and the other is much deeper at 275 feet.

This report shows our water quality and what it means.

A source water assessment plan has been prepared that provides more information such as potential sources of contamination. This plan is available thru the Cecil County Public Library or Maryland Department of the Environment (MDE). For more information call 1-800-633-6101. https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.aspx

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or your water, please contact Lori Hill at telephone number (443-350-4391) between the hours of 8:00 AM and 5:00 PM daily, Monday thru Friday.

Pleasant Hill Mobile Home Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2023. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Microgram per liter- one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Lead and Copper						
Copper (2023)	N	0.08	ppm	0	1.3	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
Lead (2023)	N	1.7	ppb	0	15	Corrosion of household plumbing systems; Erosion of natural deposits
Radioactive Contaminants						
Combined radium 226/228 (2023)	N	0.6	pCi/l	0	5	Erosion of natural deposits
Gross alpha excluding radon and uranium (2023)	N	2.3	pCi/l	0	15	Erosion of natural deposits
Inorganic Contaminants						
Nitrate (measured as Nitrogen) (2023)	N	1	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Barium (2022)	N	0.0215	ppm	2	2	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Chromium (2022)	N	4.8	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (2022)	N	0.2	ppm	4	4.0	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from aluminum and fertilizer factories
Unregulated Contaminants						
PFOA (2022)	N	1.59	ppt	N/A	N/A	Human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams.
PFBS (2022)	N	4.38	ppt	N/A	N/A	Human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams.

Note: Test results are for year 2023 or as otherwise indicated; All contaminants are not required to be tested for annually.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Pleasant Hill MHP is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Pleasant Hill MHP at 443-350-4391.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

The Maryland Department of the Environment (MDE) conducted a PFAS monitoring program for Community Water Systems from 2020 to 2022. The results are available on MDE's website: <https://mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx>.

The Environmental Protection Agency (EPA) finalized regulations for 6 PFAS compounds in drinking water in April 2024. The MCLs for PFOA and PFOS are each 4.0 parts per trillion (ppt). The MCLs for PFNA, PFHxS, and HFPO-DA (GenX chemicals) are each 10 ppt. Additionally, a mixture of two or more of the following chemicals (PFNA, PFHxS, HFPO-DA, and PFBS) will be regulated with a Hazard Index of 1 (unitless) to determine if the combined levels of these PFAS pose a risk and require action.

The 5th Unregulated Contaminant Monitoring Rule (UCMR5) began testing for 29 PFAS compounds and lithium in 2023, and testing will run through 2025. The UCMR5 should test all community water systems with populations of at least 3300 people. Three randomly selected systems in Maryland with populations less than 3300 people will also be tested under the UCMR5. Detections greater than the minimum reporting levels for each constituent should be reported in the CCR.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The Maryland Rural Water Association's State Circuit Rider assisted with the completion of this report.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Please call our office if you have questions. Our phone number is (443) 350-4391.