

Annual Drinking Water Quality Report For 2024

Laurel Water Supply, Inc.

PWSID 0080026

June 2025

We are pleased to present to you this year's Annual Water quality report. This report is designed to inform you about the water quality and service we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water. Our water source is one well which draws from the Patapsco Aquifer. Depth of the well is 729 feet.

A source water assessment plan has been completed for our system by the Maryland Department of the Environment's Water Supply Program that provides more information and its potential sources of contamination. This plan is available for review by contacting the Maryland Department of the Environment Water Supply Program. For more information call 1-800-633-6101. Results of the assessment can be found on the MDE website:

https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.aspx

We are pleased to report that our drinking water is safe and meets Federal and State requirements.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

An initial Service Line Inventory was submitted to the Maryland Department of the Environment on October 19, 2024. The report was submitted several days late due to service line investigation and lack of support resources. As a result, the water system received a violation which was resolved with report submission. The violation period lasted from the initial past due date to submission (10/17/2024 – 10/20/2024). Customer notices along with a summary of the inventory results were delivered on November 12, 2024. The full inventory report is available upon request.

Laurel Water Supply has completed the service line inventory required by U.S. EPA's Lead and Copper Rule Revisions (initial inventory due October 16th, 2024). For more information on our service line inventory please email laurelwatersupplyinc@gmail.com.

Through completing a records review, it has been determined that LWS has no Lead or Galvanized Replacement (GRR) service lines in the system-owned portion of its distribution system. Members have received notifications in cases where the lead status of their privately owned portion of the distribution system has an unknown lead status or galvanized replacement service lines. LWS did not identify any confirmed cases of lead service lines based on its investigation including all system owned portions of the system and customer portions of all service lines regardless of actual or intended use.

Construction records, meter replacements, and distribution maps were used to help us determine the composition of our systems service lines.

Laurel water Supply has reviewed all applicable sources of information to complete the inventory and will continue to identify and track service line materials as they are encountered during normal operations. Members are asked to please inform us of any changes to the privately owned portions of the distribution system resulting from maintenance or repair work. If, in the future, a Lead or Galvanized requiring replacement (GRR) service line is found within our system, we will prepare an updated inventory and submit to the Maryland Department of the Environment and in addition, the inventory will be made publicly available for water customers to view, and customer will be notified of any change in the service line material, if applicable.

For more information on our service line inventory please email laurelwatersupplyinc@gmail.com.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Laurel Water Supply is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Laurel Water Supply at laurelwatersupplyinc@gmail.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Laurel Water Supply routinely monitors for contaminants in your drinking water according to Federal and State laws. The table on the next page shows the results of our monitoring for the period of January 1st to December 31st, 2024.

The Maryland Rural Water Association's State Circuit Rider assisted with the completion of this report.

As water travels over land and underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals and radioactive substances. All drinking water including bottled drinking water may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants do not necessarily pose a health risk.

In the table below you will find many terms and abbreviations you might not be familiar with. To you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Microgram per liter- one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - (mandatory language) The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - (mandatory language) The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non Detect (ND)

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected / Range	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Stage 2 Disinfection Byproducts						
TTHM (Distribution) (2023) (Total trihalomethanes)	N	1.1	ppb	0	80	By-product of drinking water chlorination
Inorganic Contaminants						
Fluoride (2022)	N	0.6	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Barium (2022)	N	0.0022	ppm	2	2	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Chromium (2022)	N	2.2	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
Lead (distribution) (2020)	N	1.8	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Chlorine (2024)	N	0.8	ppm	4	4	Water Additive used to control microbes

Radioactive Contaminants

Beta/photon emitters (2020)	N	6.9	pCi/L	0	50	Decay of natural and man-made deposits
Combined radium 226/228 (2020)	N	0.7	pCi/L	0	5	Erosion of natural deposits
Gross alpha excluding radon and uranium (2020)	N	2.2	pCi/L	0	15	Erosion of natural deposits
Radium-228 4/15/2020	N	0.7	pCi/L	0	5	Erosion of natural deposits

<i>Lead and Copper</i>	Violation Y/N	90 th Percentile	Range of Tap Sampling	Units	MCLG or MRDLG	(AL Limits) / # Sites Over	Likely Source of Contamination
Copper (distribution) (2023)	N	0.11	ND (.05)-0.14	ppm	1.3	AL= 1.3 Zero (0)	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Lead (distribution) (2023)	N	ND (<5)	ND (<5)- ND (<5)	ppb	0	AL= 15 Zero (0)	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
--------------------------------------	---	---------	---------------------	-----	---	--	--

Note: Test results are for year 2023 or as otherwise indicated; All contaminants are not required to be tested for annually.

Violation:

LEAD AND COPPER RULE REVISIONS--LSL INVENTORY-INITIAL (2E) Violation. We failed to complete and submit our initial service line inventory that was due to MDE by October 16, 2024. *The inventory was completed and submitted on 10/19/2024.*

LEAD AND COPPER RULE REVISIONS--LSL REPORTING-INITIAL (4G) VIOLATION. We failed to complete and submit our initial service line inventory that was due to MDE by October 16, 2024. *The inventory was completed and submitted on 10/19/2024.*

If you have any questions about this report or concerning your water, please contact me at number or e-mail listed below. We want our residents to be informed about their water. We will make every effort to continue to maintain a safe and dependable water system at a minimum cost and maximum benefit to all our residents.

Sincerely,

Christopher Nisbett
Secretary, Laurel Water Supply, Inc.
laurelwatersupplyinc@gmail.com