

# Garrett Children's Center

## 2024 Drinking Water

### Quality Report

PWSID: 011-0227



## Important Information Concerning Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2024. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service (MES), an Agency of the State of Maryland, operates the water treatment facility and prepared this report on behalf of Garrett Children's Center, formally known as Savage Mountain Boys Camp.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate and identifies several hundred drinking water contaminants, establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely complete Sanitary Surveys as part of their ongoing inspection and monitoring program. MES provides safe dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney** at **410-729-8361**, or by e-mail at [jjanney@menv.com](mailto:jjanney@menv.com).

### For More Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact **Steve Baer with the Maryland Department of Juvenile Services at 301-777-2486**.

**T**he Garrett Children's Center water comes from five (5) drilled wells in the Conemaugh formation. The waterworks consists of two (2) 2,000-gallon below grade clarifiers, a 6,000-gallon reservoir, an 8,000-gallon hydro-pneumatic tank, and the distribution network. The treatment facility consists of two (2) green sand filters and a chemical feed system. Sodium Hypochlorite, Potassium Permanganate, and Soda Ash are fed. Soda Ash is added for pH control and Potassium Permanganate is used to regenerate the green sand filters. Sodium Hypochlorite is used to disinfect the water prior to distribution. The Maryland Department of the Environment has performed an assessment of the source water. A copy of the results is available. Please call **Maryland Environmental Service at 410-729-8350**.

### Inside This Issue:

Definitions	2
Special Points of Interest	2
Water Quality Report	3
Sources of Drinking Water	3
Water Security	4
Lead Prevention	4
Polyfluoroalkyl Substances	5

**S**ome people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from **the Safe Drinking Water Hotline (1-800-426-4791)**.


# Garrett Children's Center Treated Water Quality Report 2024

## Definitions:

- ◆ **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ **Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- ◆ **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water
- ◆ **Turbidity** - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of "cloudiness" of the water.
- ◆ **NTU – Nephelometric Turbidity Units.** Units of measurement used to report the level of turbidity or "cloudiness" in the water.
- ◆ **pCi/l** - Picocuries per liter. A measure of radiation.
- ◆ **ppb** - parts per billion or micrograms per liter
- ◆ **ppm** - parts per million or milligrams per liter

## Special Points of Interest

- The water at Garrett Children's Center is tested for over 120 different compounds.
- The Garrett Children's Center drinking water met all State and Federal requirements.
- Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791).**



# Garrett Children’s Center Treated Water Quality Report 2024

Contaminant	Unit	Meets Primary Standard Yes/ No	State Primary Standard MCL	State Secondary standard SMCL	Highest Level Detected	Range
<b>Regulated at the Treatment Plant</b>						
Barium (2022 Testing) Typical Source of Contamination: Erosion of natural deposits	ppb	Yes	2000	2000	59	59 – 59
<b>Regulated in the Distribution System</b>						
Chlorine Source: Water additive used to control microbes	ppm	Yes	4	4	0.98*	0.73 – 0.98
						*Annual Rolling Average
Total Trihalomethanes (TTHM) (2023 Sampling)	ppb	Yes	80	N/A	24.5	24.5 – 24.5
Haloacetic Acids (HAA5) (2023 Sampling) Typical Source of Contamination: By-product of drinking water disinfection	ppb	Yes	60	N/A	10.4	10.4 – 10.4
<b>Regulated in the Distribution System</b>						
Lead (2023 Testing) No sites exceeded the lead action level during this monitoring period.	ppb	Yes	15	0	<2*	<2 – <2**
					*90 <sup>th</sup> percentile	
Copper (2023 Testing) No sites exceeded the copper action level during this monitoring period.	ppb	Yes	1300	1300	53*	7.9 – 59**
					*90 <sup>th</sup> percentile	
Typical Source of Contamination: Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservative						
<b>**A “&lt;” symbol signifies a ND or non-detect, meaning the result was below the detection limit for testing</b>						

The table above lists all the drinking water contaminants that were detected during the 2024 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2024. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

*In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA’s regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.*



# Garrett Children’s Center Treated Water Quality Report 2024

## Service Line Inventory

An initial Service Line Inventory was completed by the Garrett Children’s Center and submitted to the Maryland Department of the Environment on 04/07/2025, past the required MDE submittal date. As a result, the Service Line Inventory requirement was fulfilled once received. No lead or galvanized needing replacement lines were detected. A copy of the Service Line Inventory Statement is available upon request by contacting [stephen.baer@maryland.gov](mailto:stephen.baer@maryland.gov).

### Initial Service Line Inventory Violation

Analyte	Violation Type	Violation Period
Lead & Copper Rule Revisions	LSL Inventory - Initial	10/17/2024 to 04/07/2025
<b>Violation Explanation:</b> We failed to complete our initial service line inventory that was due to MDE by 10/16/2024. The inventory was submitted to MDE on 04/07/2025.		
Lead & Copper Rule Revisions	LSL Reporting - Initial	10/17/2024 to 04/07/2025
<b>Violation Explanation:</b> We failed to complete our initial service line inventory that was due to MDE by 10/16/2024. The inventory was submitted to MDE on 04/07/2025.		

## Lead Prevention

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Garrett Children’s Center is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Jay Janney at [jjanney@menv.com](mailto:jjanney@menv.com) for a list of eligible labs. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

## Water Security is Everyone's Responsibility

Water system security continues to be an enormously important issue. If you notice suspicious activities in or around local water utilities, such as persons cutting or climbing facility fencing, loitering, tampering with equipment or other similar activities, please contact your local law enforcement agency immediately by dialing 911.

# Garrett Children’s Center Treated Water Quality Report 2024

## Polyfluoroalkyl Substances

PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

The Maryland Department of the Environment (MDE) conducted a PFAS monitoring program for Community Water Systems from 2020 to 2022. PFAS sampling was conducted for the Garrett Children’s Center Water Treatment System during 2024. The 2024 results are available below and on MDE’s website:

<https://mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx>.

The Environmental Protection Agency (EPA) finalized regulations for 6 PFAS compounds in drinking water in April 2024. The MCLs for PFOA and PFOS are each 4.0 parts per trillion (ppt). The MCLs for PFNA, PFHxS, and HFPO-DA (GenX chemicals) are each 10 ppt. Additionally, a mixture of two or more of the following chemicals (PFNA, PFHxS, HFPO-DA, and PFBS) will be regulated with a Hazard Index of 1 (unitless) to determine if the combined levels of these PFAS pose a risk and require action.

The 5<sup>th</sup> Unregulated Contaminant Monitoring Rule (UCMR5) began testing for 29 PFAS compounds and lithium in 2023. The UCMR5 should test all community water systems with populations of at least 3300 people. Three randomly selected systems in Maryland with populations less than 3300 people will also be tested under the UCMR5. Detections greater than the minimum reporting levels for each constituent should be reported in the CCR.

2024 PFAS Results							
Parameter	PFOS (ppt)	PFOA (ppt)	PFHxS (ppt)	GenX Chemicals (ppt)	PFNA (ppt)	PFBS (ppt)	Hazard Index (ppt)
Result	<0.5	<0.5	<0.3	<0.4	<0.6	<0.3	0
Limit	4	4	10*	10*	10*	2000*	1
Compliant	Yes	Yes	Yes	Yes	Yes	Yes	Yes

\*These parameters contribute to the calculation for the Hazard Index

*If you have any questions about this report or your drinking water, please call Jay Janney at 410-729-8350 or email your request to [jjanney@menv.com](mailto:jjanney@menv.com).*

