

Eastern Correctional Institution

2023 Drinking Water

Quality Report

PWSID: 019-0013



Important Information Concerning Your Drinking Water

We're pleased to present to you the Annual Water Quality Report for 2023. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service (MES), an Agency of the State of Maryland, operates the water treatment facility and prepared this report on behalf of Eastern Correctional Institution.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate and identifies several hundred drinking water contaminants, establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely complete Sanitary Surveys as part of their ongoing inspection and monitoring program. MES provides safe dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney at 410-729-8361**, or by e-mail at jjanney@menv.com.

For More Information:

For the opportunity to ask more questions or participate in decisions that may affect your drinking water quality, please contact Mr. David Aalders the Facility Maintenance Supervisor for the Eastern Correctional Institution at (410) 845-400 ext. 4046.

Inside This Issue:

Definitions	2
Special Points of Interest	2
Water Quality Report	3
Sources of Drinking Water	4
Lead Prevention	4
Polyfluoroalkyl Substances	4

The Eastern Correctional Institution water works consists of three drilled wells in the Patapsco formation, a treatment facility, two 500,000-gallon elevated water storage tanks and a distribution network. The treatment facility consists of three reverse osmosis units and the associated pre-treatment filters. Liquid chlorine is fed to help disinfect the water and calcium chloride is fed to adjust hardness. The Maryland Department of the Environment has performed an assessment of the source water. To receive a copy of these results, please call **Maryland Environmental Service at 410-729-8350**.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from **the Safe Drinking Water Hotline (1-800-426-4791)**.

Eastern Correctional Institution Treated Water Quality Report 2023

Definitions:

- ◆ **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ◆ **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- ◆ **Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
- ◆ **Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water
- ◆ **Turbidity** - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of "cloudiness" of the water.
- ◆ **pCi/l** - Picocuries per liter. A measure of radiation.
- ◆ **ppb** - parts per billion or micrograms per liter
- ◆ **ppm** - parts per million or milligrams per liter
- ◆ **ppt** - parts per trillion or nanograms per liter

Special Points of Interest

The water at Eastern Correctional Institution is tested for over 120 different compounds. The Eastern Correctional Institution's drinking water met all State and Federal drinking water requirements. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791).

Contaminants That May Be Present in Source Water

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Eastern Correctional Institution Treated Water Quality Report 2023

Regulated at the Treatment Plant			
Contaminant	Highest Level Allowed (EPA's MCL)	Highest Level Detected	Ideal Goal (EPA's MCLG)
Gross Beta - (2018 Testing) Source: Erosion of natural deposits *EPA considers 50 pCi/L to be the level of concern for beta particles ** Because the beta particle results were below 50 pCi/l, no testing for individual beta particle constituents was required	50 pCi/l*	6.1 pCi/l**	0.0 pCi/l
Fluoride (2023 Testing) Source: Water additive which promotes strong teeth	4 ppm	1.1 ppm (Range: 1.0 to 1.1 ppm)	4 ppm
Barium (2023 Testing) Source: Erosion of natural deposits; Water additive; Discharge from fertilizer and aluminum factories	2000 ppb	17 ppb (Range: 11 to 17 ppb)	2000 ppb
Regulated in the Distribution System	Highest Level Allowed (EPA's MCL)	Highest Level Detected	Ideal Goal (EPA's MCLG)
Total Trihalomethanes (TTHM) (2023 Testing) Source: By-product of drinking water disinfection	80 ppb	16.3 ppb	n/a
Haloacetic Acids (HAA5) (2023 Testing) Source: By-product of drinking water disinfection	60 ppb	3.7 ppb	n/a
Chlorine Source: Water additive to control microbes. * Annual Rolling Average of monthly results	4 ppm	0.6 ppm (Range: 0.6 - 0.6 ppm)	4 ppm
Regulated in the Distribution System	Action Level	90th percentile	Ideal Goal
Copper (2022 Testing) Source: Corrosion of household plumbing fixtures and systems; erosion of natural deposits; leaching from wood preservatives	1300 ppb	538 ppb	1300 ppb
Lead (2022 Testing) Source: Corrosion of household plumbing fixtures and systems; erosion of natural deposits	15 ppb	< 2 ppb	0 ppb

The table above lists all the drinking water contaminants that were detected during the 2023 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2023. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

Eastern Correctional Institution Treated Water Quality Report 2023

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Lead Prevention

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Eastern Correctional Institute Water Treatment Plant is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, please contact Jay Janney at jjanney@menv.com for a list of laboratories in your area that provide drinking water testing. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Polyfluoroalkyl Substances

PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater, and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

The Maryland Department of the Environment (MDE) conducted a PFAS monitoring program for Community Water Systems from 2020 to 2022. The results are available on MDE's website: <https://mde.maryland.gov/PublicHealth/Pages/PFAS-Landing-Page.aspx>. No PFAS sampling was conducted for the Eastern Correctional Institution's Water Treatment System during 2022-2023.

The Environmental Protection Agency (EPA) finalized regulations for 6 PFAS compounds in drinking water in April 2024. The MCLs for PFOA and PFOS are each 4.0 parts per trillion (ppt). The MCLs for PFNA, PFHxS, and HFPO-DA (GenX chemicals) are each 10 ppt. Additionally, a mixture of two or more of the following chemicals (PFNA, PFHxS, HFPO-DA, and PFBS) will be regulated with a Hazard Index of 1 (unitless) to determine if the combined levels of these PFAS pose a risk and require action.