

2022 Annual Drinking Water Quality Report Beaver Run Mobile Home Park MD0090222

In compliance with Safe Drinking Water Act amendments by Congress of 1996 and subsequent Federal and State regulations, Beaver Run is pleased to provide this annual water quality report for calendar year 2021. Beaver Run routinely monitors for contaminants in your drinking water. The source of drinking water is from ground water and is serviced by five wells. A source water assessment has been performed by the Maryland Department of the Environment and is accessible on their website at:

https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.aspx

For more information on the source of your water and the significant potential sources of contamination, contact the Maryland Water Supply Program at the Maryland Department of the Environment at (410) 537-3000 or visit the web: https://mde.maryland.gov/programs/Water/water_supply/Pages/index.aspx.

Is my water safe?

We are very pleased to provide you with this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and vigilantly safeguard our water supplies. We are proud to report that our system is not in violation of a maximum contaminant level. Last year our system was cited for failing to provide the annual water quality to our customers in a timely manner. We have since been returned to compliance status.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

How do we monitor for contaminants?

Beaver Run MHP routinely monitors for contaminants in your drinking water according to Federal and State laws. The below tables show the results of our monitoring for the period of January 1st to December 31st, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It is important to remember that the presence of these contaminants does not necessarily pose a health risk.

Why may there be contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Important Drinking Water Definitions:

- MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risks for safety. MCLG allows for margin of safety.
- MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- AL: Action Level. The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- ALG: Action Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
- MRDLG: Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbe contaminants.
- MRDL: Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbe contaminants.
- TT: Treatment Technique – a required process intended to reduce the level of a contaminant in drinking water
- Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Units of Measurement & Conversions:

- NA: Not applicable
- ppm: parts per million, or milligrams per liter (mg/L)
- mrem/yr: millirems per year (a measure of radiation absorbed by the body)
- pCi/L: picocuries per liter (a measure of radioactivity)
- ppb: parts per billion, or micrograms per liter (µg/L)

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminant	Collection Date	MCLG	MCL	Highest No. of Positive	Violation	Typical Source
Microbiological Contaminants:						
Total Coliform	2021	0	1 positive monthly sample	1	No	Naturally present in the environment

Contaminant (units)	Collection Date	MCLG	MCL	Highest Level Detected	Range		Violation	Typical Source
					Low	High		
Disinfectants and Disinfection By-Products:								
Chlorine (ppm)	2021	MRDLG=4	MRDL=4	0.7	0.5	0.7	No	Water additive used to control microbes
Haloacetic Acids HAA5 (ppb)	2020	No goal for the total	60	2.3	2.3	2.3	No	Byproduct of chlorination
Total Trihalomethanes (ppb)	2020	No goal for the total	80	0.77	0.77	0.77	No	Byproduct of chlorination
Inorganic Contaminants:								
Arsenic (ppb)	2021	0	10	8	0	12	No	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

Fluoride (ppm)	2021	4	4	2.5	2.2	2.5	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Barium (ppm)	2021	2	2	0.002	0	0.002	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Radioactive Contaminants:								
Beta/photon emitters (pCi/L)	2021	0	50	10.3	5.7	10.3	No	Decay of natural and man-made deposits.
Combined Radium 226/228 (pCi/L)	2021	0	5	0.4	0.2	0.4	No	Erosion of natural deposits.

*EPA considers 50pCi/l to be the level of concern for beta particles

Lead

If present, elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Heritage MHP is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water [treatment](#) or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Chlorine

Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Fluoride

Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease including pain and tenderness of the bones. Fluoride in water at half the MCL or more may cause mottling of children’s teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining and/or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

Arsenic

While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA’s standard balances the current understanding of arsenic’s possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Barium

Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Beta/photon Emitters

Certain minerals are radioactive and may emit a form of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Combined Radium

Some people who drink water containing radium-226 or -228 in excess of the MCL over many years may have an increased risk of getting cancer.

Beaver Run Mobile Home Park

For additional information or questions contact:

**c/o M Shapiro Group
31550 Northwestern Highway, Suite 220
Farmington Hills, MI 48334
Tim Brown, Community Manager
Office: 443-225-5108**

Prepared by: Water Testing Labs of Maryland, Inc.

For more information on contaminants in drinking water and its effects go to www.wtlmd.com