

TOWN OF EMMITSBURG - MD0100010
Annual Water Quality Report for the period of January 1 to December 31, 2021

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:
DAN FISSEL
301-600-6300 or dfissel@emmitsburgmd.gov

Este informe contiene información muy importante sobre el agua que usted bebe.
Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
- PFAS, Polyfluoroalkyl substances, large group of manmade chemicals and can last a long time in the environment and can

accumulate in the and food chain. Currently not regulated but EPA has issued a health Advisory Level @ 70 PPT (parts per trillion) combined PFOA and PFOS. Non-Detected in our System

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

A source water assessment has been performed by the Maryland Department of the Environment and is accessible on their website at:

https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.aspx

Source Water Information				
Source Water Name		Type of Water	Report Status	Location
EMMITSBURG WELL 1 FR690288	FR690288	GW	Y	EMMITSBURG
EMMITSBURG WELL 2 FR035425	FR035425	GW	Y	EMMITSBURG
EMMITSBURG WELL 3 FR650432	FR650432	GW	Y	EMMITSBURG
EMMITSBURG WELL 4 FR941117	FR941117	GW	Y	NEAR 4 W OF EMMITSBURG APPROX. 290 FT N OF HAMPTON VALLEY RD
EMMITSBURG WELL 5 FR733572	FR733572	GW	Y	NEAR 2 MI W OF EMMITSBURG APPROX. 1 MI N OF HAMPTON VALLEY RD
RAINBOW LAKE	FR1976S014-03	SW	Y	8060 HAMPTON VALLEY RD

LEAD & COPPER

Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	9/18/2019	1.3	1.3	0.072	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

LEAD	9/18/2019	0	.015	<0.002	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
WATER QUALITY TEST RESULTS								
Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.							
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.							
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.							
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.							
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.							
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.							
ppm:	Milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.							
ppb:	Micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.							
na:	Not applicable.							

Water Quality Test Results

REGULATED CONTAMINANTS

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	Daily 2021	1.4	1.0 - 1.4	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	Quarterly 2021	21	6.6 – 31.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Total Trihalomethanes (TTHM)	Quarterly 2021	52	30.7 – 40.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	----------------	----	-------------	-----------------------	----	-----	---	--

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2021	<.001	<.001	0	10	ppb	n	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Barium	2021	0.009	0 - 0.009	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2021	<.001	<.001	100	100	ppb	n	Discharge from steel and pulp mills; Erosion of natural deposits.
Nitrate [measured as Nitrogen]	2021	.3	.3	10	10	ppm	N	Run off from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
PFAS	2021	Non-detect	Non-detect	NA	NA	ppt	N	Stains, water resist. fabrics cleaning prod. Paints cookware packaging firefighting foam
Combined Radium226/228	2021	1 pCi/L	1 pCi/L	0	5	pCi/L	N	Erosion of Natural Deposits

TURBIDITY	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	5 NTU	0..742 NTU	N	Soil runoff.
Lowest monthly % meeting limit	1.0 NTU	100%	N	Soil runoff.

Information Statement: Turbidity is a measurement of cloudiness of the water caused by suspended particles. We measure it because it is a good indicator of water quality and the effectiveness of our filtration.