

Metcom St. Mary's County Metropolitan Commission

Wild Goose Crest

PWSID # 0180056

2021 Annual Water Quality Report

“Investing in a water secure future for St. Mary's County”

Once again, we proudly present our Annual Water Quality Report. This edition covers all testing completed from January through December 31, 2021. We are pleased to tell you that our compliance with all State and Federal drinking water laws remains exemplary. As in the past, we are committed to delivering the best quality water. To that end, we remain vigilant in meeting the challenges of source water protection, water conservation, and community education while continuing to serve the needs of all of our water users.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

The source of your drinking water is one well in the Aquia Aquifer. Wells in this aquifer range in depth from 450 to 600 feet beneath the land's surface. Our water comes from confined aquifers. The confining units are thick, impervious clay layers that lie above and below the water-bearing sand strata. We are very fortunate that these confining layers naturally protect our aquifers. The only treatment your water receives is the addition of chlorine as a precautionary disinfecting agent prior to entering your water distribution system

We are pleased to report that our drinking water is safe and meets or exceeds Federal and State requirements. The following report is provided in compliance with Federal regulations and will be provided annually. This report outlines the quality of our drinking water and what that quality means.

For more information regarding your drinking water or water service, call Dwayne Cantrell at the St. Mary's County Metropolitan Commission at (301) 737-7400, Extension 104 Monday through Friday, 7:30 am to 4:30 pm, or visits our website www.metcom.org.

Metcom Mission

Construct, operate and maintain public water supply and public waste water conveyance and treatment systems in a manner that is sustainable, reliable, economical and safe for the Commission's employees, the environment, and the citizens of St. Mary's County; and to ensure that construction is timely and in accordance with the St. Mary's County Comprehensive (Land Use) Plan.

Substances That Might Be in Drinking Water

To ensure that tap water is safe to drink, the U.S. EPA imposes regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for the contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The source of drinking water (both tap and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, in some cases, radioactive material; and substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and which may also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

How Can I Get Involved?

The public is invited to participate in the Commission meetings and voice concerns about the drinking water or any Commission-related issues. The public meetings are held on the second and fourth Thursday of every month beginning at 3 pm. Meetings are held at the Commission's Main Office, 23121 Camden Way, California, MD 20619.

The Commission members and the election district (ED) that they represent are as follows: Gerald E. Meyerman (ED1); Roy Alvey (ED2/9); Joe Russell Chairman (ED3); Dale Antosh, (ED4/5); Keith S. Dugan (ED6); Robert A. Russell, (ED7); Keith Fairfax, Jr. Co-Chairman (ED8); Captain John Brabazon USN Commanding Officer, Patuxent River NAS; and the Director of the St. Mary's County Metropolitan Commission, George Erichsen.

St. Mary's County Metropolitan Commission
23121 Camden Way
California, MD 20619
www.metcom.org

Water Conservation Tips

Water conservation measures are an important first step in protecting our water supply. Such measures not only save the supply of our source water, but can also save you money by reducing your water bill.

Here are a few suggestions:

Conservation measures inside your home include:

Fix leaking faucets, pipes, toilets, etc.

Replace old fixtures; install water saving devices in faucets, toilets, and appliances;

Wash only full loads of laundry;

Do not use the toilet for trash disposal;

Take shorter showers;

Do not let the water run while shaving or brushing teeth;

Soak dishes before washing;

Run dishwasher only when full.

DEFINITIONS

In this report you will find many terms and abbreviations you might not be familiar with. To help you understand these terms, we have provided the following definitions:

ND = Non-Detects

Indicates that the substance was not found by laboratory analysis.

ppm = Parts Per Million or Milligrams Per Liter (mg/l)

One part per million corresponds to one minute in two years or a single penny in \$10,000.00.

ppb = Parts Per Billion or Micrograms Per Liter (ug/l)

One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.00.

pCi/L = Picocuries Per Liter

Picocuries per liter is a measure of the radioactivity in water.

AL = Action Level

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. (Note: Only applies to copper and lead levels)

MCLG = Maximum Contaminant Level Goal

The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL = Maximum Contaminant Level

The “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

N/A = Non-Applicable

The EPA has established no minimum levels.

Substances That Might Be in Drinking Water

It is important to understand that the EPA has determined that the detection of these substances in the drinking water does not constitute a known threat to public health at levels less than the MCL. MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect. The St. Mary’s County Metropolitan Commission’s water has proved to be below those levels for the contaminants listed.

The St. Mary’s County Metropolitan Commission found some regulated contaminants present in your water system at levels below the Maximum Contaminant Level (MCL). These levels have been determined by the EPA to be safe. These contaminants are shown below, along with the MCLG and MCL for each one detected.

Although we ran tests for over 75 regulated contaminants, only the following listed substances were found. For a complete list of tested, undetected substances, contact the Water Division at (301) 737-7400.

Substance	Date Tested	Unit	MCL	MCLG	Level Detected	Violation	Possible Sources
Distribution							
TTHM’s Total Trihalomethane	2020	ppb	80	N/A	7.9	N	By-product of drinking water disinfection
HAA5’s Haloacetic Acids	2020	ppb	60	N/A	8.7	N	By-product of drinking water disinfection
Copper	2019	ppm	1.3	AL=1.3	0.055	N	Erosion of natural deposits; Leaching from wood preservative; Corrosion of household plumbing systems.

Chlorine	2021	ppm	4	4	1.6	N	Water additive used to control microbes.
Regulated Inorganic Contaminants						N	
Fluoride	2021	ppm	4.0	4.0	0.41	N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Barium	2021	Ppm	2	2	0.015	N	Discharge of drilling waste, metal refineries; Erosion of natural deposits.
Radioactive Contaminants						N	
Combined Radium	2019	pCi/L	5	0	0.8	N	Erosion of natural deposits
Beta/photon emitters	2016	pCi/L	50	0	5.8	N	Decay of natural and man-made deposits
Synthetic Organic contaminants including pesticides and herbicides							
Ethylene dibromide	2021	ppt	50	0	10		Discharge from petroleum refineries
Volatile Organic Contaminants							
Ethylbenzene	2020	ppb	700	700	0.5	N	Discharge from petroleum refineries
Xylenes	2020	ppm	10	10	0.0068	N	Discharge from petroleum factories: Discharge from chemical factories.
Un-regulated							
Radon	2013	pCi/L	N/A	N/A	247	N	Naturally occurring gas caused by the decay of uranium
PFOA/PFOS	2021	ppt	70	N/A	N/D		By-product of man-made substance

Polyfluoroalkyl substances

"PFAS – short for per- and polyfluoroalkyl substances – refers to a large group of more than 4,000 human-made chemicals that have been used since the 1940s in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging and fire-fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in soil, surface water, groundwater and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

Radon

Radon is a radioactive gas that you cannot see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. (You should pursue radon removal for your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that are not too costly. For additional information, call your state radon program or call EPA's Radon Hotline (800-SOS-RADON).

Fluoride

No fluoride has been added to any of our water systems. However, small amounts of fluoride exist naturally in our water source. These levels may not meet the recommended amounts for dental protection. You may wish to consult with your dental care provider to discuss fluoride supplements. To inquire about the amount of fluoride detected in the water system, please call the Water Division at (301) 737-7400 between the hours of 8:00 a.m. and 4:30 p.m.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The St. Mary's Metropolitan Commission is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.