



# TESTING FOR LEAD IN DRINKING WATER FOR MARYLAND PUBLIC AND NONPUBLIC SCHOOLS

Reporting Period July 2, 2022, to July 1, 2023

Prepared for:

Wes Moore, Governor  
State of Maryland  
and  
the Maryland General Assembly



**Maryland**  
Department of  
the Environment

Serena McIlwain  
Secretary



Carey M. Wright  
State Superintendent



## Background and Findings

House Bill (HB) 270 established a framework to reduce Maryland school children's exposure to lead in drinking water. HB 270 directed the Maryland Department of the Environment (MDE), in consultation with the Maryland State Department of Education (MSDE), Maryland Department of General Services (DGS), and Maryland Occupational Safety and Health (MOSH), to adopt regulations to require periodic testing for the presence of lead in each drinking water outlet located in an occupied public or nonpublic school building. The law required MDE to establish a stakeholder group and to gather information about the testing processes, protocols, and efforts undertaken by schools to test for and remediate lead. The law also required MDE, in consultation with MSDE, to provide a mechanism to grant waivers from testing to schools under certain circumstances. Furthermore, on or before Dec. 1, 2018, and each year thereafter, MDE and MSDE must jointly report to the Governor and the Maryland General Assembly on the findings of the lead testing conducted by schools.

The legislation defines an elevated level of lead as a lead concentration in drinking water that exceeds the standard recommended by the U.S. Environmental Protection Agency (EPA) in the most recent technical guidance (*3Ts for Reducing Lead in Drinking Water in Schools*). The Action Level for lead in the EPA's technical guidance, effective at the time, was 20 parts per billion (ppb).

HB 1253 (2019) strengthened the lead protection measures established in HB 270 by setting a lead level of no more than 5 ppb as a goal for schools. The law also provided a funding mechanism for schools to remediate drinking water outlets that exceeded this level and expanded the information that must be reported to the Governor and the Maryland General Assembly.

HB 636 (2021) further reinforced the lead protection measures established in both HB 270 and HB 1253 by altering the definition of an elevated level of lead from 20 to 5 ppb (effective June 1, 2021, and applied retroactively). This change significantly increased the number of drinking water outlets that were required to be removed from service immediately and remediated. In addition, the new law set a deadline of Aug. 1, 2022, for schools to complete remediation of drinking water outlets that had lead levels between 5 and 20 ppb if the samples were analyzed by a state-certified laboratory by June 1, 2021.

Maryland regulations establish a three-year testing frequency for all schools. This report, which will be made available to Maryland citizens through MDE's website, provides information on the results of validated lead samples collected from drinking water outlets in schools during the annual reporting cycle ending July 1, 2023, including:

- (1) The name and address of each school that has tested its drinking water for lead and reported the test results to the state during the reporting period (Table 1);
- (2) The name and address of each school found to have elevated levels of lead in its drinking water (Table 2); and
- (3) The type, location in the building, and use of each water outlet with an elevated level of lead (Table 2).

This report also includes results from validated lead sampling during previous reporting cycles (i.e., July 2, 2017, through July 1, 2022) that were not included in previous reports (Tables 3 and 4).

Over 430 schools submitted results of lead samples collected during the current reporting period (July 2, 2022, through July 1, 2023). Of these schools, MDE was able to review results from 205 schools (195 public schools and 10 nonpublic schools) and determine that all of the 205 schools reviewed have one or more valid samples (i.e., collected and analyzed in accordance with Code of Maryland Regulations (COMAR) 26.16.07.07). Review of the remaining schools' results is ongoing. Proper sample collection, recordkeeping, and reporting at the schools, laboratory analysis, and data review by MDE, are labor-intensive and time-consuming processes, and data received by MDE is often incomplete or contains errors. Due both to the quality and completeness of data received as well as the exacting nature of its review, MDE was only able to review and report on approximately one-half of the schools submitting lead sample results during this reporting period by the statutory deadline.

Ensuring rigorous quality control while also conducting data review in a timely manner constitutes a significant challenge for the ongoing implementation of the effort to test for lead in drinking water in schools. In response, MDE is undertaking several initiatives to further improve the quality, integrity, and tracking of the sampling and reporting process. MDE intends to use grant funds, awarded under Section 2107 of the Water Infrastructure Improvements for the Nation (WIIN) Act, to develop a database and a QR code-based, mobile-capable application to streamline sample collection and data tracking for drinking water outlets, and facilitate more rapid and accurate reporting from schools both to laboratories and MDE. Additionally, MDE is continually updating and refining its technical guidance, and has developed a series of training videos, which are now available on MDE's website. These information technology innovations and technical assistance efforts will improve data quality and expedite the review process for MDE, reducing the likelihood of a growing backlog.

Of the 205 schools for which data was reviewed and samples determined to be valid by MDE in this reporting cycle, 50% (101 public schools and 2 nonpublic schools) had one or more sample results exceeding Maryland's lead Action Level (AL) of 5 ppb. Of the approximately 4,200 valid samples collected from these 205 schools, about 11% had lead levels exceeding 5 ppb. When outlets used for drinking, food preparation, or cooking are found to have elevated levels of lead in the water, schools are required to prevent access to these outlets within 24 hours.

Maryland's goal is to eliminate any occurrence of elevated levels of lead in drinking water provided to approximately 1 million children by the nearly 3,000 public and nonpublic schools in the state. The significant reduction in the AL from 20 ppb to 5 ppb, effective June 1, 2021, coupled with continued testing and remediation, further reduces exposure to lead in drinking water, and is an important step in achieving this goal. In addition, the remediation funding mechanism provided under HB 1253 further supports MDE's goal to eliminate any occurrence of elevated lead levels in drinking water in schools.

## **List of Tables**

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023).....	5
Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023).....	25
Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022).....	73
Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022).....	81

[This page intentionally left blank]

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023)**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Allegany	Allegany High (New)	900 Seton Drive	Cumberland	21502	Public	Yes ****
Allegany	Beall Elementary	3 East College Avenue	Frostburg	21532	Public	Yes ****
Allegany	Bel Air Elementary	14401 Barton Boulevard	Cumberland	21502	Public	No ****
Allegany	Braddock Middle	909 Holland Street	Cumberland	21502	Public	Yes ****
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	21502	Public	Yes ****
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	21502	Public	Yes **, ****
Allegany	Cresaptown Elementary	13202 6th Avenue	Cresaptown	21502	Public	Yes ****
Allegany	Eckhart Alternative	17000 National Highway SW	Frostburg	21532	Public	Yes
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	21502	Public	Yes ****
Allegany	Frost Elementary	260 Shaw Street	Frostburg	21532	Public	Yes **, ****
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	21539	Public	Yes ****
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	21502	Public	Yes ****
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	21532	Public	Yes ****
Allegany	Mt. Savage Elementary/Middle	13201 New School Road NW	Mount Savage	21545	Public	Yes
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	21502	Public	Yes ****
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	21502	Public	Yes **
Allegany	South Penn Elementary	500 East Second Street	Cumberland	21502	Public	Yes ****
Allegany	Washington Middle	200 Massachusetts Avenue	Cumberland	21502	Public	Yes ****
Allegany	West Side Elementary	425 Paca Street	Cumberland	21502	Public	Yes
Allegany	Westernport Elementary	172 Church Street	Westernport	21562	Public	No ****
Allegany	Westmar Middle	16915 Lower George's Creek Road	Lonaconing	21539	Public	Yes ****
Anne Arundel	Arundel Middle	1179 Hammond Lane	Odenton	21113	Public	*
Anne Arundel	Belle Grove Elementary	4502 Belle Grove Road	Baltimore	21225	Public	No **, ***
Anne Arundel	Brooklyn Park Elementary	200 14th Avenue	Baltimore	21225	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Anne Arundel	Brooklyn Park Middle	200 Hammonds Lane	Baltimore	21225	Public	No **, ***, ****
Anne Arundel	Center of Applied Technology North	800 Stevenson Road	Severn	21144	Public	*
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	21037	Public	Yes ***
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	21037	Public	Yes **
Anne Arundel	Corkran Middle	7600 Quarterfield Road	Glen Burnie	21061	Public	Yes **, ***
Anne Arundel	Crofton Woods Elementary	1750 Urby Drive	Crofton	21114	Public	*
Anne Arundel	Eastport Elementary	420 Fifth Street	Annapolis	21403	Public	No **
Anne Arundel	Ferndale Early Education Center (EEC)	105 Packard Avenue	Glen Burnie	21061	Public	Yes **, ***
Anne Arundel	Germantown Elementary	200 Windell Avenue	Annapolis	21401	Public	No **
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	21060	Public	Yes **, ***
Anne Arundel	Glen Burnie Park Elementary	500 Marlboro Road	Glen Burnie	21061	Public	*
Anne Arundel	Glendale Elementary	105 Carroll Road	Glen Burnie	21060	Public	Yes ***
Anne Arundel	Hillsmere Elementary	3052 Arundel on the Bay Road	Annapolis	21403	Public	Yes ***
Anne Arundel	Hilltop Elementary	415 Melrose Avenue	Glen Burnie	21061	Public	Yes **, ***
Anne Arundel	Jacobsville Elementary	3801 Mountain Road	Pasadena	21122	Public	No **, ***
Anne Arundel	Lindale Middle	415 Andover Road	Linthicum	21090	Public	No **
Anne Arundel	Linthicum Elementary	101 School Lane	Linthicum	21090	Public	*
Anne Arundel	Marley Elementary	715 Cooper Road	Glen Burnie	21060	Public	No **, ***
Anne Arundel	Marley Glen Special Education	200 Scott Avenue	Glen Burnie	21060	Public	No **, ***
Anne Arundel	Marley Middle	10 Davis Court	Glen Burnie	21060	Public	*
Anne Arundel	North County High	10 East 1st Avenue	Glen Burnie	21061	Public	Yes **
Anne Arundel	North Glen Elementary	615 West Furnace Branch Road	Glen Burnie	21061	Public	No **, ***
Anne Arundel	Northeast Middle (Formerly George Fox Middle)	7922 Outing Avenue	Pasadena	21122	Public	Yes **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol



**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Anne Arundel	Oak Hill Elementary	34 Truckhouse Road	Severna Park	21146	Public	*
Anne Arundel	Oakwood Elementary	330 Oak Manor Drive	Glen Burnie	21061	Public	Yes **
Anne Arundel	Overlook Elementary	401 Hampton Road	Linthicum	21090	Public	No **,***
Anne Arundel	Park Elementary	201 East 11th Avenue	Baltimore	21225	Public	No **,***
Anne Arundel	Riviera Beach Elementary	8515 Jenkins Road	Pasadena	21122	Public	Yes **,***
Anne Arundel	Severna Park Elementary	6 Riggs Avenue	Severna Park	21146	Public	*
Anne Arundel	Shipley's Choice Elementary	310 Governor Stone Parkway	Millersville	21108	Public	No **
Anne Arundel	Solley Elementary	7608 Solley Road	Glen Burnie	21060	Public	Yes **,***
Anne Arundel	St. Paul's Lutheran School	308 Oak Manor Drive	Glen Burnie	21061	Nonpublic	*
Anne Arundel	Sunset Elementary	8572 Fort Smallwood Road	Pasadena	21122	Public	Yes **,***
Anne Arundel	Wesley Grove Pre-Kindergarten	1320 Dorsey Road	Hanover	21076	Nonpublic	*
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	21061	Public	Yes **,***
Baltimore City	Cheder Chabad	5713 Park Heights Avenue	Baltimore	21215	Nonpublic	No **
Baltimore City	Highlandtown Elementary/Middle (# 237)	231 South Eaton Street	Baltimore	21224	Public	*
Baltimore City	Woodbourne School	1301 Woodbourne Avenue	Baltimore	21239	Nonpublic	*
Baltimore County	All Stars Learning Center	1901 Middleborough Road	Essex	21221	Nonpublic	*
Baltimore County	Arbutus Elementary	1300 Sulphur Spring Road	Baltimore	21227	Public	Yes
Baltimore County	Arbutus Middle	5525 Shelbourne Road	Baltimore	21227	Public	*
Baltimore County	Battle Grove Elementary	7828 Saint Patricia Lane	Baltimore	21222	Public	*
Baltimore County	Battle Monument Special	7801 East Collingham Drive	Baltimore	21222	Public	*
Baltimore County	Bedford Elementary	7407 Dorman Drive	Baltimore	21208	Public	*
Baltimore County	Campfield Early Childhood Center	6834 Alter Street	Baltimore	21207	Public	*
Baltimore County	Carney Elementary	3131 East Joppa Road	Baltimore	21234	Public	*
Baltimore County	Catonsville Middle	2301 Edmondson Avenue	Baltimore	21228	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Cedarmere Elementary	17 Nicodemus Road	Reisterstown	21136	Public	*
Baltimore County	Charlesmont Elementary	7800 West Collingham Drive	Baltimore	21222	Public	No ***
Baltimore County	Chase Elementary	11701 Eastern Avenue	Baltimore	21220	Public	*
Baltimore County	Chatsworth Elementary	222 New Avenue	Reisterstown	21136	Public	No
Baltimore County	Cockeysville Middle	10401 Greenside Drive	Cockeysville	21030	Public	*
Baltimore County	Deep Creek Elementary	1101 East Homberg Avenue	Baltimore	21221	Public	*
Baltimore County	Dulaney High	255 Padonia Road	Timonium	21093	Public	*
Baltimore County	Dumbarton Middle	300 Dumbarton Road	Baltimore	21212	Public	*
Baltimore County	Dundalk Elementary (New Building)	2717 South Playfield Street	Baltimore	21222	Public	No **
Baltimore County	Dundalk High/Sollers Point Technical High	1901 Delvale Avenue	Baltimore	21222	Public	*
Baltimore County	Dundalk Middle	7400 Dunmanway	Baltimore	21222	Public	*
Baltimore County	Eastern Technical High	1100 Mace Avenue	Baltimore	21221	Public	*
Baltimore County	Elmwood Elementary	531 Dale Avenue	Baltimore	21206	Public	*
Baltimore County	Essex Elementary	100 Mace Avenue	Essex	21221	Public	*
Baltimore County	Featherbed Lane Elementary	6700 Richardson Road	Baltimore	21207	Public	*
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	21136	Public	*
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	21236	Public	*
Baltimore County	General John Stricker Middle	7855 Trappe Road	Baltimore	21222	Public	*
Baltimore County	George Washington Carver Center for Arts and Technology	938 York Road	Towson	21204	Public	*
Baltimore County	Glenmar Elementary	9700 Community Drive	Baltimore	21220	Public	*
Baltimore County	Halstead Academy	1111 Halstead Road	Baltimore	21234	Public	*
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	21093	Nonpublic	No
Baltimore County	Hebbsville Elementary	3335 Washington Avenue	Baltimore	21244	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Hernwood Elementary	9919 Marriottsville Road	Randallstown	21133	Public	*
Baltimore County	Hillcrest Elementary	1500 Frederick Road	Baltimore	21228	Public	*
Baltimore County	Honeygo Elementary	4816 East Joppa Road	Perry Hall	21128	Public	*
Baltimore County	Krieger Schechter Day School of Chizuk Amuno Congregation	8100 Stevenson Road	Baltimore	21208	Nonpublic	*
Baltimore County	Loch Raven High	1212 Cowpens Avenue	Baltimore	21286	Public	Yes **
Baltimore County	Loch Raven Technical Academy	8101 LaSalle Road	Baltimore	21286	Public	*
Baltimore County	Lutherville Laboratory	1700 York Road	Lutherville	21093	Public	*
Baltimore County	Lyons Mill Elementary	9435 Lyons Mill Road	Owings Mills	21117	Public	No **
Baltimore County	Mars Estates Elementary	1500 Homberg Avenue	Baltimore	21221	Public	*
Baltimore County	Martin Boulevard Elementary	210 Riverton Road	Baltimore	21220	Public	*
Baltimore County	Mays Chapel Elementary	12250 Roundwood Road	Timonium	21093	Public	No **
Baltimore County	McCormick Elementary	5101 Hazelwood Avenue	Baltimore	21206	Public	*
Baltimore County	Middle River Middle	800 Middle River Road	Baltimore	21220	Public	*
Baltimore County	Overlea High	5401 Kenwood Avenue	Baltimore	21206	Public	*
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	21117	Public	*
Baltimore County	Parkville High	2600 Putty Hill Avenue	Baltimore	21234	Public	*
Baltimore County	Parkville Middle	8711 Avondale Road	Baltimore	21234	Public	*
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	21236	Public	Yes
Baltimore County	Perry Hall High	4601 Ebenezer Road	Baltimore	21236	Public	*
Baltimore County	Pikesville High	7621 Labyrinth Road	Baltimore	21208	Public	*
Baltimore County	Pikesville Middle	7701 Seven Mile Lane	Baltimore	21208	Public	*
Baltimore County	Pine Grove Elementary	2701 Summit Avenue	Baltimore	21234	Public	*
Baltimore County	Pine Grove Middle	9200 Old Harford Road	Baltimore	21234	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Pinewood Elementary	200 Rickswood Road	Timonium	21093	Public	*
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	21093	Public	*
Baltimore County	Powhatan Elementary	3300 Kelox Road	Baltimore	21207	Public	*
Baltimore County	Randallstown Elementary	9013 Liberty Road	Randallstown	21133	Public	*
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	21133	Public	Yes **
Baltimore County	Ridge Ruxton School	6916 North Charles Street	Baltimore	21204	Public	*
Baltimore County	Rodgers Forge Elementary	250 Dumbarton Road	Baltimore	21212	Public	*
Baltimore County	Rossville Elementary	7649 Gum Spring Road	Baltimore	21237	Public	*
Baltimore County	Seneca Elementary	545 Carrollwood Road	Baltimore	21220	Public	Yes ***, ****
Baltimore County	Seven Oaks Elementary	9220 Seven Courts Road	Baltimore	21236	Public	*
Baltimore County	Sparrows Point Middle/High	7400 North Point Road	Baltimore	21219	Public	*
Baltimore County	St. Paul's School for Boys	11152 Falls Road	Brooklandville	21022	Nonpublic	*
Baltimore County	St. Paul's School for Girls	11232 Falls Road	Brooklandville	21022	Nonpublic	*
Baltimore County	St. Peter's Elementary School	7910 Belair Road	Baltimore	21236	Nonpublic	*
Baltimore County	St. Ursula School	8900 Harford Road	Parkville	21234	Nonpublic	*
Baltimore County	Stoneleigh Elementary	900 Pemberton Road	Baltimore	21212	Public	*
Baltimore County	Sudbrook Magnet Middle	4300 Bedford Road	Baltimore	21208	Public	Yes **
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	21209	Public	*
Baltimore County	Sussex Elementary	515 Woodward Drive	Baltimore	21221	Public	*
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	21117	Public	Yes **
Baltimore County	Timonium Elementary	2001 Eastridge Road	Timonium	21093	Public	*
Baltimore County	Torah Institute of Baltimore	35 Rosewood Lane	Owings Mills	21117-3704	Nonpublic	*
Baltimore County	Victory Villa Elementary	500 Compass Road	Baltimore	21220	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Villa Cresta Elementary	2600 Rader Avenue	Baltimore	21234	Public	*
Baltimore County	Wellwood International Elementary	2901 Smith Avenue	Baltimore	21208	Public	No **
Baltimore County	Windsor Mill Middle	8300 Windsor Mill Road	Baltimore	21244	Public	*
Baltimore County	Winfield Elementary	8300 Carlson Lane	Baltimore	21244	Public	*
Baltimore County	Woodbridge Elementary	1410 Pleasant Valley Drive	Baltimore	21228	Public	*
Baltimore County	Woodlawn Middle	3033 Saint Lukes Lane	Baltimore	21207	Public	*
Baltimore County	Woodmoor Elementary	3200 Elba Drive	Baltimore	21207	Public	*
Calvert	Calvert Middle	655 Chesapeake Boulevard	Prince Frederick	20678	Public	*
Calvert	Mill Creek Middle	12200 Southern Connector Boulevard	Lusby	20657	Public	*
Calvert	Windy Hill Middle	9560 Boyd's Turn Road	Owings	20736	Public	*
Caroline	Greensboro Elementary (New Building)	625 North Main Street	Greensboro	21639	Public	*
Caroline	Immanuel Lutheran Nursery School	121 Williamson Street	Preston	21655	Nonpublic	*
Cecil	Bay View Elementary	910 North East Road	North East	21901	Public	*
Cecil	Bohemia Manor Middle/High	2755 Augustine Herman Highway	Chesapeake City	21915	Public	*
Cecil	Cecil Manor Elementary	971 Elk Mills Road	Elkton	21921	Public	*
Cecil	Charlestown Elementary	550 Baltimore Street	Charlestown	21914	Public	*
Cecil	Gilpin Manor Elementary	203 Newark Avenue	Elkton	21921	Public	*
Cecil	Kenmore Elementary	2475 Singerly Road	Elkton	21921	Public	*
Cecil	North East Elementary	301 Thomas Avenue	North East	21901	Public	*
Cecil	Thomson Estates Elementary	203 East Thomson Drive	Elkton	21921	Public	*
Charles	Benjamin Stoddert Middle	2040 St. Thomas Drive	Waldorf	20601	Public	Yes **, ***
Charles	Dr. Gustavus Brown Elementary	421 University Avenue	Waldorf	20602	Public	Yes **, ***, ****
Charles	Dr. Samuel A. Mudd Elementary	820 Stone Avenue	Waldorf	20602	Public	No **, ***
Charles	F. B. Gwynn Educational Center	5998 Radio Station Road	La Plata	20646	Public	Yes **, ***, ****

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Charles	General Smallwood Middle	4990 Indian Head Highway	Indian Head	20640	Public	No **,***
Charles	Indian Head Elementary	4200 Indian Head Highway	Indian Head	20640	Public	No **,***
Charles	J.P. Ryon Elementary	12140 Vivian Adams Drive	Waldorf	20601	Public	No **,***
Charles	John Hanson Middle	3165 John Hanson Drive	Waldorf	20601	Public	No **,***
Charles	Milton Somers Middle	300 Willow Lane	La Plata	20646	Public	No **
Charles	Transition School	3155 John Hanson Drive	Waldorf	20601	Public	No **
Charles	Walter J. Mitchell Elementary	400 Willow Lane	La Plata	20646	Public	No **,***,****
Frederick	Ballenger Creek Elementary	5250 Kingsbrook Drive	Frederick	21703	Public	No
Frederick	Ballenger Creek Middle	5525 Ballenger Creek Pike	Frederick	21703	Public	No
Frederick	Brunswick Elementary	400 Central Avenue	Brunswick	21716	Public	No
Frederick	Brunswick High	101 Cummings Drive	Brunswick	21716	Public	Yes **
Frederick	Brunswick Middle	301 Cummings Drive	Brunswick	21716	Public	*
Frederick	Butterfly Ridge Elementary	601 Contender Way	Frederick	21704	Public	No
Frederick	Carroll Creek Montessori Public Charter School	7215 Corporate Court	Frederick	21703	Charter	*
Frederick	Carroll Manor Elementary	5624 Adamstown Road	Adamstown	21710	Public	No
Frederick	Catoctin High	14745 Sabillasville Road	Thurmont	21788	Public	No
Frederick	Church of the Brethren Learning Center	201 Fairview Avenue	Frederick	21701	Nonpublic	No
Frederick	Frederick Country Day Montessori & Arts School	1601 Wheyfield Drive	Frederick	21701	Nonpublic	No **
Frederick	Frederick High	650 Carroll Parkway	Frederick	21701	Public	No
Frederick	Gov. Thomas Johnson High	1501 North Market Street	Frederick	21701	Public	No
Frederick	Saint John's Catholic Prep	3989 Buckeystown Pike	Buckeystown	21717	Nonpublic	*
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	21001	Public	Yes
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	21014	Nonpublic	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Harford	New Covenant Christian School - Grammar School	128 St. Mary's Church Road	Abingdon	21009	Nonpublic	*
Howard	Applications and Research Lab	10920 Clarksville Pike (Route 108)	Ellicott City	21043	Public	*
Howard	Bonnie Branch Middle	4979 Ilchester Road	Ellicott City	21043	Public	No **
Howard	Burleigh Manor Middle	4200 Centennial Lane	Ellicott City	21042	Public	*
Howard	Cedar Lane School	11630 Scaggsville Road	Fulton	20759	Public	Yes **
Howard	Centennial High	4300 Centennial Lane	Ellicott City	21042	Public	No **
Howard	Chapelgate Christian Academy	2600 Olive Branch Way	Marriottsville	21104	Nonpublic	No **,***
Howard	Columbia Montessori School	10508 Marble Faun Court	Columbia	21044	Nonpublic	*
Howard	Ducketts Lane Elementary	6501 Ducketts Lane	Elkridge	21075	Public	*
Howard	Elkridge Elementary	7075 Montgomery Road	Elkridge	21075	Public	*
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	21075	Public	Yes **,***
Howard	Ellicott Mills Middle	4445 Montgomery Road	Ellicott City	21043	Public	Yes **
Howard	Global Children Montessori School	4790 Baugher Farm Road	Ellicott City	21043	Nonpublic	No **
Howard	Hammond High	8800 Guilford Road	Columbia	21046	Public	*
Howard	Hanover Hills Elementary	7030 Banbury Drive	Hanover	21076	Public	*
Howard	Harpers Choice Middle	5450 Beaverkill Road	Columbia	21044	Public	*
Howard	Hollifield Station Elementary	8701 Stonehouse Drive	Ellicott City	21043	Public	*
Howard	Homewood Center	10914 Clarksville Pike (Route 108)	Ellicott City	21042	Public	No **
Howard	Howard High	8700 Old Annapolis Road	Ellicott City	21043	Public	*
Howard	Ilchester Elementary	4981 Ilchester Road	Ellicott City	21043	Public	*
Howard	Lake Elkhorn Middle	6680 Cradlerock Way	Columbia	21045	Public	No
Howard	Lime Kiln Middle	11650 Scaggsville Road	Fulton	20759	Public	Yes **,***
Howard	Long Reach High	6101 Old Dobbin Lane	Columbia	21045	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Howard	Marriotts Ridge High	12100 Woodford Drive	Marriottsville	21104	Public	*
Howard	Mayfield Woods Middle	7950 Red Barn Way	Elkridge	21075	Public	*
Howard	Mount View Middle	12101 Woodford Drive	Marriottsville	21104	Public	*
Howard	Murray Hill Middle	9989 Winter Sun Road	Laurel	20723	Public	*
Howard	Oakland Mills High	9410 Kilimanjaro Road	Columbia	21045	Public	*
Howard	Oakland Mills Middle	9540 Kilimanjaro Road	Columbia	21045	Public	Yes
Howard	Patapsco Middle	8885 Old Frederick Road	Ellicott City	21043	Public	*
Howard	Phelps Luck Elementary	5370 Oldstone Court	Columbia	21045	Public	*
Howard	Reservoir High	11550 Scaggsville Road	Fulton	20759	Public	*
Howard	River Hill High	12101 Clarksville Pike (Route 108)	Clarksville	21029	Public	*
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	21042	Nonpublic	Yes **
Howard	Stevens Forest Elementary	6045 Stevens Forest Road	Columbia	21045	Public	No **
Howard	Swansfield Elementary	5610 Cedar Lane	Columbia	21044	Public	*
Howard	Talbott Springs Elementary	9550 Basket Ring Road	Columbia	21045	Public	*
Howard	Thomas Viaduct Middle	7000 Banbury Drive	Hanover	21076	Public	Yes **
Howard	Thunder Hill Elementary	9357 Mellenbrook Road	Columbia	21045	Public	*
Howard	Trinity School	4985 Ilchester Road	Ellicott City	21043	Nonpublic	Yes **, ***, ****
Howard	Veterans Elementary	4355 Montgomery Road	Ellicott City	21043	Public	*
Howard	Waverly Elementary	10220 Wetherburn Road	Ellicott City	21042	Public	*
Howard	Wilde Lake High	5460 Trumpeter Road	Columbia	21044	Public	*
Howard	Wilde Lake Middle	10481 Cross Fox Lane	Columbia	21044	Public	*
Montgomery	Arcola Elementary	1820 Franwell Avenue	Silver Spring	20902	Public	Yes **
Montgomery	Argyle Middle	2400 Bel Pre Road	Silver Spring	20906	Public	*
Montgomery	Ashburton Elementary	6314 Lone Oak Drive	Bethesda	20817	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol



**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Beall Elementary	451 Beall Avenue	Rockville	20850	Public	*
Montgomery	Bel Pre Elementary	13801 Rippling Brook Drive	Silver Spring	20906	Public	*
Montgomery	Bells Mill Elementary	8225 Bells Mill Road	Potomac	20854	Public	*
Montgomery	Beverly Farms Elementary	8501 Postoak Road	Potomac	20854	Public	*
Montgomery	Brookhaven Elementary	4610 Renn Street	Rockville	20853	Public	*
Montgomery	Cabin John Middle	10701 Gainsborough Road	Potomac	20854	Public	*
Montgomery	Churchill (Winston) High	11300 Gainsborough Road	Potomac	20854	Public	*
Montgomery	Covenant Life School	7503 Muncaster Mill Road	Gaithersburg	20877	Nonpublic	*
Montgomery	East Silver Spring Elementary	631 Silver Spring Avenue	Silver Spring	20910	Public	*
Montgomery	Eastern Middle	300 University Boulevard East	Silver Spring	20901	Public	No **, ***
Montgomery	Edison (Thomas) High	12501 Dalewood Drive	Silver Spring	20906	Public	*
Montgomery	Einstein (Albert) High	11135 Newport Mill Road	Kensington	20895	Public	No **
Montgomery	Ewing (Blair G.) Center	14501 Avery Road	Rockville	20853	Public	*
Montgomery	Farmland Elementary	7000 Old Gate Road	Rockville	20852	Public	*
Montgomery	Flower Valley Elementary	4615 Sunflower Drive	Rockville	20853	Public	*
Montgomery	Forcey Christian School	2130 East Randolph Road	Silver Spring	20904	Nonpublic	*
Montgomery	Forest Knolls Elementary	10830 Eastwood Avenue	Silver Spring	20901	Public	*
Montgomery	Forest Oak Middle	651 Saybrooke Oaks Boulevard	Gaithersburg	20877	Public	*
Montgomery	Gaithersburg Elementary	35 North Summit Avenue	Gaithersburg	20877	Public	*
Montgomery	Gaithersburg High	101 Education Boulevard	Gaithersburg	20877	Public	*
Montgomery	Gaithersburg Middle	2 Teachers' Way	Gaithersburg	20877	Public	*
Montgomery	Garrett Park Elementary	4810 Oxford Street	Kensington	20895	Public	Yes **
Montgomery	Georgian Forest Elementary	3100 Regina Drive	Silver Spring	20906	Public	*
Montgomery	Glen Haven Elementary	10900 Inwood Avenue	Silver Spring	20902	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	20902	Public	Yes **
Montgomery	Goshen Elementary	8701 Warfield Road	Gaithersburg	20879	Public	*
Montgomery	Grosvenor Center	5701 Grosvenor Lane	Bethesda	20014	Public	*
Montgomery	Harmony Hills Elementary	13407 Lydia Street	Silver Spring	20906	Public	No **
Montgomery	Heights School, The	10400 Seven Locks Road	Potomac	20854	Nonpublic	No **
Montgomery	Highland Elementary	3100 Medway Street	Silver Spring	20902	Public	*
Montgomery	Highland View Elementary	9010 Providence Avenue	Silver Spring	20901	Public	*
Montgomery	Hoover (Herbert) Middle	8810 Postoak Road	Potomac	20854	Public	*
Montgomery	JoAnn Leleck Elementary at Broad Acres	710 Beacon Road	Silver Spring	20903	Public	Yes **
Montgomery	Kemp Mill Elementary	411 Sisson Street	Silver Spring	20902	Public	*
Montgomery	Kennedy (John F.) High	1901 Randolph Road	Silver Spring	20902	Public	*
Montgomery	Kensington-Parkwood Elementary	4710 Saul Road	Kensington	20895	Public	*
Montgomery	Laytonsville Elementary	21401 Laytonsville Road	Laytonsville	20882	Public	*
Montgomery	Loiederman (A. Mario) Middle	12701 Goodhill Road	Silver Spring	20906	Public	*
Montgomery	Magruder (Col. Zadok) High	5939 Muncaster Mill Road	Rockville	20855	Public	No **, ****
Montgomery	Meadow Hall Elementary	951 Twinbrook Parkway	Rockville	20851	Public	*
Montgomery	Montgomery Blair High	51 University Boulevard East	Silver Spring	20901	Public	*
Montgomery	Montgomery Knolls Elementary	807 Daleview Drive	Silver Spring	20901	Public	*
Montgomery	Montgomery Village Middle	19300 Watkins Mill Road	Montgomery Village	20886	Public	*
Montgomery	Neelsville Middle	11700 Neelsville Church Road	Germantown	20876	Public	*
Montgomery	New Hampshire Estates Elementary	8720 Carroll Avenue	Silver Spring	20903	Public	*
Montgomery	Newport Mill Middle	11311 Newport Mill Road	Kensington	20895	Public	*
Montgomery	North Bethesda Middle	8935 Bradmoor Drive	Bethesda	20817	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Northwood High	919 University Boulevard West	Silver Spring	20901	Public	No **,****
Montgomery	Oak View Elementary	400 East Wayne Avenue	Silver Spring	20901	Public	*
Montgomery	Oakland Terrace Elementary	2720 Plyers Mill Road	Silver Spring	20902	Public	*
Montgomery	Odessa Shannon Middle	11800 Monticello Avenue	Silver Spring	20902	Public	*
Montgomery	Parkland Middle	4610 West Frankfort Drive	Rockville	20853	Public	*
Montgomery	Pine Crest Elementary	201 Woodmoor Drive	Silver Spring	20901	Public	No **
Montgomery	Piney Branch Elementary	7510 Maple Avenue	Takoma Park	20912	Public	*
Montgomery	Poole (John) Middle	17014 Tom Fox Avenue	Poolesville	20837	Public	*
Montgomery	Poolesville Elementary	19565 Fisher Avenue	Poolesville	20837	Public	*
Montgomery	Poolesville High	17501 West Willard Road	Poolesville	20837	Public	*
Montgomery	Potomac Glen Day School	9908 South Glen Road	Potomac	20854	Nonpublic	*
Montgomery	Resnik (Judith A.) Elementary	7301 Hadley Farms Drive	Gaithersburg	20879	Public	*
Montgomery	Richard Montgomery High	250 Richard Montgomery Drive	Rockville	20852	Public	No **,***
Montgomery	Rock Creek Valley Elementary	5121 Russett Road	Rockville	20853	Public	*
Montgomery	Rock View Elementary	3901 Denfeld Avenue	Kensington	20895	Public	*
Montgomery	Rockville High	2100 Baltimore Road	Rockville	20853	Public	*
Montgomery	Rolling Terrace Elementary	705 Bayfield Street	Takoma Park	20912	Public	*
Montgomery	Rosemont Elementary	16400 Alden Avenue	Gaithersburg	20877	Public	*
Montgomery	Seven Locks Elementary	9500 Seven Locks Road	Bethesda	20817	Public	*
Montgomery	Shriver (Sargent) Elementary	12518 Greenly Street	Silver Spring	20906	Public	*
Montgomery	Silver Spring International Middle	313 Wayne Avenue	Silver Spring	20907	Public	Yes **,****
Montgomery	Singer (Flora M.) Elementary	2600 Hayden Drive	Silver Spring	20902	Public	No **
Montgomery	Sligo Creek Elementary	500 Schuyler Road	Silver Spring	20910	Public	*
Montgomery	Sligo Middle	1401 Dennis Avenue	Silver Spring	20902	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Snowden Farm Elementary	22500 Sweetspire Drive	Clarksburg	20871	Public	*
Montgomery	Stedwick Elementary	10631 Stedwick Road	Montgomery Village	20879	Public	No **
Montgomery	Strathmore Elementary	3200 Beaverwood Lane	Silver Spring	20906	Public	*
Montgomery	Strawberry Knoll Elementary	18820 Strawberry Knoll Road	Gaithersburg	20879	Public	*
Montgomery	Summit Hall Elementary	101 West Deer Park Road	Gaithersburg	20877	Public	*
Montgomery	Takoma Park Elementary	7511 Holly Avenue	Takoma Park	20912	Public	*
Montgomery	Takoma Park Middle	7611 Piney Branch Road	Silver Spring	20910	Public	No **
Montgomery	Viers Mill Elementary	11711 Joseph Mill Road	Silver Spring	20906	Public	*
Montgomery	Walter Johnson High	6400 Rock Spring Drive	Bethesda	20814	Public	*
Montgomery	Washington Grove Elementary	8712 Oakmont Street	Gaithersburg	20877	Public	*
Montgomery	Watkins Mill Elementary	19001 Watkins Mill Road	Montgomery Village	20879	Public	*
Montgomery	Watkins Mill High	10301 Apple Ridge Road	Gaithersburg	20879	Public	*
Montgomery	Wayside Elementary	10011 Glen Road	Potomac	20854	Public	No **, ****
Montgomery	Weller Road Elementary	3301 Weller Road	Silver Spring	20906	Public	*
Montgomery	Wheaton High	12401 Dalewood Drive	Silver Spring	20906	Public	*
Montgomery	Wheaton Woods Elementary	4510 Faroe Place	Rockville	20853	Public	*
Montgomery	Whetstone Elementary	19201 Thomas Farm Road	Gaithersburg	20879	Public	*
Montgomery	White Oak Middle	12201 New Hampshire Avenue	Silver Spring	20904	Public	*
Montgomery	Wood (Earle B.) Middle	14615 Bauer Drive	Rockville	20853	Public	*
Montgomery	Woodfield Elementary	24200 Woodfield Road	Gaithersburg	20879	Public	*
Montgomery	Wyngate Elementary	9300 Wadsworth Drive	Bethesda	20817	Public	*
Prince George's	Accokeek Academy (Upper Campus)	14400 Berry Road	Accokeek	20607	Public	No **
Prince George's	Andrew Jackson Academy	3500 Regency Parkway	Forestville	20747	Public	Yes **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Prince George's	Arrowhead Elementary	2300 Sansbury Road	Upper Marlboro	20774	Public	Yes **
Prince George's	Barack Obama Elementary	12700 Brooke Lane	Upper Marlboro	20772	Public	No **
Prince George's	Barnaby Manor Elementary	2411 Owens Road	Oxon Hill	20745	Public	No **
Prince George's	Beacon Heights Elementary	6929 Furman Parkway	Riverdale	20737	Public	Yes **
Prince George's	Beltsville Academy	4300 Wicomico Avenue	Beltsville	20705	Public	Yes **
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	20746	Public	Yes **
Prince George's	Benjamin Stoddert Middle	2501 Olson Street	Temple Hills	20748	Public	No **
Prince George's	Benjamin Tasker Middle	4901 Collington Road	Bowie	20715	Public	*
Prince George's	Bladensburg Elementary	4915 Annapolis Road	Bladensburg	20710	Public	Yes **
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	20715	Public	Yes **
Prince George's	Bradbury Heights Elementary	1401 Glacier Avenue	Capitol Heights	20743	Public	No **
Prince George's	Buck Lodge Middle	2611 Buck Lodge Road	Adelphi	20783	Public	*
Prince George's	Calverton Elementary	3400 Beltsville Road	Beltsville	20705	Public	Yes **, ****
Prince George's	Capitol Heights Elementary	601 Suffolk Avenue	Capitol Heights	20743	Public	Yes **
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	20912	Public	Yes **
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	20784	Public	Yes **
Prince George's	Central High at Forestville	7001 Beltz Drive	Forestville	20747	Public	No **
Prince George's	Cesar Chavez Elementary	6609 Riggs Road	Hyattsville	20782	Public	Yes **
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	20715	Public	Yes **
Prince George's	Charles Carroll Middle	6130 Lamont Drive	New Carrollton	20784	Public	No **
Prince George's	Cherokee Lane Elementary	2617 Buck Lodge Road	Hyattsville	20783	Public	No **
Prince George's	Chillum Elementary	1420 Chillum Road	Hyattsville	20782	Public	Yes **
Prince George's	College Park Academy	5751 Rivertech Court	Riverdale	20737	Charter	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Prince George's	Columbia Park Elementary	1901 Kent Village Drive	Landover	20785	Public	Yes **
Prince George's	Concord Elementary	2004 Concord Lane	District Heights	20747	Public	Yes **
Prince George's	Cooper Lane Elementary	3817 Cooper Lane	Landover Hills	20784	Public	No **
Prince George's	District Heights Elementary	2200 County Road	District Heights	20747	Public	Yes **
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	20785	Public	Yes **
Prince George's	Doswell E. Brooks Elementary	1301 Brooke Road	Capitol Heights	20743	Public	Yes **
Prince George's	Dwight D. Eisenhower Middle	13725 Briarwood Drive	Laurel	20708	Public	No **
Prince George's	Eleanor Roosevelt High	7601 Hanover Parkway	Greenbelt	20770	Public	No **
Prince George's	Elizabeth C. Rieg Regional School	15542 Peach Walker Drive	Mitchellville	20716	Public	No **
Prince George's	Ernest Everett Just Middle	1300 Campus Way North	Mitchellville	20721	Public	No **
Prince George's	Flintstone Elementary	800 Comanche Drive	Oxon Hill	20745	Public	Yes **
Prince George's	Forest Heights Elementary	200 Talbert Drive	Oxon Hill	20745	Public	Yes **
Prince George's	Fort Foote Elementary	8300 Oxon Hill Road	Fort Washington	20744	Public	Yes **
Prince George's	Fort Washington Forest Elementary	1300 Fillmore Road	Fort Washington	20744	Public	No **
Prince George's	Frances R. Fuchs Early Childhood Center	11011 Cherry Hill Road	Beltsville	20705	Public	Yes **
Prince George's	Friendly High	10000 Allentown Road	Fort Washington	20744	Public	No **
Prince George's	Glenarden Woods Elementary	7801 Glenarden Parkway	Lanham	20706	Public	*
Prince George's	Glenn Dale Elementary	6700 Glenn Dale Road	Glenn Dale	20769	Public	No **
Prince George's	Glenridge Elementary	7200 Gallatin Street	Landover Hills	20784	Public	Yes **
Prince George's	Gwynn Park Middle	8000 Dyson Road	Brandywine	20613	Public	Yes **
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	20716	Public	Yes **
Prince George's	Highland Park Elementary	6501 Lowland Drive	Landover	20785	Public	No **
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	20740	Public	Yes **
Prince George's	Indian Queen Elementary	9551 Fort Foote Road	Fort Washington	20744	Public	No **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Prince George's	Isaac J. Gourdine Middle	8700 Allentown Road	Fort Washington	20744	Public	Yes **
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	20744	Public	Yes **
Prince George's	James E. Duckworth Regional School	11201 Evans Trail	Beltsville	20705	Public	Yes **
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	20708	Public	Yes
Prince George's	John H. Bayne Elementary	7010 Walker Mill Road	Capitol Heights	20743	Public	No **
Prince George's	John Hanson Montessori	6360 Oxon Hill Road	Oxon Hill	20745	Public	No **
Prince George's	Judith P. Hoyer Montessori	929 Hill Road	Landover	20785	Public	No **
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	20715	Public	Yes **
Prince George's	Kingsford Elementary	1401 Enterprise Road	Mitchellville	20721	Public	*
Prince George's	Lake Arbor Elementary	10205 Lake Arbor Way	Mitchellville	20721	Public	No **
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	20784	Public	Yes **
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	20783	Public	Yes
Prince George's	Laurel High	8000 Cherry Lane	Laurel	20707	Public	Yes **
Prince George's	Lewisdale Elementary	2400 Banning Place	Hyattsville	20783	Public	Yes **
Prince George's	Mary Harris Mother Jones Elementary	2405 Tecumseh Street	Adelphi	20783	Public	Yes **
Prince George's	NASA Goddard Child Development Center (Building 90)	8800 Greenbelt Road	Greenbelt	20771	Nonpublic	No **, ***
Prince George's	Nicholas Orem Middle	6100 Editor's Park Drive	Hyattsville	20782	Public	No **
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	20747	Public	Yes **
Prince George's	Northwestern High	7000 Adelphi Road	Hyattsville	20782	Public	No **
Prince George's	Oaklands Elementary	13710 Laurel-Bowie Road	Laurel	20708	Public	*
Prince George's	Parkdale High	6001 Good Luck Road	Riverdale	20737	Public	Yes **
Prince George's	Port Towns Elementary	4351 58th Avenue	Bladensburg	20710	Public	No **
Prince George's	Potomac Landing Elementary	12500 Fort Washington Road	Fort Washington	20744	Public	No **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Prince George's	Princeton Elementary	6101 Baxter Drive	Suitland	20746	Public	No **
Prince George's	Ridgecrest Elementary	6120 Riggs Road	Hyattsville	20783	Public	No **
Prince George's	Riverdale Elementary	5006 Riverdale Road	Riverdale	20737	Public	*
Prince George's	Robert Frost Elementary	6419 85th Avenue	New Carrollton	20784	Public	No **
Prince George's	Rogers Heights Elementary	4301 58th Avenue	Bladensburg	20710	Public	No **
Prince George's	Rosa L. Parks Elementary	6111 Ager Road	Hyattsville	20782	Public	No **
Prince George's	Rose Valley Elementary	9800 Jacqueline Drive	Fort Washington	20744	Public	*
Prince George's	Samuel P. Massie Academy	3301 Regency Parkway	Forestville	20747	Public	No **
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	20770	Public	Yes **
Prince George's	Templeton Elementary	6001 Carters Lane	Riverdale	20737	Public	*
Prince George's	Thomas S. Stone Elementary	4500 34th Street	Mount Rainier	20712	Public	No **
Prince George's	Thurgood Marshall Middle	4909 Brinkley Road	Temple Hills	20748	Public	Yes **
Prince George's	Tulip Grove Elementary	2909 Trainor Lane	Bowie	20715	Public	No
Prince George's	Waldon Woods Elementary	10301 Thrift Road	Clinton	20735	Public	No **
Prince George's	Whitehall Elementary	3901 Woodhaven Lane	Bowie	20715	Public	No **
Prince George's	William W. Hall Academy	5200 Marlboro Pike	Capitol Heights	20743	Public	No **
Prince George's	Woodridge Elementary	5001 Flintridge Drive	Hyattsville	20784	Public	No **
Prince George's	Yorktown Elementary	7301 Race Track Road	Bowie	20715	Public	Yes **
St. Mary's	George Washington Carver Elementary	46155 Carver School Boulevard	Lexington Park	20653	Public	*
St. Mary's	Great Mills High	21130 Great Mills Road	Great Mills	20634	Public	*
St. Mary's	Leonardtwn Elementary	22885 Duke Street	Leonardtwn	20650	Public	*
St. Mary's	St. John's School	43900 St. John's Road	Hollywood	20636	Nonpublic	*
Talbot	Easton Elementary (New Building)	307 Glenwood Avenue	Easton	21601	Public	Yes
Talbot	Easton High	723 Mecklenburg Avenue	Easton	21601	Public	No

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol



**Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Talbot	Easton Middle	201 Peachblossum Road	Easton	21601	Public	No
Talbot	St. Michaels Elementary	100 Seymour Avenue	St. Michaels	21663	Public	No
Talbot	St. Michaels Middle/High	200 Seymour Avenue	St. Michaels	21663	Public	No
Washington	Cascade Elementary	14519 Pennersville Road	Cascade	21719	Public	*
Washington	Claud E. Kitchens Outdoor School at Fairview	12808 Draper Road	Clear Spring	21722	Public	*
Washington	Clear Spring High	12630 Broadfording Road	Clear Spring	21722	Public	*
Washington	Hancock Elementary	290 West Main Street	Hancock	21750	Public	*
Washington	Hancock Middle/High	289 West Main Street	Hancock	21750	Public	*
Washington	Northern Middle	701 Northern Avenue	Hagerstown	21740	Public	*
Washington	Pangborn Elementary	195 Pangborn Boulevard	Hagerstown	21740	Public	*
Washington	Public Service Academy	701 Frederick Street	Hagerstown	21740	Public	*
Washington	Ruth Ann Monroe Primary	1311 Yale Drive	Hagerstown	21740	Public	*
Washington	Smithsburg Middle	68 North Main Street	Smithsburg	21783	Public	Yes ****
Wicomico	Beaver Run Elementary	31481 Old Ocean City Road	Salisbury	21804	Public	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

[This page intentionally left blank]

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023)**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Allegany High (New)	900 Seton Drive	Cumberland	Public	Faucet, Cold	Kitchen	Wall by Serving Line Kitchen 240	Sink	CO	5.66
Allegany	Beall Elementary	3 East College Avenue	Frostburg	Public	Faucet, Cold	Classroom	Classroom 120D	Sink	NC	7.13
Allegany	Beall Elementary	3 East College Avenue	Frostburg	Public	Faucet, Cold	Classroom	Classroom 010C	Sink	NC	15.90
Allegany	Beall Elementary	3 East College Avenue	Frostburg	Public	Faucet, Cold	Classroom	Classroom 001C	Sink	NC	10.50
Allegany	Beall Elementary	3 East College Avenue	Frostburg	Public	Faucet, Cold	Classroom	Classroom 001B	Sink	NC	8.65
Allegany	Beall Elementary	3 East College Avenue	Frostburg	Public	Faucet, Cold	Classroom	Classroom 114H	Sink	NC	13.60
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom	Classroom 122	Sink	NC	7.31
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom	Classroom 254	Sink	NC	7.25
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 123	Sink	CO	8.54
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 123	Sink	CO	19.10
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 123	Sink	CO	24.60
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 123	Sink	NC	18.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Nurse's Office/Health Room	Health Room Mens Bathroom 102AA	Sink	NC	12.20
Allegany	Braddock Middle	909 Holland Street	Cumberland	Public	Faucet, Cold	Staff Workroom	ISS (In School Suspension) Bathroom 107C	Sink	NC	6.85
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen 111B	Kettle	CO	12.00
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen 111BB	Sink (Right)	CO	6.05
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 120D	Sink	NC	8.42
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 155	Sink	NC	18.90
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 130	Sink	NC	5.99
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 120E	Sink	NC	12.40
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Kitchen	Dish-Room 111BA	Sink	CO	1150.00
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen 111BC	Sink	CO	5.87

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Teachers' Lounge/Break Room	Teachers Lounge 127	Sink	CO	7.35
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Teachers' Lounge/Break Room	Teachers Lounge 126	Sink	CO	15.00
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	Public	Combination Sink - Faucet, Cold	Media Center	Media Center 146	Sink	NC	7.23
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Spigot (with threadings for hose connection)	Classroom (Home Economics)	Culinary Arts 207	Serving Line Warmer Fill	NC	6.81
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen 216	Dish/Pot and Pans Sink Left Side	NC	11.10
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Combination Sink - Faucet, Cold	Bathroom	Health Room Bathroom 105	Sink	NC	6.18
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Combination Sink - Faucet, Cold	Cafeteria	Cafeteria 216 Behind Serving Line	Hand Sink	NC	6.51
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen 216	Sink by Microwave	CO	7.86
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen 216	Sink In Work Table	CO	6.94

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Cresaptown Elementary	13202 6th Avenue	Cresaptown	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen Dish-Room 021	Sink Right	NC	17.50
Allegany	Eckhart Alternative	17000 National Highway SW	Frostburg	Public	Faucet, Cold	Classroom	Classroom 113	Sink	NC	9.18
Allegany	Eckhart Alternative	17000 National Highway SW	Frostburg	Public	Faucet, Cold	Classroom	Classroom 121	Sink	NC	8.43
Allegany	Eckhart Alternative	17000 National Highway SW	Frostburg	Public	Faucet, Cold	Kitchen	Kitchen 104B	Sink	NC	7.68
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Classroom	Classroom 126	Sink	NC	5.67
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Classroom	Classroom 120	Sink	NC	8.46
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Classroom	Classroom 312	Sink	NC	33.60
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Kitchen	Kitchen Dish-room 147I	Hand Wash Sink	NC	15.20
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Kitchen	Kitchen 147 by Storage Room 148	Hand Wash Sink	NC	9.74
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Faucet, Cold	Storage Room/Area	Storage Room 315A	Sink	NC	9.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen 147	Kettle (Right)	CO	7.45
Allegany	Frost Elementary	260 Shaw Street	Frostburg	Public	Faucet, Cold	Kitchen	Kitchen 149C	Sink	CO	5.54
Allegany	Frost Elementary	260 Shaw Street	Frostburg	Public	Faucet, Cold	Nurse's Office/Health Room	Health Room 105	Sink	CO	5.57
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 115	Sink	NC	6.00
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 124F	Sink	NC	8.70
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 130E	Sink	NC	7.95
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 130C	Sink	NC	12.60
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 137	Sink	NC	5.93
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 117	Sink	NC	6.95
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 330	Sink (Left)	NC	19.90
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen 202	Hand Wash Sink	NC	5.85

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen Dishroom 202	Sink	CO	21.80
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	Public	Combination Sink - Faucet, Cold	Media Center	Library Room 311	Sink	NC	10.00
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	Public	Faucet, Cold	Concessions	Concession Stand Arnone Building	Sink (Left)	CO	6.11
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	Public	Faucet, Cold	Kitchen	Kitchen 202	Hand Wash Basin	NC	6.90
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	Public	Faucet, Cold	Kitchen	Kitchen 202	Hand Wash Basin	NC	10.90
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	Public	Faucet, Cold	Storage Room/Area	Storage Room 307A	Sink	NC	16.80
Allegany	Mountain Ridge High	100 Dr. Nancy S. Grasmick Lane	Frostburg	Public	Faucet, Cold	Nurse's Office/Health Room	Health Room 112	Sink	CO	19.60
Allegany	Mt. Savage Elementary/Middle	13201 New School Road NW	Mount Savage	Public	Faucet, Cold	Locker Room	Boys Locker Room Trainers Room 162	Sink	NC	15.20
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 225	Sink	NC	8.36
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 212	Sink	NC	7.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 208	Sink	NC	27.50
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 136	Sink	NC	5.51
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen 118	Sink	CO	18.10
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	Public	Faucet, Cold	Classroom	Classroom 6	Sink	CO	7.86
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	Public	Faucet, Cold	Classroom	Classroom 4	Sink	CO	8.37
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	Public	Faucet, Cold	Classroom	Classroom 13	Sink	CO	6.85
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	Public	Faucet, Cold	Classroom	Classroom 15	Sink	CO	5.95
Allegany	Parkside Elementary	50 Parkside Boulevard	LaVale	Public	Faucet, Cold	Classroom	Classroom 9	Sink	CO	10.60
Allegany	South Penn Elementary	500 East Second Street	Cumberland	Public	Faucet, Cold	Kitchen	Kitchen 151	Sink	CO	20.20
Allegany	South Penn Elementary	500 East Second Street	Cumberland	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Classroom	Pod 1 C	Fountain (Right)	CO	8.72
Allegany	South Penn Elementary	500 East Second Street	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 114	Sink	NC	24.50
Allegany	South Penn Elementary	500 East Second Street	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 146D	Sink	NC	8.02

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	South Penn Elementary	500 East Second Street	Cumberland	Public	Combination Sink - Faucet, Cold	Teachers' Lounge/Break Room	Cafeteria Teachers Lounge	Sink	CO	7.15
Allegany	Washington Middle	200 Massachusetts Avenue	Cumberland	Public	Faucet, Cold	Classroom	Classroom 111A	Sink	NC	7.20
Allegany	Washington Middle	200 Massachusetts Avenue	Cumberland	Public	Faucet, Cold	Nurse's Office/Health Room	Health Room 131	Sink	NC	8.17
Allegany	West Side Elementary	425 Poca Street	Cumberland	Public	Combination Sink - Faucet, Cold	Classroom	Classroom 318D	Classroom 318D	NC	11.70
Allegany	Westmar Middle	16915 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom	Classroom 14	Sink	CO	5.68
Allegany	Westmar Middle	16915 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Kitchen	Kitchen	Sink	CO	8.69
Allegany	Westmar Middle	16915 Lower George's Creek Road	Lonaconing	Public	Faucet, Cold	Classroom (Home Economics)	Food Lab 25	Sink 1	CO	9.09
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom 102 Sink [CR-NC]		NC	28.70
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Classroom 34 B [CF--C]		CO	15.20
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Classroom 7 B-L [DF--C]		CO	6.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Classroom 20 B-R [CF--C]		CO	10.90
Anne Arundel	Central Elementary	130 Stepney Lane	Edgewater	Public	Drinking Water Fountain-Bubbler Style	Nurse's Office/Health Room	Nurses Office Health Room B [NO--C]		CO	19.90
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Room 10B HS-L [SE--C]	Classroom Room 10B HS-L [SE--C]	CO	18.10
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Room 10B HS-R [SE--C]	Classroom Room 10B HS-R [SE--C]	CO	11.40
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Room 35 A HS [SE--C]	Classroom Room 35 A HS [SE--C]	CO	74.70
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Classroom Room 68 Sink Left [TL--C]	Classroom Classroom Room 68 Sink Left [TL--C]	CO	10.20
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Room 68 HS-R [TL--C]	Classroom Room 68 HS-R [TL--C]	CO	7.59
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Faucet, Cold	Classroom	Classroom Room 103 HS [SE--C]	Classroom Room 103 HS [SE--C]	CO	8.88
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Multiple Compartment Sink - Faucet, Cold	Classroom	Classroom Room 10A- Kitchen (oven) HS [KS--C]	Classroom Room 10A- Kitchen (oven) HS [KS--C]	CO	7.56
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Multiple Compartment Sink - Faucet, Cold	Classroom	Classroom Room 10A- Kitchen (Fridge) HS [KS--C]	Classroom Room 10A- Kitchen (Fridge) HS [KS--C]	CO	5.73
Anne Arundel	Central Special	140 Stepney Lane	Edgewater	Public	Multiple Compartment Sink - Faucet, Cold	Classroom	Classroom Room 20B - Kitchen (oven) HS [KS--C]	Classroom Room 20B - Kitchen (oven) HS [KS--C]	CO	13.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Corkran Middle	7600 Quarterfield Road	Glen Burnie	Public	Faucet, Cold	Classroom	Classroom 122 Sink (right) [CR-NC]	Classroom 122 Sink (right) [CR-NC]	NC	9.25
Anne Arundel	Corkran Middle	7600 Quarterfield Road	Glen Burnie	Public	Faucet, Cold	Classroom	Classroom 123 Sink (right) [CR-NC]	Classroom 123 Sink (right) [CR-NC]	NC	67.90
Anne Arundel	Corkran Middle	7600 Quarterfield Road	Glen Burnie	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 319 - Home Ecc (FAC's) Sink (window side RIGH	Home Economics 319 - Home Ecc (FAC's) Sink (window side RIGH	CO	7.09
Anne Arundel	Corkran Middle	7600 Quarterfield Road	Glen Burnie	Public	Faucet, Cold	Classroom (Home Economics)	319 Home Ecc (FAC's) Sink (window side RIGHT) (see map)	319 Home Ecc (FAC's) Sink (window side RIGHT) (see map)	CO	9.65
Anne Arundel	Ferndale Early Education Center (EEC)	105 Packard Avenue	Glen Burnie	Public	Faucet, Cold	Teachers' Lounge/Break Room	Teachers Lounge 1156 Sink [TL-C	Teachers Lounge 1156 Sink [TL-C	CO	150.00
Anne Arundel	Ferndale Early Education Center (EEC)	105 Packard Avenue	Glen Burnie	Public	Drinking Water Fountain-Bubbler Style	Office	Office Main office work room Bubbler [CF--C]	Office Main office work room Bubbler [CF--C]	CO	9.70
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Faucet, Cold	Classroom	Classroom B107 [CR--NC]	Classroom B107 [CR--NC]	CO	50.90
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Faucet, Cold	Classroom	Classroom B206 [CR--NC]	Classroom B206 [CR--NC]	CO	15.90
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Faucet, Cold	Teachers' Lounge/Break Room	Kitchen Faculty Kitchen [TL--C]	Kitchen Faculty Kitchen [TL--C]	CO	11.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Other	Other	Other Athletic Trining Room HS Water Jug Filling Station [	Other Athletic Trining Room HS Water Jug Filling Station [	CO	54.80
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Fountain (Next to exit 2) Water Fountain WF [DF--C	Hallway Fountain (Next to exit 2) Water Fountain WF [DF--C	CO	8.87
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Fountain (across from M118) WF - LEFT [DF--C]	Hallway Fountain (across from M118) WF - LEFT [DF--C]	CO	64.60
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Hall Fountain (next to 0204) WF [DF--C]	Hallway Hall Fountain (next to 0204) WF [DF--C]	CO	11.00
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Hall Fountain (next to 0305) WF [DF--C]	Hallway Hall Fountain (next to 0305) WF [DF--C]	CO	8.38
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Hall Fountain (next to WR room) WF Right [DF--C]	Hallway Hall Fountain (next to WR room) WF Right [DF--C]	CO	13.80
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Hall Fountain (across form Faculty) WF [DF--C]	Hallway Hall Fountain (across form Faculty) WF [DF--C]	CO	11.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Science Fountains WF - LEFT [DF--C]	Classroom Science Fountains WF - LEFT [DF--C]	CO	6.09
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Science Fountains WF - RIGHT [DF--C]	Classroom Science Fountains WF - RIGHT [DF--C]	CO	7.98
Anne Arundel	Glen Burnie High	7550 Baltimore Annapolis Boulevard	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Classroom- Work Room [OT--C]	Classroom Classroom- Work Room [OT--C]	CO	17.90
Anne Arundel	Glendale Elementary	105 Carroll Road	Glen Burnie	Public	Faucet, Cold	Classroom	Classroom Room B153 Media Workroom GN [OT--C]	Classroom Room B153 Media Workroom GN [OT--C]	CO	6.56
Anne Arundel	Hillsmere Elementary	3052 Arundel on the Bay Road	Annapolis	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom 120 B [CF--C]	Classroom 120 B [CF--C]	CO	45.30
Anne Arundel	Hilltop Elementary	415 Melrose Avenue	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Room 15 Bubbler [DF--C]	Classroom Room 15 Bubbler [DF--C]	CO	11.00
Anne Arundel	Hilltop Elementary	415 Melrose Avenue	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Classroom Room 12 [DF--C]	Classroom Classroom Room 12 [DF--C]	CO	9.36

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Hilltop Elementary	415 Melrose Avenue	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Room 7 Bubbler [DF--C]	Classroom Room 7 Bubbler [DF--C]	CO	14.10
Anne Arundel	North County High	10 East 1st Avenue	Glen Burnie	Public	Faucet, Cold	Concessions	Concession Concession Hand Sink [OT--0]	Concession Concession Hand Sink [OT--0]	CO	17.40
Anne Arundel	North County High	10 East 1st Avenue	Glen Burnie	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Fountain (outside F100) Water Fountain [DF--C]	Hallway Fountain (outside F100) Water Fountain [DF--C]	CO	7.59
Anne Arundel	North County High	10 East 1st Avenue	Glen Burnie	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen Right Tri Sink -R [KS--C]	Kitchen Right Tri Sink -R [KS--C]	CO	5.82
Anne Arundel	Northeast Middle (Formerly George Fox Middle)	7922 Outing Avenue	Pasadena	Public	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Bubbler Style (Non-Refrigerated)	Gymnasium	Gymnasium Fountain [DF--C]	Gymnasium Fountain [DF--C]	CO	9.20
Anne Arundel	Oakwood Elementary	330 Oak Manor Drive	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 203 Bubbler [CF--C]	Classroom 203 Bubbler [CF--C]	CO	8.26
Anne Arundel	Oakwood Elementary	330 Oak Manor Drive	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 205 Bubbler [CF--C]	Classroom 205 Bubbler [CF--C]	CO	10.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Oakwood Elementary	330 Oak Manor Drive	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 206 Bubbler [CF--C]	Classroom 206 Bubbler [CF--C]	CO	7.59
Anne Arundel	Oakwood Elementary	330 Oak Manor Drive	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 202 Bubbler [CF--C]	Classroom 202 Bubbler [CF--C]	CO	11.40
Anne Arundel	Riviera Beach Elementary	8515 Jenkins Road	Pasadena	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 7 Bubbler [CF--C]	Classroom 7 Bubbler [CF--C]	CO	7.91
Anne Arundel	Solley Elementary	7608 Solley Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom General Music Bubbler [CF--C]	Classroom General Music Bubbler [CF--C]	CO	38.60
Anne Arundel	Solley Elementary	7608 Solley Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom STEM Classroom Bubbler (Corner) [CF--C]	Classroom STEM Classroom Bubbler (Corner) [CF--C]	CO	45.10
Anne Arundel	Sunset Elementary	8572 Fort Smallwood Road	Pasadena	Public	Faucet, Cold	Nurse's Office/Health Room	Nurses Office Sink [NO--C]	Nurses Office Sink [NO--C]	CO	5.63
Anne Arundel	Sunset Elementary	8572 Fort Smallwood Road	Pasadena	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Pre-k Room -L [DF--C]	Classroom Pre-k Room -L [DF--C]	CO	24.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 108 Bubbler [CF--C]	Classroom 108 Bubbler [CF--C]	CO	9.95
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 203 Bubbler [CF--C]	Classroom 203 Bubbler [CF--C]	CO	15.50
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 101 Bubbler [CF--C]	Classroom 101 Bubbler [CF--C]	CO	7.32
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 103 Bubbler [CF--C]	Classroom 103 Bubbler [CF--C]	CO	13.30
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 210 Bubbler [CF--C]	Classroom 210 Bubbler [CF--C]	CO	27.60
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 213 Bubbler [CF--C]	Classroom 213 Bubbler [CF--C]	CO	14.50
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 211 Bubbler [CF--C]	Classroom 211 Bubbler [CF--C]	CO	7.67

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom 209 Bubbler [CF--C]	Classroom 209 Bubbler [CF--C]	CO	10.90
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom Special Classroom (Loblolly Pine Path) Bubbler [	Classroom Special Classroom (Loblolly Pine Path) Bubbler [	CO	9.29
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Classroom 105 Bubbler [CF--C]	Classroom 105 Bubbler [CF--C]	CO	6.44
Baltimore County	Arbutus Elementary	1300 Sulphur Spring Road	Baltimore	Public	Faucet, Cold	Office	Workroom	Handsink	CO	19.20
Baltimore County	Arbutus Elementary	1300 Sulphur Spring Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 108	Fountain	CO	6.40
Baltimore County	Arbutus Elementary	1300 Sulphur Spring Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room K2	Fountain	CO	13.90
Baltimore County	Loch Raven High	1212 Cowpens Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Cafeteria	Right Fountain	CO	7.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Loch Raven High	1212 Cowpens Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 203A	Fountain	CO	16.10
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria		Left Fountain	CO	7.90
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 100	Fountain	CO	6.50
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Health Suite	Fountain	CO	6.50
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 206	Right Fountain	CO	13.60
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 206	Left Fountain	CO	6.20
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom	Room 120	Station 1	CO	12.60
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom	Room 120	Station 2 Handsink	CO	12.20

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom	Room 120	Station 1 Handsink	CO	6.00
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Office	Workroom	Handsink	CO	6.60
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Office	Workroom	Handsink	CO	8.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 1	CO	9.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 2 Handsink	CO	15.50
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 3 Handsink	CO	21.40
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 6 Handsink	CO	7.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 1 Handsink	CO	12.60
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 5 Handsink	CO	13.70
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Faucet, Cold	Classroom (Home Economics)	Room 121	Station 7 Handsink	CO	13.20
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Double Sink	Sink	CO	15.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Auditorium	Left Side	Right Fountain	CO	161.40
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Gymnasium	Gym	Fountain	CO	17.40
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Gymnasium	Gym	Fountain	CO	105.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 118	Right Fountain	CO	5.80
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 215	Right Fountain	CO	14.20
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 215	Right Fountain	CO	15.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Health Suite	Right Fountain	CO	8.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Health Suite	Left Fountain	CO	13.00
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 111	Right Fountain	CO	34.10
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 111	Right Fountain	CO	52.30
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Auditorium Lobby Right Side	Right Fountain	CO	19.00
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Auditorium Lobby Right Side	Right Fountain	CO	24.20
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 201	Right Fountain	CO	16.80
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 201	Right Fountain	CO	25.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 214	Fountain	CO	23.90
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 214	Fountain	CO	24.00
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Boy's Locker Room	Fountain	CO	23.10
Baltimore County	Randallstown High	4000 Offutt Road	Randallstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Boys'	Fountain	CO	134.50
Baltimore County	Seneca Elementary	545 Carrollwood Road	Baltimore	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Fountain/End of Hallway by Gym [DF-19--C]		CO	8.64
Baltimore County	Sudbrook Magnet Middle	4300 Bedford Road	Baltimore	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen	Double Sink	CO	22.60
Baltimore County	Sudbrook Magnet Middle	4300 Bedford Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Girl's Locker	Fountain	CO	5.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Faucet, Cold	Office	Tap/Office/Workroom/ Handsink [TL-21--C]		CO	9.56
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Faucet, Cold	Nurse's Office/Health Room	Tap/Health Suite/Exam Room/Handsink [NO-27--C]		CO	17.20
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Fountain/Hallway by Room K2 [DF-34--C]		CO	39.10
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 104/Handsink [CR-11--C]		CO	22.80
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 100/Handsink [CR-3--C]		CO	16.10
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 101/Handsink [CR-5--C]		CO	18.60
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 102/Handsink [CR-7--C]		CO	15.70
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 103/Handsink [CR-9--C]		CO	6.76
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 105/Handsink [CR-13--C]		CO	15.00
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 107/Handsink [CR-15--C]		CO	28.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 108/Handsink [CR-17-C]		CO	41.10
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 109/Handsink [CR-19-C]		CO	22.00
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 200/Handsink [CR-23-C]		CO	6.84
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 202/Handsink [CR-29-C]		CO	9.57
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 203/Handsink [CR-31-C]		CO	11.80
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room K1/Handsink [CR-36-C]		CO	6.54
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 205/Handsink [CR-38-C]		CO	12.80
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 206/Handsink [CR-40-C]		CO	25.20
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 208/Handsink [CR-42-C]		CO	16.00
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 209/Handsink [CR-44-C]		CO	26.70
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 210/Handsink [CR-46-C]		CO	8.25

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 211/Handsink [CR-48-C]		CO	19.20
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 212/Handsink [CR-50-C]		CO	10.30
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 214/Handsink [CR-54-C]		CO	10.70
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 215/Hadsink [CR-56-C]		CO	34.70
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 216/Handsink [CR-58-C]		CO	53.40
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 217/Handsink [CR-60-C]		CO	15.00
Baltimore County	Timber Grove Elementary	701 Academy Avenue	Owings Mills	Public	Combination Sink - Faucet, Cold	Classroom	Tap/Room 219/Handsink [CR-64-C]		CO	13.10
Charles	Benjamin Stoddert Middle	2040 St. Thomas Drive	Waldorf	Public	Faucet, Cold	Teachers' Lounge/Break Room	105 Staff Lounge - Sink	105 Staff Lounge - Sink	CO	8.64
Charles	Dr. Gustavus Brown Elementary	421 University Avenue	Waldorf	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	kitchen - kettle	kitchen - kettle	CO	16.40
Charles	F. B. Gwynn Educational Center	5998 Radio Station Road	La Plata	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	kitchen - island sink - See map	kitchen - island sink	CO	7.06

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Frederick	Brunswick High	101 Cummings Drive	Brunswick	Public	Faucet, Cold	Kitchen	Kitchen west wall	K31-01 3066 (KS) R UniqueTag#	CO	7.00
Frederick	Brunswick High	101 Cummings Drive	Brunswick	Public	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler	Locker Room	Locker Room -in Aux gym boys locker room	W01A-10 3066 (DF) B UniqueTag#	CO	6.60
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 23 Drinking Fountain	Room 23 Drinking Fountain	CO	23.40
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 24 Drinking Fountain	Room 24 Drinking Fountain	CO	6.10
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 4 Drinking Fountain	Room 4 Drinking Fountain	CO	15.90
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 1 Drinking Fountain	Room 1 Drinking Fountain	CO	18.70
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from CR2	Drinking Fountain Across from CR2	CO	41.90
Howard	Cedar Lane School	11630 Scaggsville Road	Fulton	Public	Faucet, Cold	Classroom	[MDE-CGL]: room a147	Sink	CO	5.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Faucet, Cold	Classroom (Home Economics)	Room 119	Sink in middle of room	CO	12.50
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Faucet, Cold	Classroom (Home Economics)	Room 119	LTR Sink 4/4 along left wall	CO	8.60
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Faucet, Cold	Classroom (Home Economics)	Room 119	LTR Sink 3/4 along left wall	CO	10.80
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Faucet, Cold	Classroom (Home Economics)	Room 119	LTR Sink 1/4 along left wall	CO	9.50
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Faucet, Cold	Nurse's Office/Health Room	health suite room 140	Sink	CO	5.70
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	room 221	Fountain	CO	11.70
Howard	Ellicott Mills Middle	4445 Montgomery Road	Ellicott City	Public	Faucet, Cold	Kitchen	[MDE-CGL]: kitchen	right wall from cafeteria doors	CO	7.70
Howard	Lime Kiln Middle	11650 Scaggsville Road	Fulton	Public	Faucet, Cold	Kitchen	[MDE-CGL]: kitchen	[MDE-CGL]: Sink along right wall	CO	19.50
Howard	Lime Kiln Middle	11650 Scaggsville Road	Fulton	Public	Faucet, Cold	Kitchen	[MDE-CGL]: kitchen	[MDE-CGL]: Sink along left wall	CO	12.50
Howard	Lime Kiln Middle	11650 Scaggsville Road	Fulton	Public	Faucet, Cold	Classroom (Home Economics)	[MDE-CGL]: home ec classroom, left side	[MDE-CGL]: Sink 3/5 clockwise along wall	CO	10.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Oakland Mills Middle	9540 Kilimanjaro Road	Columbia	Public	Faucet, Cold	Classroom (Home Economics)	[MDE-CGL]: room 68	[MDE-CGL]: Sink 1/7 clockwise from door	CO	10.80
Howard	Oakland Mills Middle	9540 Kilimanjaro Road	Columbia	Public	Faucet, Cold	Classroom (Home Economics)	[MDE-CGL]: room 68	[MDE-CGL]: Sink 7/7 clockwise from door	CO	18.10
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	EC Wing 1st Fl Girls RR Left	Bathroom sink left	NC	11.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	RR Between 131 & 133 Sink	Bathroom sink	NC	6.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	EC Wing 2nd Fl Girls RR L Sink	Bathroom sink left	NC	6.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	EC Wing 2nd Fl Boys RR R Sink	Bathroom sink left	NC	6.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Kitchen	Kitchen 3-Pan Sink Left	Kitchen Dish Sink Left Side	NC	53.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Kitchen	Kitchen 3-Pan Sink Right	Kitchen Dish Sink Right side	NC	10.00
Howard	St. John's Parish Day School	9130 Frederick Road	Ellicott City	Nonpublic	Faucet, Cold	Kitchen	Kitchen Handwash S by Frig	Kitchen Hand washing sink	NC	7.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Thomas Viaduct Middle	7000 Banbury Drive	Hanover	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Locker Room, see floor plan, Fountain, Main Bldg, 1st Floor	Locker Room	[MDE-CGL]: right locker room	Fountain	CO	22.00
Howard	Thomas Viaduct Middle	7000 Banbury Drive	Hanover	Public	Faucet, Cold, Consumption, Kitchen, see floor plan, Sink, Main Bldg, 1st Floor	Kitchen	[MDE-CGL]: kitchen room b28	[MDE-CGL]: Sink opposite ice maker	CO	40.60
Howard	Thomas Viaduct Middle	7000 Banbury Drive	Hanover	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated), Consumption, Hallway, see floor plan, Fountain, Main Bldg, 2nd Floor	Hallway	[MDE-CGL]: hall by room 223/213	Fountain	CO	18.80
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	St. Ludwines	mens room - right sink	NC	101.00
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	St. Ludwines	ladies room - left sink	NC	9.80
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	St. Ludwines	ladies room - right sink	NC	6.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Bathroom	Saint Mary	faculty bathroom - top of stairs	NC	15.10
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom	St. Joseph	120	NC	10.70
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom	St. Joseph	123	NC	9.80
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Other	chapel - music room	sacristry sink	NC	93.70
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Storage Room/Area	middle school	hand sink in an open storage area by maintenance office	NC	18.30
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom (Science Lab)	middle school	room 200 - side of classroom	NC	7.70
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom (Science Lab)	middle school	room 200 - closest to the balcony - right	NC	6.60
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom (Science Lab)	middle school	room 200 - middle of classroom - left	NC	5.50
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom (Science Lab)	middle school	room 200 - furthest from the balcony - middle	NC	9.80
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Faucet, Cold	Classroom (Art)	St. Ludwines	right sink	NC	7.70
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Spigot (with threadings for hose connection)	Outdoors	St. Ludwines	front of building	NC	8.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Spigot (with threadings for hose connection)	Outdoors	St. Joseph	rear of building	NC	7.70
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	St. Joseph	pre-k hall	CO	7.40
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Storage Room/Area	middle school	utility sink in an open storage area by maintenance office	NC	176.00
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Janitor/Custodial Closet	middle school	by ladies room	NC	7.90
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Janitor/Custodial Closet	St. Ludwines	by gym	NC	11.90
Howard	Trinity School	4985 Ilchester Road	Ellicott City	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Janitor/Custodial Closet	St. Joseph	by workroom	NC	8.40
Montgomery	Arcola Elementary	1820 Franwell Avenue	Silver Spring	Public	Faucet, Cold	Nurse's Office/Health Room	In exam 102C by health		CO	51.20
Montgomery	Garrett Park Elementary	4810 Oxford Street	Kensington	Public	Faucet, Cold	Office	In office A104B by health ie. inside health		CO	5.80
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Faucet, Cold	Nurse's Office/Health Room	In health room 102 by health		CO	6.20
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 204	LTR 2 of 2	CO	5.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 216	LTR 2 of 2	CO	7.80
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 210	LTR 2 of 2	CO	7.40
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 237	LTR 2 of 2	CO	8.70
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 153		CO	7.40
Montgomery	Glenallan Elementary	12520 Heurich Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 26	LTR 2 of 2	CO	8.80
Montgomery	JoAnn Leleck Elementary at Broad Acres	710 Beacon Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 303		CO	16.30
Montgomery	JoAnn Leleck Elementary at Broad Acres	710 Beacon Road	Silver Spring	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In classroom 335		CO	7.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Silver Spring International Middle	313 Wayne Avenue	Silver Spring	Public	Faucet, Cold	Teachers' Lounge/Break Room	In team room 225	LTR 1 of 2	CO	61.70
Prince George's	Andrew Jackson Academy	3500 Regency Parkway	Forestville	Public	Faucet, Cold	Nurse/Health Room	Health	Faucet	CO	5.60
Prince George's	Andrew Jackson Academy	3500 Regency Parkway	Forestville	Public	Drinking Water Fountain	Classroom	Cr 110	Fountain	CO	7.30
Prince George's	Arrowhead Elementary	2300 Sansbury Road	Upper Marlboro	Public	Drinking Water Fountain	Classroom	Classroom 302 fountain	water fountain	CO	30.80
Prince George's	Beacon Heights Elementary	6929 Furman Parkway	Riverdale	Public	Drinking Water Fountain	Classroom	CR 153 backwall fountain	Fountain	CO	21.90
Prince George's	Beacon Heights Elementary	6929 Furman Parkway	Riverdale	Public	Drinking Water Fountain	Classroom	CR 152 backwall	Fountain	CO	18.80
Prince George's	Beltsville Academy	4300 Wicomico Avenue	Beltsville	Public	Faucet (Cold)	Nurse/Health Room	Hr next to the stairs	Faucet	CO	11.30
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Faucet, Cold	Teachers Lounge	Teachers Lounge faucet	Sink faucet	CO	8.91
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Classroom	Fountain CR107	water fountain	CO	12.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Classroom	Fountain CR109	water fountain	CO	14.50
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Hallway	Hallway fountain next to gym	water fountain	CO	18.90
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Hallway	Hallway fountain next to gym far side across CR196	water fountain	CO	25.70
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Hallway	HWF next to Workroom CR128	water fountain	CO	7.49
Prince George's	Benjamin Foulois Creative and Performing Arts Academy	4601 Beauford Road	Suitland	Public	Drinking Water Fountain	Hallway	HWF across CR106	water fountain	CO	9.79
Prince George's	Bladensburg Elementary	4915 Annapolis Road	Bladensburg	Public	Drinking Water Fountain	Hallway	Fountain	Hallway fountain near main entrance	CO	9.80
Prince George's	Bladensburg Elementary	4915 Annapolis Road	Bladensburg	Public	Faucet (Cold)	Teachers Lounge	Faucet	Teacher's lounge (Workroom)	CO	5.80
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	Public	Faucet, Cold	Nurse's/Health Room	Health room faucet	Faucet	CO	5.90
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	Public	Drinking Water Fountain	Hallway	Hallway fountain next to Library	Fountain	CO	6.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	Public	Drinking Water Fountain	Hallway	hallway fountain next to D105	Fountain	CO	10.10
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	Public	Drinking Water Fountain	Hallway	Hallway fountain next to B202	Fountain	CO	194.00
Prince George's	Bowie High - Annex Campus	3021 Belair Drive	Bowie	Public	Drinking Water Fountain	Hallway	hallway fountain by the gym	Fountain	CO	197.00
Prince George's	Calverton Elementary	3400 Beltsville Road	Beltsville	Public	Drinking Water Fountain	Classroom	Back of classroom	DRINKING FOUNTAIN	CO	13.30
Prince George's	Calverton Elementary	3400 Beltsville Road	Beltsville	Public	Drinking Water Fountain	Classroom	Back of classroom	DRINKING FOUNTAIN	CO	14.40
Prince George's	Calverton Elementary	3400 Beltsville Road	Beltsville	Public	Drinking Water Fountain	Classroom	Back of classroom	DRINKING FOUNTAIN	CO	31.20
Prince George's	Calverton Elementary	3400 Beltsville Road	Beltsville	Public	Drinking Water Fountain	Nurse/Health Room	Back room left	Left wall	CO	23.10
Prince George's	Capitol Heights Elementary	601 Suffolk Avenue	Capitol Heights	Public	Drinking Water Fountain	Classroom	CR6	Classroom 6	CO	8.00
Prince George's	Capitol Heights Elementary	601 Suffolk Avenue	Capitol Heights	Public	Drinking Water Fountain	Classroom	CR12	Classroom 12	CO	10.90
Prince George's	Capitol Heights Elementary	601 Suffolk Avenue	Capitol Heights	Public	Drinking Water Fountain	Multipurpose Room	MPR	Multipurpose Room	CO	14.50
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	Public	Drinking Water Fountain	Classroom	Left wall		CO	14.80
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	Public	Drinking Water Fountain	Classroom	Right side		CO	7.80
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	Public	Drinking Water Fountain	Classroom	Right side		CO	9.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	Public	Drinking Water Fountain	Classroom	Right side		CO	15.00
Prince George's	Carole Highlands Elementary	1610 Hannon Street	Takoma Park	Public	Drinking Water Fountain	Classroom	Right		CO	6.00
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr-101	Fountain	CO	108.00
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 103 backwall	Fountain	CO	14.50
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 107 backwall	Fountain	CO	13.40
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 104 backwall	Fountain	CO	8.50
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 119 backwall	Fountain	CO	6.20
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 118 backwall	Fountain	CO	5.50
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Classroom	Cr 202 backwall	Fountain	CO	8.20
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Hallway	Hw Fountain in front of cr 102	Fountain	CO	8.50
Prince George's	Carrollton Elementary	8300 Quintana Street	New Carrollton	Public	Drinking Water Fountain	Hallway	Hw fountain next Cr K-1	Fountain	CO	22.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Cesar Chavez Elementary	6609 Riggs Road	Hyattsville	Public	Faucet, Cold	Nurse/Health Room	Sink inside nurse room	Faucet	CO	9.10
Prince George's	Cesar Chavez Elementary	6609 Riggs Road	Hyattsville	Public	Drinking Water Fountain	Classroom	Classroom 2	DRINKING FOUNTAIN	CO	10.10
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	CR 11 backwall	Fountain	CO	14.20
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	Cr 13 backwall fountain	Fountain	CO	7.50
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	CR 5 backwall fountain	Fountain	CO	8.10
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	Cr 4 backwall fountain	Fountain	CO	34.70
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	Cr 22 right wall	Fountain	CO	9.10
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Classroom	Cr 21 Rightwall fountain	Fountain	CO	12.00
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Other	Isolation room right wall fountain	Fountain	CO	33.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Chapel Forge Early Childhood Center	12711 Milan Way	Bowie	Public	Drinking Water Fountain	Teachers Lounge	Teachers lounge backwall	Fountain	CO	17.70
Prince George's	Chillum Elementary	1420 Chillum Road	Hyattsville	Public	Drinking Water Fountain	Auditorium	Right wall	Fountain	CO	9.30
Prince George's	Columbia Park Elementary	1901 Kent Village Drive	Landover	Public	Drinking Water Fountain	Classroom	Cr 24 right wall	Fountain	CO	45.20
Prince George's	Columbia Park Elementary	1901 Kent Village Drive	Landover	Public	Drinking Water Fountain	Classroom	2nd floor right CR backwall	Fountain	CO	15.30
Prince George's	Columbia Park Elementary	1901 Kent Village Drive	Landover	Public	Drinking Water Fountain	Hallway	Fountain next to conference room 2	Fountain	CO	10.90
Prince George's	Columbia Park Elementary	1901 Kent Village Drive	Landover	Public	Drinking Water Fountain	Hallway	HW Fountain next to vocal music	Fountain	CO	10.40
Prince George's	Concord Elementary	2004 Concord Lane	District Heights	Public	Drinking Water Fountain	Classroom	Classroom 104 fountain	Fountain	CO	22.40
Prince George's	Concord Elementary	2004 Concord Lane	District Heights	Public	Drinking Water Fountain	Classroom	Classroom 105 fountain	Fountain	CO	325.00
Prince George's	Concord Elementary	2004 Concord Lane	District Heights	Public	Drinking Water Fountain	Classroom	Classroom 302 fountain	Fountain	CO	14.10
Prince George's	Concord Elementary	2004 Concord Lane	District Heights	Public	Drinking Water Fountain	Classroom	Classroom 301 fountain	Fountain	CO	92.00
Prince George's	District Heights Elementary	2200 County Road	District Heights	Public	Faucet, Cold	Teachers Lounge	Teacher's lounge faucet	Sink faucet	CO	8.40
Prince George's	District Heights Elementary	2200 County Road	District Heights	Public	Drinking Water Fountain	Hallway	Hallway fountain across CR9	water fountain	CO	15.10
Prince George's	District Heights Elementary	2200 County Road	District Heights	Public	Drinking Water Fountain	Hallway	Hallway fountain across from TL	water fountain	CO	7.20

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 11 fountain	Fountain	CO	9.60
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 1 fountain	Fountain	CO	6.10
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 7 fountain	Fountain	CO	7.90
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 6 fountain	Fountain	CO	8.80
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 18 fountain	Fountain	CO	8.80
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 20 fountain	Fountain	CO	60.60
Prince George's	Dodge Park Elementary	3401 Hubbard Road	Landover	Public	Drinking Water Fountain	Classroom	Classroom 21 fountain	Fountain	CO	9.00
Prince George's	Doswell E. Brooks Elementary	1301 Brooke Road	Capitol Heights	Public	Drinking Water Fountain	Classroom		Fountain	CO	17.00
Prince George's	Doswell E. Brooks Elementary	1301 Brooke Road	Capitol Heights	Public	Drinking Water Fountain	Classroom		Fountain	CO	222.00
Prince George's	Doswell E. Brooks Elementary	1301 Brooke Road	Capitol Heights	Public	Drinking Water Fountain	Classroom	Classroom 25	Fountain	CO	10.00
Prince George's	Doswell E. Brooks Elementary	1301 Brooke Road	Capitol Heights	Public	Drinking Water Fountain	Classroom	Classroom 24	Fountain	CO	6.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Flintstone Elementary	800 Comanche Drive	Oxon Hill	Public	Drinking Water Fountain	Classroom	Classroom 221	water fountain	CO	19.40
Prince George's	Forest Heights Elementary	200 Talbert Drive	Oxon Hill	Public	Faucet, Cold	Hallway	Hallway fountain near main office	Sink faucet	CO	9.30
Prince George's	Forest Heights Elementary	200 Talbert Drive	Oxon Hill	Public	Drinking Water Fountain	Classroom	Classroom 102	water fountain	CO	10.10
Prince George's	Forest Heights Elementary	200 Talbert Drive	Oxon Hill	Public	Drinking Water Fountain	Hallway	Hallway fountain near classroom 106	water fountain	CO	621.00
Prince George's	Fort Foote Elementary	8300 Oxon Hill Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hallway fountain next to teacher's lounge	water fountain	CO	14.30
Prince George's	Fort Foote Elementary	8300 Oxon Hill Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hallway fountain across CR4	water fountain	CO	8.50
Prince George's	Fort Foote Elementary	8300 Oxon Hill Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hallway fountain across CR11	water fountain	CO	109.00
Prince George's	Frances R. Fuchs Early Childhood Center	11011 Cherry Hill Road	Beltsville	Public	Drinking Water Fountain	Classroom	CR-9 left wall	Fountain	CO	21.10
Prince George's	Frances R. Fuchs Early Childhood Center	11011 Cherry Hill Road	Beltsville	Public	Drinking Water Fountain	Classroom	CR-12 left wall	Fountain	CO	10.30
Prince George's	Frances R. Fuchs Early Childhood Center	11011 Cherry Hill Road	Beltsville	Public	Drinking Water Fountain	Classroom	CR 14 left wall	Fountain	CO	7.10
Prince George's	Frances R. Fuchs Early Childhood Center	11011 Cherry Hill Road	Beltsville	Public	Faucet (Cold)	Kitchen	KT Left wall faucet	Faucet	CO	52.60
Prince George's	Glenridge Elementary	7200 Gallatin Street	Landover Hills	Public	Drinking Water Fountain	Classroom	CR 215	Fountain	CO	106.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Glenridge Elementary	7200 Gallatin Street	Landover Hills	Public	Drinking Water Fountain	Classroom	CR 209	Fountain	CO	27.10
Prince George's	Gwynn Park Middle	8000 Dyson Road	Brandywine	Public	Faucet (Cold)	Nurse/Health Room	Health Room	Sink faucet	CO	5.70
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	8.10
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Classroom	Right corner	Fountain	CO	16.30
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Classroom	Right corner	DRINKING FOUNTAIN	CO	7.50
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Classroom	Left corner	Drinking Water Fountain	CO	62.00
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Hallway	Near. Sprinkler valve room	DRINKING FOUNTAIN	CO	9.00
Prince George's	Heather Hills Elementary	12605 Heming Lane	Bowie	Public	Drinking Water Fountain	Hallway	2 nd floor near sprinkler control room	Drinking Water Fountain	CO	36.40
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Left wall corner	Fountain	CO	6.70
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Left wall corner	Fountain	CO	10.30
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Right wall corner	Fountain	CO	7.30
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Right wall corner	Fountain	CO	9.40
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Right wall corner	Fountain	CO	9.90
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Right wall corner	Fountain	CO	18.00
Prince George's	Hollywood Elementary	9811 49th Avenue	College Park	Public	Drinking Water Fountain	Classroom	Right wall corner	Fountain	CO	23.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Isaac J. Gourdine Middle	8700 Allentown Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hwf cross cr 215	Fountain	CO	14.30
Prince George's	Isaac J. Gourdine Middle	8700 Allentown Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hallway fountain cross Health	Fountain	CO	822.00
Prince George's	Isaac J. Gourdine Middle	8700 Allentown Road	Fort Washington	Public	Drinking Water Fountain	Hallway	Hallway fountain cross classroom 226	Fountain	CO	31.70
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Drinking Water Fountain	Classroom	Water fountain	CR18 fountain	CO	8.40
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Drinking Water Fountain	Classroom	Water fountain	CR17 fountain	CO	5.60
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Drinking Water Fountain	Classroom	Water fountain	CR1 fountain	CO	12.00
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Drinking Water Fountain	Classroom	Water fountain	CR3 fountain	CO	12.20
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Drinking Water Fountain	Hallway	Water fountain	Hallway fountain across cafe	CO	5.50
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	Public	Faucet (Cold)	Teachers Lounge	Sink faucet	Teacher's lounge faucet	CO	18.20
Prince George's	James E. Duckworth Regional School	11201 Evans Trail	Beltsville	Public	Drinking Water Fountain	Auditorium	Near pool	Faucet	CO	10.70
Prince George's	James E. Duckworth Regional School	11201 Evans Trail	Beltsville	Public	Drinking Water Fountain	Classroom	Back of class	Bubbler	CO	6.03
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Back wall	Fountain	CO	59.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Back wall	Fountain	CO	251.00
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	7.10
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	10.70
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	35.10
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	35.80
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	11.10
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	13.30
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Drinking Water Fountain	Classroom	Right center	Fountain	CO	27.10
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Faucet (Cold)	Classroom	Back wall	Fountain	CO	11.30
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Faucet (Cold)	Classroom	Back wall	Fountain	CO	28.80
Prince George's	James H. Harrison Elementary	13200 Larchdale Road	Laurel	Public	Faucet (Cold)	Classroom	Back wall	Fountain	CO	87.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	CR 10 backwall	Fountain	CO	5.90
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 104 Leftwall	Fountain	CO	21.00
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 106 left wall	Fountain	CO	9.10
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 108 left wall	Fountain	CO	12.70
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 110 Leftwall	Fountain	CO	15.00
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 204 Leftwall	Fountain	CO	13.60
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 206 Leftwall	Fountain	CO	15.10
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 207 Leftwall	Fountain	CO	253.00
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 210 Leftwall	Fountain	CO	49.10
Prince George's	Kenilworth Elementary	12520 Kembridge Drive	Bowie	Public	Drinking Water Fountain	Classroom	Cr 212 Leftwall	Fountain	CO	122.00
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	7.40
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Classroom	Right wall	Fountain	CO	18.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	6.10
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	8.70
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Classroom	Left wall	Fountain	CO	11.80
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Hallway	Fountain near boiler room	Fountain	CO	10.50
Prince George's	Lamont Elementary	7101 Good Luck Road	New Carrollton	Public	Drinking Water Fountain	Hallway	Hallway near CR 25	Fountain	CO	65.80
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	1st floor CR 20 left wall back	Fountain	CO	5.91
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	1st floor CR 17 left wallet	Fountain	CO	21.10
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	1st floor CR 15right side	Fountain	CO	16.20
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	1st floor CR -7 back wall	Fountain	CO	18.70
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	1st floor CR-4 left wall	Fountain	CO	7.28
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	2nd floor CR-38 right wall	Fountain	CO	6.22
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	2nd floor CR-39 left wall	Fountain	CO	9.89
Prince George's	Langley Park-McCormick Elementary	8201 15th Avenue	Hyattsville	Public	Drinking Water Fountain	Classroom	2nd floor CR-42 left wall	Fountain	CO	6.03

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Laurel High	8000 Cherry Lane	Laurel	Public	Faucet (Cold)	Nurse/Health Room	Health Room	Sink faucet	CO	7.50
Prince George's	Lewisdale Elementary	2400 Banning Place	Hyattsville	Public	Drinking Water Fountain	Classroom	CR-17 right wall fountain	Fountain	CO	7.10
Prince George's	Lewisdale Elementary	2400 Banning Place	Hyattsville	Public	Drinking Water Fountain	Classroom	CR-9 right wall fountain low water pressure	Fountain	CO	8.50
Prince George's	Mary Harris Mother Jones Elementary	2405 Tecumseh Street	Adelphi	Public	Drinking Water Fountain	Media Center	1st floor media center room 231 office material prep	Fountain	CO	9.92
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Classroom	Fountain CR104	water fountain	CO	98.10
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Classroom	Fountain CR105	water fountain	CO	7.60
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Classroom	Fountain CR106	water fountain	CO	159.00
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Classroom	Fountain CR109	water fountain	CO	8.10
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Hallway	Hwf next to cr 205	Fountain	CO	33.70
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Drinking Water Fountain	Hallway	Hallway fountain next to CR104	water fountain	CO	123.00
Prince George's	North Forestville Elementary	2311 Ritchie Road	Forestville	Public	Faucet (Cold)	Teachers Lounge	Teachers Lounge faucet	Sink faucet	CO	20.60
Prince George's	Parkdale High	6001 Good Luck Road	Riverdale	Public	Drinking Water Fountain	Hallway	Hallway fountain next to CR104	water fountain	CO	34.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Parkdale High	6001 Good Luck Road	Riverdale	Public	Faucet (Cold)	Teachers Lounge	Teacher's lounge	Sink faucet	CO	8.70
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Classroom	CR 2 kindergarten backwall	Fountain	CO	40.30
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Classroom	CR18 backwall	Fountain	CO	11.50
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Classroom	CR 17 backwall	Fountain	CO	5.50
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Classroom	CR 1 backwall	Fountain	CO	8.30
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Hallway	HW fountain in front of cafeteria	Fountain	CO	13.70
Prince George's	Springhill Lake Elementary	6060 Springhill Drive	Greenbelt	Public	Drinking Water Fountain	Hallway	HW fountain in front of CR 14	Fountain	CO	11.80
Prince George's	Thurgood Marshall Middle	4909 Brinkley Road	Temple Hills	Public	Drinking Water Fountain	Hallway	Hallway fountain next to Library	water fountain	CO	5.60
Prince George's	Thurgood Marshall Middle	4909 Brinkley Road	Temple Hills	Public	Drinking Water Fountain	Hallway	Hallway fountain next to CR101	water fountain	CO	16.20
Prince George's	Thurgood Marshall Middle	4909 Brinkley Road	Temple Hills	Public	Drinking Water Fountain	Gym	Fountain Gym Back Wall Right	water fountain	CO	5.80
Prince George's	Thurgood Marshall Middle	4909 Brinkley Road	Temple Hills	Public	Faucet (Cold)	Nurse/Health Room	Sink faucet Health Room	Sink faucet	CO	102.00
Prince George's	Yorktown Elementary	7301 Race Track Road	Bowie	Public	Drinking Water Fountain	Classroom	Cr- 2 Rightwall	Fountain	CO	5.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption



**Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2022 – July 1, 2023) - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE†	FIXTURE AREA TYPE†	FIXTURE LOCATION DESCRIPTION†	DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Prince George's	Yorktown Elementary	7301 Race Track Road	Bowie	Public	Drinking Water Fountain	Hallway	Hw fountain next to pupil station	Fountain	CO	223.00
Prince George's	Yorktown Elementary	7301 Race Track Road	Bowie	Public	Faucet (Cold)	Nurse/Health Room	H faucet Leftwall	Faucet	CO	13.30
Talbot	Easton Elementary (New Building)	307 Glenwood Avenue	Easton	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	rm A126	Left	CO	7.50
Washington	Smithsburg Middle	68 North Main Street	Smithsburg	Public	Faucet, Cold	Teachers' Lounge/Break Room	Left wall of health room	Single sink faucet	CO	10.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

[This page intentionally left blank]

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\*\***

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Anne Arundel	Arundel Middle	1179 Hammond Lane	Odenton	21113	Public	2021-2022	*
Baltimore City	Arundel Elementary/Middle (#164)	2400 Round Road	Baltimore	21225	Public	2021-2022	No **
Baltimore City	Frederick Elementary (# 260)	2501 Frederick Avenue	Baltimore	21223	Charter	2021-2022	*
Baltimore City	Govans Elementary	900 Woodbourne Avenue	Baltimore	21212	Charter	2021-2022	*
Baltimore City	Hampstead Hill Academy (# 047)	500 South Linwood Avenue	Baltimore	21224	Public	2021-2022	*
Baltimore City	Harford Heights Building #036	1919 North Broadway	Baltimore	21213	Public	2021-2022	*
Baltimore City	Patterson High # 405	100 Kane Street	Baltimore	21224	Public	2021-2022	*
Baltimore City	Robert Poole Building (# 056)	1300 West 36th Street	Baltimore	21211	Public	2021-2022	*
Baltimore City	Robert W. Coleman Elementary (# 142)	1807 Harlem Avenue	Baltimore	21217	Public	2020-2021	*
Baltimore City	St. Elizabeth School	801 Argonne Drive	Baltimore	21218	Nonpublic	2017-2018	*,****
Baltimore City	St. Elizabeth School	801 Argonne Drive	Baltimore	21218	Nonpublic	2021-2022	*,****
Baltimore City	The Historic Samuel Coleridge-Taylor Elementary # 122	507 West Preston Street	Baltimore	21201	Public	2021-2022	*
Baltimore County	Beth Tfiloh Dahan Community School	3300 Old Court Road	Baltimore	21208	Nonpublic	2021-2022	*
Baltimore County	Cambridge School	6200 North Charles Street	Baltimore	21212	Nonpublic	2019-2020	*
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	21093	Nonpublic	2021-2022	Yes
Baltimore County	Holy Cross Lutheran Preschool	8516 Loch Raven Boulevard	Towson	21286	Nonpublic	2020-2021	*
Baltimore County	Perry Hall Christian School	3919 Schroeder Avenue	Perry Hall	21128	Nonpublic	2020-2021	*
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	21157	Public	2021-2022	Yes **
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	21157	Public	2019-2020	Yes
Carroll	Carrolltowne Elementary	6542 Ridge Road	Sykesville	21784	Public	2019-2020	Yes **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Carroll	Century High	355 Ronsdale Road	Sykesville	21784	Public	2021-2022	No**
Carroll	Cranberry Station Elementary	505 North Center Street	Westminster	21157	Public	2019-2020	Yes**
Carroll	Ebb Valley Elementary	3100 Swiper Road	Manchester	21102	Public	2019-2020	*
Carroll	Eldersburg Elementary	1021 Johnsville Road	Sykesville	21784	Public	2019-2020	Yes
Carroll	Francis Scott Key High	3825 Bark Hill Road	Union Bridge	21791	Public	2019-2020	*
Carroll	Freedom Elementary	5626 Sykesville Road	Sykesville	21784	Public	2021-2022	Yes**
Carroll	Friendship Valley Elementary	1100 Gist Road	Westminster	21157	Public	2019-2020	Yes**
Carroll	Gateway School, The	45 Kate Wagner Road	Westminster	21157	Public	2019-2020	No**
Carroll	Liberty High	5855 Bartholow Road	Sykesville	21784	Public	2019-2020	Yes**
Carroll	Manchester Elementary	3224 York Street	Manchester	21102	Public	2019-2020	Yes**
Carroll	Manchester Valley High	3300 Maple Grove Road	Manchester	21102	Public	2019-2020	Yes**
Carroll	Mt. Airy Elementary	405 North Main Street	Mount Airy	21771	Public	2019-2020	Yes**
Carroll	Mt. Airy Elementary	405 North Main Street	Mount Airy	21771	Public	2021-2022	Yes**
Carroll	Mt. Airy Middle	102 Watersville Road	Mount Airy	21771	Public	2021-2022	Yes**
Carroll	North Carroll Middle	2401 Hanover Pike	Hampstead	21074	Public	2019-2020	Yes**
Carroll	Northwest Middle	99 Kings Drive	Taneytown	21787	Public	2019-2020	*
Carroll	Oklahoma Road Middle	6300 Oklahoma Road	Sykesville	21784	Public	2021-2022	No**
Carroll	Parr's Ridge Elementary	202 Watersville Road	Mount Airy	21771	Public	2019-2020	Yes**
Carroll	Piney Ridge Elementary	6315 Freedom Avenue	Sykesville	21784	Public	2019-2020	Yes**
Carroll	Robert Moton Elementary	1413 Washington Road	Westminster	21157	Public	2019-2020	Yes**,****
Carroll	Shiloh Middle	3675 Willow Street	Hampstead	21074	Public	2021-2022	Yes**
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	21074	Public	2019-2020	Yes

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Carroll	Sykesville Middle	7301 Springfield Avenue	Sykesville	21784	Public	2019-2020	Yes **
Carroll	Taneytown Elementary	100 Kings Drive	Taneytown	21787	Public	2019-2020	Yes **
Carroll	Westminster East Middle	121 Longwell Avenue	Westminster	21157	Public	2019-2020	*
Carroll	Westminster Elementary	811 Uniontown Road	Westminster	21157	Public	2019-2020	Yes **
Carroll	Westminster High	1225 Washington Road	Westminster	21157	Public	2019-2020	No **
Carroll	Westminster West Middle	60 Monroe Street	Westminster	21157	Public	2021-2022	No **
Carroll	William Winchester Elementary	70 Monroe Street	Westminster	21157	Public	2021-2022	Yes **
Carroll	Winters Mill High	560 Gorsuch Road	Westminster	21157	Public	2021-2022	No **
Charles	Benjamin Stoddert Middle	2040 St. Thomas Drive	Waldorf	20601	Public	2021-2022	*
Charles	Berry Elementary	10155 Berry Road	Waldorf	20603	Public	2021-2022	No **
Charles	Daniel of St. Thomas Jenifer Elementary	2820 Jenifer School Lane	Waldorf	20603	Public	2021-2022	Yes **
Charles	Eva Turner Elementary	1000 Bannister Circle	Waldorf	20602	Public	2021-2022	No **
Charles	J.C. Parks Elementary	3505 Livingston Road	Indian Head	20640	Public	2021-2022	No **
Charles	La Plata High	6035 Radio Station Road	La Plata	20646	Public	2021-2022	Yes **
Charles	Mary Burgess Neal Elementary	12105 St. Georges Drive	Waldorf	20602	Public	2021-2022	Yes **
Charles	Mary H. Matula Elementary	6025 Radio Station Road	La Plata	20646	Public	2021-2022	Yes **
Charles	Mattawoman Middle	10145 Berry Road	Waldorf	20603	Public	2021-2022	Yes **
Charles	Matthew Henson Middle	3535 Livingston Road	Indian Head	20640	Public	2021-2022	No **
Charles	North Point High	2500 Davis Road	Waldorf	20603	Public	2021-2022	No **
Charles	St. Charles High	5305 Piney Church Road	Waldorf	20602	Public	2021-2022	Yes **
Charles	Theodore G. Davis Middle	2495 Davis Road	Waldorf	20603	Public	2021-2022	Yes **

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	20601	Public	2021-2022	Yes **
Charles	Transition School	3155 John Hanson Drive	Waldorf	20601	Public	2021-2022	*
Charles	Westlake High	3300 Middletown Road	Waldorf	20603	Public	2021-2022	Yes **
Charles	William B. Wade Elementary	2300 Smallwood Drive West	Waldorf	20603	Public	2021-2022	No **
Frederick	Banner School, The	1730 North Market Street	Frederick	21701	Nonpublic	2020-2021	*
Frederick	Mother Seton School	100 Creamery Road	Emmitsburg	21727	Nonpublic	2020-2021	*
Harford	Aberdeen High	251 Paradise Road	Aberdeen	21001	Public	2021-2022	Yes **,***
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	21001	Public	2021-2022	Yes **,***
Harford	Abingdon Elementary	399 Singer Road	Abingdon	21009	Public	2021-2022	Yes **,***
Harford	Bakerfield Elementary	36 Baker Street	Aberdeen	21001	Public	2021-2022	No **,***
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	21014	Public	2021-2022	Yes **,***
Harford	Bel Air High	100 Heighe Street	Bel Air	21014	Public	2021-2022	Yes **,***
Harford	Bel Air Middle	99 Idlewild Street	Bel Air	21014	Public	2021-2022	Yes **,***
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	21015	Public	2021-2022	Yes **,***
Harford	Church Creek Elementary	4299 Church Creek Road	Belcamp	21017	Public	2021-2022	Yes ***
Harford	Deerfield Elementary	2307 Willoughby Beach Road	Edgewood	21040	Public	2021-2022	No **,***
Harford	Edgewood Elementary	2100 Cedar Drive	Edgewood	21040	Public	2021-2022	Yes **,***
Harford	Edgewood High	2415 Willoughby Beach Road	Edgewood	21040	Public	2021-2022	Yes **,***
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	21040	Public	2021-2022	Yes **,***
Harford	Emmorton Elementary	2502 South Tollgate Road	Bel Air	21015	Public	2021-2022	Yes **,***
Harford	Forest Lakes Elementary	100 Osborne Parkway	Forest Hill	21050	Public	2021-2022	Yes **,***

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Harford	Fountain Green Elementary	517 South Fountain Green Road	Bel Air	21015	Public	2021-2022	No ****
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	21001	Public	2021-2022	Yes **
Harford	Hall's Cross Roads Elementary	203 East Bel Air Avenue	Aberdeen	21001	Public	2021-2022	Yes ****
Harford	Havre de Grace Elementary	600 Juniata Street	Havre De Grace	21078	Public	2021-2022	Yes ****
Harford	Hickory Elementary	2100 Conowingo Road	Bel Air	21014	Public	2021-2022	Yes ***
Harford	Homestead Elementary	900 South Main Street	Bel Air	21014	Public	2021-2022	Yes ****
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	21014	Nonpublic	2021-2022	Yes ****, ****
Harford	Joppatowne Elementary	407 Trimble Road	Joppa	21085	Public	2021-2022	No ****
Harford	Joppatowne High	555 Joppa Farm Road	Joppa	21085	Public	2021-2022	Yes ****
Harford	Magnolia Elementary	901 Trimble Road	Joppa	21085	Public	2021-2022	Yes ****
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	21085	Public	2021-2022	Yes ****
Harford	Meadowvale Elementary	910 Grace View Drive	Havre De Grace	21078	Public	2021-2022	No ****
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	21009	Public	2021-2022	Yes ****
Harford	Patterson Mill Middle/High	85 Patterson Mill Road	Bel Air	21215	Public	2021-2022	Yes ****
Harford	Red Pump Elementary	600 Red Pump Road	Bel Air	21014	Public	2021-2022	No ****
Harford	Ring Factory Elementary	1400 Emmorton Road	Bel Air	21014	Public	2021-2022	No ****
Harford	Riverside Elementary	211 Stillmeadow Drive	Joppa	21085	Public	2021-2022	No ****
Harford	Roye-Williams Elementary	201 Oakington Road	Havre De Grace	21078	Public	2021-2022	Yes ****
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	21014	Public	2021-2022	Yes ****

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	21001	Public	2021-2022	Yes **,***
Harford	Wakefield Elementary	900 South Main Street	Bel Air	21014	Public	2021-2022	Yes **,***
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	21009	Public	2021-2022	Yes **,***
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	21009	Public	2021-2022	Yes **
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	21075	Public	2023-2024	*
Howard	Fusion Academy Columbia	10175 Little Patuxent Parkway	Columbia	21044	Nonpublic	2021-2022	No ****
Howard	Oakland Mills High	9410 Kilimanjaro Road	Columbia	21045	Public	2020-2021	*
Montgomery	Edison (Thomas) High	12501 Dalewood Drive	Silver Spring	20906	Public	2023-2024	*
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	20877	Public	2021-2022	*
Montgomery	Fairland Center	13313 Old Columbia Pike	Silver Spring	20904	Public	2021-2022	*
Montgomery	Fusion Academy Rockville	275 North Washington Street, Suite 200	Rockville	20850	Nonpublic	2021-2022	No **
Montgomery	Holton-Arms School, The	7303 River Road	Bethesda	20817	Nonpublic	2020-2021	*
Montgomery	Ivymount School, The	11614 Seven Locks Road	Rockville	20854	Nonpublic	2020-2021	*
Montgomery	Laytonsville Elementary	21401 Laytonsville Road	Laytonsville	20882	Public	2023-2024	*
Montgomery	McAuliffe (Christa S.) Elementary	12500 Wisteria Drive	Germantown	20874	Public	2021-2022	*
Montgomery	McNair (Ronald) Elementary	13881 Hopkins Road	Germantown	20874	Public	2021-2022	*
Montgomery	Pathways School - Edgewood, The	801 University Boulevard West	Silver Spring	20901	Nonpublic	2020-2021	*
Montgomery	Piney Branch Elementary	7510 Maple Avenue	Takoma Park	20912	Public	2023-2024	*
Montgomery	Rock View Elementary	3901 Denfeld Avenue	Kensington	20895	Public	2023-2024	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2022)\*\*\*\*\* - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Montgomery	Rosemont Elementary	16400 Alden Avenue	Gaithersburg	20877	Public	2023-2024	*
Prince George's	Francis T. Evans Elementary	6720 Old Alexandria Ferry Road	Clinton	20735	Public	2018-2019	*
Prince George's	J. Frank Dent Elementary	2700 Corning Avenue	Fort Washington	20744	Public	2018-2019	*
Prince George's	Kettering Elementary	11000 Layton Street	Upper Marlboro	20774	Public	2018-2019	*
Prince George's	Marlton Elementary	12520 Kembridge Dr	Bowie	20772	Public	2018-2019	*
Prince George's	Montpelier Elementary	9200 Muirkirk Road	Laurel	20708	Public	2018-2019	*
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	21666	Public	2021-2022	Yes ****,****
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	21617	Public	2017-2018	*
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	21617	Public	2020-2021	*
Talbot	Easton Elementary (New Building)	307 Glenwood Avenue	Easton	21601	Public	2021-2022	*
Washington	Boonsboro Elementary	5 Campus Avenue	Boonsboro	21713	Public	2021-2022	*
Washington	Boonsboro High	10 Campus Avenue	Boonsboro	21713	Public	2021-2022	*
Washington	Boonsboro Middle	1 Jh Wade Drive	Boonsboro	21713	Public	2021-2022	*
Washington	Ruth Ann Monroe Primary	1311 Yale Drive	Hagerstown	21740	Public	2021-2022	*
Washington	Smithsburg Middle	68 North Main Street	Smithsburg	21783	Public	2021-2022	Yes
Washington	St. Maria Goretti High School - Academics/Main Campus	18614 Crestwood Drive	Hagerstown	21742	Nonpublic	2018-2019	*
Worcester	Stephen Decatur High	9913 Seahawk Road	Berlin	21811	Public	2020-2021	*
Worcester	Worcester Preparatory School	508 South Main Street	Berlin	21811	Nonpublic	2020-2021	*

\*Data verification in progress / Insufficient documentation

\*\*Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

\*\*\*Schools with first-draw and flushed samples

\*\*\*\*Includes some samples with improper protocol

\*\*\*\*\*Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

[This page intentionally left blank]

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup>**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Faucet, Cold	Kitchen	Sink in Kitchen	Church Kitchen Sink	CO	11/10/2021	12.50
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Faucet, Cold	Kitchen	Sink in Kitchen	sink in church kitchen	CO	03/17/2022	11.40
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Faucet, Cold	Kitchen	sink in church kitchen	sink in kitchen	CO	06/15/2022	22.10
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Faucet, Cold	Teachers' Lounge/Break Room	sink in room	Teacher lounge	NC	11/10/2021	5.84
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Auditorium	outside church kitchen	outside church kitchen wall	CO	11/10/2021	12.30
Baltimore County	Havenwood Preschool Center	100 East Ridgely Road	Timonium	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Auditorium	outside kitchen	outside wall of kitchen	CO	03/17/2022	6.12
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	Public	Faucet, Cold	Kitchen	Kitchen single sink	Kitchen single sink	CO	03/22/2022	7.50
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	Public	Faucet, Cold	Kitchen	Kitchen single sink	Kitchen single sink	CO	03/22/2022	7.70

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Classroom	Fountain CTST	Fountain CTST	CO	03/22/2022	15.30
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Classroom	Fountain cosmetology 2	Fountain cosmetology 2	CO	03/22/2022	5.50
Carroll	Carroll County Career & Technology Center	1229 Washington Road	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Classroom	Fountain print production	Fountain print production	CO	03/22/2022	7.10
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Faucet, Cold	Classroom	Sink room 12	Sink room 12	CO	02/14/2020	12.30
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse office sink	Nurse office sink	CO	02/14/2020	25.10
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Gymnasium	Fountain room 34 (gymnasium)	Fountain room 34 (gymnasium)	CO	02/14/2020	14.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Fountain outside room 48	Fountain outside room 48	CO	02/14/2020	8.80
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Other	Fountain room 35 (pool room)	Fountain room 35 (pool room)	CO	02/14/2020	26.60
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen double sink	Kitchen double sink	CO	02/14/2020	11.10
Carroll	Carroll Springs School (Special Education)	495 South Center Street	Westminster	Public	Combination Sink - Faucet, Cold	Kitchen	Kitchen triple sink right dish room	Kitchen triple sink right dish room	CO	02/14/2020	47.00
Carroll	Carrolltowne Elementary	6542 Ridge Road	Sykesville	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 154	Room 154	CO	03/04/2020	7.80
Carroll	Carrolltowne Elementary	6542 Ridge Road	Sykesville	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 152	Room 152	CO	03/04/2020	10.10
Carroll	Cranberry Station Elementary	505 North Center Street	Westminster	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse office sink	Nurse office sink	CO	01/08/2020	8.60

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Eldersburg Elementary	1021 Johnsville Road	Sykesville	Public	Faucet, Cold	Staff Workroom	Room AD3	Room AD3	CO	02/26/2020	13.50
Carroll	Freedom Elementary	5626 Sykesville Road	Sykesville	Public	Faucet, Cold	Nurse's Office/Health Room	sink nurse office	sink nurse office	CO	04/05/2022	9.30
Carroll	Friendship Valley Elementary	1100 Gist Road	Westminster	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	02/07/2020	138.00
Carroll	Liberty High	5855 Bartholow Road	Sykesville	Public	Faucet, Cold	Classroom	Sink room 321	Sink room 321	CO	03/06/2020	6.00
Carroll	Manchester Elementary	3224 York Street	Manchester	Public	Faucet, Cold	Office	Main office sink	Main office sink	CO	01/23/2020	9.30
Carroll	Manchester Elementary	3224 York Street	Manchester	Public	Faucet, Cold	Staff Workroom	Media Center Teacher area	Media Center Teacher area	CO	01/23/2020	7.50
Carroll	Manchester Elementary	3224 York Street	Manchester	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	01/23/2020	71.30
Carroll	Manchester Elementary	3224 York Street	Manchester	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Combination Sink Room 149	Combination Sink Room 149	CO	01/23/2020	11.90
Carroll	Manchester Valley High	3300 Maple Grove Road	Manchester	Public	Faucet, Cold	Office	Main office sink	Main office sink	CO	01/22/2020	6.80

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Manchester Valley High	3300 Maple Grove Road	Manchester	Public	Faucet, Cold	Other	Sink Room D-121	Sink Room D-121	CO	01/22/2020	6.30
Carroll	Manchester Valley High	3300 Maple Grove Road	Manchester	Public	Faucet, Cold	Teachers' Lounge/Break Room	Teacher lounge sink	Teacher lounge sink	CO	01/22/2020	7.10
Carroll	Mt. Airy Elementary	405 North Main Street	Mount Airy	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse Office	Nurse Office	CO	02/21/2020	7.20
Carroll	Mt. Airy Elementary	405 North Main Street	Mount Airy	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 102	Room 102	CO	02/21/2020	7.90
Carroll	Mt. Airy Middle	102 Watersville Road	Mount Airy	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Pot filler kitchen	Pot filler kitchen	CO	04/08/2022	24.10
Carroll	North Carroll Middle	2401 Hanover Pike	Hampstead	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	01/14/2020	6.10
Carroll	North Carroll Middle	2401 Hanover Pike	Hampstead	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen double sink	Kitchen double sink	CO	01/14/2020	8.10

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Parr's Ridge Elementary	202 Watersville Road	Mount Airy	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room D-109	Room D-109	CO	02/21/2020	5.80
Carroll	Piney Ridge Elementary	6315 Freedom Avenue	Sykesville	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse Office	Nurse Office	CO	02/26/2020	5.80
Carroll	Robert Moton Elementary	1413 Washington Road	Westminster	Public	Faucet, Cold	Staff Workroom	Workroom sink B17	Workroom sink B17	CO	02/04/2020	9.30
Carroll	Robert Moton Elementary	1413 Washington Road	Westminster	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	02/04/2020	369.00
Carroll	Shiloh Middle	3675 Willow Street	Hampstead	Public	Faucet, Cold	Nurse's Office/Health Room	sink nurse office	sink nurse office	CO	03/31/2022	10.30
Carroll	Shiloh Middle	3675 Willow Street	Hampstead	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Pot filler kitchen	Pot filler kitchen	CO	03/31/2022	6.30
Carroll	Shiloh Middle	3675 Willow Street	Hampstead	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Double sink kitchen	Double sink kitchen	CO	03/31/2022	7.30
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Faucet, Cold	Kitchen	Kitchen single sink	Kitchen single sink	CO	01/17/2020	11.50

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Faucet, Cold	Nurse's Office/Health Room	sink nurse office	sink nurse office	CO	01/17/2020	12.00
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Faucet, Cold	Staff Workroom	Sink 100B	Sink 100B	CO	01/17/2020	6.90
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	01/17/2020	240.00
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Combination Sink Room 101	Combination Sink Room 101	CO	01/17/2020	9.60
Carroll	Spring Garden Elementary	700 Boxwood Drive	Hampstead	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Combination Sink Room 103	Combination Sink Room 103	CO	01/17/2020	5.90
Carroll	Sykesville Middle	7301 Springfield Avenue	Sykesville	Public	Faucet, Cold	Kitchen	Kitchen island sink	Kitchen island sink	CO	02/28/2020	7.80
Carroll	Sykesville Middle	7301 Springfield Avenue	Sykesville	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen double sink	Kitchen double sink	CO	02/28/2020	12.10
Carroll	Taneytown Elementary	100 Kings Drive	Taneytown	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse office sink	Nurse office sink	CO	01/16/2020	8.80

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Carroll	Taneytown Elementary	100 Kings Drive	Taneytown	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kitchen pot filler	Kitchen pot filler	CO	01/16/2020	9.70
Carroll	Taneytown Elementary	100 Kings Drive	Taneytown	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen double sink	Kitchen double sink	CO	01/16/2020	10.30
Carroll	Westminster Elementary	811 Uniontown Road	Westminster	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 105	Room 105	CO	02/12/2020	8.10
Carroll	Westminster Elementary	811 Uniontown Road	Westminster	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 106	Room 106	CO	02/12/2020	6.80
Carroll	Westminster Elementary	811 Uniontown Road	Westminster	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Portable classroom right side	Portable classroom right side	CO	02/12/2020	18.00
Carroll	William Winchester Elementary	70 Monroe Street	Westminster	Public	Faucet, Cold	Kitchen	Kitchen sink	Kitchen sink	CO	03/24/2022	17.20
Carroll	William Winchester Elementary	70 Monroe Street	Westminster	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse office sink	Nurse office sink	CO	03/24/2022	7.80

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Charles	Daniel of St. Thomas Jenifer Elementary	2820 Jenifer School Lane	Waldorf	Public	Faucet, Cold	Kitchen	kitchen--FC-island sink next to dishwasher	kitchen--FC-island sink next to dishwasher	CO	12/08/2021	21.40
Charles	La Plata High	6035 Radio Station Road	La Plata	Public	Faucet, Cold	Kitchen	kitchen--FC-water fountain - Left	kitchen--FC-water fountain - Left	CO	10/16/2021	5.64
Charles	Mary Burgess Neal Elementary	12105 St. Georges Drive	Waldorf	Public	Faucet, Cold	Classroom	Classroom F212--FC-bubbler	Classroom F212--FC-bubbler	CO	10/13/2021	36.70
Charles	Mary Burgess Neal Elementary	12105 St. Georges Drive	Waldorf	Public	Faucet, Cold	Classroom	Classroom F217--FC-bubbler	Classroom F217--FC-bubbler	CO	10/13/2021	6.79
Charles	Mary H. Matula Elementary	6025 Radio Station Road	La Plata	Public	Faucet, Cold	Classroom (Special Education)	CR 103 (Sp-Ed) SOAR--FC-sink	CR 103 (Sp-Ed) SOAR--FC-sink	CO	10/16/2021	6.87
Charles	Mattawoman Middle	10145 Berry Road	Waldorf	Public	Faucet, Cold	Kitchen	Kitchen--FC-Island sink	Kitchen--FC-Island sink	CO	11/20/2021	5.89
Charles	St. Charles High	5305 Piney Church Road	Waldorf	Public	Faucet, Cold	Concessions	Outside concession stand - see map--SG-sink	Outside concession stand - see map--SG-sink	CO	10/13/2021	14.00
Charles	Theodore G. Davis Middle	2495 Davis Road	Waldorf	Public	Faucet, Cold	Teachers' Lounge/Break Room	D115 teachers lounge--FC-sink	D115 teachers lounge--FC-sink	CO	12/08/2021	8.29
Charles	Theodore G. Davis Middle	2495 Davis Road	Waldorf	Public	Faucet, Cold	Classroom (Special Education)	CR A141 Prep (Sp-Ed) SOAR--FC-hot water dispenser	CR A141 Prep (Sp-Ed) SOAR--FC-hot water dispenser	CO	12/08/2021	9.82
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	Public	Faucet, Cold	Kitchen	kitchen--KK-kettle - Right	kitchen--KK-kettle - Right	CO	10/20/2021	28.20

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	Public	Faucet, Cold	Kitchen	kitchen--KK-Sink - Left fixture	kitchen--KK-Sink - Left fixture	CO	10/20/2021	6.96
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 101--FC-sink - See map	Home Economics 101--FC-sink - See map	CO	10/20/2021	20.30
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 101--FC-sink	Home Economics 101--FC-sink	CO	10/20/2021	7.43
Charles	Westlake High	3300 Middletown Road	Waldorf	Public	Faucet, Cold	Classroom	child development --FC-sink - See map	child development --FC-sink - See map	CO	10/23/2021	5.88
Charles	Westlake High	3300 Middletown Road	Waldorf	Public	Faucet, Cold	Classroom	Classroom 106--FC-sink	Classroom 106--FC-sink	CO	10/23/2021	7.45
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Faucet, Cold	Hallway	A124 Sink Left, HE	A124 Sink Left, HE	CO	01/22/2022	24.30
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Faucet, Cold	Hallway	A124 Sink Second Left, HE	A124 Sink Second Left, HE	CO	01/22/2022	27.80
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Faucet, Cold	Hallway	A124 Sink Back Wall, Left, HE	A124 Sink Back Wall, Left, HE	CO	01/22/2022	9.60
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Faucet, Cold	Hallway	A124 Sink Back Wall, Right, HE	A124 Sink Back Wall, Right, HE	CO	01/22/2022	12.40
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Faucet, Cold	Hallway	A124 Sink, Third Left, HE	A124 Sink, Third Left, HE	CO	01/22/2022	17.70

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Aberdeen High	251 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	A109 Drinking Fountain	A109 Drinking Fountain	CO	01/22/2022	5.60
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Classroom	Room 150 Sink, Home Ec, from CR 151, Third Right	Room 150 Sink, Home Ec, from CR 151, Third Right	CO	01/22/2022	16.60
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Classroom	Room 150 sink, Home Ec, from CR 151 Fourth Right	Room 150 sink, Home Ec, from CR 151 Fourth Right	CO	01/22/2022	35.50
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Classroom	Room 150 Sink, Home Ec from CR 151 Left	Room 150 Sink, Home Ec from CR 151 Left	CO	01/22/2022	24.50
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Classroom	Room 150 Sink, Home Ec from CR 151 Second Left	Room 150 Sink, Home Ec from CR 151 Second Left	CO	01/22/2022	12.00
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Kitchen	Room 237 Kitchen Sink	Room 237 Kitchen Sink	CO	01/22/2022	6.60
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Nurse's Office/Health Room	Health Suite, Restroom Sink Across from Office	Health Suite, Restroom Sink Across from Office	CO	01/22/2022	6.20
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Nurse's Office/Health Room	Health Suite, Restroom Sink Back Left	Health Suite, Restroom Sink Back Left	CO	01/22/2022	35.70
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Faucet, Cold	Nurse's Office/Health Room	Health Suite, Restroom Sink Back Right	Health Suite, Restroom Sink Back Right	CO	01/22/2022	20.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 120	Drinking Fountain Across from 120	CO	01/22/2022	8.60
Harford	Aberdeen Middle	111 Mount Royal Avenue	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 217	Drinking Fountain Across from 217	CO	01/22/2022	26.60
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room A-12 Drinking Fountain	Room A-12 Drinking Fountain	CO	03/17/2022	61.50
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room A-3 Drinking Fountain	Room A-3 Drinking Fountain	CO	03/17/2022	6.70
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room B-3 Drinking Fountain	Room B-3 Drinking Fountain	CO	03/17/2022	6.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Drinking Fountain in 101 B	Drinking Fountain in 101 B	CO	03/17/2022	14.20
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Outside Restroom by Room D2, Left	Drinking Fountain Outside Restroom by Room D2, Left	CO	03/17/2022	8.20
Harford	Abingdon Elementary	399 Singer Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Staff Workroom	Drinking Fountain in Teacher Planning	Drinking Fountain in Teacher Planning	CO	03/18/2022	10.00
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	A Pod Drinking Fountain	A Pod Drinking Fountain	CO	02/03/2022	14.50
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Fountain in K-4	Fountain in K-4	CO	02/03/2022	10.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	Fountain in K-3	Fountain in K-3	CO	02/03/2022	6.20
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	Fountain in K-2	Fountain in K-2	CO	02/03/2022	7.30
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	D Pod, Left Fountain, 4th Grade	D Pod, Left Fountain, 4th Grade	CO	02/03/2022	21.90
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	C Pod, Left Fountain, 3rd Grade	C Pod, Left Fountain, 3rd Grade	CO	02/03/2022	10.70
Harford	Bel Air Elementary	30 East Lee Street	Bel Air	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	E Pod, Fountain, 5th Grade	E Pod, Fountain, 5th Grade	CO	02/03/2022	14.20
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Faucet, Cold	Concessions	Concession Stand Kitchen Sink Left	Concession Stand Kitchen Sink Left	CO	03/19/2022	6.20

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Classroom	Room C111B Kettle	Room C111B Kettle	CO	03/22/2022	99.70
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Small Kettle	Small Kettle	CO	03/19/2022	7.00
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Concessions	Concession Stand Outside Drinking Fountain, Left	Concession Stand Outside Drinking Fountain, Left	CO	03/19/2022	7.90
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Refrigerator Water Dispenser -- Not required if non-metal water line	Storage Room/Area	Storage Closet A203-A205, Refrigerator w/ Cold Water	Storage Closet A203-A205, Refrigerator w/ Cold Water	CO	03/19/2022	9.50
Harford	Bel Air High	100 Heighe Street	Bel Air	Public	Ice Machine (in Refrigerator) -- Not required if non-metal water line	Storage Room/Area	Storage Closet A203-A205, Refrigerator w/ Ice Machine	Storage Closet A203-A205, Refrigerator w/ Ice Machine	CO	03/19/2022	7.20

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Bel Air Middle	99 Idlewild Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Drinking Fountain in Girls Locker Room	Drinking Fountain in Girls Locker Room	CO	03/12/2022	38.10
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Faucet, Cold	Classroom	Sink, Music Room 129	Sink, Music Room 129	CO	03/05/2022	7.40
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Faucet, Cold	Classroom	Sink, Music Room 125	Sink, Music Room 125	CO	03/05/2022	16.40
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Faucet, Cold	Classroom	Sink in 250, Right	Sink in 250, Right	CO	03/05/2022	8.10
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Faucet, Cold	Classroom	Room 117, Right Wall, Right Sink	Room 117, Right Wall, Right Sink	CO	03/05/2022	8.10
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	246 Drinking Fountain	246 Drinking Fountain	CO	03/08/2022	6.30
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Water Fountain in Pod Across from 116	Drinking Water Fountain in Pod Across from 116	CO	03/05/2022	9.90

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	C. Milton Wright High	1301 North Fountain Green Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Near 247 Near Restroom	Drinking Fountain Near 247 Near Restroom	CO	03/05/2022	6.10
Harford	Church Creek Elementary	4299 Church Creek Road	Belcamp	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 106 Drinking Fountain	Room 106 Drinking Fountain	CO	03/08/2022	11.70
Harford	Church Creek Elementary	4299 Church Creek Road	Belcamp	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 127 Drinking Fountain	Room 127 Drinking Fountain	CO	03/08/2022	17.20
Harford	Edgewood Elementary	2100 Cedar Drive	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 125 Drinking Fountain on Right Wall	Room 125 Drinking Fountain on Right Wall	CO	01/29/2022	32.70
Harford	Edgewood Elementary	2100 Cedar Drive	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 400 Drinking Fountain	Room 400 Drinking Fountain	CO	02/01/2022	6.20

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Edgewood Elementary	2100 Cedar Drive	Edgewood	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 404 Drinking Fountain on Far Wall	Room 404 Drinking Fountain on Far Wall	CO	01/29/2022	5.60
Harford	Edgewood Elementary	2100 Cedar Drive	Edgewood	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 347 Drinking Fountain on Left Wall	Room 347 Drinking Fountain on Left Wall	CO	02/01/2022	8.50
Harford	Edgewood High	2415 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	C103 Fountain	C103 Fountain	CO	01/29/2022	7.80
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Faucet, Cold	Classroom	74 Sink, Right	74 Sink, Right	CO	02/24/2022	35.70
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Drinking Fountain 22	Drinking Fountain 22	CO	02/24/2022	175.20
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Drinking Fountain 21	Drinking Fountain 21	CO	02/24/2022	8.40

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Drinking Fountain 19	Drinking Fountain 19	CO	02/24/2022	54.50
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	15 Drinking Fountain	15 Drinking Fountain	CO	02/24/2022	40.30
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	16 Drinking Fountain	16 Drinking Fountain	CO	02/24/2022	12.60
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	14 Drinking Fountain	14 Drinking Fountain	CO	02/24/2022	15.70
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	11 Drinking Fountain	11 Drinking Fountain	CO	02/24/2022	15.80

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	74 Drinking Fountain, Right	74 Drinking Fountain, Right	CO	02/25/2022	13.60
Harford	Edgewood Middle	2311 Willoughby Beach Road	Edgewood	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 56, Left	Drinking Fountain Across from 56, Left	CO	02/24/2022	12.10
Harford	Emmorton Elementary	2502 South Tollgate Road	Bel Air	Public	Faucet, Cold	Kitchen	Kitchen Sink, Left	Kitchen Sink, Left	CO	02/17/2022	9.00
Harford	Forest Lakes Elementary	100 Osborne Parkway	Forest Hill	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Fountain on Right in Cafeteria	Fountain on Right in Cafeteria	CO	02/11/2022	5.60
Harford	Forest Lakes Elementary	100 Osborne Parkway	Forest Hill	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Fountain on Left in Cafeteria	Fountain on Left in Cafeteria	CO	02/11/2022	5.70
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 22 - Drinking Fountain	Room 22 - Drinking Fountain	CO	01/22/2022	13.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 19 - Drinking Fountain	Room 19 - Drinking Fountain	CO	01/22/2022	16.20
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 17 - Drinking Fountain	Room 17 - Drinking Fountain	CO	01/22/2022	14.10
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 5 - Drinking Fountain	Room 5 - Drinking Fountain	CO	01/22/2022	34.80
Harford	George D. Lisby Elementary @ Hillsdale	810 Edmund Street	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 3 - Drinking Fountain	Room 3 - Drinking Fountain	CO	01/22/2022	6.10
Harford	Hall's Cross Roads Elementary	203 East Bel Air Avenue	Aberdeen	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	K2 Fountain	K2 Fountain	CO	04/07/2022	8.00
Harford	Havre de Grace Elementary	600 Juniata Street	Havre De Grace	Public	Faucet, Cold	Kitchen	Kitchen Sink Near Office	Kitchen Sink Near Office	CO	03/26/2022	12.40

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Havre de Grace Elementary	600 Juniata Street	Havre De Grace	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 411 Drinking Fountain in K Building	Room 411 Drinking Fountain in K Building	CO	03/26/2022	26.60
Harford	Havre de Grace Elementary	600 Juniata Street	Havre De Grace	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Drinking Fountain in K Building Pre-K Room	Drinking Fountain in K Building Pre-K Room	CO	03/26/2022	45.40
Harford	Havre de Grace Elementary	600 Juniata Street	Havre De Grace	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Storage Room/Area	Drinking Fountain in Storage Room in K Building	Drinking Fountain in Storage Room in K Building	CO	03/26/2022	11.20
Harford	Hickory Elementary	2100 Conowingo Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 501 Drinking Fountain	Room 501 Drinking Fountain	CO	03/12/2022	7.80
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 2 Drinking Fountain	Room 2 Drinking Fountain	CO	03/19/2022	15.90

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 3 Drinking Fountain	Room 3 Drinking Fountain	CO	03/19/2022	11.00
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 5 Drinking Fountain	Room 5 Drinking Fountain	CO	03/19/2022	19.90
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 19 Drinking Fountain	Room 19 Drinking Fountain	CO	03/19/2022	17.20
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 21 Drinking Fountain	Room 21 Drinking Fountain	CO	03/19/2022	9.40
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Drinking Fountain Across from 5C	Drinking Fountain Across from 5C	CO	03/19/2022	39.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Homestead Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain near Custodial Office	Drinking Fountain near Custodial Office	CO	03/19/2022	9.90
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Drinking Water Fountain - Bubblers Style	Hallway	Women's Locker Room	fountain	CO	11/24/2021	53.30
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	Men's in Main Office	Sink	NC	11/24/2021	7.70
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	in Men's Locker Room	Left Sink	NC	11/24/2021	68.30
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	in Men's Locker Room	Right Sink	NC	11/24/2021	2890.00
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	Men's by Room 107	Left Sink	NC	11/24/2021	18.00
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	Men's by Room 107	Middle Left Sink	NC	11/24/2021	7.80
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Bathroom	Men's by Room 107	Middle Right Sink	NC	11/24/2021	8.70
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom	Room 118	Middle Sink	NC	11/24/2021	54.50

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom	Room 304	Sink	NC	11/24/2021	42.80
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Kitchen	at Serving Area	Handwashing Sink	NC	11/24/2021	7.20
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Office	Accountant	Sink	NC	11/24/2021	24.30
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Office	Controller	Sink	NC	11/24/2021	44.70
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Office	Accounts Payable	Sink	NC	11/24/2021	5.60
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Other	Dorm Room 200	Sink	NC	11/24/2021	13.20
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Workroom	in Room 304	Sink	NC	11/24/2021	70.60
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Prep Room/Area	Women's Dressing Room	Sink	NC	11/24/2021	5.60
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216	Teacher's Sink	NC	11/24/2021	25.20
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216 on West Wall	North Sink	NC	11/24/2021	41.60

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216 on South Wall	West Sink	NC	11/24/2021	15.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216 on South Wall	East Sink	NC	11/24/2021	32.60
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216 on East Wall	South Sink	NC	11/24/2021	47.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 216 on East Wall	North Sink	NC	11/24/2021	52.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 on South Wall	East Sink	NC	11/24/2021	6.90
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 on East Wall	North Sink	NC	11/24/2021	15.90
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 Northeast Bench	South Sink	NC	11/24/2021	23.10
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 Northeast Bench	North Sink	NC	11/24/2021	25.00
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 Northwest Bench	South Sink	NC	11/24/2021	21.10
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 Northwest Bench	North Sink	NC	11/24/2021	16.40

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 on West Wall	South Sink	NC	11/24/2021	24.50
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 213 on West Wall	North Sink	NC	11/24/2021	8.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 222 Teacher's Counter	Sink	NC	11/24/2021	24.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 208 South Side	South Teacher's Sink	NC	11/24/2021	79.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 208 South Side	North Teacher's Sink	NC	11/24/2021	14.50
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 208 on East Wall	Sink	NC	11/24/2021	73.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Faucet, Cold	Classroom (Science Lab)	Room 208 on West Wall	Sink	NC	11/24/2021	26.40
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style	Hallway	outside Room 112	fountain	CO	11/24/2021	8.70
Harford	Joppatowne High	555 Joppa Farm Road	Joppa	Public	Faucet, Cold	Kitchen	Isle Sink, Kitchen, Left	Isle Sink, Kitchen, Left	CO	03/24/2022	19.30
Harford	Joppatowne High	555 Joppa Farm Road	Joppa	Public	Faucet, Cold	Kitchen	Kitchen Sink, Right Wall, Left	Kitchen Sink, Right Wall, Left	CO	03/24/2022	8.10

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Joppatowne High	555 Joppa Farm Road	Joppa	Public	Faucet, Cold	Weight/Training/Fitness Room	Sink in Training Room, Boys Side	Sink in Training Room, Boys Side	CO	03/24/2022	10.20
Harford	Magnolia Elementary	901 Trimble Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain in Front of Planning B	Drinking Fountain in Front of Planning B	CO	03/23/2022	10.00
Harford	Magnolia Elementary	901 Trimble Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain in Front of Pod D	Drinking Fountain in Front of Pod D	CO	03/23/2022	139.30
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Faucet, Cold	Classroom	209 Sink	209 Sink	CO	03/01/2022	15.10
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Faucet, Cold	Classroom	109 Sink	109 Sink	CO	03/01/2022	6.70
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kettle, Left	Kettle, Left	CO	02/26/2022	12.10
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Small Kettle	Small Kettle	CO	02/26/2022	18.10

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Drinking Fountain, Cafeteria, Right	Drinking Fountain, Cafeteria, Right	CO	02/26/2022	11.70
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	209 Drinking Fountain	209 Drinking Fountain	CO	02/26/2022	30.40
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	109 Drinking Fountain	109 Drinking Fountain	CO	02/26/2022	16.10
Harford	Magnolia Middle	299 Fort Hoyle Road	Joppa	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Other	Drinking Fountain on Pool Deck, Left	Drinking Fountain on Pool Deck, Left	CO	02/26/2022	19.80
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	A-1 Drinking Fountain	A-1 Drinking Fountain	CO	01/27/2022	6.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	E-4 Drinking Fountain	E-4 Drinking Fountain	CO	01/27/2022	6.30
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	E-6 Drinking Fountain	E-6 Drinking Fountain	CO	01/27/2022	11.10
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	E-8 Drinking Fountain	E-8 Drinking Fountain	CO	01/27/2022	6.00
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	E-5 Drinking Fountain	E-5 Drinking Fountain	CO	01/27/2022	14.30
Harford	Old Post Road Elementary	2706 Old Philadelphia Road	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	E-7 Drinking Fountain	E-7 Drinking Fountain	CO	01/27/2022	25.10
Harford	Patterson Mill Middle/High	85 Patterson Mill Road	Bel Air	Public	Faucet, Cold	Classroom	J116 Sink, Across from Cafe, Center Middle	J116 Sink, Across from Cafe, Center Middle	CO	02/12/2022	41.20

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Patterson Mill Middle/High	85 Patterson Mill Road	Bel Air	Public	Faucet, Cold	Classroom	J116 Sink, Across from Cafe, Center	J116 Sink, Across from Cafe, Center	CO	02/12/2022	5.50
Harford	Patterson Mill Middle/High	85 Patterson Mill Road	Bel Air	Public	Faucet, Cold	Nurse's Office/Health Room	Second Level Health Suite, G201 Sink, Middle	Second Level Health Suite, G201 Sink, Middle	CO	02/17/2022	8.50
Harford	Patterson Mill Middle/High	85 Patterson Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain, Across from E227, E Pod, Right	Drinking Fountain, Across from E227, E Pod, Right	CO	02/12/2022	17.10
Harford	Roye-Williams Elementary	201 Oakington Road	Havre De Grace	Public	Faucet, Cold	Classroom	ESOL 14 & 15 Sink	ESOL 14 & 15 Sink	CO	03/25/2022	22.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Faucet, Cold	Teachers' Lounge/Break Room	F1 Faculty Lounge Sink	F1 Faculty Lounge Sink	CO	02/19/2022	1249.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Faucet, Cold	Classroom (Home Economics)	Room 129 Home Ec Sink, Second Left	Room 129 Home Ec Sink, Second Left	CO	02/19/2022	10.40
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Faucet, Cold	Classroom (Home Economics)	Room 129 Home Ec Sink, Third Left	Room 129 Home Ec Sink, Third Left	CO	02/19/2022	54.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Faucet, Cold	Classroom (Home Economics)	Room 129 Home Ec Sink, Fourth Left	Room 129 Home Ec Sink, Fourth Left	CO	02/19/2022	9.90
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Faucet, Cold	Classroom (Home Economics)	Room 129 Home Ec Sink, Second Right	Room 129 Home Ec Sink, Second Right	CO	02/19/2022	7.10

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kettle, Left	Kettle, Left	CO	02/19/2022	45.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Kettle, Right	Kettle, Right	CO	02/19/2022	15.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Small Kettle	Small Kettle	CO	02/19/2022	21.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 103 Drinking Fountain	Room 103 Drinking Fountain	CO	02/19/2022	59.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 116 Drinking Fountain	Room 116 Drinking Fountain	CO	02/19/2022	41.90

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 115 Drinking Fountain	Room 115 Drinking Fountain	CO	02/19/2022	410.90
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 113 Drinking Fountain	Room 113 Drinking Fountain	CO	02/19/2022	413.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 112 Drinking Fountain	Room 112 Drinking Fountain	CO	02/19/2022	9.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 110 Drinking Fountain	Room 110 Drinking Fountain	CO	02/19/2022	445.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 119 Drinking Fountain	Room 119 Drinking Fountain	CO	02/19/2022	24.70

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 217 Drinking Fountain	Room 217 Drinking Fountain	CO	02/19/2022	27.60
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 211 Drinking Fountain	Room 211 Drinking Fountain	CO	02/19/2022	70.80
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 213 Drinking Fountain	Room 213 Drinking Fountain	CO	02/19/2022	6.20
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 218 Drinking Fountain	Room 218 Drinking Fountain	CO	02/19/2022	25.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 216 Drinking Fountain	Room 216 Drinking Fountain	CO	02/19/2022	4679.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 214 Drinking Fountain	Room 214 Drinking Fountain	CO	02/19/2022	561.00
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 212 Drinking Fountain	Room 212 Drinking Fountain	CO	02/19/2022	322.60
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 208 Drinking Fountain	Room 208 Drinking Fountain	CO	02/19/2022	316.40
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 207 Drinking Fountain	Room 207 Drinking Fountain	CO	02/19/2022	57.60
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Outside Gym, Left	Drinking Fountain Outside Gym, Left	CO	02/19/2022	191.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 218	Drinking Fountain Across from 218	CO	02/19/2022	33.70
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 124	Drinking Fountain Across from 124	CO	02/19/2022	6.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Teachers' Lounge/Break Room	F-21 Faculty Room Drinking Fountain	F-21 Faculty Room Drinking Fountain	CO	02/19/2022	75.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Teachers' Lounge/Break Room	F-20 Faculty Room Drinking Fountain	F-20 Faculty Room Drinking Fountain	CO	02/19/2022	74.50
Harford	Southampton Middle	1200 Moores Mill Road	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Teachers' Lounge/Break Room	F2 Faculty Lounge Drinking Fountain	F2 Faculty Lounge Drinking Fountain	CO	02/23/2022	21.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Front Wall	FAPE, Front Wall	CO	03/10/2022	16.00
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, First Left 115	FAPE, First Left 115	CO	03/10/2022	39.30
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Second Left 115	FAPE, Second Left 115	CO	03/10/2022	88.30
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Third Left 115	FAPE, Third Left 115	CO	03/10/2022	609.30
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Back Wall 115	FAPE, Back Wall 115	CO	03/10/2022	884.40
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Back Right Wall 115	FAPE, Back Right Wall 115	CO	03/10/2022	170.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Classroom	FAPE, Right Wall 115	FAPE, Right Wall 115	CO	03/10/2022	43.20
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Right Side Sink, Right	Right Side Sink, Right	CO	03/10/2022	6.40
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Right Side Sink, Middle	Right Side Sink, Middle	CO	03/10/2022	16.00
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Right Side Sink, Left	Right Side Sink, Left	CO	03/10/2022	11.60
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Left Side Sink, Right	Left Side Sink, Right	CO	03/10/2022	18.60
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Nurse's Office/Health Room	Health Suite Room 117 Sink	Health Suite Room 117 Sink	CO	03/10/2022	15.50

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold		Nurse's Office/Health Room	Health Suite Room 116 Sink	CO	03/10/2022	36.40
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	132 Drinking Fountain	132 Drinking Fountain	CO	03/10/2022	6.60
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	130 Drinking Fountain	130 Drinking Fountain	CO	03/10/2022	46.50
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	126 Drinking Fountain	126 Drinking Fountain	CO	03/10/2022	40.20
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from Café	Drinking Fountain Across from Café	CO	03/10/2022	20.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 118	Drinking Fountain Across from 118	CO	03/10/2022	65.30
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from 132	Drinking Fountain Across from 132	CO	03/10/2022	44.40
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Annex 144, Right	Annex 144, Right	CO	03/10/2022	40.70
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Annex, 144, Left	Annex, 144, Left	CO	03/10/2022	11.60
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Drinking Fountain in Girls Locker Room	Drinking Fountain in Girls Locker Room	CO	03/10/2022	59.90

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Drinking Fountain in Boys Locker Room	Drinking Fountain in Boys Locker Room	CO	03/10/2022	6.90
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Faucet, Cold	Conference Room	Conference Room Sink	Conference Room Sink	CO	03/19/2022	10.60
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 3 Drinking Fountain	Room 3 Drinking Fountain	CO	03/19/2022	9.50
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 4 Drinking Fountain	Room 4 Drinking Fountain	CO	03/19/2022	14.90
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 1 Drinking Fountain	Room 1 Drinking Fountain	CO	03/19/2022	8.00
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 5 Drinking Fountain	Room 5 Drinking Fountain	CO	03/19/2022	8.40

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 6 Drinking Fountain	Room 6 Drinking Fountain	CO	03/19/2022	6.30
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 8 Drinking Fountain	Room 8 Drinking Fountain	CO	03/19/2022	17.40
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 10 Drinking Fountain	Room 10 Drinking Fountain	CO	03/19/2022	5.50
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 11 Drinking Fountain	Room 11 Drinking Fountain	CO	03/19/2022	6.60
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 18 Drinking Fountain	Room 18 Drinking Fountain	CO	03/19/2022	11.60

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 20 Drinking Fountain	Room 20 Drinking Fountain	CO	03/19/2022	5.80
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 23 Drinking Fountain	Room 23 Drinking Fountain	CO	03/19/2022	7.30
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 24 Drinking Fountain	Room 24 Drinking Fountain	CO	03/19/2022	11.90
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	K2 Drinking Fountain	K2 Drinking Fountain	CO	03/19/2022	8.60
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	K3 Drinking Fountain	K3 Drinking Fountain	CO	03/19/2022	20.70

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>†‡</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	K4 Drinking Fountain	K4 Drinking Fountain	CO	03/19/2022	6.00
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 7 Drinking Fountain	Room 7 Drinking Fountain	CO	03/19/2022	8.70
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Guidance Office Drinking Fountain	Guidance Office Drinking Fountain	CO	03/22/2022	19.20
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Conference Room	Conference Room Drinking Fountain	Conference Room Drinking Fountain	CO	03/22/2022	16.40
Harford	Wakefield Elementary	900 South Main Street	Bel Air	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom (Art)	Art Room Drinking Fountain	Art Room Drinking Fountain	CO	03/22/2022	9.50
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Faucet, Cold	Kitchen	Kitchen Dish Sink, passed door to cafeteria	Kitchen Dish Sink, passed door to cafeteria	CO	02/08/2022	2215.00

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>‡‡</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 2 Drinking Fountain	Room 2 Drinking Fountain	CO	02/08/2022	29.50
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 5 Drinking Fountain	Room 5 Drinking Fountain	CO	02/08/2022	72.90
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 6 Drinking Fountain	Room 6 Drinking Fountain	CO	02/08/2022	6.30
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 11 Drinking Fountain	Room 11 Drinking Fountain	CO	02/08/2022	6.70
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 13 Drinking Fountain	Room 13 Drinking Fountain	CO	02/08/2022	10.60

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubler Style (Non-Refrigerated)	Classroom	Room 14 Drinking Fountain	Room 14 Drinking Fountain	CO	02/08/2022	6.40
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubler Style (Non-Refrigerated)	Classroom	Room 15 Drinking Fountain	Room 15 Drinking Fountain	CO	02/08/2022	10.70
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubler Style (Non-Refrigerated)	Classroom	Room 16 Drinking Fountain	Room 16 Drinking Fountain	CO	02/08/2022	6.90
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubler Style (Non-Refrigerated)	Classroom	Room 17 Drinking Fountain	Room 17 Drinking Fountain	CO	02/08/2022	6.40
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubler Style (Non-Refrigerated)	Classroom	Room 21 Drinking Fountain	Room 21 Drinking Fountain	CO	02/08/2022	76.10

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized



**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	William Paca Elementary	2706 Old Philadelphia Road	Abingdon	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 23 Drinking Fountain	Room 23 Drinking Fountain	CO	02/08/2022	8.10
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	K-4 Area Drinking Fountain Near Gym	K-4 Area Drinking Fountain Near Gym	CO	02/25/2022	13.60
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain in the K-1 Area Across from Office	Drinking Fountain in the K-1 Area Across from Office	CO	02/25/2022	9.30
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Drinking Fountain Across from Pod 1 & 2	Drinking Fountain Across from Pod 1 & 2	CO	02/25/2022	24.50
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Nurse's Office/Health Room	Health Suite Drinking Fountain	Health Suite Drinking Fountain	CO	02/25/2022	61.40

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

**Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2022)<sup>††</sup> - Continued**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	FIXTURE TYPE <sup>†</sup>	FIXTURE AREA TYPE <sup>†</sup>	FIXTURE LOCATION DESCRIPTION <sup>†</sup>	DESCRIPTION <sup>†</sup>	USE <sup>†,‡</sup>	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Harford	William S. James Elementary	1 Laurentum Parkway	Abingdon	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Media Center	Media Center Work Area	Media Center Work Area	CO	02/25/2022	9.20
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 120 Music	Sink	CO	12/08/2021	6.80
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 251	Sink	CO	12/08/2021	8.60
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 240	Sink	CO	12/08/2021	23.50
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 234	Sink	CO	12/08/2021	21.30
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 232	Sink	CO	12/08/2021	8.20
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	120 Music	Classroom Sink	CO	01/26/2022	7.80
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	Public	Faucet, Cold	Classroom	Room 233	Sink	CO	12/08/2021	10.20
Washington	Smithsburg Middle	68 North Main Street	Smithsburg	Public	Faucet, Cold	Nurse's Office/Health Room	Health room	Single faucet	CO	10/20/2021	7.30

<sup>†</sup>As reported by school

<sup>‡</sup>CO = Consumption, NC = Non-Consumption

<sup>††</sup>Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized