



Annual Report on Testing for Lead in Drinking Water for Maryland Public and Nonpublic Schools

Fiscal Year 2024

Submitted jointly by the Maryland Department of the Environment and the Maryland Department of Education

Revised and Submitted February 13, 2025

Prepared for:
Bill Ferguson, Senate President
Maryland General Assembly

Adrienne A. Jones, House Speaker
Maryland General Assembly



Wes Moore
Governor

Aruna Miller
Lieutenant Governor

Serena McIlwain
Secretary

Suzanne Dorsey
Deputy Secretary

Background and Findings

House Bill (HB) 270 (2017) established a framework to reduce Maryland school children's exposure to lead in drinking water. HB 270 directed the Maryland Department of the Environment (MDE), in consultation with the Maryland State Department of Education (MSDE), Maryland Department of General Services (DGS), and Maryland Occupational Safety and Health (MOSH), to adopt regulations to require periodic testing for the presence of lead in each drinking water outlet located in an occupied public or nonpublic school building. The law required MDE to establish a stakeholder group and to gather information about the testing processes, protocols, and efforts undertaken by schools to test for and remediate lead. The law also required MDE, in consultation with MSDE, to provide a mechanism to grant waivers from testing to schools under certain circumstances. Furthermore, on or before Dec. 1, 2018, and each year thereafter, MDE and MSDE must jointly report to the Governor and the Maryland General Assembly on the findings of the lead testing conducted by schools.

The legislation defines an elevated level of lead as a lead concentration in drinking water that exceeds the standard recommended by the U.S. Environmental Protection Agency (EPA) in the most recent technical guidance (*3Ts for Reducing Lead in Drinking Water in Schools*). The Action Level for lead in the EPA's technical guidance, effective at the time, was 20 parts per billion (ppb).

HB 1253 (2019) strengthened the lead protection measures established in HB 270 by setting a lead level of no more than 5 ppb as a goal for schools. The law also provided a funding mechanism for schools to remediate drinking water outlets that exceeded this level and expanded the information that must be reported to the Governor and the Maryland General Assembly.

HB 636 (2021) further reinforced the lead protection measures established in both HB 270 and HB 1253 by altering the definition of an elevated level of lead from 20 to 5 ppb (effective June 1, 2021, and applied retroactively). This change significantly increased the number of drinking water outlets that were required to be removed from service immediately and remediated. In addition, the new law set a deadline of Aug. 1, 2022, for schools to complete remediation of drinking water outlets that had lead levels between 5 and 20 ppb if the samples were analyzed by a state-certified laboratory by June 1, 2021.

Maryland regulations establish a three-year testing frequency for all schools. This report, which will be made available to Maryland citizens through MDE's website, provides information on the results of validated lead samples collected from drinking water outlets in schools during the annual reporting cycle ending July 1, 2024, including:

- (1) The name and address of each school that has tested its drinking water for lead and reported the test results to the state during the reporting period (Table 1);
- (2) The name and address of each school found to have elevated levels of lead in its drinking water (Table 2); and
- (3) The type, location in the building, and use of each water outlet with an elevated level of lead (Table 2).

This report also includes results from validated lead sampling during previous reporting cycles (i.e., July 2, 2017, through July 1, 2023) that were not included in previous reports (Tables 3 and 4).

Over 370 schools submitted results of lead samples collected during the current reporting period (July 2, 2023, through July 1, 2024). Of these schools, MDE was able to review results from 225 schools (186 public schools, 2 charter schools, and 37 nonpublic schools) and determine that 224 schools (186 public schools, 2 charter schools, and 36 nonpublic schools) reviewed have one or more valid samples (i.e., collected and analyzed in accordance with Code of Maryland Regulations (COMAR) 26.16.07.07). Review of the remaining schools' results is ongoing. Proper sample collection, recordkeeping, and reporting at the schools, laboratory analysis, and data review by MDE, are labor-intensive and time-consuming processes, and data received by MDE is often incomplete or contains errors. Due both to the quality and completeness of data received as well as the exacting nature of its review, MDE was only able to review and report on approximately three-fifths of the schools submitting lead sample results during this reporting period by the statutory deadline. Additional review of data will continue throughout the year and will be presented in the future reports.

Ensuring rigorous quality control while also conducting data review in a timely manner constitutes a significant challenge for the ongoing implementation of the effort to test for lead in drinking water in schools. In response, MDE is undertaking several initiatives to further improve the quality, integrity, and tracking of the sampling and reporting process. Using grant funds, awarded under Section 2107 of the Water Infrastructure Improvements for the Nation (WIIN) Act, MDE is currently developing a database and a mobile-capable sampling application to streamline sample collection and data tracking for drinking water outlets, and facilitate more rapid and accurate reporting from schools both to laboratories and MDE. Additionally, MDE is continually updating and refining its technical guidance, and has developed a series of training videos, which are available on MDE's website, and informational sessions (six in the Spring of 2024 and ten in the Fall of 2024) on the training videos. These information technology innovations and technical assistance efforts will improve data quality and expedite the review process for MDE, reducing the likelihood of a growing backlog.

Of the 224 schools for which data was reviewed and samples determined to be valid by MDE in this reporting cycle, 44% (84 public schools and 14 nonpublic schools) had one or more sample results exceeding Maryland's lead Action Level (AL) of 5 ppb. Of the approximately 5,835 valid samples collected from these 223 schools, about 6.0% had lead levels exceeding 5 ppb. When outlets used for drinking, food preparation, or cooking are found to have elevated levels of lead in the water, schools are required to prevent access to these outlets within 24 hours.

Maryland's goal is to eliminate any occurrence of elevated levels of lead in drinking water provided to approximately 1 million children by the nearly 3,000 public and nonpublic schools in the state. The significant reduction in the AL from 20 ppb to 5 ppb, effective June 1, 2021, coupled with continued testing and remediation, further reduces exposure to lead in drinking water, and is an important step in achieving this goal. In addition, the remediation funding mechanism provided under HB 1253 further supports MDE's goal to eliminate any occurrence of elevated lead levels in drinking water in schools.

List of Tables

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024)	5
Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024)	23
Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2023)	61
Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2023)	65

[This page intentionally left blank]

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024)

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Allegany	Allegany High (New)	900 Seton Drive	Cumberland	21502	Public	No
Allegany	Bishop Walsh School	700 Bishop Walsh Road	Cumberland	21502	Nonpublic	Yes**, ***
Allegany	Braddock Middle	909 Holland Street	Cumberland	21502	Public	No
Allegany	Cash Valley Elementary	10601 Cash Valley Road NW	LaVale	21502	Public	No
Allegany	Center For Career & Technical Education	14211 McMullen Highway SW	Cresaptown	21502	Public	No
Allegany	Fort Hill High	500 Greenway Avenue	Cumberland	21502	Public	No
Allegany	George's Creek Elementary	15600 Lower George's Creek Road	Lonaconing	21539	Public	No
Allegany	John Humbird Elementary	120 East Mary Street	Cumberland	21502	Public	No
Allegany	Northeast Elementary	11001 Forest Avenue	Cumberland	21502	Public	No
Allegany	South Penn Elementary	500 East Second Street	Cumberland	21502	Public	No
Allegany	Washington Middle	200 Massachusetts Avenue	Cumberland	21502	Public	No
Anne Arundel	Annapolis Elementary	180 Green Street	Annapolis	21401	Public	No****
Anne Arundel	Annapolis High	2700 Riva Road	Annapolis	21401	Public	Yes**, ***
Anne Arundel	Annapolis Middle	1399 Forest Drive	Annapolis	21403	Public	Yes**, ****
Anne Arundel	Belle Grove Elementary	4502 Belle Grove Road	Baltimore	21225	Public	*
Anne Arundel	Belvedere Elementary	360 Broadwater Road	Arnold	21012	Public	Yes**, ***
Anne Arundel	Broadneck High	1265 Green Holly Drive	Annapolis	21409	Public	Yes**, ***
Anne Arundel	Brooklyn Park Middle	200 Hammonds Lane	Baltimore	21225	Public	*
Anne Arundel	Cape St. Claire Elementary	931 Blue Ridge Drive	Annapolis	21409	Public	No**, ***
Anne Arundel	Center of Applied Technology North	800 Stevenson Road	Severn	21144	Public	No
Anne Arundel	Center of Applied Technology South	211 Central Avenue East	Edgewater	21037	Public	No
Anne Arundel	Central Middle	221 Central Avenue East	Edgewater	21037	Public	Yes**, ***, ****
Anne Arundel	Chesapeake Science Point Public Charter	7321 Parkway Drive South	Hanover	21076	Charter	No**
Anne Arundel	Creative Garden School	1560 Crofton Parkway	Crofton	21114	Nonpublic	*
Anne Arundel	Crofton Middle	2301 Davidsonville Road	Gambrills	21054	Public	Yes**, ***, ****

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Anne Arundel	Crofton Woods Elementary	1750 Urby Drive	Crofton	21114	Public	Yes**, ***
Anne Arundel	Eastport Elementary	420 Fifth Street	Annapolis	21403	Public	*
Anne Arundel	Ferndale Early Education Center (EEC)	105 Packard Avenue	Glen Burnie	21061	Public	*
Anne Arundel	Fort Smallwood Elementary	1720 Poplar Ridge Road	Pasadena	21122	Public	No**
Anne Arundel	Frank Hebron-Harman Elementary	7660 Ridge Chapel Road	Hanover	21076	Public	*
Anne Arundel	Georgetown East Elementary	111 Dogwood Road	Annapolis	21403	Public	Yes**, ***
Anne Arundel	Germantown Elementary	200 Windell Avenue	Annapolis	21401	Public	*
Anne Arundel	Glendale Elementary	105 Carroll Road	Glen Burnie	21060	Public	*
Anne Arundel	Granite Baptist Church School	7823 Oakwood Road	Glen Burnie	21061	Nonpublic	*
Anne Arundel	High Point Elementary (New Building)	7789 Edgewood Avenue	Pasadena	21122	Public	No**
Anne Arundel	Hillsmere Elementary	3052 Arundel on the Bay Road	Annapolis	21403	Public	*
Anne Arundel	Hilltop Elementary	415 Melrose Avenue	Glen Burnie	21061	Public	No**
Anne Arundel	Jacobsville Elementary	3801 Mountain Road	Pasadena	21122	Public	No**
Anne Arundel	Lindale Middle	415 Andover Road	Linthicum	21090	Public	No**
Anne Arundel	Magothy River Middle	241 Peninsula Farm Road	Arnold	21012	Public	Yes**
Anne Arundel	Marley Elementary	715 Cooper Road	Glen Burnie	21060	Public	*
Anne Arundel	Marley Middle	10 Davis Court	Glen Burnie	21060	Public	No**
Anne Arundel	Mary Moss @ J. Albert Adams Academy	245 Clay Street	Annapolis	21401	Public	Yes**, ***, ****
Anne Arundel	Maryland City Elementary	3359 Crumpton South	Laurel	20724	Public	*
Anne Arundel	Meade Heights Elementary	1925 Reece Road	Fort Meade	20755	Public	No**
Anne Arundel	Meade Middle	1103 26th Street	Fort Meade	20755	Public	*
Anne Arundel	Mills-Parole Elementary	1 George and Marion Phelps Lane	Annapolis	21401	Public	*
Anne Arundel	Monsignor Slade Catholic School	120 Dorsey Road	Glen Burnie	21061	Nonpublic	*
Anne Arundel	North County High	10 East 1st Avenue	Glen Burnie	21061	Public	*

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Anne Arundel	North Glen Elementary	615 West Furnace Branch Road	Glen Burnie	21061	Public	*
Anne Arundel	Odenton Elementary	1290 Odenton Road	Odenton	21113	Public	*
Anne Arundel	Overlook Elementary	401 Hampton Road	Linthicum	21090	Public	*
Anne Arundel	Park Elementary	201 East 11th Avenue	Baltimore	21225	Public	*
Anne Arundel	Pasadena Elementary	401 East Pasadena Road	Pasadena	21122	Public	No**
Anne Arundel	Pathways School - Anne Arundel, The	1819 Bay Ridge Avenue, Suite #340	Annapolis	21403	Nonpublic	*
Anne Arundel	Pershing Hill Elementary	7600 29th Division Road	Fort Meade	20755	Public	*
Anne Arundel	Phoenix Academy	1411 Cedar Park Road	Annapolis	21401	Public	No**
Anne Arundel	Piney Orchard Elementary	2641 Strawberry Lake Way	Odenton	21113	Public	*
Anne Arundel	Quarterfield Elementary	7967 Quarterfield Road	Severn	21144	Public	*
Anne Arundel	Richard Henry Lee Elementary	400 A Street	Glen Burnie	21061	Public	*
Anne Arundel	Rippling Woods Elementary	530 Nolfield Drive	Glen Burnie	21061	Public	*
Anne Arundel	Riviera Beach Elementary	8515 Jenkins Road	Pasadena	21122	Public	*
Anne Arundel	Ruth Parker Eason	648 Old Mill Road	Millersville	21108	Public	*
Anne Arundel	School of the Incarnation	2601 Symphony Lane	Gambrills	21054	Nonpublic	No**
Anne Arundel	Seven Oaks Elementary	1905 Town Center Boulevard	Odenton	21113	Public	*
Anne Arundel	Severn River Middle	241 Peninsula Farm Road	Arnold	21012	Public	*
Anne Arundel	Severn School - Teel Campus	201 Water Street	Severna Park	21146	Nonpublic	*
Anne Arundel	Severna Park Elementary	6 Riggs Avenue	Severna Park	21146	Public	*
Anne Arundel	Severna Park Middle	450 Jumpers Hole Road	Severna Park	21146	Public	*
Anne Arundel	South River High	201 Central Avenue	East Edgewater	21037	Public	*
Anne Arundel	Southgate Elementary	290 Shetlands Lane	Glen Burnie	21061	Public	*
Anne Arundel	St. John the Evangelist School - Severna Park	669 Ritchie Highway	Severna Park	21146	Nonpublic	No**
Anne Arundel	St. Martin's in-the-Field Episcopal School	375 Benfield Road	Severna Park	21146	Nonpublic	No**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Anne Arundel	St. Mary's Elementary School	111 Duke of Gloucester Street	Annapolis	21401	Nonpublic	*
Anne Arundel	Studio 39	291 Locust Avenue	Annapolis	21401	Public	*
Anne Arundel	Van Bokkelen Elementary	1140 Reece Road	Severn	21144	Public	*
Anne Arundel	Woodside Elementary	160 Funke Road	Glen Burnie	21061	Public	*
Baltimore City	Archbishop Curley High School	3701 Sinclair Lane	Baltimore	21213	Nonpublic	No**,***
Baltimore City	Baltimore Academy, The	3800 Frederick Avenue	Baltimore	21229	Nonpublic	No**
Baltimore City	Boys' Latin School of Maryland, The	822 West Lake Avenue	Baltimore	21210	Nonpublic	No
Baltimore City	Bryn Mawr School, The	109 West Melrose Avenue	Baltimore	21210	Nonpublic	*
Baltimore City	Calvert School - Lower	105 Tuscany Road	Baltimore	21210	Nonpublic	Yes**
Baltimore City	Calvert School - Middle & Luetkemeyer Athletic Center	4300 North Charles Street	Baltimore	21218	Nonpublic	Yes**
Baltimore City	Gateway School	5900 Metro Drive	Baltimore	21215	Nonpublic	*,****
Baltimore City	Greater Grace Christian Academy	6063 Moravia Park Drive	Baltimore	21206	Nonpublic	*
Baltimore City	Mother Mary Lange Catholic School	200 Martin Luther King Jr. Boulevard	Baltimore	21201	Nonpublic	*
Baltimore City	Mount Clare Christian School	320 South Vincent Street	Baltimore	21223	Nonpublic	*
Baltimore City	Ohr Chadash Academy	7310 Park Heights Avenue	Baltimore	21208	Nonpublic	Yes**
Baltimore City	St. Casimir Catholic School	1035 South Kenwood Avenue	Baltimore	21224	Nonpublic	No**
Baltimore City	St. Francis of Assisi School	3617 Harford Road	Baltimore	21218	Nonpublic	No**
Baltimore City	The Crossroads School	802 South Caroline Street	Baltimore	21231	Charter	*
Baltimore County	Arbutus Elementary	1300 Sulphur Spring Road	Baltimore	21227	Public	*
Baltimore County	Arbutus Middle	5525 Shelbourne Road	Baltimore	21227	Public	No**
Baltimore County	Baltimore Highlands Elementary	4200 Annapolis Road	Baltimore	21227	Public	*
Baltimore County	Battle Grove Elementary	7828 Saint Patricia Lane	Baltimore	21222	Public	Yes
Baltimore County	Battle Monument Special	7801 East Collingham Drive	Baltimore	21222	Public	*
Baltimore County	Berkshire Elementary	7431 Poplar Avenue	Baltimore	21224	Public	*

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Campfield Early Childhood Center	6834 Alter Street	Baltimore	21207	Public	*
Baltimore County	Catonsville High	421 Bloomsbury Avenue	Baltimore	21228	Public	No**
Baltimore County	Catonsville Middle	2301 Edmondson Avenue	Baltimore	21228	Public	*
Baltimore County	Chadwick Elementary	1918 Winder Road	Baltimore	21244	Public	No**
Baltimore County	Chapel Hill Elementary	5200 Joppa Road	Perry Hall	21128	Public	*
Baltimore County	Chase Elementary	11701 Eastern Avenue	Baltimore	21220	Public	Yes
Baltimore County	Chesapeake High	1801 Turkey Point Road	Baltimore	21221	Public	*
Baltimore County	Chesapeake Terrace Elementary	2112 Lodge Farm Road	Baltimore	21219	Public	*
Baltimore County	Church Lane Elementary	3820 Fernside Road	Randallstown	21133	Public	*
Baltimore County	Cockeysville Middle	10401 Greenside Drive	Cockeysville	21030	Public	No***,****
Baltimore County	Colgate Elementary	401 51st Street	Baltimore	21224	Public	*
Baltimore County	Concordia Preparatory School	1145 Concordia Drive	Towson	21286	Nonpublic	Yes**,****
Baltimore County	Cromwell Valley Elementary Magnet	825 Providence Road	Towson	21286	Public	*
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	21221	Public	Yes**
Baltimore County	Dogwood Elementary	7215 Dogwood Road	Baltimore	21244	Public	No**,***,****
Baltimore County	Dumbarton Middle	300 Dumbarton Road	Baltimore	21212	Public	No
Baltimore County	Dundalk Middle	7400 Dunmanway	Baltimore	21222	Public	Yes***
Baltimore County	Eastern Technical High	1100 Mace Avenue	Baltimore	21221	Public	*
Baltimore County	Edgemere Elementary	7201 North Point Road	Baltimore	21219	Public	No
Baltimore County	Edmondson Heights Elementary	1600 Langford Road	Baltimore	21207	Public	*
Baltimore County	Franklin Elementary	33 Cockeys Mill Road	Reisterstown	21136	Public	Yes***
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	21136	Public	Yes***,****
Baltimore County	Franklin Middle	10 Cockeys Mill Road	Reisterstown	21136	Public	Yes**,****
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	21236	Public	Yes***

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	21117	Nonpublic	Yes**
Baltimore County	General John Stricker Middle	7855 Trappe Road	Baltimore	21222	Public	No
Baltimore County	George Washington Carver Center for Arts and Technology	938 York Road	Towson	21204	Public	*
Baltimore County	Glyndon Elementary	445 Glyndon Drive	Reisterstown	21136	Public	*
Baltimore County	Grange Elementary	2000 Church Road	Baltimore	21222	Public	Yes
Baltimore County	Greenspring Montessori School	10807 Tony Drive	Lutherville	21093	Nonpublic	*
Baltimore County	Halstead Academy	1111 Halstead Road	Baltimore	21234	Public	Yes
Baltimore County	Harford Hills Elementary	8902 Old Harford Road	Baltimore	21234	Public	*
Baltimore County	Hebbsville Elementary	3335 Washington Avenue	Baltimore	21244	Public	*
Baltimore County	Holabird Middle	1701 Delvale Avenue	Baltimore	21222	Public	Yes**,***
Baltimore County	Honeygo Elementary	4816 East Joppa Road	Perry Hall	21128	Public	No**,****
Baltimore County	Immaculate Conception School	112 Ware Avenue	Towson	21204	Nonpublic	*
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	21128	Public	Yes***
Baltimore County	Kenwood High	501 Stemmers Run Road	Baltimore	21221	Public	Yes**,****
Baltimore County	Loch Raven High	1212 Cowpens Avenue	Baltimore	21286	Public	*
Baltimore County	Loch Raven Technical Academy	8101 La Salle Road	Baltimore	21286	Public	No**,***,****
Baltimore County	McCormick Elementary	5101 Hazelwood Avenue	Baltimore	21206	Public	*
Baltimore County	McDonogh School	8600 McDonogh Road	Owings Mills	21117	Nonpublic	*
Baltimore County	Meadowood Education Center	1849 Gwynn Oak Avenue	Baltimore	21207	Public	*
Baltimore County	Middlesex Elementary	142 Bennett Road	Baltimore	21221	Public	*
Baltimore County	Milford Mill Academy	3800 Washington Avenue	Baltimore	21244	Public	No**,****
Baltimore County	New Directions Academy	9700 Old Harford Road	Baltimore	21284	Nonpublic	*
Baltimore County	New Town Elementary	4924 New Town Boulevard	Owings Mills	21117	Public	*
Baltimore County	New Town High	4931 New Town Boulevard	Owings Mills	21117	Public	*

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Northwest Academy of Health Sciences	4627 Old Court Road	Baltimore	21208	Public	*
Baltimore County	Norwood Elementary	1700 Delvale Avenue	Baltimore	21222	Public	*
Baltimore County	Oakleigh Elementary	1900 White Oak Avenue	Baltimore	21234	Public	*
Baltimore County	Our Lady of Hope / St. Luke School	8003 North Boundary Road	Baltimore	21222	Nonpublic	Yes**,***
Baltimore County	Overlea High	5401 Kenwood Avenue	Baltimore	21206	Public	Yes
Baltimore County	Owings Mills Elementary	10824 Reisterstown Road	Owings Mills	21117	Public	No**
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	21117	Public	Yes**
Baltimore County	Padonia International Elementary	9834 Greenside Drive	Cockeysville	21030	Public	*
Baltimore County	Parkville High	2600 Putty Hill Avenue	Baltimore	21234	Public	*
Baltimore County	Patapsco High & Center for Arts	8100 Wise Avenue	Baltimore	21222	Public	*
Baltimore County	Pathways School - Catonsville, The	405 Frederick Road, Suite #110	Cathonsville	21228	Nonpublic	*
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	21236	Public	Yes**,***
Baltimore County	Perry Hall Middle	300 Ebenezer Road	Baltimore	21236	Public	Yes**
Baltimore County	Pleasant Plains Elementary	8300 Pleasant Plains Road	Baltimore	21286	Public	*
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	21093	Public	Yes
Baltimore County	Powhatan Elementary	3300 Kelox Road	Baltimore	21207	Public	*
Baltimore County	Red House Run Elementary	1717 Weyburn Road	Baltimore	21237	Public	*
Baltimore County	Reisterstown Elementary	223 Walgrove Road	Reisterstown	21136	Public	*
Baltimore County	Riderwood Elementary	1711 Landrake Road	Baltimore	21204	Public	*
Baltimore County	Ridgely Middle	121 Ridgely Road	Lutherville	21093	Public	*
Baltimore County	Riverview Elementary	3298 Kessler Road	Baltimore	21227	Public	Yes
Baltimore County	Rodgers Forge Elementary	250 Dumbarton Road	Baltimore	21212	Public	*
Baltimore County	Sacred Heart School	63 Sacred Heart Lane	Reisterstown	21071	Nonpublic	*
Baltimore County	Sandalwood Elementary	900 South Marlyn Avenue	Baltimore	21221	Public	Yes**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Baltimore County	Sandy Plains Elementary	8330 Kavanagh Road	Baltimore	21222	Public	*
Baltimore County	Shady Spring Elementary	8868 Goldenwood Road	Baltimore	21237	Public	*
Baltimore County	Southwest Academy	6200 Johnnycake Road	Baltimore	21207	Public	*
Baltimore County	Sparrows Point Middle/High	7400 North Point Road	Baltimore	21219	Public	*
Baltimore County	St. Joseph School - Fullerton	8416 Belair Road	Baltimore	21236	Nonpublic	*
Baltimore County	St. Ursula School	8900 Harford Road	Parkville	21234	Nonpublic	*
Baltimore County	Stemmers Run Middle	201 Stemmers Run Road	Baltimore	21221	Public	*
Baltimore County	Stoneleigh Elementary	900 Pemberton Road	Baltimore	21212	Public	No****
Baltimore County	Strawbridge School, The	3300 Gaither Road	Baltimore	21244	Nonpublic	*
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	21209	Public	Yes**
Baltimore County	Sussex Elementary	515 Woodward Drive	Baltimore	21221	Public	*
Baltimore County	Tashbar	7501 Park Heights Avenue	Baltimore	21208	Nonpublic	*
Baltimore County	Towson High	69 Cedar Avenue	Towson	21286	Public	*
Baltimore County	Vincent Farm Elementary	6019 Ebenezer Road	White Marsh	21162	Public	*
Baltimore County	Warren Elementary	900 Bosley Road	Cockeysville	21030	Public	*
Baltimore County	Watershed Public Charter School	6946 Dogwood Road	Windsor Mill	21244	Charter	*
Baltimore County	Westchester Elementary	2300 Old Frederick Road	Baltimore	21228	Public	*
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	21234	Public	Yes**
Baltimore County	Winand Elementary	8301 Scotts Level Road	Baltimore	21208	Public	Yes***
Baltimore County	Windsor Mill Middle	8300 Windsor Mill Road	Baltimore	21244	Public	*
Baltimore County	Woodbridge Elementary	1410 Pleasant Valley Drive	Baltimore	21228	Public	No
Baltimore County	Woodlawn High	1801 Woodlawn Drive	Baltimore	21207	Public	No**,****
Baltimore County	Woodmoor Elementary	3200 Elba Drive	Baltimore	21207	Public	Yes
Calvert	Barstow Elementary	295 JW Williams Road	Prince Frederick	20678	Public	Yes**,****

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Calvert	Chespax	3200 King's Landing Road	Huntingtown	20639	Public	No**
Calvert	Dowell Elementary	12680 H.G. Trueman Road	Lusby	20657	Public	No**
Calvert	Little Lamb's Preschool	6300 Southern Maryland Boulevard	Huntingtown	20639	Nonpublic	No
Calvert	St. Leonard Elementary	5370 St. Leonard Road	St. Leonard	20685	Public	Yes**
Calvert	Windy Hill Elementary	9550 Boyd's Turn Road	Owings	20736	Public	No**
Carroll	Christian Preschool and Kindergarten Program	65 Washington Road	Westminster	21157	Nonpublic	Yes
Carroll	Taneytown Elementary	100 Kings Drive	Taneytown	21787	Public	*
Cecil	Shorehaven School	1040 Singerly Road	Elkton	21921	Nonpublic	*
Charles	Early Learning Center, La Plata	8730 Mitchell Road, Building CL	La Plata	20646	Public	Yes**,***
Charles	Eva Turner Elementary	1000 Bannister Circle	Waldorf	20602	Public	No**,***
Charles	La Plata High	6035 Radio Station Road	La Plata	20646	Public	Yes**,***
Charles	Mary Burgess Neal Elementary	12105 St. Georges Drive	Waldorf	20602	Public	No**,***
Charles	Mary H. Matula Elementary	6025 Radio Station Road	La Plata	20646	Public	No**,***
Charles	North Point High	2500 Davis Road	Waldorf	20603	Public	*
Charles	Phoenix International School of the Arts (PISOTA)	95 Catalpa Drive	La Plata	20646	Charter	No**,***
Charles	St. Charles High	5305 Piney Church Road	Waldorf	20602	Public	No**,***,****
Charles	Thomas Stone High	3785 Leonardtown Road	Waldorf	20601	Public	No**,***,****
Charles	Westlake High	3300 Middletown Road	Waldorf	20603	Public	Yes**,***,****
Charles	William B. Wade Elementary	2300 Smallwood Drive West	Waldorf	20603	Public	No**,***
Frederick	Carroll Creek Montessori Public Charter School	7215 Corporate Court	Frederick	21703	Charter	*
Frederick	Maryland School for the Deaf - Frederick Campus	101 Clarke Place	Frederick	21795	Public	*
Frederick	St. John Regional Catholic School	8414 Opossumtown Pike	Frederick	21702	Nonpublic	No****

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Harford	John Carroll School, The	703 East Churchville Road	Bel Air	21014	Nonpublic	*
Harford	OneSchool Global - Chesapeake Campus (formerly Sterling East - Chesapeake Campus)	900 Trimble Road	Joppa	21085	Nonpublic	****
Harford	St. Joan of Arc School	230 South Law Street	Aberdeen	21001	Nonpublic	No
Howard	Applications and Research Lab	10920 Clarksville Pike (Route 108)	Ellicott City	21043	Public	Yes**
Howard	Atholton Elementary	6700 Seneca Drive	Columbia	21046	Public	*
Howard	Bellows Spring Elementary	8125 Old Stockbridge Drive	Ellicott City	21043	Public	No**
Howard	Bollman Bridge Elementary	8200 Savage-Guilford Road	Savage	20763	Public	No**
Howard	Bryant Woods Elementary	5450 Blue Heron Lane	Columbia	21044	Public	Yes**,***
Howard	Cedar Lane School	11630 Scaggsville Road	Fulton	20759	Public	*
Howard	Centennial High	4300 Centennial Lane	Ellicott City	21042	Public	*
Howard	Clemens Crossing Elementary	10320 Quarterstaff Road	Columbia	21044	Public	Yes**,***
Howard	Cradlerock Elementary	6700 Cradlerock Way	Columbia	21045	Public	*
Howard	Deep Run Elementary	6925 Old Waterloo Road	Elkridge	21075	Public	No**
Howard	Elkridge Elementary	7075 Montgomery Road	Elkridge	21075	Public	Yes**
Howard	Elkridge Landing Middle	7085 Montgomery Road	Elkridge	21075	Public	No**
Howard	Forest Ridge Elementary	9550 Gorman Road	Laurel	20723	Public	Yes**
Howard	Fulton Elementary	11600 Scaggsville Road	Fulton	20759	Public	*
Howard	Gorman Crossing Elementary	9999 Winter Sun Road	Laurel	20723	Public	No**
Howard	Guilford Elementary	7335 Oakland Mills Road	Columbia	21046	Public	*
Howard	Guilford Park High School	8500 Ridgelys Run Road	Jessup	20794	Public	No**
Howard	Hammond Elementary	8110 Aladdin Drive	Laurel	20723	Public	*
Howard	Hammond High	8800 Guilford Road	Columbia	21046	Public	No**
Howard	Hammond Middle	8110 Aladdin Drive	Laurel	20723	Public	*
Howard	Harpers Choice Middle	5450 Beaverkill Road	Columbia	21044	Public	No

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Howard	Ilchester Elementary	4981 Ilchester Road	Ellicott City	21043	Public	No**, ***
Howard	Laurel Woods Elementary	9250 North Laurel Road	Laurel	20723	Public	*
Howard	Longfellow Elementary	5470 Hesperus Drive	Columbia	21044	Public	*
Howard	Manor Woods Elementary	11575 Frederick Road	Ellicott City	21042	Public	No***
Howard	Marriotts Ridge High	12100 Woodford Drive	Marriottsville	21104	Public	No
Howard	Maryland School for the Deaf - Columbia Campus	8169 Old Montgomery Road	Ellicott City	21043	Public	*
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	21042	Public	Yes**, ***
Howard	Murray Hill Middle	9989 Winter Sun Road	Laurel	20723	Public	No
Howard	Northfield Elementary	9125 Northfield Road	Ellicott City	21042	Public	No***
Howard	Oakland Mills High	9410 Kilimanjaro Road	Columbia	21045	Public	No
Howard	Patuxent Valley Middle	9151 Vollmerhausen Road	Jessup	20794	Public	No**, ***
Howard	Phillips School - Laurel	8920 Whiskey Bottom Road	Laurel	20723	Nonpublic	No**
Howard	Pointers Run Elementary	6600 South Trotter Road	Clarksville	21029	Public	Yes**
Howard	Rockburn Elementary	6145 Montgomery Road	Elkridge	21075	Public	No**
Howard	Running Brook Elementary	5215 West Running Brook Road	Columbia	21044	Public	Yes**, ***
Howard	St. Louis School	12500 Clarksville Pike	Clarksville	21029	Nonpublic	No**
Howard	Worthington Elementary	4580 Round Hill Road	Ellicott City	21043	Public	No**, ***
Kent	Chestertown Christian Academy	401 Morgnec Road	Chestertown	21620	Nonpublic	*
Montgomery	Baker (John T.) Middle	25400 Oak Drive	Damascus	20872	Public	Yes**
Montgomery	Banneker (Benjamin) Middle	14800 Perrywood Drive	Burtonsville	20866	Public	*
Montgomery	Bethesda Chevy Chase High	4301 East-West Highway	Bethesda	20814	Public	*
Montgomery	Bethesda Elementary	7600 Arlington Road	Bethesda	20814	Public	No**
Montgomery	Blake (James Hubert) High	300 Norwood Road	Silver Spring	20905	Public	No**
Montgomery	Briggs Chaney Middle	1901 Rainbow Drive	Silver Spring	20905	Public	No**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Brown Station Elementary	851 Quince Orchard Boulevard	Gaithersburg	20878	Public	No**
Montgomery	Bullis School	10601 Falls Road	Potomac	20854	Nonpublic	Yes**
Montgomery	Burnt Mills Elementary	11211 Childs Street	Silver Spring	20901	Public	No**
Montgomery	Burtonsville Elementary	15516 Old Columbia Pike	Burtonsville	20866	Public	Yes**
Montgomery	Candlewood Elementary	7210 Osprey Drive	Rockville	20855	Public	No**
Montgomery	Cannon Road Elementary	901 Cannon Road	Silver Spring	20904	Public	No**
Montgomery	Carson (Rachel) Elementary	100 Tschiffely Square Road	Gaithersburg	20878	Public	No**
Montgomery	Cashell Elementary	17101 Cashell Road	Rockville	20853	Public	No**
Montgomery	Cedar Grove Elementary	24001 Ridge Road	Germantown	20876	Public	Yes**
Montgomery	Charles E. Smith Jewish Day School - Lower	1901 East Jefferson Street	Rockville	20852	Nonpublic	Yes**
Montgomery	Charles E. Smith Jewish Day School - Upper	11710 Hunters Lane	Rockville	20852	Nonpublic	Yes**
Montgomery	Chevy Chase Elementary	4015 Rosemary Street	Chevy Chase	20815	Public	No**
Montgomery	Christ Episcopal Day School	109 South Washington Street	Rockville	20850	Nonpublic	*
Montgomery	Clarksburg Elementary	13530 Redgrave Place	Clarksburg	20871	Public	*
Montgomery	Clarksburg High	22500 Wims Road	Clarksburg	20871	Public	*
Montgomery	Clearspring Elementary	9930 Moyer Road	Damascus	20872	Public	*
Montgomery	Clopper Mill Elementary	18501 Cinnamon Drive	Germantown	20874	Public	No**
Montgomery	Cloverly Elementary	800 Briggs Chaney Road	Silver Spring	20904	Public	No**
Montgomery	Cold Spring Elementary	9201 Falls Chapel Way	Potomac	20854	Public	Yes**
Montgomery	Concord Hill School	6050 Wisconsin Avenue	Chevy Chase	20815	Nonpublic	*
Montgomery	Cresthaven Elementary	1234 Cresthaven Drive	Silver Spring	20903	Public	No**
Montgomery	Daly (Capt. James E.) Elementary	20301 Brandermill Drive	Germantown	20876	Public	*
Montgomery	Damascus Elementary	10201 Bethesda Church Road	Damascus	20872	Public	*
Montgomery	Damascus High	25921 Ridge Road	Damascus	20872	Public	Yes**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Darnestown Elementary	15030 Turkey Foot Road	Gaithersburg	20878	Public	No**
Montgomery	Diamond Elementary	4 Marquis Drive	Gaithersburg	20878	Public	Yes**
Montgomery	Drew (Dr. Charles) Elementary	1200 Swingingdale Drive	Silver Spring	20905	Public	Yes**
Montgomery	Edison (Thomas) High	12501 Dalewood Drive	Silver Spring	20906	Public	*
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	20877	Public	Yes**
Montgomery	Fairland Elementary	14315 Fairdale Road	Silver Spring	20905	Public	No**
Montgomery	Family Academy of Bethesda, The	4330 Montgomery Avenue	Bethesda	20814	Nonpublic	No
Montgomery	Flower Hill Elementary	18425 Flower Hill Way	Gaithersburg	20879	Public	No**
Montgomery	Fox Chapel Elementary	19315 Archdale Road	Germantown	20876	Public	Yes**
Montgomery	Franklin Country Day Montessori School	10500 Darnestown Road	Rockville	20850	Nonpublic	*
Montgomery	Franklin Montessori School, The	10500 Darnestown Road	Rockville	20850	Nonpublic	*
Montgomery	Galway Elementary	12612 Galway Drive	Silver Spring	20904	Public	Yes**
Montgomery	Geneva Day School	11931 Seven Locks Road	Potomac	20854	Nonpublic	No****
Montgomery	Gibbs, Jr. (William B.) Elementary	12615 Royal Crown Drive	Germantown	20876	Public	Yes**
Montgomery	Great Seneca Creek Elementary	13010 Dairymaid Drive	Germantown	20874	Public	Yes**
Montgomery	Greencastle Elementary	13611 Robey Road	Silver Spring	20904	Public	No**
Montgomery	Holton-Arms School, The	7303 River Road	Bethesda	20817	Nonpublic	*
Montgomery	Ivymount School, The	11614 Seven Locks Road	Rockville	20854	Nonpublic	No**
Montgomery	Jackson Road Elementary	900 Jackson Road	Silver Spring	20904	Public	Yes**
Montgomery	Jones Lane Elementary	15110 Jones Lane	Gaithersburg	20878	Public	Yes**
Montgomery	Key (Francis S.) Middle	910 Schindler Drive	Silver Spring	20903	Public	Yes**
Montgomery	Kingsview Middle	18909 Kingsview Road	Germantown	20874	Public	No**
Montgomery	Lakelands Park Middle	1200 Main Street	Gaithersburg	20878	Public	Yes
Montgomery	Landon School	6101 Wilson Lane	Bethesda	20817	Nonpublic	Yes

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Laytonsville Elementary	21401 Laytonsville Road	Laytonsville	20882	Public	*
Montgomery	Little Bennett Elementary	23930 Burdette Forest Road	Clarksburg	20871	Public	Yes**
Montgomery	Lynnbrook Center	8001 Lynbrook Drive	Bethesda	20814	Public	Yes**
Montgomery	Marshall (Thurgood) Elementary	12260 McDonald Chapel Drive	Gaithersburg	20876	Public	Yes**
Montgomery	Maryvale Elementary	1010 First Street	Rockville	20851	Public	No**
Montgomery	Matsunaga (Spark M.) Elementary	13902 Bromfield Road	Germantown	20874	Public	No**
Montgomery	McLean School of Maryland, The	8224 Lochinver Lane	Potomac	20854	Nonpublic	*
Montgomery	McNair (Ronald) Elementary	13881 Hopkins Road	Germantown	20874	Public	Yes**
Montgomery	Mill Creek Towne Elementary	17700 Park Mill Drive	Rockville	20855	Public	No**
Montgomery	North Chevy Chase Elementary	3700 Jones Bridge Road	Chevy Chase	20815	Public	Yes**
Montgomery	Northwest High	13501 Richter Farm Road	Germantown	20874	Public	Yes**
Montgomery	Paint Branch High	14121 Old Columbia Pike	Burtonsville	20866	Public	No**
Montgomery	Piney Branch Elementary	7510 Maple Avenue	Takoma Park	20912	Public	*
Montgomery	Potomac Elementary	10311 River Road	Potomac	20854	Public	Yes**
Montgomery	Quince Orchard High	15800 Quince Orchard Road	Gaithersburg	20878	Public	Yes****
Montgomery	Redland Middle	6505 Muncaster Mill Road	Rockville	20855	Public	No**
Montgomery	Ridgeview Middle	16600 Raven Rock Drive	Gaithersburg	20878	Public	Yes**
Montgomery	Rock Creek Forest Elementary	8330 Grubb Road	Chevy Chase	20815	Public	No**,****
Montgomery	Rockwell (Lois P.) Elementary	24555 Cutsail Drive	Damascus	20872	Public	Yes
Montgomery	Rocky Hill Middle	22401 Brick Haven Way	Clarksburg	20871	Public	No**
Montgomery	Roscoe Nix Elementary	1100 Corliss Street	Silver Spring	20903	Public	Yes**
Montgomery	Rosemary Hills Elementary	2111 Porter Road	Silver Spring	20910	Public	No**
Montgomery	Rosemont Elementary	16400 Alden Avenue	Gaithersburg	20877	Public	*
Montgomery	Sandburg (Carl) Learning Center	451 Meadow Hall Drive	Rockville	20851	Public	Yes**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Montgomery	Sequoyah Elementary	17301 Bowie Mill Road	Derwood	20855	Public	No**
Montgomery	Shady Grove Middle	8100 Midcounty Highway	Gaithersburg	20877	Public	No**
Montgomery	Sidwell Friends School - Lower School	5100 Edgemoor Lane	Bethesda	20814	Nonpublic	*
Montgomery	Spring Bilingual Montessori Academy	3514 Plyers Mill Road	Kensington	20895	Nonpublic	No
Montgomery	Springbrook High	201 Valleybrook Drive	Silver Spring	20904	Public	No**
Montgomery	Stephen Knolls Special Education School	10731 St. Margaret's Way	Kensington	20895	Public	No**
Montgomery	Stonegate Elementary	14811 Notley Road	Silver Spring	20905	Public	No
Montgomery	Takoma Montessori School, The	7212 Carroll Avenue	Takoma Park	20912	Nonpublic	*
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	20851	Public	Yes**
Montgomery	Wells (Hallie) Middle	11701 Little Seneca Parkway	Clarksburg	20871	Public	No**
Montgomery	Westover Elementary	401 Hawkesbury Lane	Silver Spring	20904	Public	No**
Montgomery	Wilson Wims Elementary	12520 Blue Sky Drive	Clarksburg	20871	Public	No**
Montgomery	Woods Academy, The (Grades 1-8)	6801 Greentree Road	Bethesda	20817	Nonpublic	Yes**, ****
Montgomery	Woods Academy, The (Kindergarten)	6801 Greentree Road	Bethesda	20817	Nonpublic	No
Prince George's	Edward M. Felegy Elementary	6110 Editor's Park Drive	Hyattsville	20782	Public	*
Prince George's	Elizabeth Seton High School	5715 Emerson Street	Bladensburg	20710	Nonpublic	No
Prince George's	Holy Redeemer Elementary School - College Park	4902 Berwyn Road	College Park	20740	Nonpublic	No**, ***
Prince George's	Panorama Elementary	2002 Callaway Street	Temple Hills	20748	Public	*
Prince George's	Pathways School - Edgewood, The	4600 Powder Mill Road, Suite 100	Beltsville	20705	Nonpublic	*
Prince George's	Riverdale Baptist School	1133 Largo Road	Upper Marlboro	20774	Nonpublic	No
Prince George's	Scotchtown Hills Elementary	15950 Dorset Road	Laurel	20707	Public	*
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	21666	Public	Yes**, ****
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	21617	Public	Yes**, ****
Queen Anne's	Grasonville Elementary	5435 Main Street	Grasonville	21638	Public	No**, ****

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

Table 1. Schools Conducting Lead Testing During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	ANY ELEVATED LEAD RESULTS?
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	21617	Public	Yes**, ***, ****
Queen Anne's	Kent Island Elementary	110 Elementary Way	Stevensville	21666	Public	No**, ****
Queen Anne's	Kent Island High	900 Love Point Road	Stevensville	21666	Public	Yes**, ****
Queen Anne's	Matapeake Elementary	651 Romancoke Road	Stevensville	21666	Public	No**, ****
Queen Anne's	Matapeake Middle	671 Romancoke Road	Stevensville	21666	Public	Yes**, ****
Queen Anne's	New Sudlersville Middle	600 Charles Street	Sudlersville	21668	Public	Yes**, ***
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	21617	Public	Yes**, ****
Queen Anne's	Stevensville Middle	610 Main Street	Stevensville	21666	Public	No**, ***, ****
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	21668	Public	Yes**, ***
St. Mary's	Kennedy Krieger School: Southern Maryland Campus	44219 Airport Road, Building 1	California	20619	Nonpublic	Yes**
Washington	Good Shepherd Preschool	168 West Main Street	Hancock	21750	Nonpublic	*
Washington	St. Mary Catholic School	218 West Washington Street	Hagerstown	21740	Nonpublic	No**

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

[This page intentionally left blank]

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024)

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Allegany	Bishop Walsh School	700 Bishop Walsh Road	Cumberland	Nonpublic	Faucet, Cold	Kitchen	East Wall	Handwashing Sink	CO	18.20
Allegany	Bishop Walsh School	700 Bishop Walsh Road	Cumberland	Nonpublic	Faucet, Cold	Kitchen	South Wall	Handwashing Sink	CO	14.50
Allegany	Bishop Walsh School	700 Bishop Walsh Road	Cumberland	Nonpublic	Multiple Compartment Sink - Faucet, Cold	Kitchen	East Wall	Right Dishwashing Sink	CO	13.00
Allegany	Bishop Walsh School	700 Bishop Walsh Road	Cumberland	Nonpublic	Multiple Compartment Sink - Faucet, Cold	Kitchen	East Wall	Left Dishwashing Sink	CO	6.60
Anne Arundel	Annapolis High	2700 Riva Road	Annapolis	Public	Multiple Compartment Sink - Faucet, Cold	Classroom	Classroom 115 Child Development-Kitchen [KS--C]	Classroom 115 Child Development-Kitchen [KS--C]	CO	8.07
Anne Arundel	Annapolis Middle	1399 Forest Drive	Annapolis	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen Tri Sink- R [KS--C]	Kitchen Tri Sink- R [KS--C]	NC	6.20
Anne Arundel	Belvedere Elementary	360 Broadwater Road	Arnold	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom Room 210 [CF--C]	Classroom Room 210 [CF--C]	CO	6.32
Anne Arundel	Broadneck High	1265 Green Holly Drive	Annapolis	Public	Faucet, Cold	Office	Guidance B101 Mens Bathroom [BS-NC]	Guidance B101 Mens Bathroom [BS-NC]	NC	10.10
Anne Arundel	Broadneck High	1265 Green Holly Drive	Annapolis	Public	Faucet, Cold	Nurse's Office/Health Room	Nurses Office Health Rom 12-BR (front) [BS--C]	Nurses Office Health Rom 12-BR (front) [BS--C]	CO	36.50
Anne Arundel	Broadneck High	1265 Green Holly Drive	Annapolis	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen Tri Sink- R (across from sprayer) [KS--C]	Kitchen Tri Sink- R (across from sprayer) [KS--C]	CO	8.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Central Middle	221 Central Avenue East	Edgewater	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics Home EC - Closet HS [HE--C]	Home Economics Home EC - Closet HS [HE--C]	CO	12.10
Anne Arundel	Central Middle	221 Central Avenue East	Edgewater	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen Tri Sink -Right (under window) [KS--C]	Kitchen Tri Sink -Right (under window) [KS--C]	CO	7.88
Anne Arundel	Crofton Middle	2301 Davidsonville Road	Gambrills	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 406 FAC Sink 1 (going clockwise, see map) [Home Economics 406 FAC Sink 1 (going clockwise, see map) [CO	14.60
Anne Arundel	Crofton Middle	2301 Davidsonville Road	Gambrills	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 406 FAC Sink 4 (going clockwise, see map) [Home Economics 406 FAC Sink 4 (going clockwise, see map) [CO	24.30
Anne Arundel	Crofton Middle	2301 Davidsonville Road	Gambrills	Public	Faucet, Cold	Classroom (Home Economics)	Home Economics 406 FAC Sink 5 (going clockwise, see map) [Home Economics 406 FAC Sink 5 (going clockwise, see map) [CO	22.90
Anne Arundel	Crofton Woods Elementary	1750 Urby Drive	Crofton	Public	Faucet, Cold	Office	Office Annex Sink [FC-NC]	Office Annex Sink [FC-NC]	CO	8.90
Anne Arundel	Crofton Woods Elementary	1750 Urby Drive	Crofton	Public	Faucet, Cold	Office	Office Annex Bathroom Sink [FC--NC]	Office Annex Bathroom Sink [FC--NC]	CO	5.95
Anne Arundel	Crofton Woods Elementary	1750 Urby Drive	Crofton	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Classroom	Classroom 3 [DF--C]	Classroom 3 [DF--C]	CO	11.20
Anne Arundel	Georgetown East Elementary	111 Dogwood Road	Annapolis	Public	Multiple Compartment Sink - Faucet, Cold	Classroom	Classroom 145-Kitchen area HS [KS--C]	Classroom 145-Kitchen area HS [KS--C]	CO	15.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Anne Arundel	Magothy River Middle	241 Peninsula Farm Road	Arnold	Public	Faucet, Cold	Classroom	Classroom Special Ed 222 [OT--C]	Classroom Special Ed 222 [OT--C]	CO	8.58
Anne Arundel	Mary Moss @ J. Albert Adams Academy	245 Clay Street	Annapolis	Public	Faucet, Cold	Classroom	Classroom 101 [CR--NC]		CO	17.00
Anne Arundel	Mary Moss @ J. Albert Adams Academy	245 Clay Street	Annapolis	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Classroom 103 [CF--C]		CO	5.63
Baltimore City	Calvert School - Lower	105 Tuscany Road	Baltimore	Nonpublic	Faucet, Cold	Bathroom	In room 236		NC	13.00
Baltimore City	Calvert School - Lower	105 Tuscany Road	Baltimore	Nonpublic	Faucet, Cold	Bathroom	In room 238	Only Sink in Room	NC	6.90
Baltimore City	Calvert School - Lower	105 Tuscany Road	Baltimore	Nonpublic	Faucet, Cold	Kitchen	In room 313	Double Sink	NC	18.00
Baltimore City	Calvert School - Lower	105 Tuscany Road	Baltimore	Nonpublic	Stand Alone Bottle Filler (No Adjoining/Surrounding Fountain(s))	Hallway	In hall near room 376	Only water dispenser in the hall	CO	21.00
Baltimore City	Calvert School - Middle & Luetkemeyer Athletic Center	4300 North Charles Street	Baltimore	Nonpublic	Faucet, Cold	Classroom (Science Lab)	In room 110	In corner near office	NC	22.00
Baltimore City	Calvert School - Middle & Luetkemeyer Athletic Center	4300 North Charles Street	Baltimore	Nonpublic	Ice Machine (Stand Alone)	Kitchen	In room 122	ice machine	CO	23.00
Baltimore City	Ohr Chadash Academy	7310 Park Heights Avenue	Baltimore	Nonpublic	Faucet, Cold	Teachers' Lounge/Break Room	KITCHEN NOOK	Sink	CO	9.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Battle Grove Elementary	7828 Saint Patricia Lane	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Health Suite	Left Fountain	CO	7.90
Baltimore County	Chase Elementary	11701 Eastern Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 205	Fountain	CO	9.90
Baltimore County	Concordia Preparatory School	1145 Concordia Drive	Towson	Nonpublic	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler	Hallway	Hallway by Room 209	bottle filler	CO	5.90
Baltimore County	Concordia Preparatory School	1145 Concordia Drive	Towson	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Janitor/Custodial Closet	Maintenance Office Lower Level Upper School	Utility Sink	NC	12.80
Baltimore County	Concordia Preparatory School	1145 Concordia Drive	Towson	Nonpublic	Utility (Slop) Sink - Faucet, Cold	Janitor/Custodial Closet	Janitor's Closet inside weight room across from girl's locker room	Utility Sink	NC	9.90
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Front of Cafeteria near sandwich station	Left Fountain	CO	16.60
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Front of Cafeteria near sandwich station	Left Fountain	CO	73.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Girl's Locker Room	Fountain	CO	9.90
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Girl's Locker Room	Tall Fountain	CO	102.00
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Boy's Locker Room	Fountain	CO	5.90
Baltimore County	Deep Creek Middle	1000 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Locker Room	Boy's Locker Room	Fountain	CO	6.40
Baltimore County	Dundalk Middle	7400 Dunmanway	Baltimore	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Right side of Kitchen	Kettle	CO	6.70
Baltimore County	Franklin Elementary	33 Cockeys Mill Road	Reisterstown	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Triple Sink	Left Faucet	CO	5.60
Baltimore County	Franklin Elementary	33 Cockeys Mill Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 8	Fountain	CO	15.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 10	Left Fountain	CO	5.90
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 39	Fountain	CO	10.70
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 40	Fountain	CO	97.00
Baltimore County	Franklin High	12000 Reisterstown Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 41	Fountain	CO	10.50
Baltimore County	Franklin Middle	10 Cockeys Mill Road	Reisterstown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 207	Right Fountain	CO	11.80
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Triple Sink in Kitchen	Right Faucet	CO	7.30
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Cafeteria	Fountain	CO	16.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 2	Fountain	CO	11.50
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 21	Fountain	CO	8.00
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Main Lobby by Cafeteria	Fountain	CO	12.40
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	LS Room 07	Sink	CO	7.69
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Faculty Bathroom	Sink	CO	13.50
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Faculty Bathroom	Left Sink	NC	10.70
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Library Office	Sink	NC	25.60
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Lower Level Unisex Bathroom	Sink	NC	9.09
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Lower Level Girl's Bathroom	Right Sink	NC	7.18
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Men's Bathroom	Sink	CO	9.31
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Men's Bathroom	Left Sink	CO	8.53
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Men's Bathroom	Right Sink	CO	6.23

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Men's Bathroom	Middle Sink	CO	9.56
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Women's Restroom Sinks Closest to Commons	Left Sink	CO	19.20
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Women's Restroom Sinks Closest to Commons	Right Sink	CO	6.54
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Women's Restroom Sinks Furthest from Commons	Left Sink	CO	9.12
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Women's Restroom Sinks Furthest from Commons	Right Sink	NC	194.00
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Bathroom	Women's Restroom Sinks Furthest from Commons	Middle Trio Right Sink	CO	19.60
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom	LS Room 24	Sink	CO	7.63
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom	Class 2 Sink	Sink	NC	5.61
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom	Class 5 Bathroom	Sink	NC	8.24
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom	Room 6	Sink	NC	11.40
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Hallway	Closet Kitchenette	Sink	NC	13.70
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Locker Room	Locker Room	Right Sink	CO	14.10
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Nurse's Office/Health Room	Bathroom	Sink	CO	6.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom (Art)	2D Studio	Left Sinks Middle Sink	NC	8.57
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom (Art)	3D Studio	Left Sinks Middle Sink	NC	5.78
Baltimore County	Garrison Forest School	300 Garrison Forest Road	Owings Mills	Nonpublic	Faucet, Cold	Classroom (Art)	3D Studio Tool Closet	Sink	NC	59.00
Baltimore County	Grange Elementary	2000 Church Road	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Room S-6 and Boiler Room	Fountain	CO	105.00
Baltimore County	Halstead Academy	1111 Halstead Road	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Room 119	Right Fountain	CO	38.10
Baltimore County	Holabird Middle	1701 Delvale Avenue	Baltimore	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	by kitchen office	Kettle	CO	33.10
Baltimore County	Holabird Middle	1701 Delvale Avenue	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Cafeteria	by faculty dining	Fountain	CO	6.00
Baltimore County	Holabird Middle	1701 Delvale Avenue	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Room 21	Fountain	CO	34.60
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Triple Sink	Right Faucet	CO	5.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 9	Bubbler	CO	8.10
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room K2	Bubbler	CO	5.80
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 8	Bubbler	CO	10.40
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 13	Bubbler	CO	5.90
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 220	Left Bubbler	CO	5.50
Baltimore County	Joppa View Elementary	8727 Honeygo Boulevard	Perry Hall	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 247	Left Bubbler	CO	5.50
Baltimore County	Our Lady of Hope / St. Luke School	8003 North Boundary Road	Baltimore	Nonpublic	Faucet, Cold	Bathroom	In Main Office	Sink on North Wall	NC	10.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Our Lady of Hope / St. Luke School	8003 North Boundary Road	Baltimore	Nonpublic	Faucet, Cold	Kitchen	on West Wall	Left Sink	CO	6.60
Baltimore County	Overlea High	5401 Kenwood Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 303	Right Fountain	CO	25.80
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	Public	Faucet, Cold	Nurse's Office/Health Room	Exam Room	Handsink	CO	18.90
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Receiving Room	Fountain	CO	139.00
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Girls' Dressing Room	Fountain	CO	230.00
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 211	Fountain	CO	24.00
Baltimore County	Owings Mills High	124 South Tollgate Road	Owings Mills	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 309	Right Fountain	CO	66.70
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	north side of Kitchen	Triple Sink	CO	8.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 100	Fountain	CO	9.50
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	By Room 105	Fountain	CO	8.80
Baltimore County	Perry Hall Elementary	9021 Belair Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Nurse Suite	Fountain	CO	8.60
Baltimore County	Perry Hall Middle	300 Ebenezer Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 237	Fountain	CO	7.60
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	by Room 19	Fountain	CO	20.30
Baltimore County	Riverview Elementary	3298 Kessler Road	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room S9	Right Fountain	CO	9.30
Baltimore County	Sandalwood Elementary	900 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	near Room 13	Fountain	CO	7.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	Sandalwood Elementary	900 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Library Hallway	Fountain	CO	6.70
Baltimore County	Sandalwood Elementary	900 South Marlyn Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Gym & Rec Hallway	Fountain	CO	14.00
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room D108	Handsink	CO	10.90
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room C228	Handsink	CO	51.40
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room C231	Handsink	CO	25.60
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room C224	Handsink	CO	19.90
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room C214	Handsink	CO	18.90
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room D230	Handsink	CO	6.30
Baltimore County	Summit Park Elementary	6920 Diana Road	Baltimore	Public	Faucet, Cold	Classroom	Room D218	Handsink	CO	7.10
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 106	Handsink	CO	61.10
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 206	Handsink	CO	7.10
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 218	Handsink	CO	13.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 218	Handsink	CO	24.20
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 219	Handsink	CO	8.40
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 219	Handsink	CO	8.80
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 208	Handsink	CO	8.60
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 103	Handsink	CO	10.20
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Room 100	Handsink	CO	98.60
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Guidance Room	Handsink	CO	38.40
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Speech Room 4	Handsink	CO	8.00
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Speech Room 4	Handsink	CO	14.20
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Speech Room 2	Handsink	CO	5.80
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Classroom	Speech Room 2	Handsink	CO	5.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Office	Workroom	Handsink	CO	10.30
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Office	Guidance Office	Handsink	CO	15.10
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Office	Guidance Room	Handsink	CO	13.40
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Other	Guidance Office	Handsink	CO	25.50
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Nurse's Office/Health Room	Exam Room	Handsink	CO	20.90
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 5	Handsink	CO	7.70
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 5	Handsink	CO	7.90
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 3	Handsink	CO	15.70
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 7	Handsink	CO	7.70
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 7	Handsink	CO	12.40
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 6	Handsink	CO	6.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 6	Handsink	CO	29.10
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Teacher Planning Room 3	Handsink	CO	10.90
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Faucet, Cold	Staff Workroom	Office Workroom	Handsink	CO	5.90
Baltimore County	White Oak Special Education	8401 Leefield Road	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 215	Bubbler	CO	8.10
Baltimore County	Winand Elementary	8301 Scotts Level Road	Baltimore	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Triple Sink	Right Faucet	CO	12.10
Baltimore County	Woodmoor Elementary	3200 Elba Drive	Baltimore	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Gym	Left Fountain	CO	5.70
Calvert	Barstow Elementary	295 JW Williams Road	Prince Frederick	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	Outside Gym	Fountain	CO	6.20
Calvert	St. Leonard Elementary	5370 St. Leonard Road	St. Leonard	Public	Faucet, Cold	Classroom	in 122	faucet	CO	20.50
Calvert	St. Leonard Elementary	5370 St. Leonard Road	St. Leonard	Public	Faucet, Cold	Classroom	in B02	faucet	CO	5.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Carroll	Christian Preschool and Kindergarten Program	65 Washington Road	Westminster	Nonpublic	Faucet, Cold	Classroom	Room S105	room S105 is a large classroom that has a kitchen area - the sink is located under the interior window which looks into the hall	NC	6.00
Carroll	Christian Preschool and Kindergarten Program	65 Washington Road	Westminster	Nonpublic	Faucet, Cold	Kitchen	S210B	in room S210B in the kitchenette	NC	16.00
Carroll	Christian Preschool and Kindergarten Program	65 Washington Road	Westminster	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	outside of room E213	outside of room E213 near coffee maker	CO	8.00
Charles	Early Learning Center, La Plata	8730 Mitchell Road, Building CL	La Plata	Public	Faucet, Cold	Hallway	Corridor - Sink	Corridor - Sink	CO	6.73
Charles	La Plata High	6035 Radio Station Road	La Plata	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Locker Room	Womens locker room - water fountain	Womens locker room - water fountain	CO	6.54
Charles	Westlake High	3300 Middletown Road	Waldorf	Public	Faucet, Cold	Classroom (Special Education)	classroom 107 - Special Education - Sink	classroom 107 - Special Education - Sink	CO	8.92
Howard	Applications and Research Lab	10920 Clarksville Pike (Route 108)	Ellicott City	Public	Faucet, Cold	Classroom	Room A20	Sink	CO	7.50
Howard	Applications and Research Lab	10920 Clarksville Pike (Route 108)	Ellicott City	Public	Faucet, Cold	Kitchen	C21	Sink	CO	7.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Bryant Woods Elementary	5450 Blue Heron Lane	Columbia	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen	Left Sink	CO	8.40
Howard	Bryant Woods Elementary	5450 Blue Heron Lane	Columbia	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen	Right Sink	CO	11.70
Howard	Clemens Crossing Elementary	10320 Quarterstaff Road	Columbia	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen	Right Sink	CO	22.00
Howard	Elkridge Elementary	7075 Montgomery Road	Elkridge	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 70	Bubbler	CO	7.00
Howard	Elkridge Elementary	7075 Montgomery Road	Elkridge	Public	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	Room 035	Bubbler	CO	13.60
Howard	Forest Ridge Elementary	9550 Gorman Road	Laurel	Public	Faucet, Cold	Teachers' Lounge/Break Room	staff lounge	Sink	NC	17.40
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	11.30
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	35.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	138.00
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	140.00
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	581.00
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Classroom (Home Economics)	Room 104	Sink	CO	66.60
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Faucet, Cold	Stadium	Stadium	Sink	CO	5.80
Howard	Mt. Hebron High	9440 Old Frederick Road (Route 99)	Ellicott City	Public	Spigot (with threadings for hose connection)	Outdoors	Outside of Room 003	Spigot	CO	54.30
Howard	Pointers Run Elementary	6600 South Trotter Road	Clarksville	Public	Faucet, Cold	Media Center	Room Near 3300	Sink	CO	9.90
Howard	Pointers Run Elementary	6600 South Trotter Road	Clarksville	Public	Bottle Filler/Drinking Fountain Combo Unit - Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway Near Room 3310	Bubbler	CO	5.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Howard	Pointers Run Elementary	6600 South Trotter Road	Clarksville	Public	Combination Sink - Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Room 3153	Bubbler	CO	5.70
Howard	Running Brook Elementary	5215 West Running Brook Road	Columbia	Public	Faucet, Cold	Kitchen	Kitchen Room 015	Right Hand Sink	CO	9.20
Montgomery	Baker (John T.) Middle	25400 Oak Drive	Damascus	Public	Faucet, Cold	Kitchen	In "kitchen" of work room at back of media center	faucet	CO	6.50
Montgomery	Baker (John T.) Middle	25400 Oak Drive	Damascus	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Teachers' Lounge/Break Room	In room 121	Bubbler- Indoor	CO	14.70
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Men's bathroom	Sink	NC	5.90
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Men's bathroom	Sink A	NC	13.00
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Men's bathroom	Sink C	NC	8.10
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Women's bathroom	Sink A	NC	12.30
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Women's bathroom	Sink B	NC	8.70
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Women's bathroom	Sink C	NC	9.30
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Women's bathroom	Sink D	NC	19.10
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Bathroom	Bathroom in Security Office	Sink	NC	27.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Cafeteria	Café	Sink B	NC	14.80
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Concessions	Snack Bar	Sink C	CO	16.10
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Kitchen	Kitchen	Sink	NC	5.70
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Kitchen	Kitchen	Hand wash sink	NC	10.00
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Kitchen	Kitchen	Dishwashing sink by ice machine	NC	6.20
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Kitchen	Café	Sink C	NC	8.80
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Locker Room	Girl's Locker Room	Sink	NC	41.10
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Locker Room	Girl's Locker Room	Sink B	NC	5.50
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Locker Room	Boy's Locker Room	Sink A	NC	5.50
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Faucet, Cold	Locker Room	Visitor Locker Room	Sink	NC	14.10
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Spigot (with threadings for hose connection)	Outdoors	By Athletic Training	Hose Bib	NC	98.40
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Gymnasium	Small Gym	Drinking fountain	CO	7.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Bullis School	10601 Falls Road	Potomac	Nonpublic	Stand Alone Bottle Filler (No Adjoining/Surrounding Fountain(s))	Gymnasium	Wrestling gym	bottle filler	CO	7.30
Montgomery	Burtonsville Elementary	15516 Old Columbia Pike	Burtonsville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 33	Bubbler - Indoor	CO	12.70
Montgomery	Cedar Grove Elementary	24001 Ridge Road	Germantown	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	26.80
Montgomery	Charles E. Smith Jewish Day School - Lower	1901 East Jefferson Street	Rockville	Nonpublic	Combination Sink - Faucet, Cold	Bathroom	Near 718	Boys Bathroom Sink, Left	CO	19.50
Montgomery	Charles E. Smith Jewish Day School - Lower	1901 East Jefferson Street	Rockville	Nonpublic	Combination Sink - Faucet, Cold	Bathroom	Near 718	Boys Bathroom Sink, Right	CO	9.58
Montgomery	Charles E. Smith Jewish Day School - Lower	1901 East Jefferson Street	Rockville	Nonpublic	Combination Sink - Faucet, Cold	Bathroom	Near 422	Boys Bathroom Sink, Left Center	CO	14.50
Montgomery	Charles E. Smith Jewish Day School - Lower	1901 East Jefferson Street	Rockville	Nonpublic	Combination Sink - Faucet, Cold	Bathroom	Near 510	Boys Bathroom Sink, Right	CO	5.97
Montgomery	Charles E. Smith Jewish Day School - Upper	11710 Hunters Lane	Rockville	Nonpublic	Faucet, Cold	Kitchen	802C 3rd Kitchen (Meat)	Hose for Cleaning Oven	NC	9.66
Montgomery	Cold Spring Elementary	9201 Falls Chapel Way	Potomac	Public	Faucet, Cold	Classroom	In classroom 5	faucet	CO	10.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Damascus High	25921 Ridge Road	Damascus	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	In hallway outside of 238	Cooler	CO	47.10
Montgomery	Diamond Elementary	4 Marquis Drive	Gaithersburg	Public	Drinking Water Fountain - Bubblers Style	Classroom	In classroom 122	Bubbler - Indoor	CO	18.50
Montgomery	Diamond Elementary	4 Marquis Drive	Gaithersburg	Public	Drinking Water Fountain - Bubblers Style	Classroom	In classroom 128	Bubbler - Indoor	CO	5.90
Montgomery	Diamond Elementary	4 Marquis Drive	Gaithersburg	Public	Drinking Water Fountain - Bubblers Style	Classroom	In classroom 133	Bubbler - Indoor	CO	7.60
Montgomery	Diamond Elementary	4 Marquis Drive	Gaithersburg	Public	Faucet, Cold	Kitchen	In kitchen 150	faucet	CO	187.00
Montgomery	Drew (Dr. Charles) Elementary	1200 Swingingdale Drive	Silver Spring	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	6.50
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	Public	Faucet, Cold	Classroom	In classroom 120	faucet	CO	13.40
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	Public	Faucet, Cold	Classroom	In classroom 102	faucet	CO	6.80
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	Public	Faucet, Cold	Classroom	In classroom 118	faucet	CO	7.50
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	Public	Faucet, Cold	Media Center	In Media center workroom 124A	faucet	CO	47.10
Montgomery	Emory Grove Center	18100 Washington Grove Lane	Gaithersburg	Public	Faucet, Cold	Media Center	In Media Center 124	faucet	CO	23.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Fox Chapel Elementary	19315 Archdale Road	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 112	Bubbler - Indoor	CO	11.30
Montgomery	Fox Chapel Elementary	19315 Archdale Road	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 162	Bubbler - Indoor	CO	5.70
Montgomery	Fox Chapel Elementary	19315 Archdale Road	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 164	Bubbler - Indoor	CO	191.00
Montgomery	Galway Elementary	12612 Galway Drive	Silver Spring	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 30	Bubbler - Indoor	CO	18.30
Montgomery	Gibbs, Jr. (William B.) Elementary	12615 Royal Crown Drive	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 240	Bubbler - Indoor	CO	10.30
Montgomery	Gibbs, Jr. (William B.) Elementary	12615 Royal Crown Drive	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 244	Bubbler - Indoor	CO	11.40
Montgomery	Gibbs, Jr. (William B.) Elementary	12615 Royal Crown Drive	Germantown	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Office	In conference room 168	Bubbler - Indoor	CO	46.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Great Seneca Creek Elementary	13010 Dairymaid Drive	Germantown	Public	Faucet, Cold	Kitchen	In kitchen adjacent to room 108	faucet	CO	5.80
Montgomery	Jackson Road Elementary	900 Jackson Road	Silver Spring	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 174	Bubbler - Indoor	CO	16.80
Montgomery	Jones Lane Elementary	15110 Jones Lane	Gaithersburg	Public	Drinking Water Fountain - Bubblers Style	Classroom	In classroom 24	Bubbler - Indoor	CO	19.00
Montgomery	Jones Lane Elementary	15110 Jones Lane	Gaithersburg	Public	Drinking Water Fountain - Bubblers Style	Classroom	In classroom 23	Bubbler - Indoor	CO	18.50
Montgomery	Key (Francis S.) Middle	910 Schindler Drive	Silver Spring	Public	Faucet, Cold	Office	In office 210	faucet	CO	11.10
Montgomery	Lakelands Park Middle	1200 Main Street	Gaithersburg	Public	Faucet, Cold	Office	In office 271	faucet	CO	12.40
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Bathroom	Women's Room Weight Room	faucet	NC	10.60
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 127	Table 5 Left Sink	NC	6.96
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 125	Table 4 Left Sink	NC	5.57
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 122 Rear	Left Right	NC	7.04
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 122 Rear	Right Left Sink	NC	6.42
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 122 Rear	Right Right Sink	NC	7.20
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 122 Right	Left Left Sink	NC	10.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Classroom	Room 123	Left Right Sink	NC	6.31
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Locker Room	Middle School Locker Room	Left Sink	NC	9.79
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Locker Room	Middle School Locker Room	Center Left Sink	NC	6.09
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Faucet, Cold	Locker Room	Middle School Locker Room	Sink Near Coaches Office	NC	18.60
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Locker Room	Middle School Locker Room	Fountain	CO	18.60
Montgomery	Landon School	6101 Wilson Lane	Bethesda	Nonpublic	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Outdoors	Right Fountain	Right Fountain	CO	15.20
Montgomery	Little Bennett Elementary	23930 Burdette Forest Road	Clarksburg	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Classroom	In kindergarten 165	Bubbler - Indoor	CO	6.40
Montgomery	Lynnbrook Center	8001 Lynbrook Drive	Bethesda	Public	Faucet, Cold	Kitchen	In kitchen 17 in annex	faucet	CO	6.10
Montgomery	Marshall (Thurgood) Elementary	12260 McDonald Chapel Drive	Gaithersburg	Public	Drinking Water Fountain - Bubbler Style	Classroom	In classroom 34	Bubbler - Indoor	CO	5.70
Montgomery	McNair (Ronald) Elementary	13881 Hopkins Road	Germantown	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	34.80

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Montgomery	North Chevy Chase Elementary	3700 Jones Bridge Road	Chevy Chase	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	30.90
Montgomery	Northwest High	13501 Richter Farm Road	Germantown	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	8.60
Montgomery	Northwest High	13501 Richter Farm Road	Germantown	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	8.80
Montgomery	Potomac Elementary	10311 River Road	Potomac	Public	Drinking Water Fountain - Bubbler Style	Classroom	In classroom 226	Bubbler - Indoor	CO	23.00
Montgomery	Quince Orchard High	15800 Quince Orchard Road	Gaithersburg	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	7.60
Montgomery	Quince Orchard High	15800 Quince Orchard Road	Gaithersburg	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	28.30
Montgomery	Ridgeview Middle	16600 Raven Rock Drive	Gaithersburg	Public	Drinking Water Fountain - Cooler/Chiller Style	Cafeteria	in cafeteria	Cooler	CO	24.40
Montgomery	Rockwell (Lois P.) Elementary	24555 Cutsail Drive	Damascus	Public	Drinking Water Fountain - Bubbler Style	Classroom	In classroom A3	Bubbler - Indoor	CO	73.40
Montgomery	Rockwell (Lois P.) Elementary	24555 Cutsail Drive	Damascus	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	13.40
Montgomery	Rockwell (Lois P.) Elementary	24555 Cutsail Drive	Damascus	Public	Faucet, Cold	Kitchen	In kitchen by all purpose room	faucet	CO	6.80
Montgomery	Roscoe Nix Elementary	1100 Corliss Street	Silver Spring	Public	Faucet, Cold	Kitchen	in kitchen	faucet	CO	19.10

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Roscoe Nix Elementary	1100 Corliss Street	Silver Spring	Public	Faucet, Cold	Nurse's Office/Health Room	In health room 102D	faucet	CO	10.80
Montgomery	Sandburg (Carl) Learning Center	451 Meadow Hall Drive	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 102	Bubbler- Indoor	CO	6.40
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 207	Bubbler - Indoor	CO	8.00
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 400	Bubbler - Indoor	CO	10.40
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom B3	Bubbler - Indoor	CO	5.60
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 406	Bubbler - Indoor	CO	6.90
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom 311	Bubbler - Indoor	CO	10.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	In classroom B7	Bubbler - Indoor	CO	15.80
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Nurse's Office/Health Room	In health room adjacent to administration office	Bubbler - Indoor	CO	39.40
Montgomery	Twinbrook Elementary	5911 Ridgway Avenue	Rockville	Public	Stand Alone Bottle Filler (No Adjoining/Surrounding Fountain(s))	Hallway	In hallway adjacent gym	bottle filler	CO	82.80
Montgomery	Woods Academy, The (Grades 1-8)	6801 Greentree Road	Bethesda	Nonpublic	Eye Wash Station (-- considered non-potable and not counted towards the regulations)	Classroom (Science Lab)	Room 406	Middle Left Sink 2	NC	7.40
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Classroom	A2		CO	36.60
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Classroom	A3		CO	11.00
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Classroom	A5		CO	7.80
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Nurse's Office/Health Room	Lounge off Cafeteria		CO	46.90
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Classroom (Art)	Art Storage		CO	31.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Faucet, Cold	Staff Workroom	WR off Office Sink		CO	433.00
Queen Anne's	Bayside Elementary	301 Church Street	Stevensville	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Kitchen - Side Wall left		CO	6.80
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	IA 1		CO	44.40
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room C-9		CO	20.70
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room C-12		CO	93.00
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room C-13		CO	15.30
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room C-3		CO	112.00
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room B-1		CO	8.60
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-10		CO	12.60
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-11		CO	7.20
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-6		CO	6.20

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-3		CO	9.80
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-1		CO	49.30
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-12		CO	10.60
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Room A-14		CO	7.30
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Office	Art Office		CO	32.20
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Storage Room/Area	Art Work Room/Storage		CO	190.00
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Nurse's Office/Health Room	health suite		CO	11.70
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Art)	Art #1 / Front Wall		CO	12.10
Queen Anne's	Centreville Middle	231 Ruthsburg Road	Centreville	Public	Faucet, Cold	Staff Workroom	Office WR Sink		CO	11.80
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	146		CO	27.60
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	144		CO	6.90

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	207		CO	6.70
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	206		CO	9.60
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	128		CO	7.60
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	129		CO	19.20
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	127		CO	7.30
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	126		CO	8.70
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	108		CO	17.70
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	106		CO	32.10
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	103		CO	10.60
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	104		CO	9.20
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Classroom	101		CO	37.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Kennard Elementary	420 Little Kidwell Avenue	Centreville	Public	Faucet, Cold	Kitchen	Kitchen Right Veg Wash Sink		CO	37.30
Queen Anne's	Kent Island High	900 Love Point Road	Stevensville	Public	Faucet, Cold	Classroom	Rm 166		CO	21.20
Queen Anne's	Kent Island High	900 Love Point Road	Stevensville	Public	Faucet, Cold	Student Workroom/Maker Space	SGA Office RM 506		CO	17.10
Queen Anne's	Matapeake Middle	671 Romancoke Road	Stevensville	Public	Faucet, Cold	Storage Room/Area	Room 601A / Art Storage		CO	7.60
Queen Anne's	New Sudlersville Middle	600 Charles Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 709 sink		CO	7.60
Queen Anne's	New Sudlersville Middle	600 Charles Street	Sudlersville	Public	Faucet, Cold	Media Center	306 Media Office		CO	31.50
Queen Anne's	New Sudlersville Middle	600 Charles Street	Sudlersville	Public	Faucet, Cold	Classroom (Art)	Rom 209 Kiln Rm		CO	24.20
Queen Anne's	New Sudlersville Middle	600 Charles Street	Sudlersville	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Classroom	Rm 709 WF		CO	17.80
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom	Rm 302 Lab		CO	11.30
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Office	Rm 227 Teacher Planning		CO	11.70
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Science Lab)	Rm 314 A Lab		CO	14.30

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Science Lab)	Rm 316 A Lab		CO	16.60
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Science Lab)	Rm 318 Lab		CO	103.50
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Science Lab)	Rm 320 Lab		CO	13.60
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Science Lab)	Rm 322 Lab		CO	21.20
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Staff Workroom	123G Media Fac Library		CO	7.20
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Faucet, Cold	Classroom (Wood/Metal/Tech Shop)	Rm 304 A Shop		CO	71.00
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Back Wall Pot Sink #1 facing sink on right		CO	6.40
Queen Anne's	Queen Anne's County High	125 Ruthsburg Road	Centreville	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Pot Sink nr Walk in		CO	9.20
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 111		CO	18.70
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Room 9		CO	30.70

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	RM 108		CO	27.70
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	RM 107		CO	26.80
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 114		CO	15.40
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 131		CO	22.50
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 76		CO	19.20
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 68		CO	14.10
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	science Rm 66 Sink #1-island		CO	84.00
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 66 Sink #2-wall		CO	50.60
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 66 Sink #3-wall		CO	18.00
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 92		CO	16.60
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 115		CO	17.40

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†‡	LEAD SAMPLE RESULT (ppb)
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 96		CO	21.30
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 110		CO	28.00
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 104		CO	25.60
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 7		CO	9.90
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 51		CO	7.70
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 47		CO	7.10
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 10		CO	14.60
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 13		CO	14.70
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Classroom	Rm 35		CO	19.40
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Nurse's Office/Health Room	Nurse's Office		CO	7.20
Queen Anne's	Sudlersville Elementary	300 South Church Street	Sudlersville	Public	Faucet, Cold	Media Center	Media Workroom/Rm 81		CO	10.50

†As reported by school

‡CO = Consumption, NC = Non-Consumption

Table 2. Lead Samples Above Action Level of 5 ppb During Reporting Period (July 2, 2023 – July 1, 2024) - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	LEAD SAMPLE RESULT (ppb)
St. Mary's	Kennedy Krieger School: Southern Maryland Campus	44219 Airport Road, Building 1	California	Nonpublic	Faucet, Cold	Janitor/Custodial Closet	Room 126 B	Sink	CO	12.00

†As reported by school

‡CO = Consumption, NC = Non-Consumption

[This page intentionally left blank]

Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2023)*****

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	21236	Public	2022-2023	Yes ***
Baltimore County	Mars Estates Elementary	1500 Homberg Avenue	Baltimore	21221	Public	2022-2023	Yes ***
Baltimore County	Pine Grove Elementary	2701 Summit Avenue	Baltimore	21234	Public	2022-2023	Yes ***
Baltimore County	Pine Grove Middle	9200 Old Harford Road	Baltimore	21234	Public	2022-2023	Yes **, ***
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	21093	Public	2022-2023	Yes ***
Baltimore County	Stoneleigh Elementary	900 Pemberton Road	Baltimore	21212	Public	2022-2023	No
Baltimore County	Villa Cresta Elementary	2600 Rader Avenue	Baltimore	21234	Public	2022-2023	No
Frederick	Blue Heron Elementary	7100 Eaglehead Drive	New Market	21774	Public	2022-2023	No
Frederick	Brunswick Middle	301 Cummings Drive	Brunswick	21716	Public	2022-2023	No
Frederick	Crestwood Middle	7100 Foxcroft Drive	Frederick	21703	Public	2022-2023	No
Frederick	Deer Crossing Elementary	10601 Finn Drive	New Market	21774	Public	2022-2023	No
Frederick	Earth and Space Sciences Lab (ESSL)	210 Madison Street	Frederick	21701	Public	2022-2023	No
Frederick	Emmitsburg Elementary	300 South Seton Avenue	Emmitsburg	21727	Public	2022-2023	No
Frederick	Frederick County Career & Technology Center	7922 Opossumtown Pike	Frederick	21702	Public	2022-2023	No
Frederick	Glade Elementary	9525 Glade Road	Walkersville	21793	Public	2022-2023	No
Frederick	Gov. Thomas Johnson Middle	1799 Schifferstadt Drive	Frederick	21701	Public	2022-2023	No
Frederick	Heather Ridge School	1445 Taney Avenue	Frederick	21702	Public	2021-2022	No

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

*****Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2023)** - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Frederick	Heather Ridge School	1445 Taney Avenue	Frederick	21702	Public	2022-2023	No
Frederick	Hillcrest Elementary	1285 Hillcrest Drive	Frederick	21702	Public	2022-2023	No
Frederick	Lincoln Elementary	200 Madison Street	Frederick	21701	Public	2021-2022	No
Frederick	Lincoln Elementary	200 Madison Street	Frederick	21701	Public	2022-2023	No
Frederick	Lincoln Elementary - A	200 Madison Street	Frederick	21701	Public	2022-2023	No
Frederick	Middletown Elementary	201 East Green Street	Middletown	21769	Public	2022-2023	No
Frederick	Middletown High	200 Schoolhouse Drive	Middletown	21769	Public	2022-2023	No
Frederick	Middletown Middle	100 Martha Mason Street	Middletown	21769	Public	2022-2023	No
Frederick	Middletown Primary	403 Franklin Street	Middletown	21769	Public	2022-2023	No
Frederick	Monocacy Elementary	7421 Hayward Road	Frederick	21702	Public	2022-2023	No
Frederick	Monocacy Middle	8009 Opossumtown Pike	Frederick	21702	Public	2022-2023	No
Frederick	Myersville Elementary	429 Main Street	Myersville	21773	Public	2022-2023	No
Frederick	New Market Elementary	93 West Main Street	New Market	21774	Public	2022-2023	No
Frederick	New Market Middle	125 West Main Street	New Market	21774	Public	2022-2023	Yes
Frederick	North Frederick Elementary	1010 Fairview Avenue	Frederick	21701	Public	2022-2023	No
Frederick	Oakdale Elementary	5830 Oakdale School Road	Ijamsville	21754	Public	2022-2023	No
Frederick	Oakdale High	5850 Eaglehead Drive	Ijamsville	21754	Public	2022-2023	No
Frederick	Oakdale Middle	5810 Oakdale School Road	Ijamsville	21754	Public	2022-2023	No
Frederick	Orchard Grove Elementary	5898 Hannover Drive	Frederick	21701	Public	2022-2023	No
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	21001	Public	2021-2022	Yes ^{**} , ^{***}

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

*****Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

Table 3. Schools Conducting Lead Testing During Previous Reporting Periods (July 2, 2017 – July 1, 2023)** - Continued**

COUNTY	SCHOOL NAME	SCHOOL STREET ADDRESS	CITY	ZIP	SCHOOL TYPE	REPORTING PERIOD YEAR (JULY 2 THROUGH JULY 1)	ANY ELEVATED LEAD RESULTS?
Howard	Ilchester Elementary	4981 Ilchester Road	Ellicott City	21043	Public	2022-2023	No
Howard	River Hill High	12101 Clarksville Pike (Route 108)	Clarksville	21029	Public	2022-2023	No
Montgomery	Bel Pre Elementary	13801 Rippling Brook Drive	Silver Spring	20906	Public	2022-2023	No **
Montgomery	Covenant Life School	7503 Muncaster Mill Road	Gaithersburg	20877	Nonpublic	2022-2023	Yes ***
Montgomery	Edison (Thomas) High	12501 Dalewood Drive	Silver Spring	20906	Public	2022-2023	No **
Montgomery	Rosemont Elementary	16400 Alden Avenue	Gaithersburg	20877	Public	2022-2023	No **

*Data verification in progress / Insufficient documentation

**Schools with some samples that need further verification / required documentation (Note: only samples that have been verified are included in this report)

***Schools with first-draw samples (water stagnation period of 8-18 hours) and flush samples (no stagnation period; water run 30 seconds prior to sample collection)

****Includes some samples with improper protocol

*****Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

[This page intentionally left blank]

Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2023)**

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE†	OUTLET AREA TYPE†	OUTLET LOCATION DESCRIPTION†	OUTLET DESCRIPTION†	USE†,‡	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Multiple Compartmen t Sink - Faucet, Cold	Kitchen	Triple Sink in Kitchen	Right Faucet	CO	06/10/2023	6.90
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Cafeteria	Cafeteria	Fountain	CO	06/10/2023	38.70
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 2	Fountain	CO	06/10/2023	42.70
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	by Room 21	Fountain	CO	06/10/2023	46.90
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	outside Gym	Fountain	CO	06/10/2023	29.30
Baltimore County	Fullerton Elementary	4400 Fullerton Avenue	Baltimore	Public	Drinking Water Fountain - Bubblers Style (Non-Refrigerated)	Hallway	Main Lobby by Cafeteria	Fountain	CO	06/10/2023	22.60

†As reported by school

‡CO = Consumption, NC = Non-Consumption

**Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2023)^{††} - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE [†]	OUTLET AREA TYPE [†]	OUTLET LOCATION DESCRIPTION [†]	OUTLET DESCRIPTION [†]	USE ^{†,‡}	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Baltimore County	Mars Estates Elementary	1500 Homberg Avenue	Timonium	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway by BOS Office	Right Fountain	CO	02/25/2023	31.60
Baltimore County	Mays Chapel Elementary	12250 Roundwood Road	Timonium	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway by BOS Office	Left Fountain	CO	02/25/2023	20.40
Baltimore County	Mays Chapel Elementary	12250 Roundwood Road	Timonium	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway across from Café	Left Fountain	CO	02/25/2023	39.90
Baltimore County	Mays Chapel Elementary	12250 Roundwood Road	Timonium	Public	Drinking Water Fountain - Cooler/Chiller Style (Refrigerated)	Hallway	Hallway outside Main Office	Right Fountain	CO	02/25/2023	10.70
Baltimore County	Pine Grove Elementary	2701 Summit Avenue	Baltimore	Public	Faucet, Cold	Office	Tap/Office Workroom [TL-11--C]	Tap/Office Workroom [TL-11--C]	NC	12/17/2022	11.10
Baltimore County	Pine Grove Middle	9200 Old Harford Road	Baltimore	Public	Faucet, Cold	Classroom	Tap/Room 72/Station 1/Handsink [CR-3--C]	Station 1 Sink	CO	12/14/2022	30.20

[†]As reported by school

[‡]CO = Consumption, NC = Non-Consumption

^{††}Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2023)^{†‡} - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE [†]	OUTLET AREA TYPE [†]	OUTLET LOCATION DESCRIPTION [†]	OUTLET DESCRIPTION [†]	USE ^{†,‡}	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Baltimore County	Pine Grove Middle	9200 Old Harford Road	Baltimore	Public	Faucet, Cold	Classroom	Tap/Room 72/Station 2/Handsink [CR-4--C]	Station 2 Sink	CO	12/14/2022	56.40
Baltimore County	Pine Grove Middle	9200 Old Harford Road	Baltimore	Public	Commercial Kitchen Kettle, Cold (i.e., faucet leading into kettle)	Kitchen	Tap/Kitchen/Kettle/Left [KS-15--C]	Left Kettle	CO	12/14/2022	6.27
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Faucet, Cold	Office	Workroom	Handsink	CO	02/04/2023	20.60
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Faucet, Cold	Nurse's Office/Health Room	Exam Room	Handsink	CO	02/04/2023	7.10
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Multiple Compartment Sink - Faucet, Cold	Kitchen	Triple Sink	Right Faucet	CO	02/04/2023	8.00
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Room 12	Fountain	CO	02/04/2023	9.60
Baltimore County	Pot Spring Elementary	2410 Springlake Drive	Timonium	Public	Drinking Water Fountain - Bubbler Style (Non-Refrigerated)	Hallway	by Room 19	Fountain	CO	02/04/2023	26.90

[†]As reported by school

[‡]CO = Consumption, NC = Non-Consumption

^{‡‡}Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized

Table 4. Lead Samples Above Action Level of 5 ppb During Previous Reporting Periods (July 2, 2017 – July 1, 2023)^{##} - Continued

COUNTY	SCHOOL NAME	SCHOOL ADDRESS	CITY	SCHOOL TYPE	OUTLET TYPE [†]	OUTLET AREA TYPE [†]	OUTLET LOCATION DESCRIPTION [†]	OUTLET DESCRIPTION [†]	USE ^{†,‡}	DATE SAMPLED	LEAD SAMPLE RESULT (ppb)
Frederick	New Market Middle	93 West Main Street	Frederick	Public	Bottle Filler/Drinking Fountain Combo Unit - Bottle Filler	Media Center	Media Center room 90	W01A-22 2064 (DF) B UniqueTag#	CO	05/17/2023	116.00
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Left Side Sink, Middle	Left Side Sink, Middle	CO	03/10/2022	39.90
Harford	Swan Creek School (formerly Center for Educational Opportunity)	253 Paradise Road	Aberdeen	Public	Faucet, Cold	Kitchen	Left Side Sink, Left	Left Side Sink, Left	CO	03/10/2022	15.10
Montgomery	Covenant Life School	7503 Muncaster Mill Road	Gaithersburg	Nonpublic	Combination Sink - Fountain - Bubbler Style (Non-Refrigerated)	Classroom	CR 244	Sink fountain bubbler	CO	02/10/2023	10.50

[†]As reported by school

[‡]CO = Consumption, NC = Non-Consumption

^{##}Results made available to MDE after submittal deadline and/or data verification completed after previous legislative report was finalized