

Result Summary for Charter Schools

As of May 5, 2026, MDE has verified a total of 461 first-draw samples from 29 charter schools. Of these schools, there were 3 (10.34%) schools with first-draw lead sample results exceeding 20 ppb (i.e., previous Action Level effective through May 31, 2021) and there were 15 (51.72%) schools with first-draw lead sample results exceeding 5 ppb (i.e., current Action Level effective June 1, 2021).

Of the 461 first-draw samples, 4 (0.87%) sample results exceeded 20 ppb: 0 (0%) was from drinking water outlets (i.e., consumption outlets) and 4 (0.87%) were from non-consumption outlets.

Of the 461 first-draw samples, 71 (15.4%) sample results exceeded 5 ppb: 36 (7.81%) were from drinking water outlets (i.e., consumption outlets) and 35 (7.59%) were from non-consumption outlets.

Test Results* for Charter Schools Received and Verified as of May 5, 2026: Overall													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	3	152	71	81	0	0	0	0	0	6	0	6	0
Baltimore City	9	125	104	21	0	1	0	1	0	20	18	2	0
Baltimore County	1	23	4	19	0	2	0	2	0	23	4	19	0
Charles	1	9	9	0	0	0	0	0	0	0	0	0	0
Frederick	4	73	46	27	0	0	0	0	0	1	1	0	0
Prince George's	10	79	0	79	0	1	0	1	0	20	13	7	0
St. Mary's	1	0	0	0	0	0	0	0	0	1	0	1	0
Total	29	461	234	227	0	4	0	4	0	71	36	35	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2017-2018 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	1	50	14	36	0	0	0	0	0	6	0	6	0
Baltimore City	0												
Frederick	3	61	36	25	0	0	0	0	0	1	1	0	0
Prince George's	0												
St. Mary's	1	57	57	0	0	0	0	0	0	0	0	0	0
Total	5	168	107	61	0	0	0	0	0	7	1	6	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2018-2019 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	1	72	27	45	0	0	0	0	0	0	0	0	0
Baltimore City	0												
Baltimore County	0												
Frederick	0												
Prince George's	3	88	45	43	0	1	0	1	0	5	0	5	0
St. Mary's	0												
Total	4	160	72	88	0	1	0	1	0	5	0	5	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2019-2020 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	1	15	15	0	0	0	0	0	0	0	0	0	0
Baltimore City	0												
Baltimore County	0												
Frederick	0												
Prince George's	0												
St. Mary's	0												
Total	1	15	15	0	0	0	0	0	0	0	0	0	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2020-2021 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	1	10	10	0	0	0	0	0	0	0	0	0	0
Baltimore City	0												
Baltimore County	0												
Frederick	0												
Prince George's	7	129	93	36	0	0	0	0	0	15	13	2	0
St. Mary's	0												
Total	8	139	103	36	0	0	0	0	0	15	13	2	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2021-2022 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non-Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non-Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	0												
Baltimore City	1	4	4	0	0	0	0	0	0	0	0	0	0
Baltimore County	0												
Frederick	0												
Prince George's	1	10	10	0	0	0	0	0	0	0	0	0	0
St. Mary's	0												
Total	2	14	14	0	0	0	0	0	0	0	0	0	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2022-2023 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non- Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	0												
Baltimore City	0												
Baltimore County	0												
Frederick	0												
Prince George's	0												
St. Mary's	0												
Total	0	0	0	0	0	0	0	0	0	0	0	0	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2023-2024 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non- Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	1	5	5	0	0	0	0	0	0	0	0	0	0
Baltimore City	5	90	87	3	0	1	0	1	0	19	18	1	0
Baltimore County	1	23	4	19	0	2	0	2	0	23	4	19	0
Charles	1	6	6	0	0	0	0	0	0	0	0	0	0
Frederick	1	10	9	1	0	0	0	0	0	0	0	0	0
Prince George's	0												
St. Mary's	0												
Total	9	134	111	23	0	3	0	3	0	42	22	20	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year

Test Results* for Charter Schools Received and Verified as of May 5, 2026: 2024-2025 School Year													
County***	# Schools** Completing Testing	Total # Samples	# Samples From Drinking Water Outlets	# Samples From Non- Consumption Outlets	# Samples With Unknown Use	Previous Action Level of 20 ppb (effective through May 31, 2021)				Current Action Level of 5 ppb (effective on June 1, 2021)			
						Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use	Total # Elevated Samples	# Elevated Samples From Drinking Outlets	# Elevated Samples From Non- Consumption Outlets	# Elevated Samples With Unknown Use
Anne Arundel	0												
Baltimore City	4	31	13	18	0	0	0	0	0	1	0	1	0
Baltimore County	0												
Charles	1	3	3	0	0	0	0	0	0	0	0	0	0
Frederick	1	2	1	1	0	0	0	0	0	0	0	0	0
Prince George's	0												
St. Mary's	1	84	10	74	0	0	0	0	0	1	0	1	0
Total	7	120	27	93	0	0	0	0	0	2	0	2	0

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

*** Only these counties have charter schools during this specific school year