

Result Summary for Nonpublic Schools

As of August 1, 2023, MDE has received and verified a total of 10,797 first-draw samples from 247 nonpublic schools. Of these schools, there were 85 (34.41%) schools with first-draw lead sample results exceeding 20 ppb (i.e., previous Action Level effective through May 31, 2021) and there were 142 (57.49%) schools with first-draw lead sample results exceeding 5 ppb (i.e., current Action Level effective June 1, 2021).

Of the 10,797 first-draw samples, 337 (3.12%) sample results exceeded 20 ppb: 56 (0.52%) were from drinking water outlets (i.e., consumption outlets), 281 (2.6%) were from non-consumption outlets, and 0 (0%) was from outlets with unknown use (i.e., a use determination could not yet be made).

Of the 10,797 first-draw samples, 1,327 (12.29%) sample results exceeded 5 ppb: 288 (2.67%) were from drinking water outlets (i.e., consumption outlets), 1,039 (9.62%) were from non-consumption outlets, and 0 (0%) was from outlets with unknown use (i.e., a use determination could not yet be made).

| Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: Overall | | | | | | | | | | | | | |
|---|--------------------------------|-----------------|---------------------------------------|--|----------------------------|--|--|---|-------------------------------------|---|--|---|-------------------------------------|
| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non-Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | |
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non-Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non-Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 1 | 43 | 43 | 0 | 0 | 2 | 2 | 0 | 0 | 3 | 3 | 0 | 0 |
| Anne Arundel | 16 | 534 | 273 | 261 | 0 | 4 | 0 | 4 | 0 | 37 | 6 | 31 | 0 |
| Baltimore City | 34 | 2109 | 1046 | 1063 | 0 | 49 | 6 | 43 | 0 | 292 | 66 | 226 | 0 |
| Baltimore County | 53 | 2028 | 1085 | 943 | 0 | 75 | 18 | 57 | 0 | 361 | 104 | 257 | 0 |
| Calvert | 1 | 5 | 5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 4 | 76 | 33 | 43 | 0 | 8 | 1 | 7 | 0 | 24 | 5 | 19 | 0 |
| Cecil | 3 | 48 | 48 | 0 | 0 | 1 | 1 | 0 | 0 | 5 | 5 | 0 | 0 |
| Charles | 1 | 13 | 12 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 6 | 187 | 93 | 94 | 0 | 2 | 1 | 1 | 0 | 9 | 3 | 6 | 0 |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 6 | 234 | 78 | 156 | 0 | 19 | 0 | 19 | 0 | 51 | 5 | 46 | 0 |
| Howard | 13 | 424 | 291 | 133 | 0 | 5 | 1 | 4 | 0 | 12 | 8 | 4 | 0 |
| Kent | 2 | 10 | 5 | 5 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| Montgomery | 67 | 4091 | 1316 | 2775 | 0 | 134 | 11 | 123 | 0 | 392 | 29 | 363 | 0 |
| Prince George's | 24 | 588 | 342 | 246 | 0 | 20 | 8 | 12 | 0 | 57 | 28 | 29 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 5 | 102 | 89 | 13 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 2 | 0 |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 3 | 66 | 29 | 37 | 0 | 2 | 2 | 0 | 0 | 6 | 4 | 2 | 0 |
| Washington | 5 | 184 | 57 | 127 | 0 | 11 | 0 | 11 | 0 | 59 | 6 | 53 | 0 |
| Wicomico | 2 | 19 | 18 | 1 | 0 | 1 | 1 | 0 | 0 | 2 | 2 | 0 | 0 |
| Worcester | 1 | 36 | 36 | 0 | 0 | 4 | 4 | 0 | 0 | 14 | 14 | 0 | 0 |
| Total | 247 | 10797 | 4899 | 5898 | 0 | 337 | 56 | 281 | 0 | 1327 | 288 | 1039 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: 2017-2018 School Year

| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non- Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | |
|------------------|--------------------------------------|--------------------|---|--|-------------------------------------|---|--|--|---|--|--|--|---|
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 0 | | | | | | | | | | | | |
| Anne Arundel | 6 | 223 | 121 | 102 | 0 | 1 | 0 | 1 | 0 | 16 | 3 | 13 | 0 |
| Baltimore City | 13 | 865 | 517 | 348 | 0 | 21 | 0 | 21 | 0 | 107 | 20 | 87 | 0 |
| Baltimore County | 24 | 676 | 378 | 298 | 0 | 13 | 5 | 8 | 0 | 99 | 39 | 60 | 0 |
| Calvert | 0 | | | | | | | | | | | | |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 1 | 49 | 8 | 41 | 0 | 8 | 1 | 7 | 0 | 23 | 4 | 19 | 0 |
| Cecil | 1 | 17 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 0 | 0 |
| Charles | 0 | | | | | | | | | | | | |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 4 | 75 | 47 | 28 | 0 | 1 | 1 | 0 | 0 | 3 | 3 | 0 | 0 |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 3 | 151 | 34 | 117 | 0 | 19 | 0 | 19 | 0 | 48 | 5 | 43 | 0 |
| Howard | 3 | 118 | 32 | 86 | 0 | 1 | 0 | 1 | 0 | 1 | 0 | 1 | 0 |
| Kent | 1 | 7 | 2 | 5 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| Montgomery | 30 | 1829 | 602 | 1227 | 0 | 34 | 4 | 30 | 0 | 129 | 14 | 115 | 0 |
| Prince George's | 13 | 358 | 244 | 114 | 0 | 15 | 5 | 10 | 0 | 41 | 22 | 19 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 2 | 69 | 69 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 3 | 66 | 29 | 37 | 0 | 2 | 2 | 0 | 0 | 6 | 4 | 2 | 0 |
| Washington | 3 | 60 | 25 | 35 | 0 | 2 | 0 | 2 | 0 | 17 | 2 | 15 | 0 |
| Wicomico | 1 | 2 | 2 | 0 | 0 | 1 | 1 | 0 | 0 | 2 | 2 | 0 | 0 |
| Worcester | 1 | 36 | 36 | 0 | 0 | 4 | 4 | 0 | 0 | 14 | 14 | 0 | 0 |
| Total | 109 | 4601 | 2163 | 2438 | 0 | 122 | 23 | 99 | 0 | 508 | 133 | 375 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: 2018-2019 School Year

| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non- Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | |
|-------------------------|--------------------------------------|--------------------|---|--|-------------------------------------|---|--|--|---|--|--|--|---|
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 1 | 43 | 43 | 0 | 0 | 2 | 2 | 0 | 0 | 3 | 3 | 0 | 0 |
| Anne Arundel | 10 | 243 | 126 | 117 | 0 | 2 | 0 | 2 | 0 | 14 | 3 | 11 | 0 |
| Baltimore City | 19 | 991 | 334 | 657 | 0 | 20 | 1 | 19 | 0 | 149 | 23 | 126 | 0 |
| Baltimore County | 20 | 598 | 325 | 273 | 0 | 42 | 8 | 34 | 0 | 135 | 41 | 94 | 0 |
| Calvert | 0 | | | | | | | | | | | | |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 2 | 26 | 24 | 2 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 0 | 0 |
| Cecil | 2 | 14 | 14 | 0 | 0 | 1 | 1 | 0 | 0 | 3 | 3 | 0 | 0 |
| Charles | 1 | 13 | 12 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 1 | 51 | 6 | 45 | 0 | 1 | 0 | 1 | 0 | 6 | 0 | 6 | 0 |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 3 | 64 | 39 | 25 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| Howard | 9 | 208 | 161 | 47 | 0 | 4 | 1 | 3 | 0 | 9 | 6 | 3 | 0 |
| Kent | 0 | | | | | | | | | | | | |
| Montgomery | 25 | 1239 | 485 | 754 | 0 | 68 | 5 | 63 | 0 | 159 | 12 | 147 | 0 |
| Prince George's | 9 | 108 | 42 | 66 | 0 | 2 | 1 | 1 | 0 | 9 | 2 | 7 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 1 | 9 | 8 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 0 | | | | | | | | | | | | |
| Washington | 2 | 124 | 32 | 92 | 0 | 9 | 0 | 9 | 0 | 42 | 4 | 38 | 0 |
| Wicomico | 0 | | | | | | | | | | | | |
| Worcester | 0 | | | | | | | | | | | | |
| Total | 105 | 3731 | 1651 | 2080 | 0 | 151 | 19 | 132 | 0 | 531 | 98 | 433 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: 2019-2020 School Year

| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non- Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | | |
|------------------|--------------------------------------|--------------------|---|--|-------------------------------------|---|--|--|--|--------------------------------|--|--|---|
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 0 | | | | | | | | | | | | |
| Anne Arundel | 0 | | | | | | | | | | | | |
| Baltimore City | 1 | 9 | 9 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Baltimore County | 2 | 16 | 10 | 6 | 0 | 0 | 0 | 0 | 0 | 3 | 2 | 1 | 0 |
| Calvert | 0 | | | | | | | | | | | | |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 0 | | | | | | | | | | | | |
| Cecil | 0 | | | | | | | | | | | | |
| Charles | 0 | | | | | | | | | | | | |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 0 | | | | | | | | | | | | |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 0 | | | | | | | | | | | | |
| Howard | 1 | 3 | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 2 | 0 | 0 |
| Kent | 1 | 3 | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Montgomery | 2 | 107 | 48 | 59 | 0 | 1 | 0 | 1 | 0 | 2 | 0 | 2 | 0 |
| Prince George's | 1 | 30 | 3 | 27 | 0 | 1 | 0 | 1 | 0 | 3 | 0 | 3 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 0 | | | | | | | | | | | | |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 0 | | | | | | | | | | | | |
| Washington | 0 | | | | | | | | | | | | |
| Wicomico | 0 | | | | | | | | | | | | |
| Worcester | 0 | | | | | | | | | | | | |
| Total | 8 | 168 | 76 | 92 | 0 | 2 | 0 | 2 | 0 | 10 | 4 | 6 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: 2020-2021 School Year

| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non- Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | |
|------------------|--------------------------------------|--------------------|---|--|-------------------------------------|---|--|--|---|--|--|--|---|
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 0 | | | | | | | | | | | | |
| Anne Arundel | 4 | 50 | 22 | 28 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| Baltimore City | 5 | 77 | 64 | 13 | 0 | 1 | 1 | 0 | 0 | 6 | 6 | 0 | 0 |
| Baltimore County | 10 | 353 | 73 | 280 | 0 | 16 | 1 | 15 | 0 | 108 | 9 | 99 | 0 |
| Calvert | 0 | | | | | | | | | | | | |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Cecil | 1 | 17 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 0 | 0 |
| Charles | 0 | | | | | | | | | | | | |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 1 | 47 | 29 | 18 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 1 | 19 | 5 | 14 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 2 | 0 |
| Howard | 3 | 55 | 55 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Kent | 0 | | | | | | | | | | | | |
| Montgomery | 15 | 850 | 137 | 713 | 0 | 31 | 2 | 29 | 0 | 101 | 3 | 98 | 0 |
| Prince George's | 4 | 54 | 15 | 39 | 0 | 2 | 2 | 0 | 0 | 4 | 4 | 0 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 2 | 18 | 8 | 10 | 0 | 0 | 0 | 0 | 0 | 2 | 0 | 2 | 0 |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 0 | | | | | | | | | | | | |
| Washington | 0 | | | | | | | | | | | | |
| Wicomico | 1 | 17 | 16 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Worcester | 0 | | | | | | | | | | | | |
| Total | 48 | 1558 | 442 | 1116 | 0 | 50 | 6 | 44 | 0 | 225 | 23 | 202 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete

Test Results* for Nonpublic Schools Received and Verified as of August 1, 2023: 2021-2022 School Year

| County | # Schools** Completing Testing | Total # Samples | # Samples From Drinking Water Outlets | # Samples From Non- Consumption Outlets | # Samples With Unknown Use | Previous Action Level of 20 ppb (effective through May 31, 2021) | | | | Current Action Level of 5 ppb (effective on June 1, 2021) | | | |
|------------------|--------------------------------------|--------------------|---|--|-------------------------------------|---|--|--|---|--|--|--|---|
| | | | | | | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use | Total # Elevated Samples | # Elevated Samples From Drinking Outlets | # Elevated Samples From Non- Consumption Outlets | # Elevated Samples With Unknown Use |
| Allegany | 0 | | | | | | | | | | | | |
| Anne Arundel | 1 | 18 | 4 | 14 | 0 | 1 | 0 | 1 | 0 | 6 | 0 | 6 | 0 |
| Baltimore City | 6 | 167 | 122 | 45 | 0 | 7 | 4 | 3 | 0 | 30 | 17 | 13 | 0 |
| Baltimore County | 4 | 385 | 299 | 86 | 0 | 4 | 4 | 0 | 0 | 16 | 13 | 3 | 0 |
| Calvert | 1 | 5 | 5 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Caroline | 0 | | | | | | | | | | | | |
| Carroll | 0 | | | | | | | | | | | | |
| Cecil | 0 | | | | | | | | | | | | |
| Charles | 0 | | | | | | | | | | | | |
| Dorchester | 0 | | | | | | | | | | | | |
| Frederick | 1 | 13 | 10 | 3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Garrett | 0 | | | | | | | | | | | | |
| Harford | 0 | | | | | | | | | | | | |
| Howard | 2 | 40 | 40 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Kent | 0 | | | | | | | | | | | | |
| Montgomery | 7 | 66 | 44 | 22 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 0 |
| Prince George's | 1 | 38 | 38 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Queen Anne's | 0 | | | | | | | | | | | | |
| St. Mary's | 1 | 6 | 4 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Somerset | 0 | | | | | | | | | | | | |
| Talbot | 0 | | | | | | | | | | | | |
| Washington | 0 | | | | | | | | | | | | |
| Wicomico | 0 | | | | | | | | | | | | |
| Worcester | 0 | | | | | | | | | | | | |
| Total | 24 | 738 | 566 | 172 | 0 | 12 | 8 | 4 | 0 | 53 | 30 | 23 | 0 |

* All Samples are first-draw

** Number zero (0) indicates data is absent or incomplete