

APPENDIX A

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the effective period of this permit, the permittee is authorized to discharge compost toilet wastewater from a composting toilet to groundwater via manual Land Application (Outfall 001).

As specified below, such discharge shall be limited and monitored by the permittee at the wastewater storage tanks, prior to land application.

<u>PARAMETER CODE (STORET)</u>	<u>EFFLUENT CHARACTERISTIC</u>	<u>EFFLUENT LIMITATIONS</u>				<u>MONITORING REQUIREMENTS</u>	
		Loadings (gallons/day)		Concentrations (mpn/100 mL)		Measurement Frequency	Type of Sample
		Quarterly Average	Daily Maximum	Quarterly Average	Daily Maximum		
50050	Flow	N/A	N/A	N/A	N/A	Every Land Application	Estimated
74055	Fecal Coliform	N/A	N/A	N/A	200 ⁽¹⁾	Prior to land application ⁽¹⁾	Grab ⁽²⁾

(1) The wastewater shall meet the Daily Maximum Concentration limitation immediately prior to Land Application. See Part III.B.

(2) Grab samples shall be obtained from the compost toilet system.